

TARAWA TERRACE WATER SYSTEM
SUMMARY OF WATER QUALITY DATA (ppb)

Date: 3/19/85

SAMPLE DATA

| LOCATION | VOC Parameters | 16 Jan* (L) | 12 Feb (L) | 19 Feb(N) | 19 Feb(L) | 11 Mar(N)** | |
|-------------------|----------------|-------------|------------|-----------|-----------|-------------------------------------|-----------------------------------|
| TT 26 Well | TCE | 57 | ND | ND | ND | | |
| | 4CE | 1,580 | ND | 55 | 64 | | |
| | DCE | 92 | ND | ND | ND | | |
| | B | ND | ND | ND | ND | | |
| | VC | 27 | ND | ND | ND | | |
| | | | | | | | |
| TT New Well | | | | | | Pumped 2 Hours | |
| | TCE | ND | ND | 53 | ND | ND | |
| | 4CE | 132 | 37 | 26 | ND | 15 | |
| | DCE | 11 | ND | ND | 13 | ND | |
| | B | ND | ND | ND | ND | - | |
| | VC | ND | ND | ND | ND | - | |
| | | | | | | | Pumped 24 Hours |
| | TCE | | | | | | ND |
| | 4CE | | | | | | 41 |
| | DCE | | | | | | ND |
| | B | | | | | | - |
| | | | | | | | |
| TT Finished Water | | | | | | W/O New Well | |
| | TCE | | | | | ND | |
| | 4CE | | | | | ND | |
| | DCE | | | | | ND | |
| | B | | | | | ND | |
| | | | | | | | |
| | | | | | | | Upstream of Reservoir at 24 Hours |
| | TCE | | | | | | ND |
| | 4CE | | | | | | 21.3 |
| | DCE | | | | | | ND |
| | B | | | | | | - |
| | | | | | | | |
| | | | | | | Downstream of Reservoir at 24 Hours | |
| TCE | | | | | | ND | |
| 4CE | | | | | | Trace (6.6) | |
| DCE | | | | | | ND | |
| B | | | | | | - | |

CLW
0000001183

LEGEND: ND = Not Detectable at limit of 10 ppb
 TCE = Trichloroethylene
 4CE = Tetrachloroethylene
 DCE = Dichlorobenzene
 B = Benzene
 VC = Vinyl Chloride
 (L) = LANTDIV Laboratory
 (N) = State of NC Laboratory

*Wells having no detectable VOC's also included: 25,30,31,32,52,54,6
 **Dash (-) indicates parameters not reported telephonically-hard copy data to follow