

WATER SYSTEM: MARINE CORPS AIR STATION - NEW RIVER

APRIL 1983 -

DATE	WATER TREATMENT PLANT AS-100					BLDG 6-520 2ND FLR MEN'S ROOM					BLDG AS-4025 BARRACKS REC ROOM					BLDG 710 "O" CLUB GALLY SINK					BLDG 2800 BOAT MARINA					AVERAGE		
	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	TTHM	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	TTHM	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	TTHM	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	TTHM	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	TTHM	MON	QTR	
27 MAY 1983	1144										1154					1212						1204						
	2	6	15	25	48	LOCKED SHUT					2	7	23	52	84	3	10	30	66	109	7	19	47	66	139			
26 AUG 1983	1303					1254					1317					1340						1330						
	4	9	22	27	62	5	15	42	63	125	5	15	44	69	133	4	12	24	51	93	4	14	41	70	129			
29 DEC 1983	1255					1354					1304					1323						1313						
	2	5	14	34	55	3	7	20	47	77	4	10	31	67	112	9	12	34	70	125	4	11	38	78	131			
27 MAR 1984	0952					1053					1018					1037						1029						
	5	3	19	49	81	6	14	35	83	138	7	14	38	86	145	5	11	31	81	123	5	11	32	93	141			
27 JUN 1984	1240					1231	17	56	78	157	1250					1311						1301						
	8	9	27	37	81	8	8	27	56	78	9	18	53	57	137	8	15	48	59	110	10	26	68	54	158			
21 SEP 1984	1023					0952					1050					1059						1044						
	3	7	22	50	82	3	9	37	105	154	3	9	35	79	124	3	10	41	100	154	2	9	39	86	186			
29 MAR 1985	1088					1105					1058					1000						1010						
	BROKEN IN TRANSIT					2.6	10	54	30	21.6	29	10	36	93	11.9	2.7	9.5	40	120	12.2	2.5	9.5	43	160	215			
15 MAY 1985	0920-1300	4.6	8.2	21	22	55.8	6.5	17	42	52	11.5	5.8	15	37	47	104.2	6.2	15	39	44	104.2	10	32	64	67	173		
2 JUL 1985	0920-1400	3	2	15	61	81	← NOT COLLECTED															3	9	47	47	206		
9 JUL 1985	0954	2	2	15	52	71	2934				1022					1110						1052						
							3	7	42	120	222	3	6	32	143	184	2	4	31	143	1002	2	5	33	173	213		

ANALYSIS BY: APR 1982 - SEP 1984 GRAINGER LABS, MAR 1985 - JTC

RED SHADING ABOVE TABLE INDICATES EXCEEDING THE 100PPH (0.1MG/L) LIMIT

CLW

000001261