

DATE: 7 JUNE 1981

Memorandum for the Record

From: Ms. Betz, Quality Control Lab., NREAD, HMaintDepy

Subj: Hazardous Waste Sampling on 20 May 1981; Results of

1. Below are the results of the hazardous waste sampling on 20 May 1981, at the chemical landfill, received from LANTRAVFACENGCOR over the phone by Mr. Danny Sharpe. No official copy has been received yet.

Test Well 15	Clean		
Test Well 16	Benzene	77.8 ppb	
	Toluene	316 ppb	
	1,1,1-Trichloroethane	33.2 ppb	
	1,1,2,2-Tetrachloroethane	1.8 ppb	
	Trichloroethylene	15.6 ppb	
Rad Pool	Toluene	53.6 ppb	
KR Water Plant		Raw	Treated
	1,1-Dichloroethane	5.4 ppb	3.4 ppb
	Chloroform	53.4 ppb	94.4 ppb
	Methylene Chloride	14.6 ppb	4.0 ppb

Elizabeth A. Betz
Elizabeth A. Betz
Supervisory Chemist

CLW
0000003736