

WATER TREATMENT PLANT

WATER FLOW

DATE _____

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY/DAY	TREATMENT
HADNOT POINT	11,111	10,000	1,000	1,000	13	5,900	5,000	LIME
HOLCOMB BLVD.	11,111	10,000	1,000	1,000	3	2,304	2,000	LIME
AWA TERRACE	20,000	20,000	0	1,200	3	1,152	1,000	LIME
MONIFORD POINT	11,111	10,000	1,000	1,000	3	622	750	ZEOLITE
MCAS (H)	11,111	12,403	1,292	1,400	3	4,081	3,500	LIME
RIFLE RANGE	11,111	10,000	1,000	1,000	3	648	600	ZEOLITE
CGA-5 (EST)	-----	-----	-----	-----	-	288	288	CHLORINE
COURTHOUSE BAY	11,111	12,000	1,000	1,000	3	864	600	ZEOLITE
ONslow BEACH	11,111	10,000	1,000	1,000	3	250	250	ZEOLITE

WATER IN MILLION GALS.

REMARKS :

CLW
0000004436

WATER TREATMENT PLANT

WATER FLOW

DATE **FEBRUARY 1980**

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WRITS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	117,982	112,194	5,785	4,464	13	5,900	5,000	1300
HOLCOMB BLVD.	24,858	23,779	1,076	1,132	3	2,384	2,000	1300
TARAWA TERRACE	20,643	19,806	839	861	3	1,152	1,000	1100
MONTFORD POINT	9,609	9,200	406	384	3	522	750	ZEOLITE
MCAS (H)	27,864	25,557	2,304	1,065	3	4,081	3,500	1300
RIFLE RANGE	5,333	4,689	644	179	3	648	600	ZEOLITE
COURTHOUSE BAY	12,434	11,679	752	452	3	664	600	ZEOLITE
ONSTON BEACH	2,346	2,234	110	116	3	250	250	ZEOLITE

WATER IN MILLION GALS.

209,138,000

REMARKS :

CLW

0000004437

WATER TREATMENT PLANT

WATER FLOW

DATE **MARCH 1980**

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	113,740	107,550	6,184	4,716	13	5,900	5,000	LIME
HOLCOMB BLVD.	26,464	25,331	1,130	1,383	3	2,304	2,000	LIME
TARAWA TERRACE	25,991	25,095	893	1,118	3	1,152	1,000	LIME
MONTFORD POINT	8,023	7,632	388	503	3	622	750	ZEOLITE
MCAS (II)	37,174	35,251	1,920	2,134	3	4,081	3,500	LIME
RIFLE RANGE	4,908	4,205	698	195	3	648	600	ZEOLITE
COURTHOUSE BAY	12,796	11,976	817	492	3	864	600	ZEOLITE
ONSLOW BEACH	2,953	2,810	141	100	3	250	250	ZEOLITE

WATER IN MILLION GALS.

219,850,000

REMARKS :

CLW

0000004438

WATER TREATMENT PLANT

WATER FLOW

DATE **APRIL 1980**

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	107,025	101,037	5,985	3,708	13	5,900	5,000	LIME
HOLCOMB BLVD.	27,240	26,122	1,113	1,390	3	2,304	2,000	LIME
TARAWA TERRACE	20,599	19,728	864	1,049	3	1,152	1,000	LIME
MONTFORD POINT	7,182	6,805	375	295	3	622	750	ZEOLITE
MCAS (H)	35,372	33,016	2,352	1,113	3	4,081	3,500	LIME
RIFLE RANGE	5,405	4,731	671	156	3	648	600	ZEOLITE
COURTHOUSE BAY	11,766	11,013	751	428	3	864	600	ZEOLITE
OHISLOW BEACH	2,667	2,551	111	104	3	250	250	ZEOLITE

WATER IN MILLION GALS.

205,000^{3,000}

REMARKS:

CLW

0000004439

WATER TREATMENT PLANT

WATER FLOW

DATE **MAY 1980**

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	100,422	95,688	4,730	3,618	13	5,900	5,000	LIME
HOLCOMB BLVD.	33,101	32,304	811	1,384	3	2,304	2,000	LIME
TARAWA TERRACE	22,273	21,321	893	868	3	1,152	1,000	LIME
MONTFORD POINT	7,902	7,318	581	368	3	622	750	ZEOLITE
MCAS (H)	38,361	35,670	2,688	1,321	3	4,081	3,500	LIME
RIFLE RANGE	5,423	4,810	680	186	3	648	600	ZEOLITE
COURTHOUSE BAY	11,762	10,961	760	475	3	864	600	ZEOLITE
ONslow BEACH	2,668	2,546	119	130	3	250	250	ZEOLITE

WATER IN MILLION GALS.

210,688,000

REMARKS :

WASH WATER IS ESTIMATED

CLW

0000004440

WATER TREATMENT PLANT

WATER FLOW

DATE **JUNE 1980**

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	101,519	95,508	5,985	3,600	13	5,000	5,000	LINE
HOLCOMB BLVD.	36,644	35,521	1,113	1,829	3	2,304	2,000	LINE
TARAWA TERRACE	23,752	22,530	989	1,075	3	1,152	1,000	LINE
NORFORD POINT	7,014	6,414	574	278	3	622	750	ZSOLITE
NGAE (D)	36,116	33,652	2,448	1,256	3	4,001	3,500	LINE
RIFLE RANGE	6,349	5,678	665	241	3	640	600	ZSOLITE
COURTHOUSE BAY	11,879	10,944	842	409	3	804	600	ZSOLITE
ONSLOW BEACH	3,010	2,936	119	222	3	250	200	ZSOLITE

WATER IN MILLION GALS.

213,183,000

REMARKS:

CLW

0000004441

WATER TREATMENT PLANT

WATER FLOW

Date: **JULY 1980**

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
RADNOT POINT	116,904	110,798	6,154	3,348	13	5,900	5,000	LINE
VOLCOMB BLVD.	33,712	32,559	1,150	1,449	3	2,304	2,000	LINE
TARSWA TERRACE	23,066	27,162	893	868	3	1,152	1,000	LINE
MOULTON POINT	7,407	6,776	627	256	3	622	750	ZERO-LITE
MCAS (H)	35,345	33,508	2,132	1,279	3	4,081	3,500	LINE
RIFLE RANGE	6,624	5,911	709	243	3	650	600	ZERO-LITE
COURTHOUSE BAY	11,512	10,760	749	456	2	204	600	ZERO-LITE
ONISIAW BEACH	2,307	2,683	121	233	1	150	550	ZERO-LITE

WATER IN MILLION GALS.

230,157,000

REMARKS:

CLW

0000004442

WATER TREATMENT PLANT

WATER FLOW

DATE Aug. 1980

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	100,062	95,112	4,948	3,600	15	5,900	5,000	LINE
HOLCOMB BLVD.	42,590	41,435	1,150	1,902	3	2,304	2,000	LINE
TARAHA TERRACE	25,061	24,027	989	104	3	1,152	1,000	LINE
MONTFORD POINT	1,391	7,690	607	307	3	622	750	ZEOLITE
MOAS (ID)	42,178	39,682	2,496	1,200	3	4,031	3,500	LINE
RIPLE RANGE	6,319	5,567	752	213	3	648	600	ZEOLITE
COURTHOUSE BAY	13,371	12,590	781	445	3	384	600	ZEOLITE
ONSLOW BEACH	3,594	3,577	160	100	3	250	250	ZEOLITE

WATER IN MILLION GALS.

227,680,000

REMARKS:

CLW

0000004443

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	95,780	91,314	4,462	3,276	13	5,900	5,000	LIME
HOLCOMB BLVD.	40,014	38,888	1,113	1,711	3	2,304	2,000	LIME
TARAMA TERRACE	23,556	22,889	864	926	3	1,152	1,000	LIME
MONTFORD POINT	8,425	7,787	634	314	3	622	750	ZEOLITE
HCAS (H)	32,210	29,949	2,256	1,506	3	4,081	3,500	LIME
RIELE RANGE	6,151	5,459	688	291	3	648	600	ZEOLITE
COURTHOUSE BAY	11,226	10,455	767	382	3	864	600	ZEOLITE
ONSLOW BEACH	3,679	3,523	140	154	3	250	250	ZEOLITE

WATER IN MILLION GALS.

210,264,000

REMARKS:

CLW
0000004444

WATER TREATMENT PLANT

WATER FLOW

DATE OCTOBER 6

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	91,925	80,232	5,121	3 57	13	5,900	5,600	LTBE
HOLCOMB BLVD.	33,944	32,776 (est.)	1,150	1,120	3	2,305	2,000	LTBE
TARAWA TERRACE	22,307	21,725	100	97	3	1,152	1,000	LTBE
MONTEFORD POINT	7,161	6,592 (est.)	739	270	3	622	750	ZEOLITE
HCAS (H)	31,320	28,681	2,640	1,133	3	4,081	3,500	LTBE
RIFLE RANGE	6,571	5,306	705	240	3	648	600	ZEOLITE
COURTHOUSE PAV.	13,711	11,870	795	375	3	864	600	ZEOLITE
ONSLOW BEACH	4,110	3,975	127	120	3	250	250	ZEOLITE

WATER IN MILLION GALS.

197,779,000

REMARKS:

CLW

0000004445

WATER TREATMENT PLANT

WATER FLOW

DATE NOVEMBER 1987

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	114,000	99,26	4,7	3,45	13	5,900	5,000	LINE
HOLCOMB BLVD.	2,524	27,057	1,313	1,313	3	2,304	2,000	LINE
TARAWA TERRACE	21,101	20,14	94	70	3	1,152	1,000	LINE
MONTFORD POINT	7,645	6,323	71	37	3	622	750	ZEOLITE
MCAS (II)	27,703	25,120	2,040	1,250	3	4,081	3,500	LINE
RIFLE RANGE	8,311	5,620	1	213	3	648	600	ZEOLITE
COURTHOUSE PAV	12,920	11,700	70	501	3	864	600	ZEOLITE
ONSLOW BEACH	3,705	3,051	162	152	3	250	250	ZEOLITE

WATER IN MILLION GALS.

108,981,000

REMARKS:

CLW

0000004446

WATER TREATMENT PLANT

WATER FLOW

DATE DECEMBER 19

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	104,397	99,432	4,167	3,527	13	5,900	5,000	LIME
HOLCOMB BLVD.	25,013	24,020	1,150	901	3	2,305	2,000	LIME
TARAWA TERRACE	22,515	21,643	53	2	3	1,152	1,000	LIME
MONTFORD POINT	9,255	8,503	100	272	3	622	750	ZEOLITE
HCAS (H)	34,734	31,749	2,114	1,334	3	4,081	3,500	LIME
RIFLE RANGE	7,477	6,757	100	200	3	648	600	ZEOLITE
COURTHOUSE PAV	15,784	14,937	100	502	3	864	600	ZEOLITE
ONSLOW BEACH	3,400	3,257	100	147	3	250	250	ZEOLITE

WATER IN MILLION GALS.

210,458,000

REMARKS:

CLW
0000004447

WATER TREATMENT PLANT

WATER FLOW

DATE JANUARY 31

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	110,296	106,596	3,648	3,852	13	5,900	5,000	LTBE
HOLCOMB BLVD.	30,990	29,738	1,150	1,020	3	2,305	2,000	LTBE
TARAMA TERRACE	24,600	23,717	893	1,343	3	1,152	1,000	LTBE
MONTFORD POINT	9,561	8,435	111	472	3	622	750	ZEOLITE
MCAS (H)	39,820	35,423	3,120	1,420	3	4,081	3,500	LTBE
RIFLE RANGE	1,700	7,962	730	300	3	648	600	ZEOLITE
COURTHOUSE PAV	19,679	18,856	71	593	3	800	600	ZEOLITE
GONSLow BEACH	4,331	4,161	150	125	3	250	250	ZEOLITE

WATER IN MILLION GALS.

235,118,000

REMARKS:

CLW

0000004448

WATER TREATMENT PLANT

WATER FLOW

DATE FEBRUARY 71

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	91,237	91,114	4,467	3,672	13	5,900	5,000	LFHC
HOLCOMB BLVD.	25,157	25,141	1,037	1,037	3	2,304	2,000	LFHC
TARAWA TERRACE	19,287	19,114	96	11	3	1,152	1,000	LFHC
MONTFORD POINT	9,517	9,940	20	241	3	622	750	ZEOLITE
HGAS (H)	30,553	28,155	2,400	1,020	3	4,081	3,500	LFHC
RIFLE RANGE	6,445	5,769	102	230	3	648	600	ZEOLITE
COURTHOUSE BAY	11,552	10,776	12	427	3	864	600	ZEOLITE
ONSTOW BEACH	2,177	2,567	9	3	3	250	250	ZEOLITE

WATER IN MILLION GALS.

REMARKS:

CLW

0000004449

WATER TREATMENT PLANT

WATER FLOW

DATE MARCH 1

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	103,392	98,424	4,968	3,960	13	5,900	5,000	LYNE
HOLCOMB BLVD.	21,298	20,495	803	802	3	2,305	2,000	LYNE
TARAWA TERRACE	25,644	24,892	752	752	3	1,152	1,000	LYNE
HOPKINS POINT	150	152	2	356	3	622	750	ZEOLITE
MCAS (H)	34,887	31,658	3,229	3,229	3	4,081	3,500	LYNE
RIFLE RANGE	7,177	6,326	851	851	3	648	600	ZEOLITE
COURTHOUSE PAV	17,231	16,411	820	820	3	864	600	ZEOLITE
ONSLOW BEACH	2,113	2,107	6	6	3	250	250	ZEOLITE

WATER IN BILLION GALS.

REMARKS:

CLW

0000004450

WATER TREATMENT PLANT

WATER FLOW

DATE APRIL 19 1

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	103,198	90,378	4,770	3	13	5,900	5,000	LIME
HOLCOMB BLVD.	77,234	66,153	1,081	1,295	3	2,304	2,000	LIME
TARAWA TERRACE	25,710	24,174	1,536	92	3	1,152	1,000	LIME
MONTFORD POINT	9,530	8,740	790	421	3	622	750	ZEOLITE
MCAS (H)	34,191	31,425	2,766	1,346	3	4,081	3,500	LIME
RIFLE RANGE	6,549	5,730	819	219	3	648	600	ZEOLITE
COURTHOUSE FAY	14,920	14,162	758	491	3	864	600	ZEOLITE
GHESLOW BEACH	5,426	5,196	230	113	3	250	250	ZEOLITE

WATER IN MILLION GALS.

REMARKS:

NOTE: SENT WATER FROM 6-2 TO 6-4 DUE TO INCREASED WATER DEMAND, BAD LIME CAUSING INCREASING FILTER RUNS

CLW

0000004451

WATER TREATMENT PLANT

WATER FLOW

DATE MAY 1951

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	109,764	102,540	6,177	3,960	13	5,900	5,000	LTBE
HOLCOMB BLVD.	30,819	37,646	1,152	1,714	3	2,305	2,000	LTBE
TARAWA TERRACE	27,979	25,973	844	1,006	3	1,152	1,000	TJBE
MONTFORD POINT	10,472	9,715	744	550	3	622	750	ZEOHITE
NCAS (II)	32,409	29,479	2,480	1,653	3	4,081	3,500	LTBE
RIFLE RANGE	6,594	5,346	729	224	3	648	600	ZEOHITE
COURTHOUSE BAY	12,201	11,331	777	405	3	864	600	ZEOHITE
ONSTON BEACH	8,361	6,077	273	179	3	250	250	ZEOHITE

WATER IN MILLION GALS.

REMARKS:

CLW

000004452

WATER TREATMENT PLANT

WATER FLOW

DATE: JAN 1951

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	102,740	97,950	5,7	3,750	13	5,900	5,000	LTBE
HOLCOMB BLVD.	46,645	44,410	2,235	2,745	3	2,305	2,000	LTBE
TARAWA TERRACE	29,000	28,773 EST.	34	1,360	3	1,152	1,000	LTBE
HOPKINS POINT	9,255	9,000	255	300	3	622	750	ZEOLITE
MCAS (H)	32,711	30,212	2,499	1,225	3	4,081	3,500	LTBE
RIFLE RANGE	7,291	6,562 EST.	729	200	3	648	600	ZEOLITE
COURTHOUSE PAV.	11,953	11,115	838	441	3	504	600	ZEOLITE
ONSLOW BEACH	5,305	4,902	403	225	3	250	250	ZEOLITE

WATER IN MILLION GALS.

REMARKS:

CLW
0000004453

WATER TREATMENT PLANT

WATER PLANT

DATE: JULY 1 1961

PLANT	RAW	DELIVERED	WASTING FILTERS	MAX. DET.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	117,902	112,950	4,948	4,032	13	5,900	5,000	TRICK
BOLCOMB BLVD.	33,567	32,414	1,150	1,799	3	1,300	2,000	TRICK
TARAWA TERRACE	29,000	29,121	744	1,034	3	1,150	1,000	TRICK
MONTFORD POINT	9,590	8,903	693	451	3	600	750	ZINCATE
ROSE (II)	35,550	32,578	2,976	1,312	3	4,000	4,500	TRICK
RTE. 100	7,510	6,781	734	299	3	648	600	TRICK
COURTHOUSE PAV.	12,825	11,234	700	431	3	500	600	TRICK
CHESTNUT BEACH	6,000	5,707	291	229	3	250	250	TRICK

WATER IN BILLION GALS.

REMARKS:

CLW
0000004454

MAJOR TREATMENT PLANT

WATER FLOW

AUGUST 81

PLANT	RAW	DELIVERED	CASTING FILTERS	MAX. DEL.	POTABLE FILTER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
BADROT POINT	99,232	98,280	4,948	3,528	13	5,900	5,000	TREAT
HOLCOMB BLVD.	34,966	33,813	1,150	1,443	3	2,305	2,000	TREAT
TARAWA TERRACE	28,708	27,813	892	1,125	3	1,152	1,000	TREAT
MONTFORD POINT	9,459	8,763	693	543	3	632	750	ZOOB.TRE
MOAS (H)	32,427	29,688	2,736	1,140	3	4,081	3,500	TREAT
RIFLE RANGE	7,701	6,971	727	250	3	648	600	ZOOB.TRE
COURTHOUSE PAV	12,321	11,581	737	461	3	868	600	ZOOB.TRE
ONSLOW BEACH	3,951	3,762	177	188	3	250	250	ZOOB.TRE

WATER IN MILLION GALS.

REMARKS:

CLW
0000004455

WATER TREATMENT PLANT

WATER FROM

DATE: SEPTEMBER 31

PLANT	RAW	DELIVERED	WASHING FEEDERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HABROT MOUNT	95,316	9,568	4,708	3,368	11	5,900	5,600	FILTR
BOLCOMB BLVD.	30,655	37,733	1,113	1,519	7	2,304	2,000	FILTR
TARAMA TERRACE	27,442	20,575	300	945	3	1,150	1,000	FILTR
HOLTFORD POINT	8,518	7,173	136	354	3	622	750	ZOOPTIC
MCAS (II)	20,634	25,718	2,620	1,304	3	4,081	3,500	FILTR
RIPLE RANGE	9,109	7,412	634	262	3	648	600	ZOOPTIC
COURTHOUSE PAV	12,458	11,082	774	495	3	863	700	ZOOPTIC
CHSTOW BEACH	3,890	3,712	101	157	3	250	250	ZOOPTIC

WATER IN MILLION GALS.

REMARKS:

CLW

0000004456

WATER TREATMENT PLANT

WATER FLOW

DATE: OCTOBER 1962

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	29,450	27,850	1,300	3,200	13	5,900	5,000	LIME
HOLCOMB BLVD.	37,824	37,322	1,150	1,238	3	2,304	2,000	LIME
TARAWA TERRACE	30,100	29,197	93	851	3	1,152	1,000	LIME
MONTFORD POINT	7,030	6,451	500	421	3	622	750	ZEOLITE
MCAS	30,942	29,261	2,004	1,888	3	4,081	3,500	LIME
RIFLE RANGE	6,159	5,472	685	270	3	648	600	ZEOLITE
COURTHOUSE BAY	12,935	12,100	750	458	3	864	600	ZEOLITE
ONSLow BEACH	3,303	3,203	114	241	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

HADNOT POINT, TARAWA TERRACE AND MONTFORD POINT ARE STATION ESTIMATED.

CLW

0000004457

WATER TREATMENT PLANT

WATER FLOW

DATE: NOVEMBER 1982

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	102,625	96,633	5,965	3,410	13	5,900	5,000	LIME
HOLCOMB BLVD.	36,193	35,666	1,113	1,162	3	2,304	2,000	LIME
TARAWA TERRACE	22,364	21,490	804	1,494	3	1,152	1,000	LIME
MONTFORD POINT	9,666	8,511	543	384	3	622	750	ZEOLITE
MCAS	20,652	27,099	2,551	1,933	3	4,081	3,500	LIME
RIFLE RANGE	7,914	7,231	669	272	3	648	600	ZEOLITE
COURTHOUSE BAY	21,506 10,588	21,506 9,624	947	441	3	864	600	ZEOLITE
ONSLOW BEACH	3,462	2,956	125	196	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

MCAS FLOW ESTIMATED DUE TO MECHANICAL FAILURE OF TOTALIZERS.

CLW

0000004458

WATER TREATMENT PLANT

WATER FLOW

DATE: December 1982

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	103,626	97,433	6,184	3,480	13	5,900	5,000	LIME
HOLCOMB BLVD.	35,169	33,988	1,150	1,672	3	2,304	2,000	LIME
TARAWA TERRACE	26,126	25,223	893	895	3	1,152	1,000	LIME
MONTFORD POINT	9,359	8,765	595	478	3	622	750	ZEOLITE
MCAS	32,361	29,688	2,666	2,033	3	4,081	3,500	LIME
RIFLE RANGE	8,149	7,471	675	289	3	648	600	ZEOLITE
COURTHOUSE BAY	13,272	12,482	774	374	3	864	600	ZEOLITE
ONSLOW BEACH	3,199	2,747	121	115	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

MCAS FLOW ESTIMATED DUE TO MECHANICAL FAILURE OF TOTALIZERS.

(Pumps on order)

CLW

0000004459

WATER TREATMENT PLANTWATER FLOWDATE: January 1933

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	100,353	95,386	4,947	3,464	13	5,900	5,000	LIME
HOLCOMB BLVD.	32,667Est	31,352	1,150	2,130	3	2,304	2,000	LIME
TARAWA TERRACE	25,883	24,980	893	926	3	1,152	1,000	LIME
MONTFORD POINT	9,483	9,361	666	464	3	622	750	ZEOLITE
MCAS	30,417Est	28,001	2,406	1,989	3	4,081	3,500	LIME
RIFLE RANGE	9,239	8,563	718	363	3	648	600	ZEOLITE
COURTHOUSE BAY	12,842	11,113	803	439	3	864	600	ZEOLITE
ONSLOW BEACH	2,915	1,616	90	101	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

MCAS FLOW ESTIMATED DUE TO MECHANICAL FAILURE OF TOTALIZERS. (PARTS ON ORDER)

CLW

0000004460

WATER TREATMENT PLANT

WATER FLOW

DATE: ~~FEBRUARY 1983~~

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	31,500	31,154	4,400	3,424	13	5,900	5,000	LIME
HOLCOMB BLVD.	31,110	31,400	1,467	1,085	3	2,304	2,000	LIME
TARAWA TERRACE	23,001	22,500	.72	.900	3	1,152	1,000	LIME
MONTFORD POINT	9,330	9,110	.52	.514	3	622	750	ZEOLITE
MCAS (Estimated)	27,111	26,004	2,490	2,103	3	4,081	3,500	LIME
RIFLE RANGE	4,031	3,914	.10	.340	3	648	600	ZEOLITE
COURTHOUSE BAY	245	9,313	.00	.873	3	864	600	ZEOLITE
ONISLOW BEACH	1,491	1,351	.000	.050	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

MCAS estimated due to mechanical failure of totalizers. (Parts on order).

CLW

0000004461

WATER TREATMENT PLANTWATER FLOW

DATE:

4 April 1963

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	26,000	20,241	4,150	3,21	13	5,900	5,000	LIME
HOLCOMB BLVD.	33,640	30,515	1,150	1,150	3	2,304	2,000	LIME
TARAWA TERRACE	25,332	25,510	.002	.524	3	1,152	1,000	LIME
MONTFORD POINT	1,240	8,245	.022	.402	3	622	750	ZEOLITE
MCAS	33,000	27,900	2,300	1,200	3	4,081	3,500	LIME
RIFLE RANGE	8,341	8,624	.14	.310	3	648	600	ZEOLITE
COURTHOUSE BAY	12,524	11,685	.03	.45	3	864	600	ZEOLITE
ONSLow BEACH	2,000	2,450	.00	.000	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004462

WATER TREATMENT PLANTWATER FLOWDATE: APRIL 1983

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	83,787	81,355	4,110	3,033	13	5,900	5,000	LIME
HOLCOMB BLVD.	34,071	31,666	1,113	1,316	3	2,304	2,000	LIME
TARAWA TERRACE	27,383	26,510	864	928	3	1,152	1,000	LIME
MONTFORD POINT	8,111	7,425	684	298	3	622	750	ZEOLITE
MCAS	29,079	27,081	2,880	1,159	3	4,081	3,500	LIME
RIFLE RANGE	8,259	7,582	673	268	3	648	600	ZEOLITE
COURTHOUSE BAY	13,373	11,086	761	487	3	864	600	ZEOLITE
ONSLow BEACH	2,744	2,377	108	103	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW

000004463

WATER TREATMENT PLANT

WATER FLOW

DATE: MAY
JUNE 1983

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	83,482	87,290	6,184	3,021	13	5,900	5,000	LIME
HOLCOMB BLVD.	48,030	47,050	1,150	2,157	3	2,304	2,000	LIME
TARAWA TERRACE	22,266	22,470	44	1,011	3	1,152	1,000	LIME
MONTFORD POINT	8,403	8,291	601	432	3	622	750	ZEOLITE
MCAS	32,766	29,683	2,660	1,245	3	4,081	3,500	LIME
RIFLE RANGE	8,067	8,164	694	332	3	648	600	ZEOLITE
COURTHOUSE BAY	11,398	11,006	368	416	3	864	600	ZEOLITE
ONSLOW BEACH	3,445	3,590	132	145	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004464

WATER TREATMENT PLANT

WATER FLOW

DATE: JUNE 1983

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	100,312	94,968	4,389	3,773	13	5,900	5,000	LIME
HOLCOMB BLVD.	51,986	50,864	1,113	2,300	3	2,304	2,000	LIME
TARAWA TERRACE	31,292	30,923	364	1,146	3	1,152	1,000	LIME
MONTFORD POINT	10,319	9,709	601	408	3	622	750	ZEOLITE
MCAS	34,447	30,525	2,880	1,196	3	4,081	3,500	LIME
RIFLE RANGE	8,007	7,332	673	278	3	648	600	ZEOLITE
COURTHOUSE BAY	12,874	11,016	437	730	3	864	600	ZEOLITE
ONSLOW BEACH	3,152	2,953	160	123	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004465

WATER TREATMENT PLANT

WATER FLOW

DATE: JULY 1983

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	106,298	98,591	4,632	4,300	13	5,900	5,000	LIME
HOLCOMB BLVD.	44,793	43,639	1,150	1,719	3	2,304	2,000	LIME
TARAWA TERRACE	31,879	30,978	892	1,207	3	1,152	1,000	LIME
MONTFORD POINT	12,979	11,790	602	552	3	622	750	ZEOLITE
MCAS	32,884	27,610	3,027	1,105	3	4,081	3,500	LIME
RIFLE RANGE	8,291	7,587	696	313	3	648	600	ZEOLITE
COURTHOUSE BAY	14,263	11,881	805	472	3	864	600	ZEOLITE
ONSLOW BEACH	3,929	2,838	132	150	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004466

WATER TREATMENT PLANT

WATER FLOW

DATE: AUGUST 1983

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	101,333	101,344	6,184	3,935	13	5,900	5,000	LIME
HOLCOMB BLVD.	46,342	45,104	1,150	1,916	3	2,304	2,000	LIME
TARAWA TERRACE	33,209	32,313	.890	1,192	3	1,152	1,000	LIME
MONTFORD POINT	15,989	15,477	.506	.517	3	622	750	ZEOLITE
MCAS	33,881	30,536	2,880	1,075	3	4,081	3,500	LIME
RIFLE RANGE	8,111	7,447	.661	.307	3	648	600	ZEOLITE
COURTHOUSE BAY	15,077	13,362	.833	.523	3	864	600	ZEOLITE
ON SLOW BEACH	2,991	2,405	.154	.171	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004467

WATER TREATMENT PLANT

WATER FLOW

DATE: September 1963

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	32,000	31,000	1,000	1,000	13	5,900	5,000	LIME
HOLCOMB BLVD.	1,000	13,000	1,000	1,000	3	2,304	2,000	LIME
TARAWA TERRACE	1,000	1,000	0	1,000	3	1,152	1,000	LIME
MONTFORD POINT	1,000	1,111	0	1,000	3	622	750	ZEOLITE
MCAS	1,000	24,750	1,000	1,000	3	4,081	3,500	LIME
RIFLE RANGE	1,000	1,000	0	1,000	3	648	600	ZEOLITE
COURTHOUSE BAY	1,000	12,000	0	1,000	3	864	600	ZEOLITE
ONSLOW BEACH	1,000	1,000	0	1,000	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004468

WATER TREATMENT PLANTWATER FLOWDATE: October

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	94,848	91,130	3,711	3,392	13	5,900	5,000	LIME
HOLCOMB BLVD.	32,497	28,366	1,150	1,158	3	2,304	2,000	LIME
TARAWA TERRACE	26,144	25,267	883	904	3	1,152	1,000	LIME
MONTFORD POINT	7,096	6,673	370	315	3	622	750	ZEOLITE
MCAS	27,529	22,508	2,928	849	3	4,081	3,500	LIME
RIFLE RANGE	8,036	7,340	691	268	3	648	600	ZEOLITE
COURTHOUSE BAY	14,482	11,371	778	495	3	864	600	ZEOLITE
ONSLow BEACH	3,366	3,249	114	113	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004469

WATER TREATMENT PLANT

WATER FLOW

DATE: NOVEMBER 1983

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	93,746	88,524	4,788	3,459	13	5,900	5,000	LIME
HOLCOMB BLVD.	31,313	^{29,896} 25,896	1,113	965	3	2,304	2,000	LIME
TARAWA TERRACE	26,887	25,985	864	975	3	1,152	1,000	LIME
MONTFORD POINT	7,201	6,703	495	273	3	622	750	ZEOLITE
MCAS	28,350	25,522	2,784	1,280	3	4,081	3,500	LIME
RIFLE RANGE	7,452	6,797	650	296	3	648	600	ZEOLITE
COURTHOUSE BAY	14,310	13,520	751	484	3	864	600	ZEOLITE
ONslow BEACH	3,120	2,634	134	189	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004470

Copy

WATER TREATMENT PLANT

WATER FLOW

DATE: December 1983

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	110,866	105,911	4,948	4,260	13	5,900	5,000	LIME
HOLCOMB BLVD.	31,394	26,154	1,150	1,124	3	2,304	2,000	LIME
TARAWA TERRACE	34,171	33,273	893	1,011	3	1,152	1,000	LIME
MONTFORD POINT	10,712	10,022	636	550	3	622	750	ZEOLITE
MCAS	28,527	23,456	3,024	1,202	3	4,081	3,500	LIME
RIFLE RANGE	8,399	7,727	666 est	341	3	648	600	ZEOLITE
COURTHOUSE BAY	14,575	13,750	812	657	3	864	600	ZEOLITE
ON SLOW BEACH	3,161	2,876	140	202	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW

0000004471

WATER TREATMENT PLANTWATER FLOWDATE: JANUARY 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
EMERY POINT	113,655	108,549	4,589	4,046	13	5,900	5,000	LIME
HOLCOMB BLVD.	29,622	28,297	1,224	1,259	3	2,304	2,000	LIME
TARAIA TERRACE	23,991	23,088	.893	.869	3	1,152	1,000	LIME
MONTFORD POINT	11,865	10,571	.660	.449	3	622	750	ZEOLITE
NCAS	32,704	26,490	3,552	1,095	3	4,081	3,500	LIME
RIFLE RANGE	9,544	8,840	.698 Est.	.321	3	648	600	ZEOLITE
COURT HOUSE BAY	16,745	15,896	.842	.560	3	864	600	ZEOLITE
ONSLOW BEACH	3,229	3,095	.128	.138	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW

0000004472

WATER TREATMENT PLANTWATER FLOWDATE: February 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
RAMBLET POINT	104,409	99,721	4,628	3,972	13	5,900	5,000	LIME
HOLCOMB BLVD.	32,971	31,891	1,076	1,200	3	2,304	2,000	LIME
TARADA TERRACE	24,443	23,605	835	888	3	1,152	1,000	LIME
MONTFORD POINT	9,380	8,891	465	421	3	622	750	ZEOLITE
NCAS	25,180	22,479	2,496	1,015	3	4,081	3,500	LIME
RIFLE RANGE	10,371	9,670	699	271	3	648	600	ZEOLITE
COURT HOUSE BAY	16,299	15,524	756	655	3	864	600	ZEOLITE
ORNLON BEACH	2,690	2,637	114	133	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW

0000004473

WATER TREATMENT PLANT

WATER FLOW

DATE: MARCH 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HALENOT POINT	104,165	100,251	3,910	3,581	13	5,900	5,000	LIME
HOLCOMB BLVD.	37,627	36,473	1,150	1,412	3	2,304	2,000	LIME
TARAMA TERRACE	25,108	24,211	893	906	3	1,152	1,000	LIME
HORTFORD POINT	11,340	10,830	508	374	3	622	750	ZEOLITE
NCAS	26,806	24,162	2,640	945	3	4,081	3,500	LIME
RIFLE RANGE	5,899	5,462	430 EST.	243	3	648	600	ZEOLITE
COURT HOUSE BAY	12,495	11,689	796	627	3	864	600	ZEOLITE
OSBLOW BEACH	2,639	2,404	119	107	3	250	250	ZEOLITE

WATER IN BILLION GALLONS

REMARKS:

CLW
0000004474

WATER TREATMENT PLANT

WATER FLOW

DATE: APRIL 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
EMMOT POINT	104,070	100,476	3,591	3,764	13	5,900	5,000	LIME
HOLCOMB BLVD.	33,057	31,654	1,113	1,298	3	2,304	2,000	LIME
TARAMA TERRACE	25,120	24,395	720	986	3	1,152	1,000	LIME
LOCKFORD POINT	8,915	8,767	462	391	3	622	750	ZEOLITE
NCAS	23,407	20,909	2,544	811	3	4,081	3,500	LIME
RIFLE RANGE	6,669	6,146	520 est.	310	3	648	600	ZEOLITE
COURTHOUSE BAY	15,811	15,034	774	588	3	864	600	ZEOLITE
OSLON BEACH	2,769	2,189	116	102	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004475

WATER TREATMENT PLANTWATER FLOWDATE: MAY 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
MANAGE POINT	114,782	110,229	4,548	3,922	13	5,900	5,000	LIME
HOLCOMB BLVD.	41,176	39,407	1,150	1,773	3	2,304	2,000	LIME
TARAWA TERRACE	28,084	27,187	893	1,078	3	1,152	1,000	LIME
MONTFORD POINT	9,979	9,936	515	393	3	622	750	ZEOLITE
NCAS	26,680	24,227	2,448	1,009	3	4,001	3,500	LIME
RIFLE RANGE	6,764	Est 6,642	577	220	3	648	600	ZEOLITE
COURT HOUSE BAY	14,155	13,383	770	664	3	864	600	ZEOLITE
ONSLOW BEACH	2,408	2,270	134	89	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004476

WATER TREATMENT PLANTWATER FLOWDATE: June 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
EMMETT POINT	115,074	110,275	4,788	4,989	13	5,900	5,000	LIME
HOLCOMB BLVD.	48,442	47,310	1,113	1,828	3	2,304	2,000	LIME
TYRARA TERRACE	26,123	25,243	864	1,082	3	1,152	1,000	LIME
MONTFORD POINT	11,059	11,012	574	647	3	622	750	ZEOLITE
NCAS	32,744	27,576	2,832	1,137	3	4,081	3,500	LIME
RIFLE RANGE	10,531	10,157	579 est.	395	3	648	600	ZEOLITE
COURTHOUSE BAY	15,877	15,078	789	575	3	864	600	ZEOLITE
ONSLOW BEACH	3,296	3,154	134	147	3	250	250	ZEOLITE

WATER IN BILLION GALLONS

REMARKS:

CLW
0000004471

WATER TREATMENT PLANT

WATER FLOW

DATE: JULY 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
MEMOT POINT	111,473	Est. 107,260	4,947	4,213	13	5,900	5,000	LIME
HOLCOMB BLVD.	44,189	42,822	1,367	1,542	3	2,304	2,000	LIME
TARAWA TERRACE	25,830	24,938	892	1,467	3	1,152	1,000	LIME
MONTFORD POINT	11,232	11,108	580	358	3	622	750	ZEOLITE
MCAS	31,868	25,686	4,468	1,058	3	4,081	3,500	LIME
RIFLE RANGE	6,861	6,628	525	255	3	648	600	ZEOLITE
COURT HOUSE BAY	16,582	14,995	810	584	3	864	600	ZEOLITE
OSISLUM BEACH	3,947	2,293	128	163	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW

0000004478

WATER TREATMENT PLANT

WATER FLOW

DATE: August 1784
9-4-84

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
WABING POINT	115,213	110,242	4,948	4,289	13	5,900	5,000	LIME
HOLCOMB BLVD.	43,658	42,408	1,150	1,594	3	2,304	2,000	LIME
TARALA TERRACE	28,771	27,868	893	1,029	3	1,152	1,000	LIME
MONTFORD POINT	9,996	9,480	510	380	3	622	750	ZEOLITE
MCAS	30,092	27,530	2,496	923	3	4,081	3,500	LIME
RIFLE RANGE	7,739	7,104	615	291	3	648	600	ZEOLITE
COURT HOUSE BAY	17,251	16,407	814	575	3	864	600	ZEOLITE
OCEAN BEACH	3,454	3,277	147	343	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW

0000004479

WATER TREATMENT PLANT

WATER FLOW

DATE: SEPTEMBER 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	103,732	100,137	3,591	3,506	13	5,900	5,000	LIME
HOLCOMB BLVD.	37,755	36,390	1,113	1,652	3	2,304	2,000	LIME
TARANA TERRACE	25,359	24,482	864	945	3	1,152	1,000	LIME
HONTFORD POINT	8,509	7,860	636	329	3	622	750	ZEOLITE
MCAS	28,593	26,949	1,632	1,044	3	4,081	3,500	LIME
RIFLE RANGE	7,430	6,651	562	292	3	648	600	ZEOLITE
COURT HOUSE BAY	15,534	14,766	749	580	3	864	600	ZEOLITE
CHSLOW BEACH	3,569	3,561	109	113	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004480

WATER TREATMENT PLANT

WATER FLOW

DATE: OCTOBER 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HABROT POINT	112,502	107,555	4,947	4,027	13	5,900	5,000	LIME
HOLCOMB BLVD.	34,371	33,215	1,150	1,350	3	2,304	2,000	LIME
TARAMA TERRACE	26,791	25,886	.893	.939	3	1,152	1,000	LIME
HONTEFORD POINT	8,670	8,152	.481	.462	3	622	750	ZEOLITE
NCAS	30,620	25,711	1,488	.987	3	4,081	3,500	LIME
RIFLE RANGE	6,721	6,221	.500	.244	3	648	600	ZEOLITE
COURTHOUSE BAY	15,098	14,145	.804	.556	3	864	600	ZEOLITE
OSLOW BEACH	3,792	3,611	.173	.122	3	250	250	ZEOLITE

WATER IN BILLION GALLONS

REMARKS:

CLW

0000004481

WATER TREATMENT PLANTWATER FLOWDATE: NOVEMBER 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	93,584	91,704	1,875	3,958	13	5,900	5,000	LIME
HOLCOMB BLVD.	31,309	30,342	.963	1,113	3	2,304	2,000	LIME
TARAWA TERRACE	25,531	24,573	.947	.907	3	1,152	1,000	LIME
MONTFORD POINT	8,294	7,839	.455	.358	3	622	750	ZEOLITE
MCAS	24,932	23,489	1,440	.957	3	4,081	3,500	LIME
RIFLE RANGE	7,712	7,122	.585 Est.	.317	3	648	600	ZEOLITE
COURTHOUSE BAY	15,713	14,915	.788	.622	3	864	600	ZEOLITE
ONSLOW BEACH	4,700	4,556	.140	.137	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

CLW
0000004482

WATER TREATMENT PLANT

WATER FLOW

DATE: DECEMBER 1984

PLANT	RAW	DELIVERED	WASHING FILTERS	MAX. DEL.	POTABLE WATER USED	WELLS MAX. SAFE YIELD/DAY	PLANT CAPACITY DAY	TREATMENT
HADNOT POINT	99,745	98,464	1,276	3,710	13	5,900	5,000	LIME
HOLCOMB BLVD.	30,699	29,695	995	1,108	3	2,304	2,000	LIME
TARAWA TERRACE	25,092	24,000	978	1,104	3	1,152	1,000	LIME
MONTFORD POINT	9,578	9,165	409	456	3	622	750	ZEOLITE
MCAS	25,101	23,559	1,536	901	3	4,081	3,500	LIME
RIFLE RANGE	7,797	7,193 est.	600	325	3	648	600	ZEOLITE
COURTHOUSE BAY	14,977	14,152	810	560	3	864	600	ZEOLITE
ONSLow BEACH	4,182	4,048	132	131	3	250	250	ZEOLITE

WATER IN MILLION GALLONS

REMARKS:

Rifle Range delivered water water out of service

CLW

0000004483