

15 March

Water Sample Results (Samples taken 4 Feb)

<u>Well</u>	<u>VOC</u>
602	74 PPB - 1,2 TDCe ; 1.5 ppb - PCE ; 38 ppb - TCE ; 8.4 PPB - BUTANE ; 2.2 PPB - PENTANE ; 3.1 3.1 PPB - METHYL PENTANE
608	1.6 PPB - BENZENE ; 9.0 - TCE
610	ND
645	ND
649	ND
654	ND
AS 191	ND
AS 203	ND

Water Plant

HOLCOMB (670)	FILTER # 1 - 2.8 PPB TCE " # 2 - 1.5 PPB TCE
HADNOT (20)	150 PPB - 1,2 TDCe ; 7.5 PPB - PCE ; 429 PPB - TCE ; 2.9 PPB - VC ;
AIR STATION (110)	ND
MONTFORD Pt	ND
TARAWA TERRACE	12 PPB - 1,2 TDCe 8 PPB - TCE 215 PPB - PCE

CLW

0000004709

* Results Rec'd from E. Betz - 15 March 1985