

PWRCON Alpha Checklist

EMERGENCY ENERGY EFFICIENCY CHECKLIST for PWRCON ALPHA		Page	1	of	1
BLDG:		FACILITY MGR/DTY PH:	DATE:		
		INSPECTOR:	TIME:		
No.	Item	YES	NO	N/A	
RESIDENTIAL CUSTOMERS					
1	<i>Lighting:</i>				
a	Lighting turned off when ambient light is sufficient				
b	No more than three (3) rooms lit concurrently during night time hours				
c	Lighting in unoccupied rooms turned off				
d	Outdoor lighting minimized where safe to do so				
2	<i>Household:</i>				
a	All unnecessary plug loads are unplugged including:				
	Extraneous entertainment center and computing surge protectors				
	Transformers feeding gaming consoles				
	Kitchen appliances not in use (Coffee Makers, Microwaves, Rice Makers, etc)				
b	All rooms not in use isolated from heating load as much as possible				
c	Refrigerator/Freezer adjusted to lowest setting possible to preserve food (35F/ 1.7C)				
d	In winter: heat set to 20C/68F or below; In summer: cooling set to 26C/78F or above				
3	<i>Hygiene Reminders:</i>				
a	Laundry and dishwashers are run before 0900 or after 1700				
b	Air dry laundry as much as possible; run dryer on low or no heat setting only				
c	Use of stovetop & oven preparation minimized; use during off peak hours				
INDUSTRIAL/ADMINISTRATIVE CUSTOMERS					
1	<i>Lighting:</i>				
a	Lighting turned off when ambient light is sufficient				
b	Task lighting is relied on to the maximum extent during night hours				
c	Lighting in unoccupied rooms including hallways and restrooms is off				
d	Outdoor lighting minimized where safe to do so				
e	Security lighting minimized to not exceed the need				
2	<i>Facility:</i>				
a	All unnecessary plug loads are unplugged including:				
	Extraneous entertainment center and computing surge protectors				
	Transformers feeding gaming consoles				
	Appliances/machinery not in use				

PWRCON Alpha Checklist

b	All rooms not in use isolated from heating load as much as possible		
c	Refrigerator/Freezer adjusted to lowest setting possible to preserve food (35 F/ 1.7C)		
d	In winter: heat set to 20C/68F or below; In summer: cooling set to 26C/78F or above unless superseded by another directive		
e	Print only critical documents		
*	Compliance is monitored and enforced by facility managers		
COMMERCIAL CUSTOMERS			
1	Lighting:		
a	Indoor lighting reduced to approximately one half		
b	Lighted outdoor signs turned off		
c	Outdoor lighting minimized where safe to do so		
2	Facility:		
a	All non-critical plug loads are unplugged particularly during peak times (0900-1700 in the summer)		
b	Isolate all rooms not in use from heating load as much as possible		
c	In winter: heat set to 20C/68F or below; In summer: cooling set to 26C/78F or above		
d	Kitchen loads reduced as much as possible		
*	Compliance is monitored and enforced by facility managers		
Comments:			