



REPLY TO  
ATTENTION OF

**DEPARTMENT OF THE ARMY**  
NEW ORLEANS DISTRICT, CORPS OF ENGINEERS  
P. O. BOX 60267  
NEW ORLEANS, LOUISIANA 70160-0267

JUL 26 2012

Operations Division  
Operations Manager, Completed Works

Ms. Susan H. Maclay  
President  
Southeast Louisiana Flood Protection Authority – West  
7001 River Road  
Marrero, Louisiana 70072

Dear Ms. Maclay:

You are hereby informed that the contract for the West Bank and Vicinity (WBV), Hurricane and Storm Damage Risk Reduction System, WBV-07, Planters Pump Station Fronting Protection and Modifications (W912P8-09-C-0119), in Plaquemines Parish, Louisiana, has been completed. This project was completed by the United States pursuant to Public Law 109-148, Emergency Supplemental Appropriations to address Hurricanes in the Gulf of Mexico, and Pandemic Influenza Act, 2006.

A final inspection of the project was conducted on June 28, 2012, and all contract work was performed in accordance with the approved plans and specifications and meets the 100-year event design criteria. For operations and maintenance guidance, refer to the interim operation, maintenance, repair, replacement, and rehabilitation (OMRR&R) manual, Volume 1 and Volume 2, previously provided to you. Please note, Volume 3 of the OMRR&R manual will be provided in the near future which will provide the final OMRR&R information associated with above referenced contract. Please see enclosed the following items:

- a. As-built contract drawings – Enclosure 1
- b. Notification of Contract Completion (NCC) survey data – Enclosure 2
- c. Final inspection attendance roster – Enclosure 3

The punch list items identified during the pre-final inspection have been corrected and inspected by representatives of the Southeast Louisiana Flood Protection Authority – West, the Coastal Protection and Restoration Authority Board of Louisiana (CPRAB), formerly known as Coastal Protection and Restoration Authority (CPRA), and by our office. The Bermuda grass has been established and with proper maintenance should continue to improve in density and root structure.


The NCC survey data includes a table presenting elevations at stations that can be compared to the construction plans. The data represents a centerline profile of the floodwall. The survey data reflects the elevations of the floodwall are within the tolerance of the elevations required by the construction plans, and it is above the required retention design grade of elevation 8.2 feet.

In accordance with the Local Cooperation Agreement Amendment Number 2 between the Department of the Army and the Louisiana Department of Transportation and Development and the West Jefferson Levee District dated April 2, 2007, West Jefferson Levee District shall undertake the OMRR&R of this completed project feature of the West Bank and Vicinity, Hurricane and Storm Damage Risk Reduction System in Plaquemines Parish.

In this connection, maintenance is construed as keeping all completed works in working condition to serve the purpose for which they were designed.

If there are any questions concerning your OMRR&R responsibilities, please call Ms. Amy Powell, Operations Manager, Completed Works, or Ms. Karen Clement, Assistant Operations Manager, Completed Works, at (504) 862-2241 and (504) 862-2313, respectively.

Sincerely,

A handwritten signature in black ink, appearing to read 'E. Fleming', written over a horizontal line.

Edward R. Fleming  
Colonel, US Army  
District Engineer

Enclosures

Copies Furnished w/enclosures:

Mr. Garret Graves  
Chairman  
Coastal Protection and Restoration Authority Board of Louisiana  
1501 North 3<sup>rd</sup> Street  
Capitol Annex Building  
Baton Rouge, Louisiana 70802

Mr. Giuseppe Miserendino, Regional Director  
Southeast Louisiana Flood Protection Authority - West  
West Jefferson Levee District  
7001 River Road  
Marrero, Louisiana 70072

Mr. Jerome Zeringue  
Executive Director  
Coastal Protection and Restoration Authority  
Post Office Box 44027  
Baton Rouge, Louisiana 70804-4027

Mr. Clifton Bingham  
General Counsel  
Coastal Protection and Restoration Authority  
Post Office Box 44027  
Baton Rouge, Louisiana 70804-4027

Mr. John R. Monzon, B.S.C.E., P.E.  
Chief Engineer, Flood Protection Division  
Coastal Protection and Restoration Authority  
Post Office Box 44027  
Baton Rouge, Louisiana 70804-4027

Mr. James McMenis, P.E.  
Program Manager, Program – Project Management Division  
Coastal Protection and Restoration Authority  
Post Office Box 44027  
Baton Rouge, Louisiana 70804-4027

Mr. Harold Daigle, P.E.  
Administrator, Program – Project Management Division  
Coastal Protection and Restoration Authority  
Post Office Box 44027  
Baton Rouge, Louisiana 70804-4027

Mr. Ennis Johnson  
Engineer 6  
Louisiana Department of Transportation and Development  
District 02  
7252 Lakeshore Drive  
New Orleans, Louisiana 70124