SANDIA REPORT

SAND2010-4530 Unlimited Release Printed August 2010

Adapting ORAP® to Wind Plants: Industry Value and Functional Requirements

Salvatore A. DellaVilla Strategic Power Systems®, Inc. 11016 Rushmore Dr. Frenette Bldg., Suite 275 Charlotte, NC 28277

Prepared for the Sandia CREW Project Team:
Bridget L. McKenney, Alistair B. Ogilvie, Valerie A. Peters, Paul S. Veers
Sandia National Laboratories
P.O. Box 5800
Albuquerque, NM 87123

Prepared by
Sandia National Laboratories
Albuquerque, New Mexico 87185 and Livermore, California 94550

Sandia National Laboratories is a multi-program laboratory operated by Sandia Corporation, a wholly owned subsidiary of Lockheed Martin company, for the U.S. Department of Energy's National Nuclear Security Administration under Contract DE-AC04-94AL85000.

Approved for public release; further dissemination unlimited.



Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, make any warranty, express or implied, or assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represent that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof, or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof, or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from

U.S. Department of Energy Office of Scientific and Technical Information P.O. Box 62 Oak Ridge, TN 37831

Telephone: (865) 576-8401 Facsimile: (865) 576-5728

E-Mail: reports@adonis.osti.gov
Online ordering: http://www.osti.gov/bridge

Available to the public from

U.S. Department of Commerce National Technical Information Service 5285 Port Royal Rd. Springfield, VA 22161

Telephone: (800) 553-6847 Facsimile: (703) 605-6900

E-Mail: <u>orders@ntis.fedworld.gov</u>

Online order: http://www.ntis.gov/help/ordermethods.asp?loc=7-4-0#online



SAND2010-4530 Unlimited Release Printed August 2010

Adapting ORAP® to Wind Plants: Industry Value and Functional Requirements

Strategic Power Systems®, Inc. 11016 Rushmore Dr. Frenette Bldg., Suite 275 Charlotte, NC 28277

CREW Project Team: Bridget McKenney, Alistair Ogilvie, Valerie A. Peters, Paul S. Veers Sandia National Laboratories

Abstract

Strategic Power Systems (SPS) was contracted by Sandia National Laboratories to assess the feasibility of adapting their ORAP (Operational Reliability Analysis Program) tool for deployment to the wind industry. ORAP for Wind is proposed for use as the primary data source for the CREW (Continuous Reliability Enhancement for Wind) database which will be maintained by Sandia to enable reliability analysis of US wind fleet operations. The report primarily addresses the functional requirements of the wind-based system. The SPS ORAP reliability monitoring system has been used successfully for over twenty years to collect RAM (Reliability, Availability, Maintainability) and operations data for benchmarking and analysis of gas and steam turbine performance. This report documents the requirements to adapt the ORAP system for the wind industry. It specifies which existing ORAP design features should be retained, as well as key new requirements for wind. The latter includes alignment with existing and emerging wind industry standards (IEEE 762, ISO 3977 and IEC 61400). There is also a comprehensive list of thirty critical-to-quality (CTQ) functional requirements which must be considered and addressed to establish the optimum design for wind.

Contents

BACKGROUND	5
A FOCUS ON RELIABILITY	
LEVERAGING ORAP® FOR WIND	
BUILDING BLOCKS FOR VALUE	12
APPLYING ORAP® DESIGN FEATURES FOR WIND	
CRITICAL-TO-QUALITY FUNCTIONAL REQUIREMENTS	19

BACKGROUND

An assessment of the wind turbine industry today shows a gap exists between the growth in the installed base of wind turbines and the availability of current, factual, and detailed "reliability" performance metrics that can be used to characterize the operational performance of these assets. While owner/operators and Original Equipment Manufacturers (OEM's) have access to their own operational, maintenance, and outage experience data at some level of detail, which is required for in-warranty administration, product service and support, and asset management, the market has limited or no access to current and relevant reliability performance information on the installed base. A data-poor environment can contribute to a sense of uncertainty as to the reliability of the equipment that has been installed. This leaves the market and the public in a position to question the technology, and perhaps to set inaccurate or false product performance expectations. It is clear that the market will insist on "best in class" performance, while the public interest will expect the lowest possible cost of power with the highest levels of product reliability.

The power generation industry fully appreciates the need for meaningful and current reliability performance metrics. For successful conventional thermal power stations, the rigor and value associated with collecting, analyzing, and reporting operational, failure, and maintenance data is ingrained in their business culture and operating practice. The data provides a basis for developing the key performance indicators (KPI's) that are essential for profitably managing the plant(s). Today, various data capture and reporting systems are implemented to ensure that "critical to quality" (CTQ) data is available for assessment and action, plant improvement, effective communication with the OEM, required reporting to various industry or governmental organizations, as well as information sharing among product specific user groups. From Computerized Maintenance Management System(s) (CMMS) to remote monitoring (typically with the OEM), there is an emphasis on effective asset management and product improvement through information gathering and sharing, condition monitoring, and knowledge creation.

These power generation industry best practices must be extended to and implemented in the wind industry. Improved information sharing and knowledge is required to characterize the availability and reliability of these operating assets. The vast number of newly installed wind turbines and the associated increase in system capacity that they represent has no energy parallel. For the industry to sustain its continued growth, developers, owner/operators, insurers, banks, and others providing risk capital are requiring more meaningful data and information to establish realistic "pay-back" expectations. These financial pay-back requirements have placed a premium on effective asset management strategies to achieve operational excellence, to ensure that an accurate and meaningful pro forma is developed based on realistic equipment performance, to drive toward an acceptable return on equity, and to ensure a sustained level of profitability over the life cycle of the plant.

Each reliability issue that significantly impacts plant performance cannot be completely addressed within the operating environment. The equipment that is placed in the field must have the capability of high reliability operations designed into the system and specified at a component level. Component enhancement efforts need to be guided and prioritized by the

information that comes from the operating plant. While turbine manufacturers and component suppliers may get quality feedback during the warranty period, information on the performance of their equipment even after the warranty is over will enable them to make the design and specification changes that continuously improve the reliability of their products. Reliability issues that are uncovered across the entire industry may warrant dedication of public resources to work with the industry to resolve those issues. An example of this is the Gearbox Reliability Collaborative project sponsored by the Department of Energy (DOE) Wind Program. It is also the purpose of this data gathering effort to inform these initiatives, both public and private, for the benefit of the industry as a whole.

A FOCUS ON RELIABILITY

The "20% Wind Energy by 2030: Overcoming the Challenges" report from the DOE identified six technical challenges that must be overcome to improve the likelihood that wind technology can be seen as a high penetration energy option. One challenge calls for performance improvement and reduced operating and maintenance cost, "through improved reliability." Reliability is recognized as a KPI that requires improvement, and continuous reliability enhancement is a program goal. Success will be determined by how effectively and transparently any gap in reliability is understood, verified, documented, and corrected.

In today's energy market, expectations for acceptable, sustainable, and reliable product performance are established on a pro forma basis, regardless of technology. For wind technology to effectively compete as a viable energy alternative, irrespective of the value of production tax credits or incentives, the reliability performance of manufactured components and full systems must improve. To achieve a substantial increase in total generating capacity, from approximately 2% in 2010 to 20% by 2030, the reliability issue must be addressed. It is important to recognize that the critical criteria for successfully executing this growth objective is determined by how reliably and cost effectively wind turbines actually perform.

To understand the performance of wind turbines in the United States, DOE has initiated a Reliability Collaboration and System Analysis activity to be executed and managed by Sandia National Laboratories (SNL). A major element of this program is the creation of a Continuous Reliability Enhancement for Wind (CREW) database that has on-going access to field data. One objective is to use the data to develop a factual assessment of the reliability of wind turbines at a plant, turbine, system, and component level, as well as across the several OEM's. Another DOE objective is to drive down operating and maintenance (O&M) costs by 35% by 2030. To achieve these objectives, reliability improvement must take place. Openness and information sharing should stimulate a competitive market, as it does in other related industries, driving down costs through manufacturing improvements, as well as implementing on-going process and performance improvements at the operating plants.

SNL and Strategic Power Systems, Inc. (SPS®) are engaged in an effort to create a capability to gather operating data from a variety of sources and merge it into a database that fills the above needs. The specific purpose of this document is to summarize the value this capability will provide and to outline the functional requirements for developing and implementing this capability. This collaborative effort will result in a reliability tracking database large enough to characterize and benchmark the operation and maintenance experience of the US fleet; transforming plant data into Reliability, Availability, and Maintainability (RAM) metrics.

To achieve this objective, the project will leverage SPS' Operational Reliability Analysis Program (ORAP). ORAP is a reliability monitoring system, which collects RAM and operations data for benchmarking and analysis. ORAP is recognized as an independent and unbiased data collection, analysis, and reporting system for conventional gas and steam turbine technologies. A similar system, ORAP for Wind, will be deployed for the wind industry (see Figure 1). SPS' unbiased market presence ensures a repeatable process that is accurate, auditable, and verifiable.




Figure 1: ORAP Data Collection & Reporting Process for Wind

To achieve this objective, the specific project plan will address the following seven (7) critical to quality (CTQ) requirements:

- 1. Leverage SPS's existing ORAP as the foundation for a wind plant database and information architecture, which can be a primary data source for CREW.
- 2. Build on the results of the North American Electric Reliability Corporation (NERC) Wind Turbine Working Group (WTWG) to ensure consistency and compatibility with appropriate reliability metrics deployed through the NERC GADS (Generating Availability Data System), while providing a more granular level of wind turbine operating data. This means that ORAP will be focused on each wind turbine in the plant to develop a perspective of each power producing element as well as the total plant.
- 3. Develop and implement an optimized data capturing process with maximum automation and minimum human (operator and maintenance staff) intervention to obtain the required operating, maintenance, and failure history at the right level of detail and with a high degree of accuracy and efficiency.
- 4. Provide value to plant operators by automating reporting requirements for various regulatory and business interests, including NERC GADS and specific ISO (Independent System Operator) reporting requirements.

- 5. Establish an effective, on-going, long-term data exchange at the right level of detail to meet the reporting requirements for the analytical assessments and reliability benchmarking goals of SNL, SPS, and other industry stakeholders.
- 6. Define the necessary data categories and elements required from each participating plant; pedigree data (plant configuration data essential for establishing "peer groups"), operational data, outage event data, maintenance work order data, site ambient data, and met tower data.
- 7. Provide key stakeholders "real time" access to data and analysis to improve asset management and operations.

LEVERAGING ORAP® FOR WIND

SPS has the unique benefit of being able to look back over twenty-two (22) years of reliability engineering experience, with specific focus on electrical generation. SPS provides products and services that are focused on capturing plant operational and maintenance data, and transforming that data into standard industry performance metrics and benchmarks for use by some of the most recognized organizations in the global energy market today: EPRI (Electric Power Research Institute), ALSTOM, Chevron, Rolls-Royce, Iberdrola, GE, Direct Energy, E.on, BP, Mitsubishi... as well as hundreds of gas and steam turbine-driven plants all over the world.

SPS' industry recognition is based on reliability engineering and information technology strengths that are executed through the ORAP system. Fundamentally, ORAP provides a strong information infrastructure that has been developed and improved over time. The evolution of the ORAP infrastructure is based on three (3) criteria: first, the value of data gathering; second, implementing productivity processes to minimize manual input and time; and third, transforming the data into meaningful, unbiased information for reliability engineering assessment and action. SPS' brand and value is directly associated with how our customers see and use ORAP to their maximum benefit.

SPS' core competence and added value are based on:

- Collecting and analyzing operating, failure, and maintenance data from power plants all over the U.S and the world...
- Ensuring data completeness, accuracy, validity, and timeliness...
- Providing meaningful RAM benchmarks and identifying "best in class" performance...

ORAP is all about transforming data into actionable reliability information and knowledge. ORAP provides an understanding of RAM characteristics or KPI's that represent the performance of today's mature and advanced gas and steam turbine technologies. These KPI's provide reliability and availability trends, the sources of and the reasons for plant downtime at the component level, as well as relevant industry benchmarks. As such, ORAP provides up-to-date KPI's for each participating customer, especially owner/operators and OEM's. For the owner/operator, how the equipment performs on a service hour per start basis impacts maintenance schedules and outage durations, influences parts' lives and spare part requirements, and ultimately determines whether pro forma profitability goals are achievable. For the OEM, availability and reliability performance are a reflection of both product and service quality. Consequently, the owner/operators and equipment manufacturers have a shared objective: to ensure that the actual availability and reliability performance of the operating asset is measured, is acceptable, and is sustainable. SPS, through ORAP, provides an understanding of what is required to attain "best in class" performance.

The critical issue is to determine what is required to adapt the ORAP system for wind. The issue relates to whether the foundational building blocks for developing time and energy based

measures can be easily determined and retrieved from operating wind turbines. These foundational building blocks include: equipment taxonomy, pedigree data, operating data, outage data, and counter data (or aging characteristics). And industry standards, like IEEE (Institute of Electrical and Electronic Engineers) 762 (IEEE Standard Definitions for Use in Reporting Electric Generating Unit Reliability, Availability, and Productivity) and ISO (International Organization for Standardization) 3977 (Part 11 – Reliability, Availability, Maintainability and Safety) must be considered as well. They provide important guidance and insight for addressing any operational or performance differences between thermal and wind turbine plants. Any gap in the data that is required to track and develop meaningful time and energy based RAM metrics must be identified, addressed, and closed. Ultimately, the feasibility of developing, implementing, and deploying ORAP for wind will be determined by how effectively and productively the data collection, validation, analysis, and benchmark reporting can be defined and executed.

BUILDING BLOCKS FOR VALUE

Availability and reliability metrics as key power plant performance metrics rely on an accurate understanding of four fundamental informational elements: time, capacity (production or energy), events, and pedigree (configuration detail including taxonomy). It is absolutely essential that any proposed system initiated for capturing and reporting the reliability performance of wind turbines across a variety of designs, manufacturers, Megawatt (MW) sizes, O&M practices, or any other important technology characteristics, explicitly address these four elements. From this perspective, the ORAP system provides a sophisticated architecture that captures each of these CTQ elements and establishes a process that is uniform and consistent. Moreover, ORAP follows existing industry standards (IEEE 762 and ISO 3977) to ensure that both the collection of data and the reporting of reliability metrics follow these industry standards and are meaningful, accurate, verifiable, and repeatable. And while the ORAP system has been designed and implemented for the conventional gas and steam turbine power plants, the extension to wind technology should be relatively straight forward and deployable to the market for validation and full implementation. It should be noted that reviewing and being compliant with IEC (International Electrotechnical Committee) standards for wind turbines is a CTQ requirement as well. It is expected that the IEC will issue standards relating to both reliability metrics (time and energy based) as well as standardizing data points/tags. As ORAP is consistent with industry standards (IEEE 762 and ISO 3977), using the IEC standard will have a positive influence on establishing ORAP for wind.

It is important to point out that the electric power industry recognizes NERC as the de facto standard for monitoring and reporting the reliability of electric generating assets in the United States. The NERC reporting standards and guidelines are based on IEEE 762, providing the industry with uniform reliability metrics and formulae for application across the various generating technologies available in the market. NERC's processes and database architecture GADS adequately address the four fundamental elements of time, capacity, events, and pedigree. With the support of the Independent System Operators (ISO's) at the state level, NERC provides a valuable resource for understanding the reliability performance of the various generating options, providing meaningful comparisons of the different technologies on a consistent basis, and ensuring a uniform process for capturing the required reliability performance data from participating plants. NERC is currently in the process of addressing the addition of wind turbine technology to the generating mix, and understanding what the implications are from a data capturing and reporting perspective. With the advice and technical direction of their WTWG (a group of industry owner/operators, ISO's, and other industry stakeholders) NERC has made significant progress in defining additional reliability metrics specific to the wind industry. This includes identifying specific additional data that is required from participating plants to calculate these RAM metrics. However, it is important to note that with guidance from the WTWG, NERC has focused data collection and reporting efforts at the revenue meter level, not at the individual turbine level. This means that NERC will have very limited granularity. This will not provide sufficient information to determine system and component issues, and their impact on individual turbine capability and performance. This is counter to the approach that will be taken with ORAP. ORAP will be focused on each wind turbine in the plant, and will utilize data down

to the component level, to develop a perspective of each power producing element as well as the total plant.

It should be noted that SPS and NERC have a long standing relationship based on data exchange and information sharing. The primary distinction between NERC GADS and ORAP is the level of reporting granularity. A key requirement of ORAP is to provide system and component outage experience detail (whether forced outages or scheduled maintenance) to support improvement in component reliability. Since improvement in system and component reliability can be achieved through reduction in forced outages (on both a frequency and duration basis) or by verifying that maintenance outages are performed in an optimum manner (i.e. following manufacturer recommendations), it is important to track these events to the lowest level of detail possible. It is an absolute requirement of this project that the ORAP system provide a basis for capturing the wind turbine reliability data at the right level of detail (system and component data). With ORAP capturing work order or maintenance events at the component level, the ability to roll up the detailed outage data to the level required by NERC GADS becomes a routine task. This will provide a productivity benefit for the wind plant, as data capture at the component level will only be performed once with direct input to ORAP, then automated translation for NERC GADS will create data at the higher level and for the wind plant. Conversely however, because the NERC GADS data is not at the turbine level or at the component level of detail, there is no opportunity to create the reporting detail required by ORAP.

ORAP, as a reliability reporting system and database, has grown and evolved since it was first designed, developed, and introduced by SPS for commercial use in the power generation and industrial process markets in 1987. ORAP has a state-of-the-art relational database architecture based on Microsoft SQL Server technology. Today, ORAP has been migrated to Microsoft's most current software release; MS SQL Server 2005/2008. With MS SQL Server 2005/2008 as the backbone, ORAP is fully Web enabled through a .NET framework, with state-of-the-art reporting and analysis services, inherent in the current release of Microsoft's family of database and development products. The ORAP information architecture provides a strong infrastructure that effectively handles and supports the information flow of data from participating plants; from data retrieval, to information processing and storage, through report generation and analysis. Data confidentiality is required, enforced and maintained through designed-in security features. For optimum reliability, with a secure 24/7 access capability, the ORAP database and Web based reporting services is hosted at an off-site, fully redundant and secure data center.

APPLYING ORAP® DESIGN FEATURES FOR WIND

The ORAP system has a robust database architecture that has evolved and expanded over time. Technology changes that have taken place in the power industry have driven improvement and flexibility in the design of the ORAP database. This has favorably positioned ORAP to accommodate wind turbine and plant technology differences, when compared with existing ORAP capability in place for thermal power plants.

Existing design and operational features of the ORAP system must be reviewed to determine any necessary changes or additions to support wind technology. Existing ORAP design features that are in place for thermal plants include the following: (They are the foundation for expanding to wind).

- 1. The ORAP database schema (relational structure) provides a design framework for capturing and storing operational data, outage events, counter readings, and plant configuration (pedigree) information from participating generating plants. These data elements are fully consistent with the industry standards: IEEE 762 and ISO 3977, (in the future, the IEC standards). This data structure is fully consistent and goes beyond the NERC GADS reporting requirements:
 - Configuration (Pedigree) Data –

Company, Site, Plant, Unit
OEM (main equipment supplier)
Model
MW Rating (ISO Conditions) (International Organization for Standardization)
Site Conditions
Others...

<u>Note</u>: The configuration or pedigree data are essential for defining units of like model, design, or operation. The configuration data tracks the engineering design to meaningful equipment levels. This is important for defining "peer groups" for benchmark comparison of operational performance.

Operating Data –

Service Hours
Reserve Standby Hours
Starts (successful, attempted, testing)
Megawatts
Site Ambient
Others...

Note: To the largest degree possible, process data from either the plant SCADA (Supervisory Control and Data Acquisition) or a central remote monitoring facility on a

turbine by turbine basis will be required. This will provide the optimum automated approach for collecting data that can be transformed into time, capacity, and energy values.

The objective is to capture the appropriate and most complete set of data tags, or process points, and equipment faults available from the SCADA, without imposing any requirement for additional sensors. The objective is to define and develop logical transformations of the points into time, capacity, and energy values. These transformations will define service hours, standby hours, megawatt hours, wind speed and other relevant site ambient conditions, start-up and shutdown, lockouts, and other important operational and process parameters.

Event (outage) Data –

Planned, Unplanned, and Forced outages (based on the outage classification) Major Inspection Activity (time to perform and interval) Concurrent Maintenance, Non-curtailing Events, and Deratings Outage Cause, Symptoms, and Corrective Actions (narrative/description) Others...

<u>Note</u>: The outage classifications will be consistent with the existing SPS structure, and will be made compatible with the NERC GADS requirements. However, it is expected that required changes or additions to the outage classification will be required to address faults and automatic resets.

Data from CMMS and lock-out/tag-out systems will provide useful information pertaining to outage events. In addition, outage descriptions may be supplemented by various attachments (pictures, drawings, plant outage reports) for comprehensive assessment of symptom, corrective action, and root cause of outage events.

Counter Readings –

Service Hours
Stops/Starts
Equivalent Operating Hours/Maintenance Factors
Others...

<u>Note</u>: Counter readings are taken to track the aging characteristics of the turbine. The issue of age for a wind turbine and/or other key equipment will require tracking by serial number of critical components like the gearbox. This will require parts tracking capability to a serialized part number level.

Other Data Reporting –

Part Replacements
Major Equipment Removals
Compliance with Manufacturer Service Bulletins

Testing Details Others...

2. The ORAP database contains a standard equipment coding "taxonomy", based on EPRI's "Equipment Breakdown Structure" (EBS), developed and maintained by SPS. This breakdown structure is based on a hierarchical structure: major system, system, component group, and component. This provides the opportunity to develop an equipment taxonomy that is modifiable and expandable based on introduction of new technology. These equipment codes are also fully compliant with the European Kraftwerk-Kennzeichensystem (KKS) standard and can accommodate multiple coding structures.

The fundamental design structure of the EBS allows field data to be reported at the necessary level to characterize the cause of plant downtime; usually defined based on a symptom or corrective action. The impact of outage events, on a frequency and duration basis, can be easily grouped at any level based on this hierarchical structure.

These standard codes are at a significant level of detail. The codes provide an approach for organizing and categorizing outage events (both maintenance and forced outages) for detailed statistical and engineering analyses. Sufficient data is obtained to identify design and/or operating and maintenance issues at a component level. This level of detail will be essential to meet the goals of identifying reliability issues and constraints that must be resolved through product development and improvement.

<u>Note</u>: The equipment taxonomy EBS must be developed to meet the overall project objectives. Independent work already performed by SNL, NERC, and SPS will provide a strong basis for developing a standard architecture. The various wind turbine models (based on OEM, size, and other technical differences) will be used to develop the existing technology matrix. This will then provide the basis for developing the standard taxonomy (see Figure 2).




Figure 2: Deriving Wind Plant Taxonomy – Equipment Breakdown Structure

3. ORAP data is received on a monthly basis (at minimum) for timely assessment of operational reliability and availability at the unit level. ORAP is capable of dealing with near "real time" control system data using patented data transformation logic developed by SPS. SPS processes require timely, comprehensive, and accurate feedback from participating plants on a scheduled basis.

The database has a flexible design to quickly modify or add new data fields as required and to support anticipated differences required with wind technology without having to significantly change the underlying design.

4. Engineering review, edit, and validation of all reported data (automated and manual) is conducted to ensure the completeness and accuracy of reported data.

<u>Note</u>: Data validation is a CTQ requirement. The data validation begins at the various operating plants, as well as being an essential process for adding data to the ORAP database. To the largest degree possible, validation of the data must be automated, with sufficient and comprehensive checks put in place to ensure data quality.

5. ORAP has full data input reporting capability using both local and distributed personal computer (PC) or Internet based reporting. A specific design objective relative to the collection of data from the operating plants is simplicity, minimum human effort, maximum automation, and scalability. It is a CTQ requirement that the data flow to the ORAP database

for processing and direct flow to the SNL CREW database, and to the degree required, NERC GADS and various ISO's (Independent System Operators).

6. A reporting data warehouse for quarterly and on-demand statistical reporting is also part of the ORAP system. The reporting database structure covers both individual turbine generators and the total plant with data ready for reporting on both a "unit year" and "pooled statistics basis". With ORAP as the fundamental building block, SPS has developed a family of robust, interactive decision support tools that significantly enhance the process of capturing field data at the unit and plant level. Through an on-line Web based process called ORAP Interactive, direct access to the ORAP database provides an effective means for reporting and analysis of the data and transformed information (see Figure 3). SPS developed these tools to provide owner/operators, OEM's, and those with a vested interest in the energy industry the ability to achieve operational excellence through effective asset management. These same processes, procedures, and core competencies will be applied as ORAP is expanded for wind.




Figure 3: Reporting – Value to Stakeholders

Clearly, leveraging ORAP for wind is feasible. The infrastructure is in place to ensure a successful design and development effort for deployment of ORAP for wind.

CRITICAL-TO-QUALITY FUNCTIONAL REQUIREMENTS

The following specific critical to quality (CTQ) functional requirements must be considered and fully addressed to establish the optimum design; ORAP for Wind:

- 1. Must be at the individual turbine level (including groups and subgroups) with roll-up to the total plant.
- 2. Must understand plant arrangement and operational issues from an engineering perspective (influences on data capture).
- 3. Must recognize and protect the proprietary nature of specific owner/operator data.
- 4. Must be fully compliant with IEEE 762 and ISO 3977 for time and capacity/energy based data requirements (i.e. pedigree, operational, event, counter, capacity, energy, ambient) and measurements (i.e. metrics). Also, the design efforts made by the NERC WTWG must also be considered to ensure that data requirements will be met.
- 5. Must consider and be compliant with the IEC reliability standard (time and energy) when released to the industry for application.
- 6. Must obtain SCADA (and/or control system) data points/tags and faults/alarms automatically at a desired scan rate/frequency (no manual effort (push vs. pull) and no invasion/intrusion on SCADA). This data must cover both the complete plant and substation(s).
- 7. Must consider and be compliant with the IEC standard that will address standardizing SCADA data points/tags and faults/alarms.
- 8. Must develop a scalable approach for archiving the SCADA data points/tags and faults/alarms as required and for some acceptable period of time for future review and reference.
- 9. Must develop and utilize transformation logic to process the data point/tags and faults/alarms to develop accumulators of time, capacity/energy, and events.
- 10. Must obtain outage event data from available CMMS and/or lock-out/tag-out systems at a desired rate/frequency (manual effort should be minimized). It is recognized that some manual effort will be required. This data must cover both the complete plant and substation(s).
- 11. Must consider streamlining a CMMS version for owner/operators not using an off-the-shelf product. This would be required to provide manual input capability to capture meaningful outage event details.

- 12. Must develop a scalable approach for archiving the CMMS and/or lock-out/tag-out data as required and for some acceptable period of time for future review and reference.
- 13. Must develop and utilize transformation logic to process the CMMS and/or lock-out/tagout data to determine the beginning and ending of events (outage duration), as well as the symptom, corrective action, and the root cause of the event.
- 14. Must develop an equipment breakdown structure (taxonomy) consistent with SPS' standard (major system, system, component group, and component). The ability to add, edit, modify, and delete codes must be provided. It is expected that EBS codes for specific wind turbine models will be developed to then derive a generic taxonomy. Must include KKS translation (input and reporting).
- 15. Must consider ReliaWind project efforts and results, including taxonomy and benchmark reporting.
- 16. Must revise current ORAP data collection process for symptom, corrective action, and root cause. Input process should define whether the outage description provided represents symptom, corrective action, and root cause (all can be reported). The equipment breakdown structure code must be captured for each.
- 17. Must consider impact of capturing the symptom, corrective action, and root cause on reporting.
- 18. Must assess and determine the value of capturing and/or making changes to the Outage Mechanism Code (OMC). The OMC code is used in the existing ORAP system in a limited manner. The OMC is used specifically for sorting data and reporting specific failure modes. Additional OMC codes and possibly other uses will be required for wind.
- 19. Must develop (unite) data on a turbine/plant month basis (at a maximum hourly/daily/weekly also available) to develop/roll-up unit year data.
- 20. Must develop automated and manual data validation routines to identify issues, data errors, and ensure data quality.
- 21. Must provide ability to add, delete, and modify data to ensure validity of all types/classes of transformed data.
- 22. Must ensure full security of data transfer and database access.
- 23. Must ensure strong internet based communications for high speed and secure data transfers from plant/central monitoring center and SPS.
- 24. Must minimize the need for additional hardware (servers) at the plant or at a central monitoring center.

- 25. Must develop the process for aggregating data for meaningful reporting (at the right level of detail and metrics), including benchmark reports for owner/operators. This must support "data partners" with information consistent with their specific level of data provided.
- 26. Must develop the approach for access to reports through ORAP Interactive (internet based). This must support "data partners" with information consistent with their specific level of data provided.
- 27. Must develop the data transfer requirements for the SNL CREW database. It is expected that this will include, but not be limited to: performance history of each turbine, power output, wind speed, wind direction, wind conditions and a complete set of downtime events, including associated symptoms, root cause and corrective actions.
- 28. Must consider the NERC WTWG efforts to ensure capability of providing required data to NERC and to various ISO's (Independent System Operators).
- 29. Must consider off-shore issues and logistical concerns.
- 30. Must consider the unavailability types to be consistent with the existing SPS structure, and with the NERC GADS requirements. It is expected that required changes or additions to the outage classification will be required to address faults and automatic resets specific to wind plants.

These critical to quality functional requirements must be executed in an efficient manner to provide value and to ensure scalability. The specific requirements will be organized into the following major categories so that the specification and the work performed can be further developed in an efficient manner (see Table 1).

Table 1: Functional Requirements - Major Categories

Topic	Specific Issue Number
Taxonomy Definition	14, 15
Review All Standard(s) – RAM Metrics	4, 5, 7, 22, 23, 30
Automated Data Collection (ADC) &	1, 2, 3, 6, 8, 9, 10, 12, 13, 19, 22, 23, 24, 29
Transformation Logic	
Modification to ORAP Data Entry	11, 16, 18, 30
Tools	
NERC Export	22, 23, 26, 28
CREW Export	22, 23, 26, 28
Data Validation & Populating	20, 21, 23, 24
Reporting Database	
Reporting	15, 17, 19,22, 23, 25, 26
Documentation Plan	User & System Doc. Begins in Detailed Design
Hardware & Security	22, 23, 24

DISTRIBUTION

Kurt Anderson Upwind Solutions 3555 Lear Way Medford, OR 97504

Warren Ault LM Glasfiber ND Inc. 117 N. Jefferson Street, Suite 201 Chicago, IL 60661

Larry Barr enXco 17298 Commerce Way Tracy, CA 95377

Rashi Bates Shell Wind Energy 150 N. Dairy Ashford Bldg C, Room 334C Houston, TX 77079

William Beecher AES Wind Generation, Inc. P.O. Box 581010 North Palm Springs, CA 92258-1010

Harvey Benes Nebraska Public Power District PO Box 310 402 East State Farm Road North Platte, NE 69103-0310

Daniel W. Bernadett AWS Truewind LLC 463 New Karner Road Albany, NY 12205

Eckart Bodenbach Winergy Drive Systems Corporation 950 Tollgate Road Elgin, IL 60123 Mark Anderson Centennial Power, Inc. 1150 West Century Avenue PO Box 5558 Bismarck, ND 58506

Paul Baker Moventas, Inc. 8823 N. Harborgate Street Portland, OR 97203

Phillip O. Barry NAWRTC at Mesalands Community College 911 South Tenth Street Tucumcari, NM 88401

Fred "Doc" Beasom NextEra Energy 7021 Oak Creek Road Mojave, CA 93501

Benjamin Bell Garrad Hassan America, Inc. 45 Main Street, Suite 302 Peterporough, NH 03458

Glen Benson AWS Truewind LLC 463 New Karner Road Albany, NY 12205

Roy Blackshear AEP, Desert Sky Wind Farm Lp PO Box 518 Iraan, TX 79744

Ken Bolin XCEL Energy 1225 17th Street, #483 Denver, CO 80202-5534 Dan Brake NextEra Energy 700 Universe Blvd Juno Beach, FL 33408

Sandy Butterfield Boulder WindPower 209 Boulder View lane Boulder, CO 80304

Jon N. Chafin Wind Hunter 821 East Dove Loop Road, Suite 2425 Grapevine, TX 76051

Michael Courville Shell Wind Energy 150 N. Dairy Ashford Bldg C, Room 334C Houston, TX 77079

Mike Curley NERC 116-390 Village Blvd. Princeton, NJ 08540

Tracy Deadman AES Wind Generation 4300 Wilson Boulevard Arlington, VA 22203

Edgar DeMeo Renewable Energy Consulting Services 2791 Emerson St. Palo Alto, CA 94306

Carlos J. Diaz Edison Mission Energy-Midwest Generation EME, LLC 440 South LaSalle Street, Suite 3500 Chicago, IL 60605

Philip K. Dutton 206 Reveille Road Austin, TX 78746 Geoffrey Bratton JP Morgan Capital Corporation 10 South Dearborn Street Chicago, IL 60603

Luis Cerezo EPRI 1300 West WT Harris Blvd Charlotte, NC 28262

Craig Christensen Clipper Windpower Technology, Inc. 6305 Carpinteria Ave., Suite 300 Carpinteria, CA 93013

Martin C. Crotty Upwind Solutions 3555 Lear Way Medford, OR 97504

Ted De Rocher Caithness Operating Company, LLC 9790 Gateway Dr., Suite 220 Reno, NV 89521

Salvatore A. DellaVilla Strategic Power Systems, Inc. 11016 Rushmore Drive Frenette Building Suite 275 Charlotte, NC 28277

Chris E. Derickson Nebraska Public Power District PO Box 310, 402 East State Farm Road North Platte, NE 69103-0310

John R. Dunlop American Wind Energy Association 448 Morgan Avenue South, Suite 300 Minneapolis, MN 55405

Marc Dworkin Reunion Power LLC PO Box 2049 Manchester Center, VT 05255 Scott Eatherton AES Wind Generation 14740 Altamont Pass Road Tracy, CA 95391

Neal Emmerton Bluarc Management Group LLC 777 Tahquitz Canyon Way, Suite 200-13 Palm Springs, CA 92262

Miguel Ezpeleta Acciona Wind Energy USA, LLC 101 North Wacker Drive, Suite 610 Chicago, IL 60606

Jeff Gibbons AES Wind Generation, Inc. P.O. Box 581010 North Palm Springs, CA 92258-1010

Miguel Angel Gonzalez-Posada Gamesa 2050 Cabot Blvd. West Langhorne, PA 19047

Randall Grayson enXco 215 111th Street Lake Wilson, MN 56151

Bruce Hamilton PPM Energy, Inc.-A Scottish Power Company 1125 NW Couch, Suite 700 Portland, OR 97209-4129

David A. Healy MidAmerican Energy 666 Grand Avenue, PO Box 657 Des Moines, IA 50309-2506

Bill Holley GE Wind GTTC, 200-D 300 Garlington Road Greenville, SC 29615 Ahmed Elgamal University of California-San Diego 9500 Gilman Drive #0085 San Diego, CA 92093-0085

Energy Research Centre of the Netherlands T.S. Obdam PO Box 1 1755 ZG Petten The Netherlands

Margaret M. Ganczak Vestas Americas 1881 SW Naito Parkway, Suite 100 Portland, OR 97201

Ben M. Givens American Electric Power 1423 CR 131, Trent Wind Farm, L.P. Trent, TX 79561-3029

AnneMarie Graves Garrad Hassan America, Inc. 11770 Bernardo Plaza Court, Suite 209 San Diego, CA 92128

Gary Hackett Portland General Electric Company 121 SW Salmon Street Portland, OR 97204-2908

Bruce Hammett WECS Electric Supply, Inc. Box 580276, 19465-3A N. Indian Avenue North Palm Springs, CA 92258-0276

James Heenan GE Energy 2 Central Quay, 89 Hydepark Street Glasgow, G3 8 BW Great Britain James Holly BP Alternative Energy North America Inc. 501 Westlake Park Boulevard Houston, TX 77079

Desiree Johnson Iberdrola Renewables 1125 NW Couch St, Suite 700 Portland, OR 97209

Gary Kanaby Knight & Carver Yacht Center 2423 Hoover Avenue National City, CA 91950

Carl Knowlan Horizon Wind Energy 808 Travis Street, Suite 700 Houston, TX 77002

Benjamin Lanz IMCORP 179 Middle Turnpike Storrs, CT 06268

S. Doug Levitt CalWind Resources Inc. 2659 Townsgate Rd. #122 Westlake Village, CA 91361

James Locke AIRBUS North America Engineering, Inc. 213 Mead Street Wichita, KS 67202

Shaw Makaremi Clipper Windpower 6305 Carpinteria Ave. Carpinteria, CA 93013

Lance Manuel University of Texas at Austin 1 University Station, C1748 Austin, TX 78712 Peter Hjuler Jensen Riso National Laboratory Station for Wind Turbines, Box 49 DK-4000, Denmark

Thomas Jonsson iQwind LLC 8208 NW 30th Terrace Miami, FL 33122

Morten Karulf ABB Danish Wind Team Meterbuen 33 8382 Skovlunde Denmark

Clifford Lange Structural Integrity Associates, Inc. 5215 Hellyer Ave. Suite 210 San Jose CA, 95138

Scott Larwood 1120 N. Stockton St. Stockton, CA 95203

Steve Lockard TPI Composites, Inc. 373 Market Street Warren, RI 02885-0367

James Lyons Novus Energy Partners 201 North Union St., Suite 350 Alexandria, VA 22314

Ninochska Maldonado enXco 3896 Begonia Street Palm Beach Gardens, FL 33410-5608

Shane Mawhinney B9 Energy (O&M) Ltd. Willowbank Road Milbrook Industrial Estate Larne, Co. Antrim N. Ireland, BT402SF United Kingdom Brian McNiff McNiff Light Industry 43 Dog Island Road Harborside, ME 04642

Jim Mikel Energy Maintenance Service, LLC PO Box 158 Gary, SD 57237-0158

Amir Mikhail Clipper Windpower Technology, Inc. 6305 Carpinteria Ave., Suite 300 Carpinteria, CA 93013

Jim Morgan, LCDR, USN Mesalands Community College 911 South Tenth Street Tucumcari, NM 88401

Walt Musial NREL/NWTC 1617 Cole Boulevard MS 3811 Golden, CO 80401

Ross Newlin enXco 3818 Aspenwood Drive Richmond, TX 77469

Tim Olsen Tim Olsen Consulting 1428 S. Humboldt St. Denver, CO 80210

Francicso Oyague National Renewable Energy Laboratory 1617 Cole Bldv. MS 3811 Golden, CO 80401

Robert Z. Poore DNV-Global Energy Concepts 1809 7th Ave., Suite 900 Seattle, WA 98101 Glenn Melski Enel North America, Inc. One Tech Drive, Suite 220 Andover, MA 01810

Steve Mikel Suzlon Wind Energy Corporation 620 3RD Avenue Pipestone, MN 56164

Laura Miner Invenergy LLC One South Wacker Drive Suite 1900 Chicago, IL 60606

Larry Mumper SKF USA Inc. 1510 Gehman Road, PO Box 332 Kulpsville, PA 19443-0332

Juan Nasiff NextEra Energy 700 Universe Blvd Juno Beach, FL 33408

NWTC Library (5) NREL/NWTC 1617 Cole Boulevard Golden, CO 80401

Terry Oswald Horizon Wind Energy 808 Travis St., Suite 700 Houston, TX 77002

Venkata Subbaiah Pasupulati Oak Creek Energy Systems, Inc. 14633 Willow Springs Rd. Mojave, CA 93501

Jon Powers CalWind Resources, Inc. 2659 Townsgate Road #122 Westlake Village, CA 91361-2738 Pep Prats Ecotecnia Roc Boronat 78 8005 Barcelona Spain

Dave Roberts OSI Soft 777 Davis Street, Suite 300 San Leandro, CA 94577

Paul Rowan MLS Electrosystem 9333 Timber Trail Pittsburgh, PA 15237

Jeanfils Saint-Cyr Strategic Power Systems, Inc. 11016 Rushmore Drive Frenette Building Suite 275 Charlotte, NC 28277

Manny Sanchez NextEra Energy 700 Universe Blvd Juno Beach, FL 33408

Kevin Schroeder Invenergy LLC One South Wacker Drive Suite 1900 Chicago, IL 60606

Brian Smith NREL/NWTC 1617 Cole Boulevard MS 3811 Golden, CO 80401

Robert F. Steele Jr. Strategic Power Systems, Inc. 11016 Rushmore Drive Frenette Building Suite 275 Charlotte, NC 28277 Kenda Ransom Strategic Power Systems, Inc. 11016 Rushmore Drive Frenette Building Suite 275 Charlotte, NC 28277

Dan Rottler Puget Sound Energy PO Box 97034, PSE-09S Bellevue, WA 98009-9734

Rene Rysbergen B9 Energy O&M Ltd Millbrook Industrial Estate Larne, Northern Ireland BT40 2SF, United Kingdom

Matt Sakurada BP Wind Energy 130 N. Steele St., Suite A Sanford, NC 27330

Michael Schmidt Iowa Lakes Community College 19 South 7 Street Estherville, IA 51334-2234

Shawn Sheng National Renewable Energy Laboratory 1617 Cole Bldv. MS 3811 Golden, CO 80401

Sandy Smith Utility Wind Integration Group PO Box 2787 Reston, VA 20195

Cece Sterling (10)
Office of Wind and Hydropower Technologies
EE-2B Forrestal Building
U.S. Department of Energy
1000 Independence Ave. SW
Washington, DC 20585

Phil Stiles Acciona Energy North America Corporation 333 West Wacker Drive, Suite 1500 Chicago, IL 60606

Andrew Swift Texas Tech University Civil Engineering PO Box 41023 Lubbock, TX 79409-1023

Kedian Taborn Strategic Power Systems, Inc. 11016 Rushmore Drive Frenette Building Suite 275 Charlotte, NC 28277

Michael Tyson Suzlon Wind Energy Corp. 8750 W. Bryn Mawr Ave., Suite 720 Chicago, IL 60631

Case P. van Dam Dept. of Mechanical & Aerospace Eng. University of California at Davis One Shields Avenue Davis, CA 95616-5294

Chris Walford Puget Sound Energy PO Box 97034, PSE-09S Bellevue, WA 98009-9734

Charles White B9 Energy (O&M) Ltd. Willowbank Road Milbrook Industrial Estate Larne, Co. Antrim, N. Ireland, BT402SF United Kingdom

Simon Wright Industrial Evolution Deer Valley Financial Center, Suite 100 22601 North 19th Ave Phoenix, AZ 85027 Bahvahnie Suppiah OGE Energy Corp. P.O. Box 321, M/C 504 Oklahoma City, OK 73101-0321

Bob Szymanski enXco 17298 Commerce Way Tracy, CA 95377

Britt Theismann American Wind Energy Association 1101 14th Street, NW, 12th Floor Washington, DC 20005-5601

William A. Vachon W. A. Vachon & Associates PO Box 149 Manchester, MA 01944

Paul Veers National Renewable Energy Laboratory 1617 Cole Bldv. MS 3811 Golden, CO 80401

Carsten Westergaard Vestas Technology 440 Louisiana St., Suite 400 Houston, TX 77002

Eric White AWS Truewind LLC 463 New Karner Road Albany, NY 12205

INTERNAL DISTRIBUTION:

MS	0557	D.T. Griffith, 1523	
MS	0734	E. Stechel, 6383	
MS	1033	A. Ellis, 6352	
MS	1108	J. Torres, 6351	
MS	1124	T.D. Ashwill, 6362	
MS	1124	D.E. Berg, 6362	
MS	1124	S.M. Gershin, 6362	
MS	1124	R.R. Hill, 6362	
MS	1124	W. Johnson, 6362	
MS	1124	B. Karlson, 6362	
MS	1124	D.L. Laird, 6362	
MS	1124	B. McKenney, 6362	(10)
MS	1124	A. Ogilvie, 6362	(5)
MS	1124	J. Paquette, 6362	
MS	1124	M.A. Rumsey, 6362	
MS	1124	J.R. Zayas, 6362	
MS	1124	Wind Library, 6362	(5)
MS	1188	B. Thompson, 6384	
MS	9406	D. Manley, 8114	
MS	9406	V. Peters, 8114	(5)
MS	0899	Technical Library, 9536	(Electronic)

