


Taking Advantage of Your Data to Increase Reliability

Optimizing Wind Power Performance Conference
September 28-29, 2010

Bridget McKenney
Acting Manager
Wind & Water Power Technologies Department
Sandia National Laboratories
Albuquerque, NM



Sandia is a multiprogram laboratory operated by Sandia Corporation, a Lockheed Martin Company, for the United States Department of Energy's National Nuclear Security Administration under contract DE-AC04-94AL85000.



CREW: Continuous Reliability Enhancement for Wind database

Program Focus:

- ◆ Create national reliability database of wind plant operating data
 - ◆ Sub-component level
 - ◆ Characterize performance of US wind fleet
 - ◆ Identification of issues and technology improvement opportunities
 - ◆ Improved quality of next-generation components
 - ◆ Industry RAM benchmarks



Industry Maturity Level

2010: 35GW

2030: 305GW

❑ Still many **small** operators with little data expertise, running basic operations

- ❑ **Larger** players with previous fossil experience growing
- ❑ Emerging supply chain: wide variance in **quality** and **availability**
- ❑ Market instability > players come and go

Increasing Reliability:

Fewer Failures = Increased Capital Utilization +
Decreased O&M Costs +
Increased Investor Confidence + ...

2010

2030

**Current operators care about capital utilization more than “new technology” –
Strong need to reduce O&M costs;
Protection of proprietary data**

**DOE goal:
Pull-in earlier**


**Future operators will have stabilized operations and begin to focus on “new technology” –
Jump to the next level of performance;
More collaboration across industry**



CREW Database Program: Partner Maturity

*LESS Mature
Data & Analysis*

*MORE Mature
Data & Analysis*



Maintenance Data Scheduled & Unscheduled	<ul style="list-style-type: none"> •No documentation (tribal knowledge) •“I’ve got my work orders up here” <taps head> 	<ul style="list-style-type: none"> •Paper work orders •Scanning or typing paper forms 	<ul style="list-style-type: none"> •CMMS with true electronic work orders
Failure Data	<ul style="list-style-type: none"> •Not captured from SCADA 	<ul style="list-style-type: none"> •Data captured; large amounts of time unaccounted (10-15%) 	<ul style="list-style-type: none"> •SCADA data reviewed, and errors addressed
Data Infrastructure	<ul style="list-style-type: none"> •Flat text files •FTP sites 	<ul style="list-style-type: none"> •Data transfer processes •SCADA & Work Orders disconnected 	<ul style="list-style-type: none"> •SCADA, CMMS, data historian linked •SCADA “events” drive work orders

Manual collection
Hard copy

Data historian
Automated



Data-Based Decision-Making

What decisions do you need to make?

Data-Based Decisions


Data Analysis

Data Collection


7. Isolate possible improvements
8. Select improvement(s) with largest ROI
9. Implement and track improvement(s)

4. Establish baseline performance
5. Identify (high-level) performance drivers
6. Determine root cause

1. Install/upgrade data collection systems
2. Collect and store data
 - SCADA (time series; faults)
 - Work Orders / CMMS
 - Other data (cost, inventory, etc.)
3. Integrate data (symptoms vs. resolutions)



Data Collection & Data Storage/Retrieval



1. Install/upgrade data collection systems
2. Collect and store data
3. Integrate data



Collecting the Data

Translate Plant Knowledge To Corporate Knowledge!

Data Collection Systems

- Reconfigure, upgrade, install
- Staff skills and abilities

Collect & Store Data

■ SCADA:

- Time Series: real-time, data points (~25 fault tags), granularity (1' averages)
- Events and Alarms (Automatic Reset, Remote Reset, Technician Reset)

■ CMMS data: centralized for linking with SCADA data and analysis


- Paper Work Orders: At minimum enter them in an electronic format
- Ultimate Goal – SCADA Faults Generate Work Orders

■ Environmental data (failure context)

■ Centralized database/historian – real-time and historical data, data integrity



Operational
Data




Integrating Data

Operational data must be linked to maintenance and repair data in order to understand performance issues

- **Link SCADA summary, SCADA events/alarms, and work orders**
 - Relational database products: use relationships between data pieces to meet storage and access management requirements
 - Data historians: store time series data, using compression to manage storage of very large data streams
 - Knowledgeable staff to apply emerging automated tools for data linkage
- **Operations Command Center (OCC) approach**
 - Real-time SCADA data flowing from plant to centralized monitoring and control
 - Data stored in single large database
 - Robust, secure, reliable high-speed connection from plant to OCC
- **For smaller operators**
 - Site storage system to collect finite time-period SCADA data
 - Send subsets of data to central office for storage and analysis



Data Analysis



4. Establish baseline performance
5. Identify (high-level) performance drivers
6. Determine root cause

Baseline Performance


■ Establish baseline performance

- **Understand the current situation: What is it? How good is it?**
 - ◆ Calculate basic operations and reliability metrics (Availability, MTBE, Mean Downtime)
- **How does performance compare to OEM expectations?**
 - ◆ Power curve (wind speed vs. power output), including outliers
 - ◆ How does a typical turbine spend its time:
 - Non-generating (no wind, down for scheduled maintenance, curtailed, etc.)
 - Generating (power rating vs. wind speed)
 - Transitional/Unaccounted (no data)/Illogical (positive generation with no wind)
 - ◆ What data is missing: e.g., identify when turbine state cannot be determined
- **Document assumptions** (if 5% of SCADA records are not usable, was the turbine up or down during that time?)



Time Allocation

■ How does a “typical” turbine spend its time?




- **Transition:** Turbine changes from running to not running (or vice versa) during Measurement Period
- **Unknown:** Either turbine’s status or environmental conditions are not captured; OR they are captured, but are illogical
- **Unaccounted:** Missing records and/or time lost due to rounding of small Measurement Period lengths

Percent of Time	Wind				
	Above Cut Out	Rated	Moderate	Below Cut In	
Rated	0.0%	3.4%	3.6%	0.0%	7.0%
Moderate	0.0%	1.8%	43.9%	0.0%	45.7%
Low	0.0%	0.0%	9.1%	4.7%	13.8%
None (Online)	0.0%	0.0%	1.6%	8.6%	10.3%
None (Offline)	0.0%	1.4%	7.0%	8.1%	16.5%
	0.0%	6.7%	65.2%	21.4%	93.3%

Transition = 1.3% Unknown = 5.2% Unaccounted = 0.2%

DISCLAIMER: This chart contains only notional (fictional) data to demonstrate the type of results which reliability analysis may provide.

Power Curve



DISCLAIMER: This chart contains only notional (fictional) data to demonstrate the type of results which reliability analysis may provide.



Determining the issues

Identify high-level performance drivers

- Explore trends, outliers, good performance and surprising results
- Which are the good turbines? Which are problematic and why?
- Which types of downtime events are driving poor performance
 - Pareto analysis is simple but powerful
- Compare multiple metrics
 - Event frequency vs. event duration
 - Generation vs. turbine's recorded wind speed
 - Outliers are very revealing
 - Where is performance roughly the same? Where is there great variability?

Determine root causes

- Why are good turbines good, and vice versa?
- Why are certain aspects of operations having such a negative impact? (investigate de-rates, unexplained performance, unexpected patterns)
- What are root causes of the top problems? (fishbone chart, etc.)



Determining the issues


Identify High-level Performance Drivers

- Explore trends, outliers, good performance and surprising results
- Which are the good turbines?
Which are problematic and why?
- Which types of downtime events are driving poor performance
 - Pareto analysis is simple but powerful
- Compare multiple metrics
 - Event frequency vs. event duration
 - Generation vs. turbine's recorded wind speed
 - Outliers are very revealing
 - Where is performance roughly the same? Where is there great variability?

Determine Root Causes

- Why are good turbines good, and vice versa?
- Why are certain aspects of operations having such a negative impact? (investigate de-rates, unexplained performance, unexpected patterns)
- What are root causes of the top problems? (fishbone chart, etc.)


Data-Based Decisions



7. Isolate possible improvements
8. Select improvements with largest ROI
9. Implement and track improvements



Data-Based Decision Making



Reduce COE



Business Decisions

**Improving in areas you know you should be looking into -
Discovering areas you didn't think to look at.**

- **Minimizing O&M Costs (Isolate possible improvements)**
 - Maintenance schedules: Decrease component failure and early replacement
 - Schedule downtimes to minimize impact to generation and grid
- **Maximizing Capital Investment (Select improvements with largest ROI)**
 - Funding improvement efforts
 - Equipment purchase selections (performance to spec)
 - Reduce cost of financing and insurance
- **Policy & Public Sector**
 - Increase pace of development
 - Grow public support (drives policies)
 - Influence developing standards
- **Implement and Track Improvements**



Other Value

- **Doing a good job with reliability data collection, analysis, and decision-making sets the foundation for all kinds of other analysis & decision-making**
 - Grid integration (ex: impact of curtailment)
 - Labor analysis
 - Understanding weather & seasonal impacts
 - Supply chain analysis
 - Data-based input to investment decisions (your own & others)
 - ◆ Insurance
 - ◆ Tax-payers, rate-payers
 - Policy-making



Path Forward

- ❑ **Improve your capability to collect, store and analyze your operational data. Decrease COE through reduced O&M cost and higher availability.**
- ❑ **SNL report to be published October, 2010**
- ❑ **Participate as a pilot site in the CREW database project**
 - Courtesy reliability analysis
 - Early use of ORAP for Wind tool to collect and link SCADA to CMMS data

