

# Pacific Northwest National Laboratory (Richland, WA) Safety Basis Report

Total Facilities: 1

Facility	Hazard Category	Safety Basis Type	Approval Status	Date Approved
Building 325, Radiochemical Processing Laboratory (RPL)	HC2	DSA	AUR	10/17/2012

Safety Basis Report current as of Feb 15, 2013

## Program Office

Office of Science

## Safety Basis Type

BIO – Basis for Interim Operation

DSA – Documented Safety Analysis

PDSA – Preliminary Documented Safety Analysis

## Hazard Category

HC1 – Hazard Category 1 (a nuclear facility with the potential for significant off-site consequences)

HC2 – Hazard Category 2 (a nuclear facility with the potential for significant on-site consequences)

HC3 – Hazard Category 3 (a nuclear facility with the potential for only significant localized consequences)

HCR – Hazard Category Radiological (a radiological facility only)

## Approval Status

AUR – Approved Under the Rule (10 CFR 830 – Nuclear Safety Management)

E – Temporary Exemption Granted

SBPA – Operating Safety Basis Pending Approval

UD – Under Development

UMR – Operating Safety Basis Pending Update to Meet the Rule