

PROJECT facts

Environmental and
Water Resources

11/2006

U.S. DEPARTMENT OF ENERGY
OFFICE OF FOSSIL ENERGY
NATIONAL ENERGY TECHNOLOGY LABORATORY



SORBENT INJECTION FOR SMALL ESP MERCURY CONTROL IN LOW SULFUR EASTERN BITUMINOUS COAL FLUE GAS

Background

Full-scale field testing has demonstrated the effectiveness of activated carbon injection (ACI) as a mercury-specific control technology for certain coal-fired power plants, depending on the plant's coal feedstock and existing air pollution control device configuration. In a typical configuration, powdered activated carbon (PAC) is injected downstream of the plant's air heater and upstream of the existing particulate control device – either an electrostatic precipitator (ESP) or a fabric filter (FF). The PAC adsorbs the mercury from the combustion flue gas and is subsequently captured along with the fly ash in the ESP or FF. ACI can have some negative side effects. Even a slight increase in primary particulate emissions resulting from PAC passing through the particulate control device could trigger New Source Review (NSR) requirements, potentially exposing the plant to costly equipment upgrades. In addition, ACI results in commingling of PAC and the fly ash, which can impact fly ash marketability due to carbon contamination and the perceived health hazards associated with mercury.

CONTACTS

Thomas J. Feeley III
Technology Manager
Environmental & Water Resources
National Energy Technology
Laboratory
626 Cochran Mill Road
P.O. Box 10940
Pittsburgh, PA 15236-0940
412-386-6134
thomas.feeley@netl.doe.gov

Pierina Noceti
Project Manager
National Energy Technology
Laboratory
626 Cochran Mill Road
P.O. Box 10940
Pittsburgh, PA 15236-0940
412-386-5428
pierina.noceti@netl.doe.gov

Carl Richardson
Principal Investigator
9400 Amberglen Blvd.
Austin, TX 78729
512-419-5966
carl_richardson@urscorp.com

Primary Project Goal

Field tests are being conducted to: (1) evaluate the ability of various PACs to remove mercury from full-scale units configured with small specific collection area (SCA) ESPs; (2) document the impact of ACI on small-SCA ESP and wet flue gas desulfurization (FGD) scrubber operations; and (3) assess the impact of ACI on coal utilization byproducts. Full-scale ACI field tests have been completed at Georgia Power's Plant Yates Unit 1 and Unit 2 in Newnan, GA. Both Units 1 and 2 fire a low-sulfur Eastern bituminous coal. Unit 1 is equipped with a small-SCA ESP and a downstream jet bubbler reactor wet FGD system, while Unit 2 is outfitted with a dual flue gas conditioning system to enhance ESP performance. Additional ACI field testing will be conducted at Reliant Energy's Shawville Station Unit 3 in Shawville, PA during Summer 2006. This bituminous coal-fired unit is equipped with two ESPs in series.

Objectives

- Conduct short-term parametric tests to: (1) gain a better understanding of the plant-specific factors that influence mercury capture; (2) determine the best PAC for long-term testing; and (3) establish the optimal operating conditions for long-term continuous ACI tests.
- Conduct long-term (30-day) ACI trials to: (1) evaluate mercury removal efficiency over time; (2) examine the impacts of unit load and ACI concentration on small-SCA ESP and wet FGD operations; (3) quantify the effect of continuous ACI on primary particulate matter emissions; and (4) develop cost estimates for full-scale implementation of ACI for mercury control.



PARTNER

URS Group
Austin, TX

PERIOD OF PERFORMANCE

09/26/2003 to 07/31/2006

COST

Total Project Value
\$1,183,656

DOE/Non-DOE Share
\$858,004 / \$325,652

ADDRESS

National Energy Technology Laboratory

1450 Queen Avenue SW
Albany, OR 97321-2198
541-967-5892

2175 University Avenue South
Suite 201
Fairbanks, AK 99709
907-452-2559

3610 Collins Ferry Road
P.O. Box 880
Morgantown, WV 26507-0880
304-285-4764

626 Cochran Mill Road
P.O. Box 10940
Pittsburgh, PA 15236-0940
412-386-4687

One West Third Street, Suite 1400
Tulsa, OK 74103-3519
918-699-2000

CUSTOMER SERVICE

1-800-553-7681

WEBSITE

www.netl.doe.gov

Accomplishments

Parametric tests have been conducted at Plant Yates Unit 1 using two conventional (untreated) sorbents and one chemically-treated sorbent. The conventional sorbents were NORIT Americas' DARCO® Hg and RWE Rhinebraun's Super HOK, and the treated sorbent was an iodine-impregnated NH Carbon from Ningxia Huahui. Test results indicated similar performance for the three sorbents, with maximum total mercury removal of approximately 60 percent across the ESP using an ACI concentration of 6 pounds per million actual cubic feet (lb/MMacf) of flue gas. Because of its lower delivered cost, Super HOK was selected for the 30-day long-term continuous injection trial. Additional parametric tests performed on Unit 2 with DARCO® Hg revealed that the dual flue gas conditioning system had no impact on mercury removal efficiency.


During the 30-day long-term test, Plant Yates Unit 1 operated at low load (50-60 MW) and high load (95-107 MW) conditions, while the Super HOK injection concentration varied from 0-16 lb/MMacf. Super HOK injection concentrations of 4.5 lb/MMacf, 6.5 lb/MMacf, and 9.5 lb/MMacf were required to achieve average total mercury removals of approximately 68 percent, 75 percent, and 76 percent across the ESP, respectively.

Approximately 70 percent of the long-term ACI data fell within or below the range of ESP outlet particulate matter concentrations measured during baseline testing.

The following observations were made after monitoring the Unit 1 ESP arcing rate for three months: (1) ESP arcing rate increased during ACI; (2) ESP arcing rate was higher during high load versus low load; (3) ESP arcing rate appeared to be independent of the ACI concentration at low load; (4) ESP arcing rate may increase with ACI concentration at high load; and (5) the long-term continuous ACI trial caused no physical damage to the ESP.

Planned Activities

URS will be completing overall data analysis, economic analysis, and the final report. In addition, URS will conduct full-scale field testing at Reliant Energy's Shawville Station Unit 3 during Summer 2006.



Long-Term Field Testing Results at Plant Yates Unit 1