

8.4.1 WaterSense List of Covered Products and Efficiency Specifications

<u>Covered Product</u>	<u>Specification Effective Date</u>	<u>WaterSense Criteria</u>	<u>Federal Standard Level</u>
Lavatory Faucets	October 2007	1.5 gpm (1)	2.2 gpm
Toilets	January 2007	1.28 gpf (2)	1.6 gpf
Urinals	October 2009	0.5 gpf	1.0 gpf
Shower Heads	March 2010	2.0 gpm	2.5 gpm
Irrigation Control Equipment	November 2011	Qualitative (3)	-
Pre-Rinse Spray Valves	In Progress	1.25 gpm (4)	1.6 gpm
Water Softeners	In Progress	- (4)	-

WaterSense Landscape Irrigation Partners as of February 2012: 2001 (5)

Note(s): 1) GPM = gallons per minute. 2) GPF = gallons per flush. 3) Multiple criteria for irrigation includes requirements for percentage reduction in irrigation adequacy and irrigation excess, as well as conformance to supplemental capability requirements 4) Final criteria for these categories have not been set. These are criteria levels that WaterSense is considering. 5) WaterSense qualifies individuals as partners via private programs certified by WaterSense.

Source(s): EPA, High-Efficiency Lavatory Faucet Specification, October 2007; EPA, Tank-Type High-Efficiency Toilet Specification, January 2007; EPA, Showerheads Specification, March 2010; EPA, High-Efficiency Urinals Specification, October 2009; EPA, Irrigation Controllers Specification, January 2011; and EPA, Meet Our Partners List as of 2/8/2012, http://www.epa.gov/watersense/meet_our_partners.html.