DITCH SCHEDULES

DITCH SCHD	DITCH DEPTH—D	BOTTOM WIDTH—W	LINING
1	2.5' NOM/2' MIN	–	SEE NOTE 3, DET D71
2	2.5' NOM/2' MIN	5' NOM/4' MIN	SEE NOTE 5, DET A71
3	3.5' NOM/3' MIN	10' NOM/9' MIN	SEE NOTE 3, DET A71
4	3.5' NOM/3' MIN	20' NOM/18' MIN	SEE NOTE 3, DET A71
5	4' NOM/2.5' MIN	40' NOM/35' MIN	SEE NOTE 3, DET B71
6	2.5' NOM/ 2' MIN	5' NOM/ 4' MIN	SEE NOTE 5, DET A71
7	4' NOM/ 2.5' MIN	10' NOM/ 9' MIN	DET C71
8	3.5' NOM/ 3' MIN	5' NOM/ 4.5' MIN	SEE NOTE 5, DET A71

LEGEND

- ROCK CHUTES
- TRUNK DITCHES
- DITCHES
- TERRACE DITCHES
- 1 DITCH CLASS
- *.01 DITCH SLOPE

NOTE:

1. FOR TERRACE DITCH DETAIL, SEE DETAIL E71, 10W425-71

6/9/04

R									
R.G.		DRS	BSB	WPT	HLP	REP	JOA		D
ISSUED FOR DREDGE CELL EXPANSION									
REV NO.	DR'G	DRAWN	CHKD	CHKD	SUPV	PROJ	APPD	DESIGN	APPROVED

SCALE: 1"=200' EXCEPT AS NOTED

YARD

DREDGE CELL
LATERAL EXPANSION FINAL COVER
DRAINAGE PLAN & SCHEDULE

DESIGNED BY:	DRAWN BY:	CHECKED BY:	SUPERVISED BY:	APPROVED BY:	ISSUE NO.
D.R. SMITH	B.S. BURT	W.P. TAYLOR	H.L. PETTY	R.E. PURKEY	J.C. ADAIR

KINGSTON FOSSIL PLANT
TENNESSEE VALLEY AUTHORITY
FOSSIL AND HYDRO ENGINEERING

AUTOCAD R14 | DATE | 36 | C | 10W425-76 | R 0

PLOT FACTOR 200
W_TVA

C.A.D. DRAWING
DO NOT ALTER MANUALLY

PARSONS | 0
TASK COMPLETED BY: | REV NO.