

SECTION A80–A80
SCALE: HORIZONTAL 1"=50'
VERTICAL 1"=10'



SECTION B80–B80
SCALE: HORIZONTAL 1"=20'
VERTICAL 1"=10'



NOTE: HOLES POSITIONED TO FACE DOWNSTREAM

DETAIL C80
N.T.S.



DETAIL E80
N.T.S.



DETAIL D80
(ANTI SEEP COLLAR)
N.T.S.



DETAIL F80
N.T.S.



DETAIL G60
N.T.S.



DETAIL I180
PIPE SUPPORT
N.T.S.



DETAIL J80
PIPE BOLLARD
N.T.S.



DETAIL J80
TEMPORARY SILT LINE
N.T.S.

NOTES:

1. FILTER FABRIC LINE TO BE PLACED PRIOR TO THE START OF ROUGH GRADING.
2. STEEL POSTS SHALL BE STAKE "T" POSTS – 6'-0" LONG.
3. POSTS SHALL BE PLACED AT 4' INTERVALS MAX.
4. WIRE FABRIC AND FILTER FABRIC SHALL BE SECURELY BOUND TO POSTS WITH FILTER STAPLES OR WIRE TIES.
5. CONTRACTOR SHALL BE RESPONSIBLE FOR MAINTAINING CONDITION OF FILTER FABRIC FENCE IN A CONDITION THAT IS SATISFACTORY TO TVA UNTIL FINAL ACCEPTANCE OF WORK. REMOVE SEDIMENT WHEN SEDIMENT REACHES ONE-THIRD THE HEIGHT OF THE FENCE.
6. FILTER FABRIC SHALL BE A CLASS A FABRIC IN ACCORDANCE WITH TVA SPECIFICATION ___, SECTION 971.



DETAIL K80
N.T.S.

MINIMUM WIDTH (D)	
DIAMETER	D MIN
27" & SMALLER	3"
30" TO 60"	4"
66" & LARGER	6"

NOTES:

1. 3/4" ACF COMPACTED MINERAL AGGREGATE BEDDING SOIL BACKFILL IN LOOSE LIFTS NOT EXCEEDING 8" IN THICKNESS & COMPACTED TO 95% STANDARD PROCTOR DENSITY IN ACCORDANCE WITH ASTM D 698. MOISTURE & DENSITY TESTING SHALL BE IN ACCORDANCE WITH ASTM D 2922. A MINIMUM FREQUENCY OF NOT LESS THAN 5 TESTS PER 100 LINEAR FEET SHALL BE USED. A DEPTH OF 3' PRIOR TO PLACEMENT OF THE FIRST FILL COMPACTION TESTING IS REQUIRED AROUND STORM DRAIN PIPING AND DITCH ONLY REQUIRES 2 TESTS PER LOT.
2. STORM DRAIN PIPING USED WITH INSTALLATIONS INCLUDED ON THESE DRAWINGS SHALL BE INSTALLED WITH BEDDING MATERIAL PLACED INTO THE HAUNCHES AND HAND TAMPED. DO NOT PLACE DUMPED MATERIAL UNDER ANY ROADWAYS.

2/16/05