

## Summary Report of Occurrences Reviewed From February 9 – 13, 2009

**Summary:** 21 occurrences at 9 sites reviewed during this period.

### Significant Occurrences (1)

#### Electrical Safety – 1 occurrence at 1 site

- ***EM – Idaho Cleanup Project (Significance Category 3).*** On February 11, shortly after striking an arc, a URS Carpenter/Welder felt a tingling and his hand momentarily clenched onto the weld stinger while he was welding at the Integrated Waste Treatment Unit. The welder was standing on wet scaffolding and water dripped onto his head from the scaffolding above. His leather welding gloves were damp. The water had been applied to the work area per the Hot Work Permit. At the time of the event, the welding unit was set at 92 Amps. An electrical inspection of the welding unit, leads and surrounding area was performed. Because of the electrical shock, the welder was examined at medical and released with no restrictions.

**Other Occurrences (20).** See Table (Note: The Table includes the occurrences listed above).

Occurrence Category	Number of Occurrences				Number of Sites
	E&E	NNSA	SC	DOE Total	
Injury - Industrial Hygiene/Occupational Safety	1	0	1	2	2
Near Miss	1	2	0	3	2
Authorization Basis	1	1	0	2	2
Radiological Concerns	0	3	0	3	3
Environmental	0	1	0	1	1
Fire Safety	0	0	0	0	0
Shipping/Quality Assurance	0	1	0	1	1
Criticality Concerns	0	0	0	0	0
Industrial Operations	0	0	0	0	0
Conduct of Operations	1	1	0	2	2
Electrical Safety	1	0	0	1	1
Vehicle Accident	0	0	0	0	0
Equipment Failures	1	1	1	3	3
Safeguards and Security	0	1	0	1	1
Suspect & Counterfeit Parts	1	1	0	2	2
Other	0	0	0	0	0
<b>Total</b>	<b>7</b>	<b>12</b>	<b>2</b>	<b>21</b>	

### Secretarial Office Summary

National Nuclear Security Administration	12 occurrences	(3 sites)
Office of Environmental Management	6 occurrences	(3 sites)
Office of Fossil Energy	1 occurrence	(1 site)
Office of Science	2 occurrences	(2 sites)