## **ENERGY STAR Geothermal Heat Pump Qualified Product List**

## List Posted on February 20, 2013

Below are currently qualified ENERGY STAR models available for sale in the U.S.

				Additional Model		000 0 4		Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
			GTC36S1-(A-C)D (C,N) with						
ard Manufacturing Company, Inc.	Bard	Geo-Trio	GTA3600UD(-, A- G)		Closed Loop Water-to-Air	4.1	21.6	8/1/2010	2/18/2011
			GTC36S1-(A-C)D (C,N) with		0				
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	GTA3600UD(-, A- G)		Open Loop Water-to-Air	4.6	26.1	8/1/2010	2/18/2011
			GTC36S1-(A-C)D (C,N) with GTA3600UD(-, A-G) and GTB1-(A,		Closed Loop			2///22/2	04404044
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	C)		Water-to-Air	4.2	21.2	8/1/2010	2/18/2011
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	GTC36S1-(A-C)D (C,N) with GTA3600UD(-, A- G) and GTB1-(A, C)		Open Loop Water-to-Air	4.7	25.6	8/1/2010	2/18/2011
dra Manaractaning Company, inc.	Bara	GCO THO	GTC48S1-(A-C)D		vater to 7 til	7.7	20.0	0/1/2010	2/10/2011
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	(C,N) with GTA4860UD(-, A- G)		Closed Loop Water-to-Air	3.8	19.1	8/1/2010	2/18/2011
			GTC48S1-(A-C)D (C,N) with GTA4860UD(-, A-		Open Loop				
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	G)		Water-to-Air	4.3	22.4	8/1/2010	2/18/2011
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	GTC48S1-(A-C)D (C,N) with GTA4860UD(-, A-G) and GTB1-(A, C)		Closed Loop Water-to-Air	3.9	18.8	8/1/2010	2/18/2011
	33.3		GTC48S1-(A-C)D (C,N) with GTA4860UD(-, A-G) and GTB1-(A,		Open Loop		, , , ,		2.0.20.1
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	C)		Water-to-Air	4.3	21.8	8/1/2010	2/18/2011
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	GTC60S1-(A-C)D (C,N) with GTA4860UD(-, A- G)		Closed Loop Water-to-Air	3.7	19.8	8/1/2010	2/18/2011
a. a a a. a. a. a. a. a. a. a.	20.0	300 1110	GTC60S1-(A-C)D (C,N) with GTA4860UD(-, A-		Open Loop			5.1120.10	2,10,2011
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	G)		Water-to-Air	4.2	23.7	8/1/2010	2/18/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	GTC60S1-(A-C)D (C,N) with GTA4860UD(-, A-G) and GTB1-(A, C)		Closed Loop Water-to-Air	3.7	18.1	8/1/2010	2/18/2011
Bard Manufacturing Company, Inc.	Bard	Geo-Trio	GTC60S1-(A-C)D (C,N) with GTA4860UD(-, A- G) and GTB1-(A, C)		Open Loop Water-to-Air	4.2	21.8	8/1/2010	2/18/2011
Bard Manufacturing Company, Inc.	Bard	GeoTec	GV27S1		Closed Loop Water-to-Air	4.5	22.0	2/1/2009	2/18/2011
Bard Manufacturing Company, Inc.	Bard	GeoTec	GV27S1		Open Loop Water-to-Air	5.2	26.5	2/1/2009	8/11/2011
Bard Manufacturing Company, Inc.	Bard	GeoTec	GV38S1		Closed Loop Water-to-Air	4.2	21.3	2/1/2009	2/18/2011
Bard Manufacturing Company, Inc.	Bard	GeoTec	GV38S1		Open Loop Water-to-Air	4.6	25.2	2/1/2009	2/18/2011
Bard Manufacturing Company, Inc.	Bard	GeoTec	GV51S1		Closed Loop Water-to-Air	3.8	19.9	2/1/2009	2/18/2011
Bard Manufacturing Company, Inc.	Bard	GeoTec	GV51S1		Open Loop Water-to-Air	4.4	23.8	2/1/2009	2/18/2011
ard Manufacturing Company, Inc.	Bard	GeoTec	GV61S1		Closed Loop Water-to-Air	3.8	19.4	2/1/2009	2/18/2011
ard Manufacturing Company, Inc.	Bard	GeoTec	GV61S1		Open Loop Water-to-Air	4.2	23.3	2/1/2009	2/18/2011
ard Manufacturing Company, Inc.	Bard	GeoTec	GV71S1		Closed Loop Water-to-Air	3.8	17.3	2/1/2009	2/18/2011
ard Manufacturing Company, Inc.	Bard	GeoTec	GV71S1		Open Loop Water-to-Air	4.2	21.1	2/1/2009	1/4/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD026*2		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD026*2		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD038		Closed Loop Water-to-Air	4.3	22.6	8/1/2004	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD038*3		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD038*3		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD049*2		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PX	50YDD049*2	momation	Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PX	50YDD064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD064*2		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD064*2		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD072*2		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDD072*2		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH026*2		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH026*2		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH038		Closed Loop Water-to-Air	4.3	22.6	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH038*3		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH038*3		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH049*2		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH049*2		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH064*2		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH064*2		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH072*2		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDH072*2		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS026 (with Bryant Model CNP**24)		Closed Loop Water-to-Air	3.9	20.4	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS026 (with Bryant Model CNP**24)		Open Loop Water-to-Air	4.5	24.9	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS026 (with Bryant Model FE4***003)		Closed Loop Water-to-Air	4.0	21.3	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PX	50YDS026 (with Bryant Model FE4***003)		Open Loop Water-to-Air	4.7	26.3	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PX	50YDS026 (with Bryant Model FV4***003)		Closed Loop Water-to-Air	4.0	21.3	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PX	50YDS026 (with Bryant Model FV4***003)		Open Loop Water-to-Air	4.7	26.3	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS038 (with Bryant Model CNP**36)		Closed Loop Water-to-Air	3.6	18.8	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS038 (with Bryant Model CNP**36)		Open Loop Water-to-Air	4.2	23.7	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS038 (with Bryant Model FE4***005)		Closed Loop Water-to-Air	4.0	20.2	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS038 (with Bryant Model FE4***005)		Open Loop Water-to-Air	4.6	24.3	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS038 (with Bryant Model FV4***005)		Closed Loop Water-to-Air	4.0	20.2	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS038 (with Bryant Model FV4***005)		Open Loop Water-to-Air	4.6	24.3	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS049 (with Bryant Model CNP**48)		Closed Loop Water-to-Air	4.0	20.5	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS049 (with Bryant Model CNP**48)		Open Loop Water-to-Air	4.5	24.4	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS049 (with Bryant Model FE4***006)		Closed Loop Water-to-Air	4.1	19.7	5/1/2010	2/8/2011

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS049 (with Bryant Model FE4***006)		Open Loop Water-to-Air	4.7	23.9	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS049 (with Bryant Model FV4***006)		Closed Loop Water-to-Air	4.1	19.7	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS049 (with Bryant Model FV4***006)		Open Loop Water-to-Air	4.7	23.9	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS064 (with Bryant Model CNP**60)		Closed Loop Water-to-Air	3.6	17.4	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS064 (with Bryant Model CNP**60)		Open Loop Water-to-Air	4.1	23.0	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS064 (with Bryant Model FE4***006)		Closed Loop Water-to-Air	3.8	18.8	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS064 (with Bryant Model FE4***006)		Open Loop Water-to-Air	4.4	22.5	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS064 (with Bryant Model FV4***006)		Closed Loop Water-to-Air	3.8	18.8	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDS064 (with Bryant Model FV4***006)		Open Loop Water-to-Air	4.4	22.5	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV026*2		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV026*2		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV038		Closed Loop Water-to-Air	4.3	22.6	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV038*3		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV038*3		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV049*2		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV049*2		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV064*2		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV064*2		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV072*2		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PX	50YDV072*2		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED0183		Closed Loop Water-to-Air	3.6	18.4	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED0183		Open Loop Water-to-Air	4.5	24.8	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED018 3K		Closed Loop Water-to-Air	3.9	19.4	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED018 3K		Open Loop Water-to-Air	4.9	26.3	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED024 3		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED024 3		Open Loop Water-to-Air	4.3	25.7	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED024 3K		Closed Loop Water-to-Air	3.8	20.0	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED024 3K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED030 3		Closed Loop Water-to-Air	3.8	17.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED030 3		Open Loop Water-to-Air	4.4	22.9	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED030 3K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED030 3K		Open Loop Water-to-Air	4.6	23.9	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED036 3		Closed Loop Water-to-Air	3.9	19.2	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED036 3		Open Loop Water-to-Air	4.8	25.1	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED036 3K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED036 3K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED042 3		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED042 3		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED042 3K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED042 3K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED048 3		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED048 3		Open Loop Water-to-Air	4.4	23.3	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED048 3K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED048 3K		Open Loop Water-to-Air	4.5	24.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED060 3		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED060 3		Open Loop Water-to-Air	4.5	23.2	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED060 3K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED060 3K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED070 3		Open Loop Water-to-Air	4.3	21.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED070 3K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YED070 3K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH0183		Closed Loop Water-to-Air	3.6	18.4	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH0183		Open Loop Water-to-Air	4.5	24.8	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH018 3K		Closed Loop Water-to-Air	3.9	19.4	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH018 3K		Open Loop Water-to-Air	4.9	26.3	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH024 3		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH024 3		Open Loop Water-to-Air	4.3	25.7	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH024 3K		Closed Loop Water-to-Air	3.8	20.0	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH024 3K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH030 3		Closed Loop Water-to-Air	3.8	17.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH030 3		Open Loop Water-to-Air	4.4	22.9	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEH030 3K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH030 3K		Open Loop Water-to-Air	4.6	23.9	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH036 3		Closed Loop Water-to-Air	3.9	19.2	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH036 3		Open Loop Water-to-Air	4.8	25.1	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH036 3K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH036 3K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH042 3		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH042 3		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH042 3K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH042 3K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH048 3		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH048 3		Open Loop Water-to-Air	4.4	23.3	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH048 3K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH048 3K		Open Loop Water-to-Air	4.5	24.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH060 3		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH060 3		Open Loop Water-to-Air	4.5	23.2	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH060 3K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH060 3K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH070 3		Open Loop Water-to-Air	4.3	21.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH070 3K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PG	50YEH070 3K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PW	50YER036 3 0		Closed Loop Water-to- Water	3.1	16.4	6/1/2009	9/22/2011
Bryant Heating and Cooling Systems (Carrier Corporation)	Bryant	GT-PW	50YER036 3 0		Open Loop Water-to- Water	4.0	23.1	6/1/2009	9/22/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PW	50YER060 3 1		Closed Loop Water-to- Water	3.1	16.2	3/15/2010	9/22/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PW	50YER060 3 1		Open Loop Water-to- Water	4.0	20.3	3/15/2010	9/22/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PW	50YER120 3 1		Closed Loop Water-to- Water	3.1	16.1	4/1/2010	9/22/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PW	50YER120 3 1		Open Loop Water-to- Water	3.9	20.1	4/1/2010	9/22/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV0183		Closed Loop Water-to-Air	3.6	18.4	12/1/2006	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV0183		Open Loop Water-to-Air	4.5	24.8	12/1/2006	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV018 3K		Closed Loop Water-to-Air	3.9	19.4	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV018 3K		Open Loop Water-to-Air	4.9	26.3	12/1/2006	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV024 3		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV024 3		Open Loop Water-to-Air	4.3	25.7	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV024 3K		Closed Loop Water-to-Air	3.8	20.0	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV024 3K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV030 3		Closed Loop Water-to-Air	3.8	17.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV030 3		Open Loop Water-to-Air	4.4	22.9	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV030 3K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV030 3K		Open Loop Water-to-Air	4.6	23.9	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV036 3		Closed Loop Water-to-Air	3.9	19.2	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV036 3		Open Loop Water-to-Air	4.8	25.1	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV036 3K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV036 3K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV042 3		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV042 3		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV042 3K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV042 3K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV048 3		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV048 3		Open Loop Water-to-Air	4.4	23.3	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV048 3K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV048 3K		Open Loop Water-to-Air	4.5	24.6	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV060 3		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV060 3		Open Loop Water-to-Air	4.5	23.2	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV060 3K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV060 3K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV070 3		Open Loop Water-to-Air	4.3	21.6	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV070 3K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PG	50YEV070 3K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	50YEW	50YEW010 3 1		Closed Loop Water-to- Water	3.2		10/1/2007	9/26/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	50YEW	50YEW010 3 1		Open Loop Water-to- Water	4.0		10/1/2007	9/26/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH024		Closed Loop Water-to-Air	3.6	17.5	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH024		Open Loop Water-to-Air	4.3	22.1	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH030		Closed Loop Water-to-Air	3.7	18.1	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH030		Open Loop Water-to-Air	4.2	22.6	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH036		Closed Loop Water-to-Air	3.7	17.5	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH036		Open Loop Water-to-Air	4.3	22.3	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH042		Closed Loop Water-to-Air	3.6	18.9	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH042		Open Loop Water-to-Air	4.1	23.7	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH048		Closed Loop Water-to-Air	3.8	18.2	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH048		Open Loop Water-to-Air	4.4	23.7	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH060		Closed Loop Water-to-Air	3.6	18.9	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFH060		Open Loop Water-to-Air	4.1	23.2	7/2/2012	9/4/2012

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV024		Closed Loop Water-to-Air	3.6	17.5	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV024		Open Loop Water-to-Air	4.3	22.1	7/2/2012	9/4/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV030		Closed Loop Water-to-Air	3.7	18.1	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV030		Open Loop Water-to-Air	4.2	22.6	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV036		Closed Loop Water-to-Air	3.7	17.5	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV036		Open Loop Water-to-Air	4.3	22.3	7/2/2012	9/4/2012
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV042		Closed Loop Water-to-Air	3.6	18.9	7/2/2012	9/4/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV042		Open Loop Water-to-Air	4.1	23.7	7/2/2012	9/4/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV048		Closed Loop Water-to-Air	3.8	18.2	7/2/2012	9/4/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV048		Open Loop Water-to-Air	4.4	23.7	7/2/2012	9/4/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV060		Closed Loop Water-to-Air	3.6	18.9	7/2/2012	9/4/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PB	50YFV060		Open Loop Water-to-Air	4.1	23.2	7/2/2012	9/4/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS026 (with Bryant Model CNP**24)		Closed Loop Water-to-Air	3.9	20.5	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS026 (with Bryant Model CNP**24)		Open Loop Water-to-Air	4.5	24.9	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS026 (with Bryant Model FE4***003)		Closed Loop Water-to-Air	4.0	21.3	5/1/2010	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS026 (with Bryant Model FE4***003)		Open Loop Water-to-Air	4.7	26.3	5/1/2010	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS026 (with Bryant Model FV4***003)		Closed Loop Water-to-Air	4.0	21.3	5/1/2010	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS026 (with Bryant Model FV4***003)		Open Loop Water-to-Air	4.7	26.3	5/1/2010	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS038 (with Bryant Model CNP**36)		Closed Loop Water-to-Air	3.6	18.8	5/1/2010	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS038 (with Bryant Model CNP**36)		Open Loop Water-to-Air	4.2	23.7	5/1/2010	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS038 (with Bryant Model FE4***005)		Closed Loop Water-to-Air	4.0	20.2	5/1/2010	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS038 (with Bryant Model FE4***005)		Open Loop Water-to-Air	4.6	24.3	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS038 (with Bryant Model FV4***005)		Closed Loop Water-to-Air	4.0	20.2	5/1/2010	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS038 (with Bryant Model FV4***005)		Open Loop Water-to-Air	4.6	24.3	5/1/2010	2/8/2011
ryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS049 (with Bryant Model CNP**48)		Closed Loop Water-to-Air	4.0	20.5	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS049 (with Bryant Model CNP**48)		Open Loop Water-to-Air	4.5	24.4	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS049 (with Bryant Model FE4***006)		Closed Loop Water-to-Air	4.1	19.7	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS049 (with Bryant Model FE4***006)		Open Loop Water-to-Air	4.7	23.9	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS049 (with Bryant Model FV4***006)		Closed Loop Water-to-Air	4.1	19.7	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS049 (with Bryant Model FV4***006)		Open Loop Water-to-Air	4.7	23.9	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS064 (with Bryant Model CNP**60)		Closed Loop Water-to-Air	3.6	17.4	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS064 (with Bryant Model CNP**60)		Open Loop Water-to-Air	4.1	23.0	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS064 (with Bryant Model FE4***006)		Closed Loop Water-to-Air	3.8	18.8	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS064 (with Bryant Model FE4***006)		Open Loop Water-to-Air	4.4	22.5	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS064 (with Bryant Model FV4***006)		Closed Loop Water-to-Air	3.8	18.8	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Bryant	GT-PE	50YPS064 (with Bryant Model FV4***006)		Open Loop Water-to-Air	4.4	22.5	5/1/2010	2/8/2011
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD026		Closed Loop Water-to-Air	4.2	23.8	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD026		Open Loop Water-to-Air	5.1	31.1	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD038		Closed Loop Water-to-Air	4.5	24.8	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD038		Open Loop Water-to-Air	5.2	30.6	10/15/2012	11/19/2012

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD049		Closed Loop Water-to-Air	4.1	23.4	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD049		Open Loop Water-to-Air	4.9	30.0	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD064		Closed Loop Water-to-Air	4.1	22.6	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD064		Open Loop Water-to-Air	4.8	28.2	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD072		Closed Loop Water-to-Air	3.7	19.9	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGD072		Open Loop Water-to-Air	4.4	25.4	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH026		Closed Loop Water-to-Air	4.2	23.8	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH026		Open Loop Water-to-Air	5.1	31.1	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH038		Closed Loop Water-to-Air	4.5	24.8	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH038		Open Loop Water-to-Air	5.2	30.6	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH049		Closed Loop Water-to-Air	4.1	23.4	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH049		Open Loop Water-to-Air	4.9	30.0	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH064		Closed Loop Water-to-Air	4.1	22.6	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH064		Open Loop Water-to-Air	4.8	28.2	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH072		Closed Loop Water-to-Air	3.7	19.9	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGH072		Open Loop Water-to-Air	4.4	25.4	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV026		Closed Loop Water-to-Air	4.2	23.8	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV026		Open Loop Water-to-Air	5.1	31.1	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV038		Closed Loop Water-to-Air	4.5	24.8	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV038		Open Loop Water-to-Air	5.2	30.6	10/15/2012	11/19/2012
Bryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV049		Closed Loop Water-to-Air	4.1	23.4	10/15/2012	11/19/2012
ryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV049		Open Loop Water-to-Air	4.9	30.0	10/15/2012	11/19/2012
ryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV064		Closed Loop Water-to-Air	4.1	22.6	10/15/2012	11/19/2012
ryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV064		Open Loop Water-to-Air	4.8	28.2	10/15/2012	11/19/2012
ryant Heating and Cooling Systems Carrier Corporation)	Carrier	GT-PC	50YGV072		Closed Loop Water-to-Air	3.7	19.9	10/15/2012	11/19/2012

				Additional				Data Assallable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Bryant Heating and Cooling Systems (Carrier Corporation)	Carrier	GT-PC	50YGV072		Open Loop Water-to-Air	4.4	25.4	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PX	50YDD026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD026*2		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD026*2		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD038		Closed Loop Water-to-Air	4.3	22.6	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD038*3		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD038*3		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD049*2		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD049*2		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD064*2		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD064*2		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDD072*2		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDD072*2		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH026*2		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH026*2		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013

ENERGY STAR Partner	Brand Name	Model Name	Model Number	Additional Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Carrier Corporation	Carrier	GT-PX	50YDH038	mormacion	Closed Loop Water-to-Air	4.3	22.6	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH038*3		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH038*3		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH049*2		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH049*2		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH064*2		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH064*2		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDH072*2		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDH072*2		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDS026 (with Carrier Model CNP**24)		Closed Loop Water-to-Air	3.9	20.4	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS026 (with Carrier Model CNP**24)		Open Loop Water-to-Air	4.5	24.9	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS026 (with Carrier Model FE4***003)		Closed Loop Water-to-Air	4.0	21.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS026 (with Carrier Model FE4***003)		Open Loop Water-to-Air	4.7	26.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS026 (with Carrier Model FV4***003)		Closed Loop Water-to-Air	4.0	21.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS026 (with Carrier Model FV4***003)		Open Loop Water-to-Air	4.7	26.3	5/1/2010	2/8/2011

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PX	50YDS038 (with Carrier Model CNP**36)		Closed Loop Water-to-Air	3.6	18.8	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS038 (with Carrier Model CNP**36)		Open Loop Water-to-Air	4.2	23.7	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS038 (with Carrier Model FE4***005)		Closed Loop Water-to-Air	4.0	20.2	5/1/2010	2/8/2011
·			50YDS038 (with Carrier Model		Open Loop				
Carrier Corporation	Carrier	GT-PX	FE4***005) 50YDS038 (with		Water-to-Air	4.6	24.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	Carrier Model FV4***005)		Closed Loop Water-to-Air	4.0	20.2	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS038 (with Carrier Model FV4***005)		Open Loop Water-to-Air	4.6	24.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS049 (with Carrier Model CNP**48)		Closed Loop Water-to-Air	4.0	20.1	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS049 (with Carrier Model CNP**48)		Open Loop Water-to-Air	4.5	24.4	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS049 (with Carrier Model FE4***006)		Closed Loop Water-to-Air	4.1	19.7	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS049 (with Carrier Model FE4***006)		Open Loop Water-to-Air	4.7	23.9	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS049 (with Carrier Model FV4***006)		Closed Loop Water-to-Air	4.1	19.7	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS049 (with Carrier Model FV4***006)		Open Loop Water-to-Air	4.7	23.9	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS064 (with Carrier Model CNP**60)		Closed Loop Water-to-Air	3.6	17.4	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS064 (with Carrier Model CNP**60)		Open Loop Water-to-Air	4.1	23.0	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS064 (with Carrier Model FE4***006)		Closed Loop Water-to-Air	3.8	18.8	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS064 (with Carrier Model FE4***006)		Open Loop Water-to-Air	4.4	22.5	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDS064 (with Carrier Model FV4***006)		Closed Loop Water-to-Air	3.8	18.8	5/1/2010	2/8/2011

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PX	50YDS064 (with Carrier Model FV4***006)		Open Loop Water-to-Air	4.4	22.5	5/1/2010	2/8/2011
arrier Corporation	Carrier	GT-PX	50YDV026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	2/8/2011
arrier Corporation	Carrier	GT-PX	50YDV026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	2/8/2011
arrier Corporation	Carrier	GT-PX	50YDV026*2		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
arrier Corporation	Carrier	GT-PX	50YDV026*2		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
arrier Corporation	Carrier	GT-PX	50YDV038		Closed Loop Water-to-Air	4.3	22.6	8/1/2004	2/8/2011
arrier Corporation	Carrier	GT-PX	50YDV038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDV038*3		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDV038*3		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDV049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	2/8/2011
arrier Corporation	Carrier	GT-PX	50YDV049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	2/8/2011
carrier Corporation	Carrier	GT-PX	50YDV049*2		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
carrier Corporation	Carrier	GT-PX	50YDV049*2		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDV064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDV064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDV064*2		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDV064*2		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Carrier Corporation	Carrier	GT-PX	50YDV072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	2/8/2011
Carrier Corporation	Carrier	GT-PX	50YDV072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	2/8/2011
arrier Corporation	Carrier	GT-PX	50YDV072*2		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
arrier Corporation	Carrier	GT-PX	50YDV072*2		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
arrier Corporation	Carrier	GT-PG	50YED0183		Closed Loop Water-to-Air	3.6	18.4	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED0183		Open Loop Water-to-Air	4.5	24.8	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED018 3K		Closed Loop Water-to-Air	3.9	19.4	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED018 3K		Open Loop Water-to-Air	4.9	26.3	12/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PG	50YED024 3		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED024 3		Open Loop Water-to-Air	4.3	25.7	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED024 3K		Closed Loop Water-to-Air	3.8	20.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED024 3K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED030 3		Closed Loop Water-to-Air	3.8	17.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED030 3		Open Loop Water-to-Air	4.4	22.9	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED030 3K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED030 3K		Open Loop Water-to-Air	4.6	23.9	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED036 3		Closed Loop Water-to-Air	3.9	19.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED036 3		Open Loop Water-to-Air	4.8	25.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED036 3K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED036 3K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED042 3		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED042 3		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED042 3K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED042 3K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED048 3		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED048 3		Open Loop Water-to-Air	4.4	23.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED048 3K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED048 3K		Open Loop Water-to-Air	4.5	24.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED060 3		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED060 3		Open Loop Water-to-Air	4.5	23.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED060 3K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED060 3K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED070 3		Open Loop Water-to-Air	4.3	21.6	2/1/2005	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PG	50YED070 3K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YED070 3K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH0183		Closed Loop Water-to-Air	3.6	18.4	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH0183		Open Loop Water-to-Air	4.5	24.8	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH018 3K		Closed Loop Water-to-Air	3.9	19.4	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH018 3K		Open Loop Water-to-Air	4.9	26.3	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH024 3		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH024 3		Open Loop Water-to-Air	4.3	25.7	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH024 3K		Closed Loop Water-to-Air	3.8	20.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH024 3K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH030 3		Closed Loop Water-to-Air	3.8	17.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH030 3		Open Loop Water-to-Air	4.4	22.9	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH030 3K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH030 3K		Open Loop Water-to-Air	4.6	23.9	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH036 3		Closed Loop Water-to-Air	3.9	19.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH036 3		Open Loop Water-to-Air	4.8	25.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH036 3K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH036 3K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH042 3		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH042 3		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH042 3K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH042 3K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH048 3		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH048 3		Open Loop Water-to-Air	4.4	23.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH048 3K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PG	50YEH048 3K		Open Loop Water-to-Air	4.5	24.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH060 3		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH060 3		Open Loop Water-to-Air	4.5	23.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH060 3K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH060 3K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH070 3		Open Loop Water-to-Air	4.3	21.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH070 3K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEH070 3K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PW	50YER036 3 0		Closed Loop Water-to- Water	3.1	16.4	6/1/2009	9/22/2011
Carrier Corporation	Carrier	GT-PW	50YER036 3 0		Open Loop Water-to- Water	4.0	23.1	6/1/2009	9/22/2011
Carrier Corporation	Carrier	GT-PW	50YER060 3 1		Closed Loop Water-to- Water	3.1	16.2	3/15/2010	9/22/2011
Carrier Corporation	Carrier	OTT W	301E1(000 0 1		Open Loop Water-to-	0.1	10.2	0/10/2010	SIZZIZO I I
Carrier Corporation	Carrier	GT-PW	50YER060 3 1		Water Closed Loop	4.0	20.3	3/15/2010	9/22/2011
Carrier Corporation	Carrier	GT-PW	50YER120 3 1		Water-to- Water	3.1	16.1	4/1/2010	9/22/2011
Carrier Corporation	Carrier	GT-PW	50YER120 3 1		Open Loop Water-to- Water	3.9	20.1	4/1/2010	9/22/2011
Carrier Corporation	Carrier	GT-PG	50YEV0183		Closed Loop Water-to-Air	3.6	18.4	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV0183		Open Loop Water-to-Air	4.5	24.8	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV018 3K		Closed Loop Water-to-Air	3.9	19.4	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV018 3K		Open Loop Water-to-Air	4.9	26.3	12/1/2006	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV024 3		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV024 3		Open Loop Water-to-Air	4.3	25.7	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV024 3K		Closed Loop Water-to-Air	3.8	20.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV024 3K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV030 3		Closed Loop Water-to-Air	3.8	17.6	2/1/2005	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PG	50YEV030 3		Open Loop Water-to-Air	4.4	22.9	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV030 3K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV030 3K		Open Loop Water-to-Air	4.6	23.9	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV036 3		Closed Loop Water-to-Air	3.9	19.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV036 3		Open Loop Water-to-Air	4.8	25.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV036 3K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV036 3K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV042 3		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV042 3		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV042 3K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV042 3K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV048 3		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV048 3		Open Loop Water-to-Air	4.4	23.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV048 3K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV048 3K		Open Loop Water-to-Air	4.5	24.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV060 3		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV060 3		Open Loop Water-to-Air	4.5	23.2	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV060 3K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV060 3K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV070 3		Open Loop Water-to-Air	4.3	21.6	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV070 3K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	2/8/2011
Carrier Corporation	Carrier	GT-PG	50YEV070 3K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	2/8/2011
·					Closed Loop Water-to-				
Carrier Corporation	Carrier	50YEW	50YEW010 3 1		Water	3.2		10/1/2007	9/26/2011
Carrier Corporation	Carrier	50YEW	50YEW010 3 1		Open Loop Water-to- Water	4.0		10/1/2007	9/26/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PB	50YFH024		Closed Loop Water-to-Air	3.6	17.5	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH024		Open Loop Water-to-Air	4.3	22.1	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH030		Closed Loop Water-to-Air	3.7	18.1	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH030		Open Loop Water-to-Air	4.2	22.6	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH036		Closed Loop Water-to-Air	3.7	17.5	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH036		Open Loop Water-to-Air	4.3	22.3	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH042		Closed Loop Water-to-Air	3.6	18.9	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH042		Open Loop Water-to-Air	4.1	23.7	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH048		Closed Loop Water-to-Air	3.8	18.2	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH048		Open Loop Water-to-Air	4.4	23.7	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH060		Closed Loop Water-to-Air	3.6	18.9	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFH060		Open Loop Water-to-Air	4.1	23.2	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV024		Closed Loop Water-to-Air	3.6	17.5	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV024		Open Loop Water-to-Air	4.3	22.1	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV030		Closed Loop Water-to-Air	3.7	18.1	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV030		Open Loop Water-to-Air	4.2	22.6	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV036		Closed Loop Water-to-Air	3.7	17.5	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV036		Open Loop Water-to-Air	4.3	22.3	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV042		Closed Loop Water-to-Air	3.6	18.9	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV042		Open Loop Water-to-Air	4.1	23.7	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV048		Closed Loop Water-to-Air	3.8	18.2	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV048		Open Loop Water-to-Air	4.4	23.7	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV060		Closed Loop Water-to-Air	3.6	18.9	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PB	50YFV060		Open Loop Water-to-Air	4.1	23.2	7/2/2012	9/4/2012
Carrier Corporation	Carrier	GT-PC	50YGD026		Closed Loop Water-to-Air	4.2	23.8	10/15/2012	11/19/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PC	50YGD026		Open Loop Water-to-Air	5.1	31.1	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGD038		Closed Loop Water-to-Air	4.5	24.8	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGD038		Open Loop Water-to-Air	5.2	30.6	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGD049		Closed Loop Water-to-Air	4.1	23.4	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGD049		Open Loop Water-to-Air	4.9	30.0	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGD064		Closed Loop Water-to-Air	4.1	22.6	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGD064		Open Loop Water-to-Air	4.8	28.2	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGD072		Closed Loop Water-to-Air	3.7	19.9	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGD072		Open Loop Water-to-Air	4.4	25.4	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH026		Closed Loop Water-to-Air	4.2	23.8	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH026		Open Loop Water-to-Air	5.1	31.1	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH038		Closed Loop Water-to-Air	4.5	24.8	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH038		Open Loop Water-to-Air	5.2	30.6	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH049		Closed Loop Water-to-Air	4.1	23.4	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH049		Open Loop Water-to-Air	4.9	30.0	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH064		Closed Loop Water-to-Air	4.1	22.6	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH064		Open Loop Water-to-Air	4.8	28.2	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH072		Closed Loop Water-to-Air	3.7	19.9	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGH072		Open Loop Water-to-Air	4.4	25.4	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV026		Closed Loop Water-to-Air	4.2	23.8	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV026		Open Loop Water-to-Air	5.1	31.1	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV038		Closed Loop Water-to-Air	4.5	24.8	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV038		Open Loop Water-to-Air	5.2	30.6	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV049		Closed Loop Water-to-Air	4.1	23.4	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV049		Open Loop Water-to-Air	4.9	30.0	10/15/2012	11/19/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Carrier Corporation	Carrier	GT-PC	50YGV064		Closed Loop Water-to-Air	4.1	22.6	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV064		Open Loop Water-to-Air	4.8	28.2	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV072		Closed Loop Water-to-Air	3.7	19.9	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PC	50YGV072		Open Loop Water-to-Air	4.4	25.4	10/15/2012	11/19/2012
Carrier Corporation	Carrier	GT-PE	50YPS026 (with Carrier Model CNP**24)		Closed Loop Water-to-Air	3.9	20.4	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS026 (with Carrier Model CNP**24)		Open Loop Water-to-Air	4.5	24.9	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS026 (with Carrier Model FE4***003)		Closed Loop Water-to-Air	4.0	21.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS026 (with Carrier Model FE4***003)		Open Loop Water-to-Air	4.7	26.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS026 (with Carrier Model FV4***003)		Closed Loop Water-to-Air	4.0	21.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS026 (with Carrier Model FV4***003)		Open Loop Water-to-Air	4.7	26.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS038 (with Carrier Model CNP**36)		Closed Loop Water-to-Air	3.6	18.8	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS038 (with Carrier Model CNP**36)		Open Loop Water-to-Air	4.2	23.7	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS038 (with Carrier Model FE4***005)		Closed Loop Water-to-Air	4.0	20.2	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS038 (with Carrier Model FE4***005)		Open Loop Water-to-Air	4.6	24.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS038 (with Carrier Model FV4***005)		Closed Loop Water-to-Air	4.0	20.2	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS038 (with Carrier Model FV4***005)		Open Loop Water-to-Air	4.6	24.3	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS049 (with Carrier Model CNP**48)		Closed Loop Water-to-Air	4.0	20.1	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS049 (with Carrier Model CNP**48)		Open Loop Water-to-Air	4.5	24.4	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS049 (with Carrier Model FE4***006)		Closed Loop Water-to-Air	4.1	19.7	5/1/2010	2/8/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Carrier Corporation	Carrier	GT-PE	50YPS049 (with Carrier Model FE4***006)		Open Loop Water-to-Air	4.7	23.9	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS049 (with Carrier Model FV4***006)		Closed Loop Water-to-Air	4.1	19.7	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS049 (with Carrier Model FV4***006)		Open Loop Water-to-Air	4.7	23.9	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS064 (with Carrier Model CNP**60)		Closed Loop Water-to-Air	3.6	17.4	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS064 (with Carrier Model CNP**60)		Open Loop Water-to-Air	4.1	23.0	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS064 (with Carrier Model FE4***006)		Closed Loop Water-to-Air	3.8	18.8	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS064 (with Carrier Model FE4***006)		Open Loop Water-to-Air	4.4	22.5	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS064 (with Carrier Model FV4***006)		Closed Loop Water-to-Air	3.8	18.8	5/1/2010	2/8/2011
Carrier Corporation	Carrier	GT-PE	50YPS064 (with Carrier Model FV4***006)		Open Loop Water-to-Air	4.4	22.5	5/1/2010	2/8/2011
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED026		Closed Loop Water-to-Air	4.3	24.0	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED026		Open Loop Water-to-Air	5.2	31.3	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED038		Closed Loop Water-to-Air	4.6	25.0	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	-	TED038		Open Loop Water-to-Air	5.3	30.8	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED049		Closed Loop Water-to-Air	4.2	23.6	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED049		Open Loop Water-to-Air	5.0	30.2	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED064		Closed Loop Water-to-Air	4.2	22.8	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED064		Open Loop Water-to-Air	4.9	28.4	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED072		Closed Loop Water-to-Air	3.8	20.1	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TED072		Open Loop Water-to-Air	4.5	25.6	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH026		Closed Loop Water-to-Air	4.3	24.0	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH026		Open Loop Water-to-Air	5.2	31.3	3/5/2012	2/24/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH038		Closed Loop Water-to-Air	4.6	25.0	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH038		Open Loop Water-to-Air	5.3	30.8	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH049		Closed Loop Water-to-Air	4.2	23.6	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH049		Open Loop Water-to-Air	5.0	30.2	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH064		Closed Loop Water-to-Air	4.2	22.8	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH064		Open Loop Water-to-Air	4.9	28.4	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH072		Closed Loop Water-to-Air	3.8	20.1	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEH072		Open Loop Water-to-Air	4.5	25.6	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP026A		Closed Loop Water-to-Air	4.2	22.1	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP026A		Closed Loop Water-to-Air	4.3	22.7	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP026A		Open Loop Water-to-Air	5.1	28.1	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP026A		Open Loop Water-to-Air	5.2	29.2	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP038A		Closed Loop Water-to-Air	4.1	21.9	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP038A		Closed Loop Water-to-Air	4.3	22.4	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP038A		Open Loop Water-to-Air	4.7	27.6	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP038A		Open Loop Water-to-Air	4.9	28.8	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP049A		Closed Loop Water-to-Air	4.1	20.5	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP049A		Closed Loop Water-to-Air	4.1	20.8	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP049A		Open Loop Water-to-Air	4.8	25.9	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP049A		Open Loop Water-to-Air	4.9	26.7	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP064A		Closed Loop Water-to-Air	3.8	19.5	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP064A		Closed Loop Water-to-Air	3.9	19.8	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP064A		Open Loop Water-to-Air	4.4	24.4	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TEP064A		Open Loop Water-to-Air	4.5	24.7	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES026A		Closed Loop Water-to-Air	4.2	22.1	12/3/2012	1/25/2013

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES026A		Closed Loop Water-to-Air	4.3	22.7	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES026A		Open Loop Water-to-Air	5.1	28.1	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES026A		Open Loop Water-to-Air	5.2	29.2	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES038A		Closed Loop Water-to-Air	4.1	21.9	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES038A		Closed Loop Water-to-Air	4.3	22.4	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES038A		Open Loop Water-to-Air	4.7	27.6	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES038A		Open Loop Water-to-Air	4.9	28.8	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES049A		Closed Loop Water-to-Air	4.1	20.5	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES049A		Closed Loop Water-to-Air	4.1	20.8	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES049A		Open Loop Water-to-Air	4.8	25.9	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES049A		Open Loop Water-to-Air	4.9	26.7	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES064A		Closed Loop Water-to-Air	3.8	19.5	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES064A		Closed Loop Water-to-Air	3.9	19.8	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES064A		Open Loop Water-to-Air	4.4	24.4	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split Digital	TES064A		Open Loop Water-to-Air	4.5	24.7	12/3/2012	1/25/2013
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV026		Closed Loop Water-to-Air	4.3	24.0	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV026		Open Loop Water-to-Air	5.2	31.3	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV038		Closed Loop Water-to-Air	4.6	25.0	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV038		Open Loop Water-to-Air	5.3	30.8	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV049		Closed Loop Water-to-Air	4.2	23.6	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV049		Open Loop Water-to-Air	5.0	30.2	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV064		Closed Loop Water-to-Air	4.2	22.8	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV064		Open Loop Water-to-Air	4.9	28.4	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV072		Closed Loop Water-to-Air	3.8	20.1	3/5/2012	2/24/2012
ClimateMaster Inc.	Climatemaster	Tranquility 30 Digital	TEV072		Open Loop Water-to-Air	4.5	25.6	3/5/2012	2/24/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
					Closed Loop				
ClimateMaster Inc.	Climatemaster	THW010	THW010		Water-to- Water	3.2		10/1/2007	4/1/2011
					Open Loop Water-to-				
ClimateMaster Inc.	Climatemaster	THW010	THW010		Water	4.0		10/1/2007	4/1/2011
					Closed Loop Water-to-				
ClimateMaster Inc.	Climatemaster	TMW036AG	TMW036AG		Water	3.1	16.4	6/1/2009	4/1/2011
					Open Loop Water-to-				
ClimateMaster Inc.	Climatemaster	TMW036AG	TMW036AG		Water	4.0	23.1	6/1/2009	4/1/2011
					Closed Loop Water-to-				
ClimateMaster Inc.	Climatemaster	TMW060BG	TMW060BG		Water	3.1	16.2	3/15/2010	4/1/2011
					Open Loop Water-to-				
ClimateMaster Inc.	Climatemaster	TMW060BG	TMW060BG		Water Closed Loop	4.0	20.3	3/15/2010	4/1/2011
					Water-to-				
ClimateMaster Inc.	Climatemaster	TMW120BG	TMW120BG		Water Open Loop	3.1	16.1	4/1/2010	3/28/2012
Of and Market Land		T1414400D0	TA 414/400D O		Water-to-	0.0	00.4	4/4/0040	0/00/0040
ClimateMaster Inc.	Climatemaster	TMW120BG	TMW120BG		Water Closed Loop	3.9	20.1	4/1/2010	3/28/2012
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD018		Water-to-Air	3.6	18.4	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD018		Open Loop Water-to-Air	4.5	24.8	12/1/2006	1/21/2011
	011 /		T0D04014		Closed Loop		40.4	40/4/0000	1/0.1/0.11
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD018K		Water-to-Air Open Loop	3.9	19.4	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD018K		Water-to-Air	4.9	26.3	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD024		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	1/21/2011
		. ,			Open Loop				
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD024		Water-to-Air Closed Loop	4.3	25.7	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD024K		Water-to-Air	3.8	20.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD024K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	1/21/2011
					Closed Loop				
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD030		Water-to-Air Open Loop	3.8	17.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD030		Water-to-Air	4.4	22.9	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD030K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	1/21/2011
					Open Loop				
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD030K		Water-to-Air Closed Loop	4.6	23.9	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD036		Water-to-Air	3.9	19.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD036		Open Loop Water-to-Air	4.8	25.1	2/1/2005	1/21/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD036K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD036K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD042		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD042		Open Loop Water-to-Air	4.6	24.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD042K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD042K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD048		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD048		Open Loop Water-to-Air	4.4	23.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD048K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD048K		Open Loop Water-to-Air	4.5	24.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD060		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD060		Open Loop Water-to-Air	4.5	23.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD060K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD060K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD070		Open Loop Water-to-Air	4.3	21.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD070K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSD070K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH006		Open Loop Water-to-Air	4.4	25.5	4/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH009		Open Loop Water-to-Air	4.3	25.2	8/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH018		Closed Loop Water-to-Air	3.6	18.4	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH018		Open Loop Water-to-Air	4.5	24.8	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH018K		Closed Loop Water-to-Air	3.9	19.4	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH018K		Open Loop Water-to-Air	4.9	26.3	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH024		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH024		Open Loop Water-to-Air	4.3	25.7	2/1/2005	1/21/2011

				Additional				Doto Aveilable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH024K		Closed Loop Water-to-Air	3.8	20.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH024K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH030		Closed Loop Water-to-Air	3.8	17.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH030		Open Loop Water-to-Air	4.4	22.9	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH030K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH030K		Open Loop Water-to-Air	4.6	23.9	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH036		Closed Loop Water-to-Air	3.9	19.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH036		Open Loop Water-to-Air	4.8	25.1	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH036K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH036K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH042		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH042		Open Loop Water-to-Air	4.6	24.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH042K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH042K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH048		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH048		Open Loop Water-to-Air	4.4	23.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH048K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH048K		Open Loop Water-to-Air	4.5	24.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH060		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH060		Open Loop Water-to-Air	4.5	23.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH060K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH060K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH070		Open Loop Water-to-Air	4.3	21.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH070K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSH070K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	1/21/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV006		Open Loop Water-to-Air	4.4	25.5	4/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV009		Open Loop Water-to-Air	4.3	25.2	8/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV018		Closed Loop Water-to-Air	3.6	18.4	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV018		Open Loop Water-to-Air	4.5	24.8	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV018K		Closed Loop Water-to-Air	3.9	19.4	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV018K		Open Loop Water-to-Air	4.9	26.3	12/1/2006	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV024		Closed Loop Water-to-Air	3.7	19.1	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV024		Open Loop Water-to-Air	4.3	25.7	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV024K		Closed Loop Water-to-Air	3.8	20.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV024K		Open Loop Water-to-Air	4.6	27.4	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV030		Closed Loop Water-to-Air	3.8	17.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV030		Open Loop Water-to-Air	4.4	22.9	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV030K		Closed Loop Water-to-Air	3.9	18.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV030K		Open Loop Water-to-Air	4.6	23.9	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV036		Closed Loop Water-to-Air	3.9	19.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV036		Open Loop Water-to-Air	4.8	25.1	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV036K		Closed Loop Water-to-Air	4.2	20.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV036K		Open Loop Water-to-Air	5.1	26.5	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV042		Closed Loop Water-to-Air	3.8	18.4	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV042		Open Loop Water-to-Air	4.6	24.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV042K		Closed Loop Water-to-Air	4.0	20.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV042K		Open Loop Water-to-Air	4.9	27.1	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV048		Closed Loop Water-to-Air	3.7	17.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV048		Open Loop Water-to-Air	4.4	23.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV048K		Closed Loop Water-to-Air	3.8	18.5	2/1/2005	1/21/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV048K			4.5	24.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV060		Closed Loop Water-to-Air	3.7	18.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV060		Open Loop Water-to-Air	4.5	23.2	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV060K		Closed Loop Water-to-Air	3.8	19.0	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV060K		Open Loop Water-to-Air	4.6	24.3	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV070		Open Loop Water-to-Air	4.3	21.6	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV070K		Closed Loop Water-to-Air	3.6	17.8	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 20	TSV070K		Open Loop Water-to-Air	4.4	23.5	2/1/2005	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD038		Closed Loop Water-to-Air	4.3	22.6	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTD072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH038		Closed Loop Water-to-Air	4.3	22.6	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	1/21/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTH072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP026 (with_ClimateMas ter_model_numbe r_TAC026)		Closed Loop Water-to-Air	4.4	21.1	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP026 (with_ClimateMas ter_model_numbe r_TAC026)		Open Loop Water-to-Air	5.0	25.9	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP026 (with_ClimateMas ter_model_numbe r_TAH026)		Closed Loop Water-to-Air	4.4	22.0	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP026 (with_ClimateMas ter_model_numbe r_TAH026)		Open Loop Water-to-Air	5.1	27.6	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP038 (with_ClimateMas ter_model_numbe r_TAC038)		Closed Loop Water-to-Air	4.4	21.7	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP038 (with_ClimateMas ter_model_numbe r_TAC038)		Open Loop Water-to-Air	5.0	26.4	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP038 (with_ClimateMas ter_model_numbe r_TAH038)		Closed Loop Water-to-Air	4.3	20.9	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP038 (with_ClimateMas ter_model_numbe r_TAH038)		Open Loop Water-to-Air	5.0	26.1	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP049 (with_ClimateMas ter_model_numbe r_TAC049)		Closed Loop Water-to-Air	4.3	20.4	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP049 (with_ClimateMas ter_model_numbe r_TAC049)		Open Loop Water-to-Air	4.9	25.4	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP049 (with_ClimateMas ter_model_numbe r_TAH049)		Closed Loop Water-to-Air	4.4	19.4	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP049 (with_ClimateMas ter_model_numbe r_TAH049)		Open Loop Water-to-Air	5.1	24.1	5/1/2010	1/21/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP064 (with_ClimateMas ter_model_numbe r_TAC064)		Closed Loop Water-to-Air	3.8	19.1	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP064 (with_ClimateMas ter_model_numbe r_TAC064)		Open Loop Water-to-Air	4.3	22.8	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP064 (with_ClimateMas ter_model_numbe r_TAH064)		Closed Loop Water-to-Air	3.7	19.2	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTP064 (with_ClimateMas ter_model_numbe r_TAH064)		Open Loop Water-to-Air	4.3	23.7	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS026 (with_ClimateMas ter_model_numbe r_TAC026)		Closed Loop Water-to-Air	4.4	21.1	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS026 (with_ClimateMas ter_model_numbe r_TAC026)		Open Loop Water-to-Air	5.0	25.9	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS026 (with_ClimateMas ter_model_numbe r_TAH026)		Closed Loop Water-to-Air	4.4	22.0	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS026 (with_ClimateMas ter_model_numbe r_TAH026)		Open Loop Water-to-Air	5.1	27.6	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS038 (with_ClimateMas ter_model_numbe r_TAC038)		Closed Loop Water-to-Air	4.4	21.7	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS038 (with_ClimateMas ter_model_numbe r_TAC038)		Open Loop Water-to-Air	5.0	26.4	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS038 (with_ClimateMas ter_model_numbe r_TAH038)		Closed Loop Water-to-Air	4.3	20.9	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS038 (with_ClimateMas ter_model_numbe r_TAH038)		Open Loop Water-to-Air	5.0	26.1	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS049 (with_ClimateMas ter_model_numbe r_TAC049)		Closed Loop	4.3	20.4	5/1/2010	1/21/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS049 (with_ClimateMas ter_model_numbe r_TAC049)	mormanon	Open Loop Water-to-Air	4.9	25.4	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS049 (with_ClimateMas ter_model_numbe r_TAH049)		Closed Loop Water-to-Air	4.4	19.4	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS049 (with_ClimateMas ter_model_numbe r_TAH049)		Open Loop Water-to-Air	5.1	24.1	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS064 (with_ClimateMas ter_model_numbe r_TAC064)		Closed Loop Water-to-Air	3.8	19.1	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS064 (with_ClimateMas ter_model_numbe r_TAC064) TTS064		Open Loop Water-to-Air	4.3	22.8	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	(with_ClimateMas ter_model_numbe r_TAH064)		Closed Loop Water-to-Air	3.7	19.2	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27 Split	TTS064 (with_ClimateMas ter_model_numbe r_TAH064)		Open Loop Water-to-Air	4.3	23.7	5/1/2010	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV026		Closed Loop Water-to-Air	4.3	22.3	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV026		Open Loop Water-to-Air	5.0	27.7	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV038		Closed Loop Water-to-Air	4.3	22.6	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV038		Open Loop Water-to-Air	4.9	27.3	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV049		Closed Loop Water-to-Air	4.3	21.4	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV049		Open Loop Water-to-Air	4.9	25.6	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV064		Closed Loop Water-to-Air	4.1	21.4	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV064		Open Loop Water-to-Air	4.6	25.9	8/1/2004	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV072		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 27	TTV072		Open Loop Water-to-Air	4.3	22.2	1/1/2007	1/21/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH024		Closed Loop Water-to-Air	3.7	17.4	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH024		Open Loop Water-to-Air	4.4	22.3	6/20/2011	6/27/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH030		Closed Loop Water-to-Air	3.8	18.3	12/19/2011	12/23/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH030		Open Loop Water-to-Air	4.3	22.8	12/19/2011	12/23/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH036		Closed Loop Water-to-Air	3.8	17.7	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH036		Open Loop Water-to-Air	4.4	22.5	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH042		Closed Loop Water-to-Air	3.6	19.1	12/19/2011	12/23/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH042		Open Loop Water-to-Air	4.2	23.9	12/19/2011	12/23/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH048		Closed Loop Water-to-Air	3.9	18.4	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH048		Open Loop Water-to-Air	4.5	23.9	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH060		Closed Loop Water-to-Air	3.7	19.1	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZH060		Open Loop Water-to-Air	4.2	23.4	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZV024		Closed Loop Water-to-Air	3.7	17.4	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZV024		Open Loop Water-to-Air	4.4	22.3	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZV036		Closed Loop Water-to-Air	3.8	17.7	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZV036		Open Loop Water-to-Air	4.4	22.5	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZV048		Closed Loop Water-to-Air	3.9	18.4	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZV048		Open Loop Water-to-Air	4.5	23.9	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZV060		Closed Loop Water-to-Air	3.7	19.1	6/20/2011	6/27/2011
ClimateMaster Inc.	Climatemaster	Tranquility 22 Digital	TZV060		Open Loop Water-to-Air	4.2	23.4	6/20/2011	6/27/2011
COLDFLO	Dual Air	CFX024	CFX024		Closed Loop Water-to-Air	3.6	19.7	8/1/2010	5/12/2011
COLDFLO	Dual Air	CFX024	CFX024		Open Loop Water-to-Air	4.2	27.6	8/1/2010	5/12/2011
COLDFLO	Dual Air	CFX031	CFX031		Open Loop Water-to-Air	4.1	26.0	8/1/2010	5/12/2011
COLDFLO	Dual Air	CFX036	CFX036		Closed Loop Water-to-Air	3.6	17.9	8/1/2010	5/12/2011
COLDFLO	Dual Air	CFX036	CFX036		Open Loop Water-to-Air	4.2	23.5	8/1/2010	5/12/2011
COLDFLO	Dual Air	CFX041	CFX041		Open Loop Water-to-Air	4.1	21.4	8/1/2010	5/12/2011
COLDFLO	Dual Air	CFX048	CFX048		Closed Loop Water-to-Air	3.6	20.0	8/1/2010	5/12/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
COLDFLO	Dual Air	CFX048	CFX048		Open Loop Water-to-Air	4.3	27.0	8/1/2010	5/12/2011
COLDFLO	Dual Air	CFX060	CFX060		Open Loop Water-to-Air	4.1	22.0	8/1/2010	5/12/2011
Eagle Mountain	Geomax	Everest	GS22		Closed Loop Water-to-Air	4.0	22.0	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS22		Closed Loop Water-to-Air	4.0	22.0	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS22		Open Loop Water-to-Air	5.4	32.2	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS22		Open Loop Water-to-Air	5.4	32.2	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS30		Closed Loop Water-to-Air	3.9	21.2	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS30		Closed Loop Water-to-Air	3.9	21.2	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS30		Open Loop Water-to-Air	5.1	30.0	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS30		Open Loop Water-to-Air	5.1	30.0	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS36		Closed Loop Water-to-Air	4.2	21.8	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS36		Closed Loop Water-to-Air	4.2	21.8	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS36		Open Loop Water-to-Air	5.2	29.8	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS36		Open Loop Water-to-Air	5.2	29.8	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS42		Closed Loop Water-to-Air	4.1	22.2	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS42		Closed Loop Water-to-Air	4.1	22.2	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS42		Open Loop Water-to-Air	5.1	29.5	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS42		Open Loop Water-to-Air	5.1	29.5	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS48		Closed Loop Water-to-Air	4.0	19.5	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS48		Closed Loop Water-to-Air	4.0	19.5	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS48		Open Loop Water-to-Air	4.9	27.0	6/1/2006	2/8/2011
Eagle Mountain		Everest	GS48		Open Loop Water-to-Air	4.9	27.0	6/1/2006	2/18/2011
	Geomax				Closed Loop				
Eagle Mountain	Geomax	Everest	GS60		Water-to-Air Closed Loop	3.8	19.2	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS60		Water-to-Air Open Loop	3.8	19.2	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS60		Water-to-Air	4.6	25.5	6/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Eagle Mountain	Geomax	Everest	GS60		Open Loop Water-to-Air	4.6	25.5	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS70		Closed Loop Water-to-Air	3.7	17.9	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS70		Closed Loop Water-to-Air	3.7	17.9	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GS70		Open Loop Water-to-Air	4.5	24.3	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GS70		Open Loop Water-to-Air	4.5	24.3	6/1/2006	2/18/2011
Eagle Mountain	Geomax	GeoMax Cascade Series	GSW018		Open Loop Water-to- Water	3.7	22.9	2/1/2010	5/20/2011
Eagle Mountain	Geomax	GeoMax Cascade Series	GSW025		Open Loop Water-to- Water	3.8	21.2	2/1/2010	5/20/2011
Eagle Mountain	Geomax	GeoMax Cascade Series	GSW040		Closed Loop Water-to- Water	3.1	17.5	2/1/2010	5/20/2011
Eagle Mountain	Geomax	GeoMax Cascade Series	GSW040		Open Loop Water-to- Water	3.9	23.4	2/1/2010	5/20/2011
Eagle Mountain	Geomax	GeoMax Cascade Series	GSW050		Closed Loop Water-to- Water	3.1	16.4	2/1/2010	5/20/2011
Eagle Mountain	Geomax	GeoMax Cascade Series	GSW050		Open Loop Water-to- Water	3.7	21.6	2/1/2010	5/20/2011
Eagle Mountain	Geomax	GeoMax Cascade Series	GSW060		Open Loop Water-to- Water	3.8	20.6	2/1/2010	5/20/2011
Eagle Mountain	Geomax	Everest	GT26		Closed Loop Water-to-Air	4.1	19.0	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GT26		Closed Loop Water-to-Air	4.1	19.0	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GT26		Open Loop Water-to-Air	5.1	25.8	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GT26		Open Loop Water-to-Air	5.1	25.8	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GT38		Closed Loop Water-to-Air	4.2	19.8	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GT38		Closed Loop Water-to-Air	4.2	19.8	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GT38		Open Loop Water-to-Air	4.9	24.1	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GT38		Open Loop Water-to-Air	4.9	24.1	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GT49		Closed Loop Water-to-Air	3.9	17.5	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GT49		Closed Loop Water-to-Air	3.9	17.5	6/1/2006	2/18/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Eagle Mountain	Geomax	Everest	GT49		Open Loop Water-to-Air	4.7	22.7	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GT49		Open Loop Water-to-Air	4.7	22.7	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GT64		Closed Loop Water-to-Air	3.9	17.5	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GT64		Closed Loop Water-to-Air	3.9	17.5	6/1/2006	2/18/2011
agle Mountain	Geomax	Everest	GT64		Open Loop Water-to-Air	4.4	22.2	6/1/2006	2/8/2011
agle Mountain	Geomax	Everest	GT64		Open Loop Water-to-Air	4.4	22.2	6/1/2006	2/18/2011
Eagle Mountain	Geomax	Everest	GT72		Open Loop Water-to-Air	4.5	21.6	6/1/2006	2/8/2011
Eagle Mountain	Geomax	Everest	GT72		Open Loop Water-to-Air	4.5	21.6	6/1/2006	2/18/2011
Eagle Mountain	Geomax	GeoMax Cascade Series	GTW100		Closed Loop Water-to- Water	3.2	19.4	9/1/2009	5/20/2011
		GeoMax	O.T.N.400		Open Loop Water-to-			0/4/0000	E (00 (00 4 4
Eagle Mountain	Geomax	GeoMax Cascade Series	GTW100 GTW120		Water Closed Loop Water-to- Water	3.5	19.0	9/1/2009	5/20/2011
agle Mountain	Geomax	GeoMax Cascade Series	GTW120		Open Loop Water-to- Water	3.5	22.3	9/1/2009	5/20/2011
agle Mountain	Geomax	Rainier	QT38		Closed Loop Water-to-Air	4.2	20.8	9/1/2008	2/24/2011
agle Mountain	Geomax	Rainier	QT38		Open Loop Water-to-Air	4.7	23.3	9/1/2008	2/24/2011
agle Mountain	Geomax	Rainier	QT49		Closed Loop Water-to-Air	3.9	18.8	9/1/2008	2/24/2011
agle Mountain	Geomax	Rainier	QT49		Open Loop Water-to-Air	4.5	23.3	9/1/2008	2/24/2011
agle Mountain	Geomax	Rainier	QT64		Closed Loop Water-to-Air	3.6	17.8	9/1/2008	2/24/2011
agle Mountain	Geomax	Rainier	QT64		Open Loop Water-to-Air	4.1	21.8	9/1/2008	2/24/2011
agle Mountain	Geomax	Rainier	QT72		Closed Loop Water-to-Air	3.7	17.3	9/1/2008	2/24/2011
agle Mountain	Geomax	Rainier	QT72		Open Loop Water-to-Air	4.1	21.1	9/1/2008	1/4/2012
agle Mountain	Geomax	Sierra	YS024***4		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/24/2011
agle Mountain	Geomax	Sierra	YS024***4		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/24/2011
agle Mountain	Geomax	Sierra	YS030***4		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/24/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Eagle Mountain	Geomax	Sierra	YS030****4		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Sierra	YS036****4		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
Eagle Mountain	Geomax	Sierra	YS036****4		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Sierra	YS042****4		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Sierra	YS042***4		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Sierra	YS048***4		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Sierra	YS048***4		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Sierra	YS060****4		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Sierra	YS060****4		Open Loop Water-to-Air	4.1	23.0	12/1/2009	1/4/2012
Eagle Mountain	Geomax	Sierra	YS070***4		Closed Loop Water-to-Air	3.6	17.1	12/1/2009	1/4/2012
Eagle Mountain	Geomax	Sierra	YS070****4		Open Loop Water-to-Air	4.1	21.1	12/1/2009	1/4/2012
Eagle Mountain	Geomax	Denali	ZS015****0		Open Loop Water-to-Air	4.1	24.0	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS015****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS015****1		Open Loop Water-to-Air	4.4	24.3	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS018****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS018****1		Open Loop Water-to-Air	4.4	24.0	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS023****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS024***1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS024***1		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS030****1		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS030****1		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/24/2011
		Denali	ZS036****1		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/24/2011
Eagle Mountain	Geomax				Closed Loop				
Eagle Mountain	Geomax	Denali	ZS042****1		Water-to-Air Open Loop	3.7	18.5	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS042****1		Water-to-Air Closed Loop	4.3	23.5	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS048***1		Water-to-Air	3.6	18.1	12/1/2009	2/24/2011

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Eagle Mountain	Geomax	Denali	ZS048****1		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/24/2011
Eagle Mountain	Geomax	Denali	ZS060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/24/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-018-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-018-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-024-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-024-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-030-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-030-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-036-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-036-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-042-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-042-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-048-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-048-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-060-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-060-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-068-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
arthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-068-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
arthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-072-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
arthLinked Technologies, Inc.	EarthLinked®	EarthLinked	C**-072-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-018-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-018-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-024-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-024-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-030-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-030-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-036-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-036-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-042-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-042-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-048-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-048-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-060-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-060-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-068-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	H**-068-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
arthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-018-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
arthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-018-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
farthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-024-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-024-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-030-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-030-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-036-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-036-1C		DGX	3.6	16.0	2/1/2002	2/10/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type		EER Rating	On Market	Date Qualified
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-042-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
arthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-042-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-048-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-048-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-060-1B		DGX	3.6	16.0	2/1/2002	2/10/2011
EarthLinked Technologies, Inc.	EarthLinked®	EarthLinked	S**-060-1C		DGX	3.6	16.0	2/1/2002	2/10/2011
arth To Air Systems, LLC	ETA	TS Series	TS18C1P-U		DGX	4.2	20.0	1/4/2010	1/17/2012
Earth To Air Systems, LLC	ETA	TS Series	TS24C1P-U		DGX	4.0	25.0	1/4/2010	1/17/2012
Earth To Air Systems, LLC	ETA	TS Series	TS30C1P-U		DGX	4.2	21.0	1/4/2010	1/17/2012
arth To Air Systems, LLC	ETA	TS Series	TS30C2P-U		DGX	4.2	21.0	1/4/2010	1/17/2012
arth To Air Systems, LLC	ETA	TS Series	TS36C1P-U		DGX	4.2	21.0	1/4/2010	1/17/2012
Earth To Air Systems, LLC	ETA	TS Series	TS42C1P-U		DGX	4.1	21.0	1/4/2010	1/17/2012
arth To Air Systems, LLC	ETA	TS Series	TS48C1P-U		DGX	4.2	21.0	1/4/2010	1/17/2012
Earth To Air Systems, LLC	ETA	TS Series	TS54C1P-U		DGX	4.2	21.0	1/4/2010	1/17/2012
Earth To Air Systems, LLC	ETA	TS Series	TS60C1P-U		DGX	4.0	19.7	1/4/2010	1/17/2012
arth To Air Systems, LLC	ETA	TS Series	TS60C2P-U		DGX	4.2	21.0	1/4/2010	1/17/2012
Ecologix Heating Technologies Inc.	Ecologix W2W Series	GX-W2W36-DS	GX-W2W36-DS		Open Loop Water-to- Water	3.6	20.7	5/10/2011	6/5/2012
cologix Heating Technologies Inc.	Ecologix W2W Series	GX-W2W72-DS	GX-W2W72-DS		Open Loop Water-to- Water	3.6	19.2	5/10/2011	6/5/2012
Enertech Global, LLC	Compass	Compass	GWT036B		Closed Loop Water-to- Water	3.1	16.8	11/1/2011	9/22/2011
			CIMTOGOR		Open Loop Water-to-		00.5	44440044	0/00/0044
nertech Global, LLC	Compass	Compass	GWT036B		Water Closed Loop Water-to-	3.5	20.5	11/1/2011	9/22/2011
nertech Global, LLC	Compass	Compass	GWT048B		Water Open Loop	3.1	17.1	11/1/2011	9/22/2011
nertech Global, LLC	Compass	Compass	GWT048B		Water-to- Water	3.6	21.1	11/1/2011	9/22/2011
inertech Global, LLC	Compass	Compass	GWT060B		Closed Loop Water-to- Water	3.1	16.4	9/30/2011	1/16/2013
inertech Global, LLC	Compass	Compass	GWT060B		Open Loop Water-to- Water	3.6	20.2	9/30/2011	1/16/2013
nertech Global, LLC	ECONAR	Vara 2+	EV380/381		Closed Loop Water-to-Air	3.6	18.2	1/1/2011	2/13/2013
nertech Global, LLC	ECONAR	Vara 2+	EV380/381		Open Loop Water-to-Air	4.1	23.0	1/1/2011	2/13/2013
nertech Global, LLC	ECONAR	Cold Climate	REC-V036		Closed Loop Water-to-Air	3.6	19.0	7/1/2012	2/13/2013
nertech Global, LLC	ECONAR	Cold Climate	REC-V036		Open Loop Water-to-Air Closed Loop	4.1	26.1	7/1/2012	2/13/2013
nertech Global, LLC	ECONAR	Cold Climate	REC-V048		Water-to-Air	3.6	22.0	7/1/2012	2/13/2013

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	ECONAR	Cold Climate	REC-V048		Open Loop Water-to-Air	4.1	25.9	7/1/2012	2/13/2013
Enertech Global, LLC	ECONAR	Cold Climate	REC-V060		Closed Loop Water-to-Air	3.6	19.6	7/1/2012	2/13/2013
Enertech Global, LLC	ECONAR	Cold Climate	REC-V060		Open Loop Water-to-Air	4.1	25.1	7/1/2012	2/13/2013
Enertech Global, LLC	ES4	ES4	TWT036B		Closed Loop Water-to- Water	3.1	16.8	11/1/2011	9/22/2011
Enertech Global, LLC	ES4	ES4	TWT036B		Open Loop Water-to- Water	3.5	20.5	11/1/2011	9/22/2011
Enertech Global, LLC	ES4	ES4	TWT048B		Closed Loop Water-to- Water	3.1	17.1	11/1/2011	9/22/2011
Enertech Global, LLC	ES4	ES4	TWT048B		Open Loop Water-to- Water	3.6	21.1	11/1/2011	9/22/2011
Enertech Global, LLC	ES4	ES4	TWT060B		Closed Loop Water-to- Water	3.1	16.4	9/30/2011	1/16/2013
Enertech Global, LLC	ES4	ES4	TWT060B		Open Loop Water-to- Water	3.6	20.2	9/30/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GCT024C		Closed Loop Water-to-Air	4.4	23.0	4/23/2012	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GCT024C		Closed Loop Water-to- Water	4.7	24.0	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT024C		Open Loop Water-to-Air	5.2	29.3	4/23/2012	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GCT024C		Open Loop Water-to- Water	5.4	30.3	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT036A		Closed Loop Water-to-Air	4.5	23.1	6/3/2011	5/20/2011
Enertech Global, LLC	GeoComfort	Compass	GCT036A		Open Loop Water-to-Air	4.8	27.1	6/3/2011	5/20/2011
Enertech Global, LLC	GeoComfort	Compass	GCT036C		Closed Loop Water-to-Air	4.4	22.4	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT036C		Closed Loop Water-to- Water	4.7	23.0	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT036C		Open Loop Water-to-Air	5.3	28.1	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT036C		Open Loop Water-to- Water	5.4	28.7	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT048A		Closed Loop Water-to-Air	4.4	21.5	6/3/2011	5/20/2011
Enertech Global, LLC	GeoComfort	Compass	GCT048A		Open Loop Water-to-Air	4.9	25.2	6/3/2011	5/20/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	GeoComfort	Compass	GCT048C		Closed Loop Water-to-Air	4.1	20.8	4/23/2012	2/10/2012
Frantock Clabal II C	CooComfort	Company	CCT049C		Closed Loop Water-to-	4.4	22.0	4/22/2042	2/40/2042
Enertech Global, LLC	GeoComfort	Compass	GCT048C		Water Open Loop	4.4	22.8	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT048C		Water-to-Air	4.7	26.0	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT048C		Open Loop Water-to- Water	5.1	28.5	4/23/2012	2/10/2012
Enertech Global, LLC	GeoComfort	Compass	GCT060A		Closed Loop Water-to-Air	4.0	20.2	6/3/2011	5/20/2011
Enertech Global, LLC	GeoComfort	Compass	GCT060A		Open Loop Water-to-Air	4.5	24.1	6/3/2011	5/20/2011
Enertech Global, LLC	GeoComfort	Compass	GCT060D		Closed Loop Water-to-Air	3.9	20.9	7/23/2012	9/4/2012
Enertech Global, LLC	GeoComfort	Compass	GCT060D		Open Loop Water-to-Air	4.6	25.4	7/23/2012	9/4/2012
Enertech Global, LLC	GeoComfort	Compass	GCT072A		Closed Loop Water-to-Air	3.8	17.7	6/3/2011	5/20/2011
Enertech Global, LLC	GeoComfort	Compass	GCT072A		Open Loop Water-to-Air	4.3	21.1	6/3/2011	5/20/2011
Enertech Global, LLC	GeoComfort	Compass	GCT072D		Closed Loop Water-to-Air	3.8	19.0	7/23/2012	9/4/2012
Enertech Global, LLC	GeoComfort	Compass	GCT072D		Open Loop Water-to-Air	4.4	22.9	7/23/2012	9/4/2012
Enertech Global, LLC	GeoComfort	Compass	GHT024A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	GeoComfort	Compass	GHT024A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	GeoComfort	Compass	GHT036A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	GeoComfort	Compass	GHT036A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	GeoComfort	Compass	GHT048A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	GeoComfort	Compass	GHT048A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	GeoComfort	Compass	GHT060A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	GeoComfort	Compass	GHT060A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	GeoComfort	Compass	GRT024A		Closed Loop Water-to-Air	3.7	19.8	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT024A		Closed Loop Water-to-Air	3.7	20.1	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT024A (WITH A-COIL MODEL NUMBER: ACD024)		Closed Loop Water-to-Air	3.8	20.5	4/16/2012	5/4/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
			GRT024A (WITH AIR HANDLER MODEL NUMBER:	mormation	Closed Loop				
Enertech Global, LLC	GeoComfort	Compass	MPD024)		Water-to-Air	3.7	20.1	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT036A		Closed Loop Water-to-Air	4.0	21.0	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT036A		Closed Loop Water-to-Air	4.1	20.2	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT036A (WITH A-COIL MODEL NUMBER: ACD036)		Closed Loop Water-to-Air	4.1	20.5	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT036A (WITH AIR HANDLER MODEL NUMBER: MPD036)		Closed Loop Water-to-Air	4.1	21.5	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT048A		Closed Loop Water-to-Air	4.1	20.5	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT048A		Closed Loop Water-to-Air	4.2	21.7	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT048A (WITH A-COIL MODEL NUMBER: ACD060)		Closed Loop Water-to-Air	4.1	21.1	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT048A (WITH AIR HANDLER MODEL NUMBER: MPD060)		Closed Loop Water-to-Air	4.3	22.2	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT060A		Closed Loop Water-to-Air	3.8	20.2	4/16/2012	5/4/2012
Frontsch Clohol II C	CooComfort	Company	GRT060A		Closed Loop	2.0	20.7	4/46/2012	E/A/2012
Enertech Global, LLC  Enertech Global, LLC	GeoComfort  GeoComfort	Compass	GRT060A GRT060A (WITH A-COIL MODEL NUMBER: ACD060)		Water-to-Air  Closed Loop Water-to-Air	3.8	20.7	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT060A (WITH AIR HANDLER MODEL NUMBER: MPD060)		Closed Loop Water-to-Air	3.9	21.0	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT072A (WITH A-COIL MODEL NUMBER: ACD060)		Closed Loop Water-to-Air	3.6	19.0	4/16/2012	5/4/2012
Enertech Global, LLC	GeoComfort	Compass	GRT072A (WITH AIR HANDLER MODEL NUMBER: MPD072)		Closed Loop Water-to-Air	3.6	19.7	4/16/2012	5/4/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	GeoComfort	Serenity GS	GS018		Closed Loop Water-to-Air	3.7	18.9	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GS	GS018		Open Loop Water-to-Air	4.3	21.7	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GS	GS024		Closed Loop Water-to-Air	3.7	18.0	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GS	GS042		Open Loop Water-to-Air	4.8	22.0	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Compass	GST024A		Closed Loop Water-to-Air	3.6	19.1	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST024A		Closed Loop Water-to-Air	3.8	19.6	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST024A		Open Loop Water-to-Air	4.2	23.8	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST024A		Open Loop Water-to-Air	4.4	24.2	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST024A (with_A- Coil_model_numb er:ACD024)		Closed Loop Water-to-Air	3.8	19.5	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST024A (with_A- Coil_model_numb er:ACD024)		Open Loop Water-to-Air	4.4	24.0	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST024A (with_Air Handler_model_n umber:MPD024)		Closed Loop Water-to-Air	3.8	20.0	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST024A (with_Air Handler_model_n umber:MPD024)		Open Loop Water-to-Air	4.3	24.6	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST036A		Closed Loop Water-to-Air	4.0	19.8	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST036A		Closed Loop Water-to-Air	4.0	20.2	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST036A		Open Loop Water-to-Air	4.6	23.9	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST036A		Open Loop Water-to-Air	4.6	25.4	11/1/2011	10/31/2011
·		·	GST036A (with_A- Coil_model_numb		Closed Loop				
Enertech Global, LLC	GeoComfort	Compass	er:ACD036) GST036A (with_A- Coil_model_numb		Water-to-Air  Open Loop	4.0	20.0	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	er:ACD036) GST036A		Water-to-Air	4.6	24.7	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	(with_Air Handler_model_n umber:MPD036)		Closed Loop Water-to-Air	4.2	20.6	11/1/2011	10/31/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
			GST036A (with_Air						
Enertech Global, LLC	GeoComfort	Compass	Handler_model_n umber:MPD036)		Open Loop Water-to-Air	4.7	25.8	11/1/2011	10/31/2011
		- Сомрасс			Closed Loop				
Enertech Global, LLC	GeoComfort	Compass	GST048A		Water-to-Air	4.0	22.6	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST048A		Closed Loop Water-to-Air	4.2	21.7	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST048A		Open Loop Water-to-Air	4.7	27.3	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST048A		Open Loop Water-to-Air	4.8	26.6	11/1/2011	1/16/2013
-nortook Olokal III O	CooComfort	Company	GST048A (with_A- Coil_model_numb		Closed Loop	4.0	24.0	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	er:ACD060) GST048A (with_A-		Water-to-Air	4.2	21.0	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	Coil_model_numb er:ACD060)		Open Loop Water-to-Air	4.7	25.8	11/1/2011	10/31/2011
			GST048A (with_Air Handler_model_n		Closed Loop				
Enertech Global, LLC	GeoComfort	Compass	umber:MPD060)		Water-to-Air	4.3	23.5	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST048A (with_Air Handler_model_n umber:MPD060)		Open Loop Water-to-Air	4.9	29.2	11/1/2011	10/31/2011
		- Сомрасс			Closed Loop				
Enertech Global, LLC	GeoComfort	Compass	GST060A		Water-to-Air	3.7	19.7	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST060A		Closed Loop Water-to-Air	3.8	19.7	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST060A		Open Loop Water-to-Air	4.3	23.2	11/1/2011	1/16/2013
Enertech Global, LLC	GeoComfort	Compass	GST060A		Open Loop Water-to-Air	4.3	23.7	11/1/2011	1/16/2013
Enorteeh Clohel III C	GeoComfort	Compage	GST060A (with_A- Coil_model_numb er:ACD060)		Closed Loop	3.8	10.1	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComort	Compass	GST060A (with_A-		Water-to-Air	3.0	19.1	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	Coil_model_numb er:ACD060)		Open Loop Water-to-Air	4.3	22.8	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST060A (with_Air Handler_model_n umber:MPD060)		Closed Loop Water-to-Air	4.0	21.0	11/1/2011	10/31/2011
Enotadii Global, EEO	Scooningt	Оотгразз	GST060A (with_Air		Water to-Air	1.0	21.0	11/1/2011	10/01/2011
Enertech Global, LLC	GeoComfort	Compass	Handler_model_n umber:MPD060)		Open Loop Water-to-Air	4.5	25.8	11/1/2011	10/31/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	GeoComfort	Compass	GST072A		Closed Loop Water-to-Air	3.6	17.9	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST072A		Closed Loop Water-to-Air	3.6	19.0	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST072A		Open Loop Water-to-Air	4.1	21.1	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST072A		Open Loop Water-to-Air	4.1	23.1	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST072A (with_A- Coil_model_numb er:ACD060)		Closed Loop Water-to-Air	3.6	17.8	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST072A (with_Air Handler_model_n umber:MPD072)		Closed Loop Water-to-Air	3.7	19.4	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Compass	GST072A (with_Air Handler_model_n umber:MPD072)		Open Loop Water-to-Air	4.2	23.6	11/1/2011	10/31/2011
Enertech Global, LLC	GeoComfort	Serenity GT	GT024		Closed Loop Water-to-Air	3.7	18.0	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GT	GT036		Closed Loop Water-to-Air	3.7	21.0	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GT	GT036		Open Loop Water-to-Air	4.5	23.1	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GT	GT048		Closed Loop Water-to-Air	3.8	19.8	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GT	GT060		Closed Loop Water-to-Air	3.7	19.0	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GT	GT060		Open Loop Water-to-Air	4.3	22.5	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC024(with_A-Coil_model_number:ACD024)		Closed Loop Water-to-Air	3.7	19.7	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC024(with_A-Coil_model_number:ACD024)		Open Loop Water-to-Air	4.2	24.1	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC024(with_Air Handler_model_n umber:MPD024)		Closed Loop Water-to-Air	3.7	19.7	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC024(with_Air Handler_model_n umber:MPD024)		Open Loop Water-to-Air	4.2	24.1	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC036(with_A-Coil_model_number:ACD036)		Closed Loop Water-to-Air	3.6	18.6	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC036(with_A-Coil_model_numb er:ACD036)		Open Loop Water-to-Air	4.2	22.6	11/1/2007	1/21/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC036(with_Air Handler_model_n umber:MPD036)		Closed Loop Water-to-Air	3.8	19.1	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC048(with_A-Coil_model_number:ACD048)		Closed Loop Water-to-Air	3.6	19.0	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC048(with_A-Coil_model_numb er:ACD048)		Open Loop Water-to-Air	4.1	22.8	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC048(with_Air Handler_model_n umber:MPD048)		Closed Loop Water-to-Air	3.7	19.5	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC048(with_Air Handler_model_n umber:MPD048)		Open Loop Water-to-Air	4.1	22.6	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC060(with_A-Coil_model_number:ACD060)		Closed Loop Water-to-Air	3.6	18.7	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC060(with_A-Coil_model_number:ACD060)		Open Loop Water-to-Air	4.1	21.6	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC060(with_Air Handler_model_n umber:MPD060)		Closed Loop Water-to-Air	3.7	18.8	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	Serenity GTC	GTC060(with_Air Handler_model_n umber:MPD060)		Open Loop Water-to-Air	4.1	21.8	11/1/2007	1/21/2011
Enertech Global, LLC	GeoComfort	GWT 2-Stage W-to-W	GWT060B		Closed Loop Water-to- Water	3.2	17.0	9/30/2011	9/22/2011
Enertech Global, LLC	GeoComfort	GWT 2-Stage W-to-W	GWT060B		Open Loop Water-to- Water	3.7	21.1	9/30/2011	9/22/2011
Enertech Global, LLC	GeoComfort	Compass	GXT024B		Closed Loop Water-to-Air	4.6	24.2	4/7/2011	5/5/2011
Enertech Global, LLC	GeoComfort	Compass	GXT024B		Open Loop Water-to-Air Closed Loop	5.5	31.1	4/7/2011	5/5/2011
Enertech Global, LLC	GeoComfort	Compass	GXT024C		Water-to-Air	4.5	24.4	11/4/2011	9/27/2011
Enertech Global, LLC	GeoComfort	Compass	GXT024C		Open Loop Water-to-Air	5.4	30.5	11/4/2011	9/27/2011
Enertech Global, LLC	GeoComfort	Compass	GXT036A		Closed Loop Water-to-Air	4.5	23.3	7/1/2010	1/21/2011
Enertech Global, LLC	GeoComfort	Compass	GXT036A		Open Loop Water-to-Air	4.8	27.1	7/1/2010	1/21/2011
Enertech Global, LLC	GeoComfort	Compass	GXT036C		Closed Loop Water-to-Air	4.4	22.7	11/4/2011	9/27/2011
Enertech Global, LLC	GeoComfort	Compass	GXT036C		Open Loop Water-to-Air	5.1	28.1	11/4/2011	9/27/2011
Enertech Global, LLC	GeoComfort	Compass	GXT048A		Closed Loop Water-to-Air	4.4	21.5	1/26/2010	1/21/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	GeoComfort	Compass	GXT048A		Open Loop Water-to-Air	4.9	25.2	1/26/2010	1/21/2011
Enertech Global, LLC	GeoComfort	Compass	GXT048C		Closed Loop Water-to-Air	4.2	20.8	11/4/2011	9/27/2011
Enertech Global, LLC	GeoComfort	Compass	GXT048C		Open Loop Water-to-Air	4.7	26.1	11/4/2011	9/27/2011
Enertech Global, LLC	GeoComfort	Compass	GXT060A		Closed Loop Water-to-Air	4.1	20.6	1/26/2010	1/21/2011
Enertech Global, LLC	GeoComfort	Compass	GXT060A		Open Loop Water-to-Air	4.7	24.1	1/26/2010	1/21/2011
Enertech Global, LLC	GeoComfort	Compass	GXT060B		Closed Loop Water-to-Air	4.2	20.6	10/5/2011	10/7/2011
Enertech Global, LLC	GeoComfort	Compass	GXT060B		Open Loop Water-to-Air	4.7	25.1	10/5/2011	10/7/2011
Enertech Global, LLC	GeoComfort	Compass	GXT060D		Closed Loop Water-to-Air	4.0	21.4	7/23/2012	9/4/2012
Enertech Global, LLC	GeoComfort	Compass	GXT060D		Open Loop Water-to-Air	4.7	26.1	7/23/2012	9/4/2012
Enertech Global, LLC	GeoComfort	Compass	GXT072A		Closed Loop Water-to-Air	4.1	18.0	1/26/2010	1/21/2011
Enertech Global, LLC	GeoComfort	Compass	GXT072B		Closed Loop Water-to-Air	3.9	17.9	10/5/2011	10/7/2011
Enertech Global, LLC	GeoComfort	Compass	GXT072B		Open Loop Water-to-Air	4.5	22.2	10/5/2011	10/7/2011
Enertech Global, LLC	GeoComfort	Compass	GXT072D		Closed Loop Water-to-Air	3.9	20.0	7/23/2012	9/4/2012
Enertech Global, LLC	GeoComfort	Compass	GXT072D		Open Loop Water-to-Air	4.5	24.0	7/23/2012	9/4/2012
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V024		Closed Loop Water-to-Air	3.6	17.1	2/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V024		Open Loop Water-to-Air	4.4	22.0	2/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V036		Closed Loop Water-to-Air	3.6	17.1	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V036		Open Loop Water-to-Air	4.1	22.0	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V048		Closed Loop Water-to-Air	3.6	17.1	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V048		Open Loop Water-to-Air	4.2	21.1	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V060		Closed Loop Water-to-Air	3.6	17.1	2/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V060		Open Loop Water-to-Air	4.1	21.1	2/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-V072		Closed Loop Water-to-Air	3.6	17.1	1/1/2012	2/13/2013
	·				Closed Loop Water-to-				
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W036		Water	3.1	17.6	1/1/2012	2/13/2013

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W036		Open Loop Water-to- Water	3.7	23.5	1/1/2012	2/13/2013
					Closed Loop Water-to-				
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W048		Water Open Loop	3.2	18.0	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W048		Water-to- Water	3.6	24.6	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W060		Closed Loop Water-to- Water	3.2	17.4	1/1/2012	2/13/2013
					Open Loop Water-to-				
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W060		Water Closed Loop	3.6	24.0	1/1/2012	2/13/2013
					Water-to-				
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W072		Water Open Loop	3.2	17.0	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W072		Water-to- Water	3.5	20.3	1/1/2012	2/13/2013
Fnortagh Clahal II C	ConSustama	GeoSource	DCC W094		Closed Loop Water-to-	2.2	16.1	1/1/2012	2/42/2042
Enertech Global, LLC	GeoSystems		RGS-W084		Water Open Loop Water-to-	3.2	16.1	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W084		Water	4.1	20.1	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W120		Closed Loop Water-to- Water	3.1	17.1	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGS-W120		Open Loop Water-to- Water	3.5	21.5	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V024		Closed Loop Water-to-Air	3.8	18.7	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V024		Open Loop Water-to-Air	4.6	21.5	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V036		Closed Loop Water-to-Air	4.0	19.9	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V036		Open Loop Water-to-Air	4.6	25.1	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V048		Closed Loop Water-to-Air	3.9	21.7	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V048		Open Loop Water-to-Air	4.4	27.5	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V060		Closed Loop Water-to-Air	3.6	19.7	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V060		Open Loop Water-to-Air	4.1	23.7	1/1/2012	2/13/2013
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V072		Closed Loop Water-to-Air	3.6	20.0	1/1/2012	2/13/2013

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	GeoSystems	GeoSource	RGT-V072		Open Loop Water-to-Air	4.1	24.9	1/1/2012	2/13/2013
Enertech Global, LLC	HydroHeat	Extended Range	HE5D019		Closed Loop Water-to-Air	3.6	17.1	1/1/2011	2/13/2013
Enertech Global, LLC	HydroHeat	Extended Range	HE5D019		Open Loop Water-to-Air	4.2	21.1	1/1/2011	2/13/2013
Enertech Global, LLC	HydroHeat	Extended Range	HE5V019		Closed Loop Water-to-Air	3.6	17.1	1/1/2011	2/13/2013
Enertech Global, LLC	HydroHeat	Extended Range	HE5V019		Open Loop Water-to-Air	4.2	21.1	1/1/2011	2/13/2013
Enertech Global, LLC	Hydron	H Series	H018		Closed Loop Water-to-Air	3.7	18.9	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series	H018		Open Loop Water-to-Air	4.3	21.7	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series	H024		Closed Loop Water-to-Air	3.7	18.0	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H026		Closed Loop Water-to-Air	3.7	18.0	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H026C(with _A- Coil_model_numb er:ACD024)		Closed Loop Water-to-Air	3.7	19.7	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H026C(with _A- Coil_model_numb er:ACD024)		Open Loop Water-to-Air	4.2	24.0	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H026C(with _Air Handler_model_n umber:MPD024)		Closed Loop Water-to-Air	3.7	19.7	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H026C(with _Air Handler_model_n umber:MPD024)		Open Loop Water-to-Air	4.2	24.1	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H038		Closed Loop Water-to-Air	3.7	21.0	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H038		Open Loop Water-to-Air	4.5	23.1	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H038C(with _A- Coil_model_numb er:ACD036)		Closed Loop Water-to-Air	3.6	18.6	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H038C(with _A- Coil_model_numb er:ACD036)		Open Loop Water-to-Air	4.2	22.6	11/1/2007	1/21/2011
Enertech Global, LLC		H Series Dual	H038C(with _Air Handler_model_n umber:MPD036)		Closed Loop Water-to-Air	3.8	19.1	11/1/2007	1/21/2011
	Hydron				Open Loop				
Enertech Global, LLC	Hydron	H Series	H042		Water-to-Air Closed Loop	4.8	22.0	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H050 H050C(with _A- Coil_model_numb		Water-to-Air Closed Loop	3.8	20.7	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	er:ACD048)		Water-to-Air	3.6	19.0	11/1/2007	1/21/2011

				Additional				Data Assallable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	Hydron	H Series Dual	H050C(with _A- Coil_model_numb er:ACD048)		Open Loop Water-to-Air	4.1	22.8	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H050C(with _Air Handler_model_n umber:MPD048)		Closed Loop Water-to-Air	3.7	19.5	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H050C(with _Air Handler_model_n umber:MPD048)		Open Loop Water-to-Air	4.1	22.6	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H062		Closed Loop Water-to-Air	3.7	19.0	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H062		Open Loop Water-to-Air	4.3	22.5	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H062C(with _A- Coil_model_numb er:ACD060)		Closed Loop Water-to-Air	3.6	18.7	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H062C(with _A- Coil_model_numb er:ACD060)		Open Loop Water-to-Air	4.1	21.6	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H062C(with _Air Handler_model_n umber:MPD060)		Closed Loop Water-to-Air	3.7	18.8	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	H Series Dual	H062C(with _Air Handler_model_n umber:MPD060)		Open Loop Water-to-Air	4.1	21.8	11/1/2007	1/21/2011
Enertech Global, LLC	Hydron	Revolution	HCT024C		Closed Loop Water-to-Air	4.4	23.0	4/23/2012	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HCT024C		Open Loop Water-to-Air	5.2	29.3	4/23/2012	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HCT036C		Closed Loop Water-to-Air	4.4	22.4	4/23/2012	2/10/2012
Enertech Global, LLC	Hydron	Revolution	НСТ036С		Open Loop Water-to-Air	5.3	28.1	4/23/2012	2/10/2012
Enertech Global, LLC	Hydron	Revolution	HCT048C		Closed Loop Water-to-Air Open Loop	4.1	20.8	4/23/2012	2/10/2012
Enertech Global, LLC	Hydron	Revolution	HCT048C		Water-to-Air Closed Loop	4.7	26.0	4/23/2012	2/10/2012
Enertech Global, LLC	Hydron	Revolution	HCT060D		Water-to-Air Open Loop	3.9	20.9	7/23/2012	9/4/2012
Enertech Global, LLC	Hydron	Revolution	HCT060D		Water-to-Air Closed Loop	4.6	25.4	7/23/2012	9/4/2012
Enertech Global, LLC	Hydron	Revolution	HCT072D		Water-to-Air Open Loop	3.8	19.0	7/23/2012	9/4/2012
Enertech Global, LLC Enertech Global, LLC	Hydron	Revolution  Revolution	HCT072D HHT024A		Water-to-Air Closed Loop Water-to-Air	3.6	22.9 17.1	7/23/2012	9/4/2012 7/28/2011
Enertech Global, LLC	Hydron	Revolution	HHT024A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	Hydron	Revolution	HHT036A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	Hydron	Revolution	ННТ036А		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	Hydron	Revolution	HHT048A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	Hydron	Revolution	HHT048A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	Hydron	Revolution	ННТ060А		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	Hydron	Revolution	ННТ060А		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	Hydron	Revolution	HRT024A		Closed Loop Water-to-Air	3.7	19.8	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT024A		Closed Loop Water-to-Air	3.7	20.1	4/16/2012	5/4/2012
Frontech Clohol III C	Under	Develotion	HRT024A (WITH A-COIL MODEL NUMBER:		Closed Loop	2.0	20.5	4/40/2042	F/4/2042
Enertech Global, LLC	Hydron	Revolution	ACD024) HRT024A (WITH AIR HANDLER MODEL NUMBER:		Water-to-Air Closed Loop	3.8	20.5	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	MPD024)		Water-to-Air	3.7	20.1	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT036A		Closed Loop Water-to-Air	4.0	21.0	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT036A		Closed Loop Water-to-Air	4.1	20.2	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT036A (WITH A-COIL MODEL NUMBER: ACD036)		Closed Loop Water-to-Air	4.1	20.5	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT036A (WITH AIR HANDLER MODEL NUMBER: MPD036)		Closed Loop Water-to-Air	4.1	21.5	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT048A		Closed Loop Water-to-Air	4.1	20.5	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT048A		Closed Loop Water-to-Air	4.2	21.7	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT048A (WITH A-COIL MODEL NUMBER: ACD060)		Closed Loop Water-to-Air	4.1	21.1	4/16/2012	5/4/2012
Enertech Global, LLC		Revolution	HRT048A (WITH AIR HANDLER MODEL NUMBER:		Closed Loop Water-to-Air	4.3	22.2	4/16/2012	5/4/2012
	Hydron		MPD060)		Closed Loop				
Enertech Global, LLC	Hydron	Revolution	HRT060A		Water-to-Air Closed Loop	3.8	20.2	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT060A		Water-to-Air	3.8	20.7	4/16/2012	5/4/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	Hydron	Revolution	HRT060A (WITH A-COIL MODEL NUMBER: ACD060)		Closed Loop Water-to-Air	3.8	20.5	4/16/2012	5/4/2012
Energed Global, EEG	Tiyalon	revolution	HRT060A (WITH AIR HANDLER MODEL NUMBER:		Closed Loop	0.0	20.0	4,10,2012	0.4.2012
Enertech Global, LLC	Hydron	Revolution	MPD060) HRT072A (WITH A-COIL MODEL NUMBER:		Water-to-Air Closed Loop	3.9	21.0	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	ACD060)		Water-to-Air	3.6	19.0	4/16/2012	5/4/2012
Enertech Global, LLC	Hydron	Revolution	HRT072A (WITH AIR HANDLER MODEL NUMBER: MPD072)		Closed Loop Water-to-Air	3.6	19.7	4/16/2012	5/4/2012
·	-		,		Closed Loop				
Enertech Global, LLC  Enertech Global, LLC	Hydron Hydron	Revolution  Revolution	HST024A		Water-to-Air Closed Loop Water-to-Air	3.6	19.1	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST024A		Open Loop Water-to-Air	4.2	23.8	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST024A		Open Loop Water-to-Air	4.4	24.2	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST036A		Closed Loop Water-to-Air	4.0	19.8	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron	Revolution	HST036A		Closed Loop Water-to-Air	4.0	20.2	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron	Revolution	HST036A		Open Loop Water-to-Air	4.6	23.9	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron	Revolution	HST036A		Open Loop Water-to-Air	4.6	25.4	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron	Revolution	HST048A		Closed Loop Water-to-Air	4.0	22.6	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST048A		Closed Loop Water-to-Air	4.2	21.7	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST048A		Open Loop Water-to-Air	4.7	27.3	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST048A		Open Loop Water-to-Air	4.8	26.6	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST060A		Closed Loop Water-to-Air	3.7	19.7	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST060A		Closed Loop Water-to-Air	3.8	19.7	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST060A		Open Loop Water-to-Air	4.3	23.2	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST060A		Open Loop Water-to-Air	4.3	23.7	11/1/2011	1/16/2013
Enertech Global, LLC	Hydron	Revolution	HST072A		Closed Loop Water-to-Air	3.6	17.9	11/1/2011	10/31/2011

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
nertech Global, LLC	Hydron	Revolution	HST072A		Closed Loop Water-to-Air	3.6	19.0	11/1/2011	10/31/2011
nertech Global, LLC	Hydron	Revolution	HST072A		Open Loop Water-to-Air	4.1	21.1	11/1/2011	10/31/2011
nertech Global, LLC	Hydron	Revolution	HST072A		Open Loop Water-to-Air	4.1	23.1	11/1/2011	10/31/2011
nertech Global, LLC	Hydron	Revolution	HXT024C		Closed Loop Water-to-Air	4.5	24.4	11/4/2011	9/27/2011
nertech Global, LLC	Hydron	Revolution	HXT024C		Open Loop Water-to-Air	5.4	30.5	11/4/2011	9/27/2011
nertech Global, LLC	Hydron	Revolution	HXT036A		Closed Loop Water-to-Air	4.5	23.3	7/1/2010	1/21/2011
nertech Global, LLC	Hydron	Revolution	HXT036A		Open Loop Water-to-Air	4.8	27.1	7/1/2010	1/21/2011
nertech Global, LLC	Hydron	Revolution	HXT036C		Closed Loop Water-to-Air	4.4	22.7	11/4/2011	9/27/2011
nertech Global, LLC	Hydron	Revolution	HXT036C		Open Loop Water-to-Air	5.1	28.1	11/4/2011	9/27/2011
nertech Global, LLC	Hydron	Revolution	HXT048A		Closed Loop Water-to-Air	4.4	21.5	1/26/2010	1/21/2011
nertech Global, LLC	Hydron	Revolution	HXT048A		Open Loop Water-to-Air	4.9	25.2	1/26/2010	1/21/2011
nertech Global, LLC	Hydron	Revolution	HXT048C		Closed Loop Water-to-Air	4.2	20.8	11/4/2011	9/27/2011
nertech Global, LLC	Hydron	Revolution	HXT048C		Open Loop Water-to-Air	4.7	26.1	11/4/2011	9/27/2011
nertech Global, LLC	Hydron	Revolution	HXT060A		Closed Loop Water-to-Air	4.1	20.6	1/26/2010	1/21/2011
nertech Global, LLC	Hydron	Revolution	HXT060A		Open Loop Water-to-Air	4.7	24.1	1/26/2010	1/21/2011
Enertech Global, LLC	Hydron	Revolution	HXT060D		Closed Loop Water-to-Air	4.0	21.4	7/23/2012	9/4/2012
Enertech Global, LLC	Hydron	Revolution	HXT060D		Open Loop Water-to-Air	4.7	26.1	7/23/2012	9/4/2012
inertech Global, LLC	Hydron	Revolution	HXT072A		Closed Loop Water-to-Air	4.1	18.0	1/26/2010	1/21/2011
nertech Global, LLC	Hydron	Revolution	HXT072D		Closed Loop Water-to-Air	3.9	20.0	7/23/2012	9/4/2012
	-				Open Loop				
nertech Global, LLC	Hydron	Revolution	HXT072D		Water-to-Air Closed Loop	4.5	24.0	7/23/2012	9/4/2012
nertech Global, LLC	Hydron Module	Revolution	HCT024C		Water-to- Water	4.7	24.0	4/23/2012	2/10/2012
nertech Global, LLC	Hydron Module	Revolution	HCT024C		Open Loop Water-to- Water	5.4	30.3	4/23/2012	2/10/2012
nertech Global, LLC	Hydron Module	Revolution	HCT036A		Closed Loop Water-to-Air	4.5	23.1	6/3/2011	5/20/2011
nertech Global, LLC	Hydron Module	Revolution	HCT036A		Open Loop Water-to-Air	4.8	27.1	6/3/2011	5/20/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	Hydron Module	Revolution	HCT036C		Closed Loop Water-to- Water	4.7	23.0	4/23/2012	2/10/2012
					Open Loop Water-to-				
Enertech Global, LLC	Hydron Module	Revolution	HCT036C		Water Closed Loop	5.4	28.7	4/23/2012	2/10/2012
Enertech Global, LLC	Hydron Module	Revolution	HCT048A		Water-to-Air	4.4	21.5	6/3/2011	5/20/2011
Enertech Global, LLC	Hydron Module	Revolution	HCT048A		Open Loop Water-to-Air	4.9	25.2	6/3/2011	5/20/2011
Enertech Global, LLC	Hydron Module	Revolution	HCT048C		Closed Loop Water-to- Water	4.4	22.8	4/23/2012	2/10/2012
Enertech Global, LLC	Hydron Module	Revolution	HCT048C		Open Loop Water-to- Water	5.1	28.5	4/23/2012	2/10/2012
inortoon Global, 220	Tryaron modulo	i tovolation			Closed Loop	0.1		1/20/2012	2,10,2012
Enertech Global, LLC	Hydron Module	Revolution	HCT060A		Water-to-Air	4.0	20.2	6/3/2011	5/20/2011
Enertech Global, LLC	Hydron Module	Revolution	НСТ060А		Open Loop Water-to-Air	4.5	24.1	6/3/2011	5/20/2011
Enertech Global, LLC	Hydron Module	Revolution	HCT072A		Closed Loop Water-to-Air	3.8	17.7	6/3/2011	5/20/2011
Enertech Global, LLC	Hydron Module	Revolution	HCT072A		Open Loop Water-to-Air	4.3	21.1	6/3/2011	5/20/2011
Enertech Global, LLC	Hydron Module	Revolution	HST024A (with_A- Coil_model_numb er:ACD024)		Closed Loop Water-to-Air	3.8	19.5	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST024A (with_A- Coil_model_numb er:ACD024)		Open Loop Water-to-Air	4.4	24.0	11/1/2011	10/31/2011
	,		HST024A (with_Air Handler_model_n		Closed Loop				
Enertech Global, LLC	Hydron Module	Revolution	umber:MPD024) HST024A		Water-to-Air	3.8	20.0	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	(with_Air Handler_model_n umber:MPD024)		Open Loop Water-to-Air	4.3	24.6	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST036A (with_A- Coil_model_numb er:ACD036)		Closed Loop Water-to-Air	4.0	20.0	11/1/2011	10/31/2011
			HST036A (with_A- Coil_model_numb		Open Loop				
Enertech Global, LLC	Hydron Module	Revolution	er:ACD036) HST036A		Water-to-Air	4.6	24.7	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	(with_Air Handler_model_n umber:MPD036)		Closed Loop Water-to-Air	4.2	20.6	11/1/2011	10/31/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
		illoudi Numb	HST036A (with_Air Handler_model_n		Open Loop				
Enertech Global, LLC	Hydron Module	Revolution	umber:MPD036) HST048A (with_A- Coil model numb		Water-to-Air Closed Loop	4.7	25.8	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	er:ACD060)		Water-to-Air	4.2	21.0	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST048A (with_A- Coil_model_numb er:ACD060)		Open Loop Water-to-Air	4.7	25.8	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST048A (with_Air Handler_model_n umber:MPD060)		Closed Loop Water-to-Air	4.3	23.5	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST048A (with_Air Handler_model_n umber:MPD060)		Open Loop Water-to-Air	4.9	29.2	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST060A (with_A- Coil_model_numb er:ACD060)		Closed Loop Water-to-Air	3.8	19.1	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST060A (with_A- Coil_model_numb er:ACD060)		Open Loop Water-to-Air	4.3	22.8	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST060A (with_Air Handler_model_n umber:MPD060)		Closed Loop Water-to-Air	4.0	21.0	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST060A (with_Air Handler_model_n umber:MPD060)		Open Loop Water-to-Air	4.5	25.8	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST072A (with_A- Coil_model_numb er:ACD060)		Closed Loop Water-to-Air	3.6	17.8	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST072A (with_Air Handler_model_n umber:MPD072)		Closed Loop Water-to-Air	3.7	19.4	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	Revolution	HST072A (with_Air Handler_model_n umber:MPD072)		Open Loop Water-to-Air	4.2	23.6	11/1/2011	10/31/2011
Enertech Global, LLC	Hydron Module	HWT 2-Stage W-to-W	HWT060B		Closed Loop Water-to- Water	3.2	17.0	9/30/2011	9/22/2011
Enertech Global, LLC	Hydron Module	HWT 2-Stage W-to-W	HWT060B		Open Loop Water-to- Water	3.7	21.1	9/30/2011	9/22/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	Hydron Module	Revolution	HXT024B		Closed Loop Water-to-Air	4.6	24.2	4/7/2011	5/5/2011
Enertech Global, LLC	Hydron Module	Revolution	HXT024B		Open Loop Water-to-Air	5.5	31.1	4/7/2011	5/5/2011
Enertech Global, LLC	Hydron Module	Revolution	HXT060B		Closed Loop Water-to-Air	4.2	20.6	10/5/2011	10/7/2011
nertech Global, LLC	Hydron Module	Revolution	HXT060B		Open Loop Water-to-Air	4.7	25.1	10/5/2011	10/7/2011
nertech Global, LLC	Hydron Module	Revolution	HXT072B		Closed Loop Water-to-Air	3.9	17.9	10/5/2011	10/7/2011
nertech Global, LLC	Hydron Module	Revolution	HXT072B		Open Loop Water-to-Air	4.5	22.2	10/5/2011	10/7/2011
nertech Global, LLC	Revolution	Revolution	HWT036B		Closed Loop Water-to- Water	3.1	16.8	11/1/2011	9/22/2011
					Open Loop Water-to-				
Enertech Global, LLC	Revolution	Revolution	HWT036B		Water Closed Loop	3.5	20.5	11/1/2011	9/22/2011
nertech Global, LLC	Revolution	Revolution	HWT048B		Water-to- Water	3.1	17.1	11/1/2011	9/22/2011
Enertech Global, LLC	Revolution	Revolution	HWT048B		Open Loop Water-to- Water	3.6	21.1	11/1/2011	9/22/2011
Enertech Global, LLC	Revolution	Revolution	HWT060B		Closed Loop Water-to- Water	3.1	16.4	9/30/2011	1/16/2013
Enertech Global, LLC	Revolution	Revolution	HWT060B		Open Loop Water-to- Water	3.6	20.2	9/30/2011	1/16/2013
					Closed Loop				
nertech Global, LLC	Roth Industries	TerraStar	RCT024C		Water-to-Air Closed Loop	4.4	23.0	4/23/2012	1/16/2013
nertech Global, LLC	Roth Industries	TerraStar	RCT024C		Water-to- Water	4.7	24.0	4/23/2012	2/10/2012
nertech Global, LLC	Roth Industries	TerraStar	RCT024C		Open Loop Water-to-Air	5.2	29.3	4/23/2012	1/16/2013
inertech Global, LLC	Roth Industries	TerraStar	RCT024C		Open Loop Water-to- Water	5.4	30.3	4/23/2012	2/10/2012
nertech Global, LLC	Roth Industries	TerraStar	RCT036A		Closed Loop Water-to-Air	4.5	23.1	6/3/2011	5/20/2011
nertech Global, LLC	Roth Industries	TerraStar	RCT036A		Open Loop Water-to-Air	4.8	27.1	6/3/2011	5/20/2011
nertech Global, LLC	Roth Industries	TerraStar	RCT036C		Closed Loop Water-to-Air	4.4	22.4	4/23/2012	2/10/2012
nertech Global, LLC	Roth Industries	TerraStar	RCT036C		Closed Loop Water-to- Water	4.7	23.0	4/23/2012	2/10/2012
nertech Global, LLC	Roth Industries	TerraStar	RCT036C		Open Loop Water-to-Air	5.3	28.1	4/23/2012	2/10/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	Roth Industries	TerraStar	RCT036C		Open Loop Water-to- Water	5.4	28.7	4/23/2012	2/10/2012
Enertech Global, LLC	Roth Industries	TerraStar	RCT048A		Closed Loop Water-to-Air	4.4	21.5	6/3/2011	5/20/2011
Enertech Global, LLC	Roth Industries	TerraStar	RCT048A		Open Loop Water-to-Air	4.9	25.2	6/3/2011	5/20/2011
Enertech Global, LLC	Roth Industries	TerraStar	RCT048C		Closed Loop Water-to-Air	4.1	20.8	4/23/2012	2/10/2012
Enertech Global, LLC	Roth Industries	TerraStar	RCT048C		Closed Loop Water-to- Water	4.4	22.8	4/23/2012	2/10/2012
Enertech Global, LLC	Roth Industries	TerraStar	RCT048C		Open Loop Water-to-Air	4.7	26.0	4/23/2012	2/10/2012
Enertech Global, LLC	Roth Industries	TerraStar	RCT048C		Open Loop Water-to- Water	5.1	28.5	4/23/2012	2/10/2012
Enertech Global, LLC	Roth Industries	TerraStar	RCT060A		Closed Loop Water-to-Air	4.0	20.2	6/3/2011	5/20/2011
Enertech Global, LLC	Roth Industries	TerraStar	RCT060A		Open Loop Water-to-Air	4.5	24.1	6/3/2011	5/20/2011
Enertech Global, LLC	Roth Industries	TerraStar	RCT060D		Closed Loop Water-to-Air	3.9	20.9	7/23/2012	9/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RCT060D		Open Loop Water-to-Air	4.6	25.4	7/23/2012	9/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RCT072A		Closed Loop Water-to-Air	3.8	17.7	6/3/2011	5/20/2011
Enertech Global, LLC	Roth Industries	TerraStar	RCT072A		Open Loop Water-to-Air	4.3	21.1	6/3/2011	5/20/2011
Enertech Global, LLC	Roth Industries	TerraStar	RCT072D		Closed Loop Water-to-Air	3.8	19.0	7/23/2012	9/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RCT072D		Open Loop Water-to-Air	4.4	22.9	7/23/2012	9/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RRT024A		Closed Loop Water-to-Air	3.7	19.8	4/16/2012	5/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RRT024A		Closed Loop Water-to-Air	3.7	20.1	4/16/2012	5/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RRT024A (WITH A-COIL MODEL NUMBER: ACD024)		Closed Loop Water-to-Air	3.8	20.5	4/16/2012	5/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RRT024A (WITH AIR HANDLER MODEL NUMBER: MPD024)		Closed Loop Water-to-Air	3.7	20.1	4/16/2012	5/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RRT036A		Closed Loop Water-to-Air	4.0	21.0	4/16/2012	5/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RRT036A		Closed Loop Water-to-Air	4.1	20.2	4/16/2012	5/4/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
			RRT036A (WITH A-COIL MODEL NUMBER:	miormation	Closed Loop				
nertech Global, LLC	Roth Industries	TerraStar	ACD036) RRT036A (WITH AIR HANDLER MODEL NUMBER:		Water-to-Air Closed Loop	4.1	20.5	4/16/2012	5/4/2012
nertech Global, LLC	Roth Industries	TerraStar	MPD036)		Water-to-Air	4.1	21.5	4/16/2012	5/4/2012
nertech Global, LLC	Roth Industries	TerraStar	RRT048A		Closed Loop Water-to-Air	4.1	20.5	4/16/2012	5/4/2012
nertech Global, LLC	Roth Industries	TerraStar	RRT048A		Closed Loop Water-to-Air	4.2	21.7	4/16/2012	5/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RRT048A (WITH A-COIL MODEL NUMBER: ACD060)		Closed Loop Water-to-Air	4.1	21.1	4/16/2012	5/4/2012
nertech Global, LLC	Roth Industries	TerraStar	RRT048A (WITH AIR HANDLER MODEL NUMBER: MPD060)		Closed Loop Water-to-Air	4.3	22.2	4/16/2012	5/4/2012
nertech Global, LLC	Roth Industries	TerraStar	RRT060A		Closed Loop Water-to-Air	3.8	20.2	4/16/2012	5/4/2012
nertech Global, LLC	Roth Industries	TerraStar	RRT060A		Closed Loop Water-to-Air	3.8	20.7	4/16/2012	5/4/2012
		, , , , , , , , , , , , , , , , , , , ,	RRT060A (WITH A-COIL MODEL NUMBER:		Closed Loop				V. //=V.=
nertech Global, LLC	Roth Industries	TerraStar	ACD060)		Water-to-Air	3.8	20.5	4/16/2012	5/4/2012
		- 0	RRT060A (WITH AIR HANDLER MODEL NUMBER:		Closed Loop		24.2	1110/00 10	511/00 10
inertech Global, LLC	Roth Industries	TerraStar	MPD060) RRT072A (WITH A-COIL MODEL NUMBER:		Water-to-Air Closed Loop	3.9	21.0	4/16/2012	5/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	ACD060) RRT072A (WITH AIR HANDLER MODEL NUMBER:		Water-to-Air Closed Loop	3.6	19.0	4/16/2012	5/4/2012
Enertech Global, LLC	Roth Industries	TerraStar  RWT 2-Stage W-	MPD072)		Water-to-Air Closed Loop Water-to-	3.6	19.7	4/16/2012	5/4/2012
nertech Global, LLC	Roth Industries	to-W	RWT060B		Water Open Loop	3.2	17.0	9/30/2011	9/22/2011
nertech Global, LLC	Roth Industries	RWT 2-Stage W- to-W	RWT060B		Water-to- Water Closed Loop	3.7	21.1	9/30/2011	9/22/2011
nertech Global, LLC	Roth Industries	TerraStar	RXT024B		Water-to-Air	4.6	24.2	4/7/2011	5/5/2011
nertech Global, LLC	Roth Industries	TerraStar	RXT024B		Open Loop Water-to-Air	5.5	31.1	4/7/2011	5/5/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	Roth Industries	TerraStar	RXT024C		Closed Loop Water-to-Air	4.5	24.4	11/4/2011	9/27/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT024C		Open Loop Water-to-Air	5.4	30.5	11/4/2011	9/27/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT036A		Closed Loop Water-to-Air	4.5	23.3	10/1/2010	1/21/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT036A		Open Loop Water-to-Air	4.8	27.1	10/1/2010	1/21/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT036C		Closed Loop Water-to-Air	4.4	22.7	11/4/2011	9/27/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT036C		Open Loop Water-to-Air	5.1	28.1	11/4/2011	9/27/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT048A		Closed Loop Water-to-Air	4.4	21.5	10/1/2010	1/21/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT048A		Open Loop Water-to-Air	4.9	25.2	10/1/2010	1/21/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT048C		Closed Loop Water-to-Air	4.2	20.8	11/4/2011	9/27/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT048C		Open Loop Water-to-Air	4.7	26.1	11/4/2011	9/27/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT060A		Closed Loop Water-to-Air	4.1	20.6	10/1/2010	1/21/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT060A		Open Loop Water-to-Air	4.7	24.1	10/1/2010	1/21/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT060B		Closed Loop Water-to-Air	4.2	20.6	10/5/2011	10/7/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT060B		Open Loop Water-to-Air	4.7	25.1	10/5/2011	10/7/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT060D		Closed Loop Water-to-Air	4.0	21.4	7/23/2012	9/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RXT060D		Open Loop Water-to-Air	4.7	26.1	7/23/2012	9/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RXT072A		Closed Loop Water-to-Air	4.1	18.0	10/1/2010	1/21/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT072B		Closed Loop Water-to-Air	3.9	17.9	10/5/2011	10/7/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT072B		Open Loop Water-to-Air	4.5	22.2	10/5/2011	10/7/2011
Enertech Global, LLC	Roth Industries	TerraStar	RXT072D		Closed Loop Water-to-Air	3.9	20.0	7/23/2012	9/4/2012
Enertech Global, LLC	Roth Industries	TerraStar	RXT072D		Open Loop Water-to-Air	4.5	24.0	7/23/2012	9/4/2012
					Closed Loop Water-to-				
Enertech Global, LLC	TerraStar	TerraStar	RWT036B		Water	3.1	16.8	11/1/2011	9/22/2011
Enortagh Clohal III C	TorroStor	TorroStor	DWT026D		Open Loop Water-to-	3.5	20.5	11/1/2011	0/22/2011
Enertech Global, LLC	TerraStar	TerraStar	RWT036B		Water Closed Loop	3.5	20.5	11/1/2011	9/22/2011
Enertech Global, LLC	TerraStar	TerraStar	RWT048B		Water-to- Water	3.1	17.1	11/1/2011	9/22/2011

				Additional				5	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	TerraStar	TerraStar	RWT048B		Open Loop Water-to- Water	3.6	21.1	11/1/2011	9/22/2011
Elicitedii Global, EEG	renaotai	rendotal	144410405		Closed Loop	0.0	<b>2</b> 1.1	11/1/2011	0/22/2011
Enertech Global, LLC	TerraStar	TerraStar	RWT060B		Water-to- Water	3.1	16.4	9/30/2011	1/16/2013
					Open Loop		-		
Enertech Global, LLC	TerraStar	TerraStar	RWT060B		Water-to- Water	3.6	20.2	9/30/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TCT024C		Closed Loop Water-to-Air	4.4	23.0	4/23/2012	1/16/2013
Enertech Global, LLC	TETCO	ES4	TCT024C		Closed Loop Water-to- Water	4.7	24.0	4/23/2012	2/10/2012
					Open Loop				
Enertech Global, LLC	TETCO	ES4	TCT024C		Water-to-Air	5.2	29.3	4/23/2012	1/16/2013
Enertech Global, LLC	TETCO	ES4	TCT024C		Open Loop Water-to- Water	5.4	30.3	4/23/2012	2/10/2012
Enertech Global, LLC	TETCO	ES4	TCT036A		Closed Loop Water-to-Air	4.5	23.1	6/3/2011	5/20/2011
Enertech Global, LLC	TETCO	ES4	TCT036A		Open Loop Water-to-Air	4.8	27.1	6/3/2011	5/20/2011
Enertech Global, LLC	TETCO	ES4	TCT036C		Closed Loop Water-to-Air	4.4	22.4	4/23/2012	2/10/2012
Enertech Global, LLC	TETCO	ES4	TCT036C		Closed Loop Water-to- Water	4.7	23.0	4/23/2012	2/10/2012
Enertech Global, LLC	TETCO	ES4	TCT036C		Open Loop Water-to-Air	5.3	28.1	4/23/2012	2/10/2012
Enertech Global, LLC	TETCO	ES4	TCT036C		Open Loop Water-to- Water	5.4	28.7	4/23/2012	2/10/2012
Enertech Global, LLC	TETCO	ES4	TCT048A		Closed Loop	4.4	21.5	6/3/2011	5/20/2011
Enertech Global, LLC	TETCO	ES4	TCT048A		Open Loop Water-to-Air	4.9	25.2	6/3/2011	5/20/2011
Enertech Global, LLC	TETCO	ES4	TCT048C		Closed Loop Water-to-Air	4.1	20.8	4/23/2012	2/10/2012
Enertech Global, LLC	TETCO	ES4	TCT048C		Closed Loop Water-to- Water	4.4	22.8	4/23/2012	2/10/2012
Enertech Global, LLC	TETCO	ES4	TCT048C		Open Loop Water-to-Air	4.7	26.0	4/23/2012	2/10/2012
					Open Loop Water-to-				
Enertech Global, LLC	TETCO	ES4	TCT048C		Water Closed Loop	5.1	28.5	4/23/2012	2/10/2012
Enertech Global, LLC	TETCO	ES4	TCT060A		Water-to-Air	4.0	20.2	6/3/2011	5/20/2011
Enertech Global, LLC	TETCO	ES4	TCT060A		Open Loop Water-to-Air	4.5	24.1	6/3/2011	5/20/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	TETCO	ES4	TCT060D		Closed Loop Water-to-Air	3.9	20.9	7/23/2012	9/4/2012
Enertech Global, LLC	TETCO	ES4	TCT060D		Open Loop Water-to-Air	4.6	25.4	7/23/2012	9/4/2012
Enertech Global, LLC	TETCO	ES4	TCT072A		Closed Loop Water-to-Air	3.8	17.7	6/3/2011	5/20/2011
Enertech Global, LLC	TETCO	ES4	TCT072A		Open Loop Water-to-Air	4.3	21.1	6/3/2011	5/20/2011
Enertech Global, LLC	TETCO	ES4	TCT072D		Closed Loop Water-to-Air	3.8	19.0	7/23/2012	9/4/2012
Enertech Global, LLC	TETCO	ES4	TCT072D		Open Loop Water-to-Air	4.4	22.9	7/23/2012	9/4/2012
Enertech Global, LLC	TETCO	ES4	THT024A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	TETCO	ES4	THT024A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	TETCO	ES4	THT036A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	TETCO	ES4	THT036A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	TETCO	ES4	THT048A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	TETCO	ES4	THT048A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	TETCO	ES4	THT060A		Closed Loop Water-to-Air	3.6	17.1	7/25/2011	7/28/2011
Enertech Global, LLC	TETCO	ES4	THT060A		Open Loop Water-to-Air	4.1	21.1	7/25/2011	7/28/2011
Enertech Global, LLC	TETCO	ES4	TRT024A		Closed Loop Water-to-Air	3.7	19.8	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT024A		Closed Loop Water-to-Air	3.7	20.1	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT024A (WITH A-COIL MODEL NUMBER: ACD024)		Closed Loop Water-to-Air	3.8	20.5	4/16/2012	5/4/2012
	T5T00	504	TRT024A (WITH AIR HANDLER MODEL NUMBER:		Closed Loop		20.4	4440/0040	5/4/9949
Enertech Global, LLC	TETCO	ES4	MPD024)		Water-to-Air Closed Loop	3.7	20.1	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT036A		Water-to-Air Closed Loop	4.0	21.0	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT036A		Water-to-Air	4.1	20.2	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT036A (WITH A-COIL MODEL NUMBER: ACD036)		Closed Loop Water-to-Air	4.1	20.5	4/16/2012	5/4/2012

				Additional				D. ( A . ( )   1	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	TETCO	ES4	TRT036A (WITH AIR HANDLER MODEL NUMBER: MPD036)		Closed Loop Water-to-Air	4.1	21.5	4/16/2012	5/4/2012
Ellertech Global, LLC	TETCO	E34	WIPD030)		Closed Loop	4.1	21.5	4/10/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT048A		Water-to-Air	4.1	20.5	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT048A		Closed Loop Water-to-Air	4.2	21.7	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT048A (WITH A-COIL MODEL NUMBER: ACD060)		Closed Loop Water-to-Air	4.1	21.1	4/16/2012	5/4/2012
	T5700	504	TRT048A (WITH AIR HANDLER MODEL NUMBER:		Closed Loop		20.0	4/40/0040	FILIDAG
Enertech Global, LLC	TETCO	ES4	MPD060)		Water-to-Air Closed Loop	4.3	22.2	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT060A		Water-to-Air	3.8	20.2	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT060A		Closed Loop Water-to-Air	3.8	20.7	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT060A (WITH A-COIL MODEL NUMBER: ACD060)		Closed Loop Water-to-Air	3.8	20.5	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT060A (WITH AIR HANDLER MODEL NUMBER: MPD060)		Closed Loop Water-to-Air	3.9	21.0	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT072A (WITH A-COIL MODEL NUMBER: ACD060)		Closed Loop Water-to-Air	3.6	19.0	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TRT072A (WITH AIR HANDLER MODEL NUMBER: MPD072)		Closed Loop Water-to-Air	3.6	19.7	4/16/2012	5/4/2012
Enertech Global, LLC	TETCO	ES4	TST024A		Closed Loop Water-to-Air	3.6	19.1	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST024A		Closed Loop Water-to-Air	3.8	19.6	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST024A		Open Loop Water-to-Air	4.2	23.8	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST024A		Open Loop Water-to-Air	4.4	24.2	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4-X	TST024A (with_A-Coil_model_numb er:ACD024)		Closed Loop Water-to-Air	3.8	19.5	11/1/2011	10/31/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Enertech Global, LLC	TETCO	ES4-X	TST024A (with_A-Coil_model_numb er:ACD024)	momation	Open Loop Water-to-Air	4.4	24.0	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST024A (with_Air Handler_model_n umber:MPD024)		Closed Loop Water-to-Air	3.8	20.0	11/1/2011	10/31/2011
	TETCO	ES4-X	TST024A (with_Air Handler_model_n		Open Loop	4.3	24.6	11/1/2011	10/31/2011
Enertech Global, LLC  Enertech Global, LLC	TETCO	ESIII-X Series	umber:MPD024) TST028(with _A- Coil_model_numb er:ACD024)		Water-to-Air Closed Loop Water-to-Air	3.7	19.7	12/1/2010	1/21/2011
Enertech Global, LLC	ТЕТСО	ESIII-X Series	TST028(with _A- Coil_model_numb er:ACD024)		Open Loop Water-to-Air	4.2	24.1	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST028(with _Air Handler_model_n umber:MPD024)		Closed Loop Water-to-Air	3.7	19.7	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST028(with _Air Handler_model_n umber:MPD024)		Open Loop Water-to-Air	4.2	24.1	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TST036A		Closed Loop Water-to-Air	4.0	19.8	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4	TST036A		Closed Loop Water-to-Air	4.0	20.2	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4	TST036A		Open Loop Water-to-Air	4.6	23.9	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4	TST036A		Open Loop Water-to-Air	4.6	25.4	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST036A (with_A-Coil_model_numb er:ACD036)		Closed Loop Water-to-Air	4.0	20.0	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST036A (with_A-Coil_model_numb er:ACD036)		Open Loop Water-to-Air	4.6	24.7	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST036A (with_Air Handler_model_n umber:MPD036)		Closed Loop Water-to-Air	4.2	20.6	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST036A (with_Air Handler_model_n umber:MPD036)		Open Loop Water-to-Air	4.7	25.8	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST040(with _A- Coil_model_numb er:ACD036)		Closed Loop Water-to-Air	3.6	18.6	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST040(with _A-Coil_model_numb er:ACD036)		Open Loop Water-to-Air	4.2	22.6	12/1/2010	1/21/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	TETCO	ESIII-X Series	TST040(with _Air Handler_model_n umber:MPD036)		Closed Loop Water-to-Air	3.8	19.1	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TST048A		Closed Loop Water-to-Air	4.0	22.6	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST048A		Closed Loop Water-to-Air	4.2	21.7	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST048A		Open Loop Water-to-Air	4.7	27.3	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST048A		Open Loop Water-to-Air	4.8	26.6	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4-X	TST048A (with_A-Coil_model_numb er:ACD060)		Closed Loop Water-to-Air	4.2	21.0	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST048A (with_A-Coil_model_numb er:ACD060)		Open Loop Water-to-Air	4.7	25.8	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST048A (with_Air Handler_model_n umber:MPD060)		Closed Loop Water-to-Air	4.3	23.5	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST048A (with_Air Handler_model_n umber:MPD060)		Open Loop Water-to-Air	4.9	29.2	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST054(with _A-Coil_model_numb er:ACD048)		Closed Loop Water-to-Air	3.6	19.0	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST054(with _A- Coil_model_numb er:ACD048)		Open Loop Water-to-Air	4.1	22.8	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST054(with _Air Handler_model_n umber:MPD048)		Closed Loop Water-to-Air	3.7	19.5	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST054(with _Air Handler_model_n umber:MPD048)		Open Loop Water-to-Air	4.1	22.6	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TST060A		Closed Loop Water-to-Air	3.7	19.7	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST060A		Closed Loop Water-to-Air	3.8	19.7	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST060A		Open Loop Water-to-Air	4.3	23.2	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4	TST060A		Open Loop Water-to-Air	4.3	23.7	11/1/2011	1/16/2013
Enertech Global, LLC	TETCO	ES4-X	TST060A (with_A-Coil_model_numb er:ACD060)		Closed Loop Water-to-Air	3.8	19.1	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST060A (with_A-Coil_model_numb er:ACD060)		Open Loop Water-to-Air	4.3	22.8	11/1/2011	10/31/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number TST060A (with Air	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	TETCO	ES4-X	Handler_model_n umber:MPD060)		Closed Loop Water-to-Air	4.0	21.0	11/1/2011	10/31/2011
			TST060A (with_Air Handler_model_n		Open Loop				
nertech Global, LLC	TETCO	ES4-X	umber:MPD060) TST066(with _A-		Water-to-Air	4.5	25.8	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ESIII-X Series	Coil_model_numb er:ACD060)		Closed Loop Water-to-Air	3.6	18.7	12/1/2010	1/21/2011
nertech Global, LLC	TETCO	ESIII-X Series	TST066(with _A- Coil_model_numb er:ACD060)		Open Loop Water-to-Air	4.1	21.6	12/1/2010	1/21/2011
inertech Global, LLC	TETCO	ESIII-X Series	TST066(with _Air Handler_model_n umber:MPD060)		Closed Loop Water-to-Air	3.7	18.8	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ESIII-X Series	TST066(with _Air Handler_model_n umber:MPD060)		Open Loop Water-to-Air	4.1	21.8	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TST072A		Closed Loop Water-to-Air	3.6	17.9	11/1/2011	10/31/2011
nertech Global, LLC	TETCO	ES4	TST072A		Closed Loop Water-to-Air	3.6	19.0	11/1/2011	10/31/2011
nertech Global, LLC	TETCO	ES4	TST072A		Open Loop Water-to-Air	4.1	21.1	11/1/2011	10/31/2011
nertech Global, LLC	TETCO	ES4	TST072A		Open Loop Water-to-Air	4.1	23.1	11/1/2011	10/31/2011
nertech Global, LLC	TETCO	ES4-X	TST072A (with_A-Coil_model_numb er:ACD060)		Closed Loop Water-to-Air	3.6	17.8	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST072A (with_Air Handler_model_n umber:MPD072)		Closed Loop Water-to-Air	3.7	19.4	11/1/2011	10/31/2011
Enertech Global, LLC	TETCO	ES4-X	TST072A (with_Air Handler_model_n umber:MPD072)		Open Loop Water-to-Air	4.2	23.6	11/1/2011	10/31/2011
inertech Global, LLC	TETCO	TWT 2-Stage W-to-W	TWT060B		Closed Loop Water-to- Water	3.2	17.0	9/30/2011	9/22/2011
nertech Global, LLC	TETCO	TWT 2-Stage W-to-W	TWT060B		Open Loop Water-to- Water	3.7	21.1	9/30/2011	9/22/2011
nertech Global, LLC	TETCO	ES4	TXT024B		Closed Loop Water-to-Air	4.6	24.2	4/7/2011	5/5/2011
nertech Global, LLC	TETCO	ES4	TXT024B		Open Loop Water-to-Air	5.5	31.1	4/7/2011	5/5/2011
nertech Global, LLC	TETCO	ES4	TXT024C		Closed Loop Water-to-Air	4.5	24.4	11/4/2011	9/27/2011
nertech Global, LLC	TETCO	ES4	TXT024C		Open Loop Water-to-Air	5.4	30.5	11/4/2011	9/27/2011

				Additional Model				Date Available	_
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Enertech Global, LLC	TETCO	ES4	TXT036A		Closed Loop Water-to-Air	4.5	23.3	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TXT036A		Open Loop Water-to-Air	4.8	27.1	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TXT036C		Closed Loop Water-to-Air	4.4	22.7	11/4/2011	9/27/2011
Enertech Global, LLC	TETCO	ES4	TXT036C		Open Loop Water-to-Air	5.1	28.1	11/4/2011	9/27/2011
Enertech Global, LLC	TETCO	ES4	TXT048A		Closed Loop Water-to-Air	4.4	21.5	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TXT048A		Open Loop Water-to-Air	4.9	25.2	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TXT048C		Closed Loop Water-to-Air	4.2	20.8	11/4/2011	9/27/2011
Enertech Global, LLC	TETCO	ES4	TXT048C		Open Loop Water-to-Air	4.7	26.1	11/4/2011	9/27/2011
Enertech Global, LLC	TETCO	ES4	TXT060A		Closed Loop Water-to-Air	4.1	20.6	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TXT060A		Open Loop Water-to-Air	4.7	24.1	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TXT060B		Closed Loop Water-to-Air	4.2	20.6	10/5/2011	10/7/2011
Enertech Global, LLC	TETCO	ES4	TXT060B		Open Loop Water-to-Air	4.7	25.1	10/5/2011	10/7/2011
Enertech Global, LLC	TETCO	ES4	TXT060D		Closed Loop Water-to-Air	4.0	21.4	7/23/2012	9/4/2012
Enertech Global, LLC	TETCO	ES4	TXT060D		Open Loop Water-to-Air	4.7	26.1	7/23/2012	9/4/2012
Enertech Global, LLC	TETCO	ES4	TXT072A		Closed Loop Water-to-Air	4.1	18.0	12/1/2010	1/21/2011
Enertech Global, LLC	TETCO	ES4	TXT072B		Closed Loop Water-to-Air	3.9	17.9	10/5/2011	10/7/2011
Enertech Global, LLC	TETCO	ES4	TXT072B		Open Loop Water-to-Air	4.5	22.2	10/5/2011	10/7/2011
Enertech Global, LLC	TETCO	ES4	TXT072D		Closed Loop Water-to-Air	3.9	20.0	7/23/2012	9/4/2012
Enertech Global, LLC	TETCO	ES4	TXT072D		Open Loop Water-to-Air	4.5	24.0	7/23/2012	9/4/2012
FHP Manufacturing Bosch Group	Aquarius	EP007	EP007-1HZ		Closed Loop Water-to-Air	3.6	18.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP007	EP007-1HZ		Open Loop Water-to-Air	4.9	25.1	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP007	EP007-1VT		Closed Loop Water-to-Air	3.6	18.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP007	EP007-1VT		Open Loop Water-to-Air	4.9	25.1	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP009	EP009-1HZ		Closed Loop Water-to-Air	3.6	19.3	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP009	EP009-1HZ		Closed Loop Water-to-Air	3.6	19.3	6/1/2010	2/25/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Aquarius	EP009	EP009-1HZ		Open Loop Water-to-Air	4.5	25.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP009	EP009-1VT		Closed Loop Water-to-Air	3.6	19.3	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP009	EP009-1VT		Closed Loop Water-to-Air	3.6	19.3	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP009	EP009-1VT		Open Loop Water-to-Air	4.5	25.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP012	EP012-1HZ		Closed Loop Water-to-Air	3.6	17.5	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP012	EP012-1HZ		Closed Loop Water-to-Air	3.6	17.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP012	EP012-1HZ		Open Loop Water-to-Air	4.3	22.7	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP012	EP012-1VT		Closed Loop Water-to-Air	3.6	17.5	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP012	EP012-1VT		Closed Loop Water-to-Air	3.6	17.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP012	EP012-1VT		Open Loop Water-to-Air	4.3	22.7	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP015	EP015-1HZ		Closed Loop Water-to-Air	3.9	20.6	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP015	EP015-1HZ		Closed Loop Water-to-Air	3.9	20.6	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP015	EP015-1HZ		Open Loop Water-to-Air	4.6	28.8	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP015	EP015-1VT		Closed Loop Water-to-Air	3.9	20.6	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP015	EP015-1VT		Closed Loop Water-to-Air	3.9	20.6	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP015	EP015-1VT		Open Loop Water-to-Air	4.6	28.8	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP018	EP018-1HZ		Closed Loop Water-to-Air	3.8	19.0	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP018	EP018-1HZ		Closed Loop Water-to-Air	3.8	19.0	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP018	EP018-1HZ		Open Loop Water-to-Air	4.5	25.6	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP018	EP018-1VT		Closed Loop Water-to-Air	3.8	19.0	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP018	EP018-1VT		Closed Loop Water-to-Air	3.8	19.0	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP018	EP018-1VT		Open Loop Water-to-Air	4.5	25.6	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	·	EP018	EP018-1V1		Closed Loop Water-to-Air	4.0	21.1	6/1/2010	2/10/2011
<u> </u>	Aquarius				Closed Loop				
FHP Manufacturing Bosch Group	Aquarius	EP024	EP024-1HZ		Water-to-Air Open Loop	4.0	21.1	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP024	EP024-1HZ		Water-to-Air	4.6	28.1	6/1/2010	2/25/2011

				Additional				Data Assailable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Aquarius	EP024	EP024-1VT		Closed Loop Water-to-Air	4.0	21.1	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP024	EP024-1VT		Closed Loop Water-to-Air	4.0	21.1	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP024	EP024-1VT		Open Loop Water-to-Air	4.6	28.1	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP030	EP030-1HZ		Closed Loop Water-to-Air	4.3	19.4	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP030	EP030-1HZ		Closed Loop Water-to-Air	4.3	19.4	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP030	EP030-1HZ		Open Loop Water-to-Air	5.2	27.0	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP030	EP030-1VT		Closed Loop Water-to-Air	4.3	19.4	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP030	EP030-1VT		Closed Loop Water-to-Air	4.3	19.4	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP030	EP030-1VT		Open Loop Water-to-Air	5.2	27.0	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP036	EP036-1HZ		Closed Loop Water-to-Air	4.1	19.7	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP036	EP036-1HZ		Closed Loop Water-to-Air	4.1	19.7	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP036	EP036-1HZ		Open Loop Water-to-Air	4.9	25.9	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP036	EP036-1VT		Closed Loop Water-to-Air	4.1	19.7	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP036	EP036-1VT		Closed Loop Water-to-Air	4.1	19.7	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP036	EP036-1VT		Open Loop Water-to-Air	4.9	25.9	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP042	EP042-1HZ		Closed Loop Water-to-Air	4.1	21.2	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP042	EP042-1HZ		Closed Loop Water-to-Air	4.1	21.2	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP042	EP042-1HZ		Open Loop Water-to-Air	4.4	25.7	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP042	EP042-1VT		Closed Loop Water-to-Air	4.1	21.2	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP042	EP042-1VT		Closed Loop Water-to-Air	4.1	21.2	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP042	EP042-1VT		Open Loop Water-to-Air	4.4	25.7	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP048	EP048-1HZ		Closed Loop Water-to-Air	3.7	19.8	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP048	EP048-1HZ		Closed Loop	3.7	19.8	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP048	EP048-1HZ		Open Loop Water-to-Air	4.3	25.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP048	EP048-1VT		Closed Loop	3.7	19.8	6/1/2010	2/10/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Aquarius	EP048	EP048-1VT		Closed Loop Water-to-Air	3.7	19.8	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP048	EP048-1VT		Open Loop Water-to-Air	4.3	25.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP060	EP060-1HZ		Closed Loop Water-to-Air	4.3	19.5	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP060	EP060-1HZ		Closed Loop Water-to-Air	4.3	19.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP060	EP060-1HZ		Open Loop Water-to-Air	4.9	24.4	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP060	EP060-1VT		Closed Loop Water-to-Air	4.3	19.5	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP060	EP060-1VT		Closed Loop Water-to-Air	4.3	19.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP060	EP060-1VT		Open Loop Water-to-Air	4.9	24.4	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP070	EP070-1HZ		Closed Loop Water-to-Air	4.2	18.5	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP070	EP070-1HZ		Closed Loop Water-to-Air	4.2	18.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP070	EP070-1HZ		Open Loop Water-to-Air	5.0	22.4	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP070	EP070-1VT		Closed Loop Water-to-Air	4.2	18.5	6/1/2010	2/10/2011
FHP Manufacturing Bosch Group	Aquarius	EP070	EP070-1VT		Closed Loop Water-to-Air	4.2	18.5	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius	EP070	EP070-1VT		Open Loop Water-to-Air	5.0	22.4	6/1/2010	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP025	AP025-1CF		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	2/10/2011
<u> </u>	Aquarius II				Closed Loop				
FHP Manufacturing Bosch Group	Premier Aquarius II	AP025	AP025-1CF		Water-to-Air Open Loop	4.4	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II	AP025	AP025-1CF		Water-to-Air Open Loop	5.1	28.8	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Premier Aquarius II	AP025	AP025-1CF		Water-to-Air Closed Loop	5.1	28.8	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Premier Aquarius II	AP025	AP025-1HZ		Water-to-Air Closed Loop	4.4	23.5	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Premier Aquarius II	AP025	AP025-1HZ		Water-to-Air Open Loop	4.4	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Premier Aquarius II	AP025	AP025-1HZ		Water-to-Air Open Loop	5.1	28.8	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Premier Aquarius II	AP025	AP025-1HZ		Water-to-Air Closed Loop	5.1	28.8	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Premier	AP025	AP025-1VT		Water-to-Air	4.4	23.5	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP025	AP025-1VT		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP025	AP025-1VT		Open Loop Water-to-Air	5.1	28.8	1/7/2009	2/10/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Aquarius II Premier	AP025	AP025-1VT		Open Loop Water-to-Air	5.1	28.8	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1CF		Closed Loop Water-to-Air	4.5	23.5	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1CF		Closed Loop Water-to-Air	4.5	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1CF		Open Loop Water-to-Air	5.0	28.8	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1CF		Open Loop Water-to-Air	5.0	28.8	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1HZ		Closed Loop Water-to-Air	4.5	23.5	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1HZ		Closed Loop Water-to-Air	4.5	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1HZ		Open Loop Water-to-Air	5.0	28.8	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1HZ		Open Loop Water-to-Air	5.0	28.8	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1VT		Closed Loop Water-to-Air	4.5	23.5	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1VT		Closed Loop Water-to-Air	4.5	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1VT		Open Loop Water-to-Air	5.0	28.8	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP035	AP035-1VT		Open Loop Water-to-Air	5.0	28.8	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP049	AP049-1CF		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP049	AP049-1CF		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP049	AP049-1CF		Open Loop Water-to-Air	4.9	28.3	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP049	AP049-1CF		Open Loop Water-to-Air	4.9	28.3	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP049	AP049-1HZ		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP049	AP049-1HZ		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP049	AP049-1HZ		Open Loop Water-to-Air		28.3	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II				Open Loop Water-to-Air	4.9			
	Premier Aquarius II	AP049	AP049-1HZ		Closed Loop	4.9	28.3	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Premier Aquarius II	AP049	AP049-1VT		Water-to-Air Closed Loop	4.4	23.5	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Premier Aquarius II	AP049	AP049-1VT		Water-to-Air Open Loop	4.4	23.5	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Premier Aquarius II	AP049	AP049-1VT		Water-to-Air Open Loop	4.9	28.3	1/7/2009	2/10/2011
HP Manufacturing Bosch Group	Premier	AP049	AP049-1VT		Water-to-Air	4.9	28.3	1/7/2009	2/25/2011

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
HP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1CF		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1CF		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1CF		Open Loop Water-to-Air	5.1	28.4	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1CF		Open Loop Water-to-Air	5.1	28.4	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1HZ		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1HZ		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1HZ		Open Loop Water-to-Air	5.1	28.4	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1HZ		Open Loop Water-to-Air	5.1	28.4	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1VT		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1VT		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1VT		Open Loop Water-to-Air	5.1	28.4	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP061	AP061-1VT		Open Loop Water-to-Air	5.1	28.4	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1CF		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1CF		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1CF		Open Loop Water-to-Air	4.7	25.3	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1CF		Open Loop Water-to-Air	4.7	25.3	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1HZ		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1HZ		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1HZ		Open Loop Water-to-Air	4.7	25.3	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1HZ		Open Loop Water-to-Air	4.7	25.3	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1VT		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1VT		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1VT		Open Loop Water-to-Air	4.7	25.3	1/7/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	AP071	AP071-1VT		Open Loop Water-to-Air	4.7	25.3	1/7/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT025	WT025-1		Closed Loop Water-to- Water	3.1	19.0	1/1/2009	2/25/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
					Open Loop	<b>J</b>	3		
FHP Manufacturing Bosch Group	Aquarius II Premier	WT025	WT025-1		Water-to- Water	3.6	23.5	1/1/2009	2/25/2011
FUD Magnifesturing Death Craus	Aquarius II	WTOOF	WT00F 4		Closed Loop Water-to-	2.4	47.0	4/4/2000	2/25/2044
FHP Manufacturing Bosch Group	Premier	WT035	WT035-1		Water Open Loop	3.1	17.6	1/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT035	WT035-1		Water-to- Water	3.6	22.5	1/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT049	WT049-1		Closed Loop Water-to- Water	3.1	17.5	1/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT049	WT049-1		Closed Loop Water-to- Water	3.1	17.5	1/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II				Open Loop Water-to-				
-ne Manufacturing Bosch Group	Premier	WT049	WT049-1		Water Open Loop	3.6	21.7	1/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT049	WT049-1		Water-to- Water	3.6	21.7	1/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT061	WT061-1		Closed Loop Water-to- Water	3.2	17.3	1/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT061	WT061-1		Open Loop Water-to- Water	3.6	21.6	1/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT071	WT071-1		Closed Loop Water-to- Water	3.1	16.8	1/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier	WT071	WT071-1		Open Loop Water-to- Water	3.5	20.3	1/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP025	AP025-1CS		Closed Loop Water-to-Air	4.3	23.4	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP025	AP025-1CS		Closed Loop Water-to-Air	4.3	23.4	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP025	AP025-1CS		Open Loop Water-to-Air	5.1	28.7	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP025	AP025-1CS		Open Loop Water-to-Air	5.1	28.7	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP035	AP035-1CS		Closed Loop Water-to-Air	4.4	23.5	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP035	AP035-1CS		Closed Loop Water-to-Air	4.4	23.5	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP035	AP035-1CS		Open Loop Water-to-Air	4.9	28.5	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP035	AP035-1CS		Open Loop Water-to-Air	4.9	28.5	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP049	AP049-1CS		Closed Loop Water-to-Air	4.3	23.4	6/1/2009	2/10/2011

				Additional				Doto Aveilable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP049	AP049-1CS		Closed Loop Water-to-Air	4.3	23.4	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP049	AP049-1CS		Open Loop Water-to-Air	4.8	28.2	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP049	AP049-1CS		Open Loop Water-to-Air	4.8	28.2	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP061	AP061-1CS		Closed Loop Water-to-Air	4.3	23.0	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP061	AP061-1CS		Closed Loop Water-to-Air	4.3	23.0	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP061	AP061-1CS		Open Loop Water-to-Air	5.0	28.3	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP061	AP061-1CS		Open Loop Water-to-Air	5.1	28.2	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP071	AP071-1CS		Closed Loop Water-to-Air	3.9	21.5	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP071	AP071-1CS		Closed Loop Water-to-Air	3.9	21.5	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP071	AP071-1CS		Open Loop Water-to-Air	4.6	25.2	6/1/2009	2/10/2011
FHP Manufacturing Bosch Group	Aquarius II Premier Split	AP071	AP071-1CS		Open Loop Water-to-Air	4.6	25.2	6/1/2009	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP007	BP007-1HZ		Closed Loop Water-to-Air	3.6	18.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP007	BP007-1HZ		Open Loop Water-to-Air	4.9	25.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP007	BP007-1VT		Closed Loop Water-to-Air	3.6	18.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP007	BP007-1VT		Open Loop Water-to-Air	4.9	25.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP009	BP009-1HZ		Closed Loop Water-to-Air	3.6	19.3	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP009	BP009-1HZ		Open Loop	4.5	25.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP009	BP009-1VT		Closed Loop Water-to-Air	3.6	19.3	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP009	BP009-1VT		Open Loop Water-to-Air	4.5	25.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP012	BP012-1HZ		Closed Loop Water-to-Air	3.6	17.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP012	BP012-1HZ		Open Loop Water-to-Air	4.3	22.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP012	BP012-1VT		Closed Loop Water-to-Air	3.6	17.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP012	BP012-1VT		Open Loop Water-to-Air	4.3	22.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP015	BP015-1HZ		Closed Loop Water-to-Air	3.9	20.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP015	BP015-1HZ		Open Loop Water-to-Air	4.6	28.8	2/20/2011	2/25/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
FHP Manufacturing Bosch Group	Bosch-Geo	BP015	BP015-1VT		Closed Loop Water-to-Air	3.9	20.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP015	BP015-1VT		Open Loop Water-to-Air	4.6	28.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP018	BP018-1HZ		Closed Loop Water-to-Air	3.8	19.0	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP018	BP018-1HZ		Open Loop Water-to-Air	4.5	25.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP018	BP018-1VT		Closed Loop Water-to-Air	3.8	19.0	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP018	BP018-1VT		Open Loop Water-to-Air	4.5	25.6	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP024	BP024-1HZ		Closed Loop Water-to-Air	4.0	21.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP024	BP024-1HZ		Open Loop Water-to-Air	4.6	28.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP024	BP024-1VT		Closed Loop Water-to-Air	4.0	21.1	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP024	BP024-1VT		Open Loop Water-to-Air	4.6	28.1	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP030	BP030-1HZ		Closed Loop Water-to-Air	4.3	19.4	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP030	BP030-1HZ		Open Loop Water-to-Air	5.2	27.0	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP030	BP030-1VT		Closed Loop Water-to-Air	4.3	19.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP030	BP030-1VT		Open Loop Water-to-Air	5.2	27.0	2/20/2011	2/25/2011
THP Manufacturing Bosch Group	Bosch-Geo	BP036	BP036-1HZ		Closed Loop Water-to-Air	4.1	19.7	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP036	BP036-1HZ		Open Loop Water-to-Air	4.9	25.9	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP036	BP036-1VT		Closed Loop Water-to-Air	4.1	19.7	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP036	BP036-1VT		Open Loop Water-to-Air	4.9	25.9	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP042	BP042-1HZ		Closed Loop Water-to-Air	4.1	21.2	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP042	BP042-1HZ		Open Loop Water-to-Air	4.4	25.7	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP042	BP042-1VT		Closed Loop Water-to-Air	4.1	21.2	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP042	BP042-1VT		Open Loop Water-to-Air	4.4	25.7	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP048	BP048-1HZ		Closed Loop Water-to-Air	3.7	19.8	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP048	BP048-1HZ		Open Loop Water-to-Air	4.3	25.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP048	BP048-1VT		Closed Loop Water-to-Air	3.7	19.8	2/20/2011	2/25/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
HP Manufacturing Bosch Group	Bosch-Geo	BP048	BP048-1VT		Open Loop Water-to-Air	4.3	25.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP060	BP060-1HZ		Closed Loop Water-to-Air	4.3	19.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP060	BP060-1HZ		Open Loop Water-to-Air	4.9	24.4	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP060	BP060-1VT		Closed Loop Water-to-Air	4.3	19.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP060	BP060-1VT		Open Loop Water-to-Air	4.9	24.4	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP070	BP070-1HZ		Closed Loop Water-to-Air	4.2	18.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	BP070	BP070-1HZ		Open Loop Water-to-Air	5.0	22.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP070	BP070-1VT		Closed Loop Water-to-Air	4.2	18.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	BP070	BP070-1VT		Open Loop Water-to-Air	5.0	22.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1CF		Closed Loop Water-to-Air	3.9	21.6	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1CF		Open Loop Water-to-Air	4.6	27.0	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1CS		Closed Loop Water-to-Air	3.8	21.2	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1CS		Open Loop Water-to-Air	4.5	26.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1CS (with DX025)		Closed Loop Water-to-Air	4.3	21.4	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1CS (with DX025)		Open Loop Water-to-Air	4.8	26.9	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1HZ		Closed Loop Water-to-Air	3.9	21.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1HZ		Open Loop Water-to-Air	4.6	27.0	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1VT		Closed Loop Water-to-Air	3.9	21.6	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE025	CE025-1VT		Open Loop Water-to-Air	4.6	27.0	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1CF		Closed Loop Water-to-Air	3.9	20.9	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1CF		Open Loop Water-to-Air	4.4	24.8	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1CS		Closed Loop Water-to-Air	3.8	20.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1CS		Open Loop Water-to-Air	4.3	24.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1CS (with DX035)		Closed Loop Water-to-Air	4.0	20.2	11/11/2011	11/29/2011
HP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1CS (with DX035)		Open Loop Water-to-Air	4.4	25.4	11/11/2011	11/29/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1HZ		Closed Loop Water-to-Air	3.9	20.9	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1HZ		Open Loop Water-to-Air	4.4	24.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1VT		Closed Loop Water-to-Air	3.9	20.9	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE035	CE035-1VT		Open Loop Water-to-Air	4.4	24.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1CF		Closed Loop Water-to-Air	3.8	18.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1CF		Open Loop Water-to-Air	4.4	21.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1CS		Closed Loop Water-to-Air	3.7	18.3	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1CS		Open Loop Water-to-Air	4.3	21.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1CS (with DX049)		Closed Loop Water-to-Air	3.8	18.2	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1CS (with DX049)		Open Loop Water-to-Air	4.3	22.4	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1HZ		Closed Loop Water-to-Air	3.8	18.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1HZ		Open Loop Water-to-Air	4.4	21.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1VT		Closed Loop Water-to-Air	3.8	18.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE049	CE049-1VT		Open Loop Water-to-Air	4.4	21.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1CF		Closed Loop Water-to-Air	3.8	19.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1CF		Open Loop Water-to-Air	4.5	22.9	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1CS		Closed Loop Water-to-Air	3.7	19.2	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1CS		Open Loop Water-to-Air	4.4	22.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1CS (with DX061)		Closed Loop Water-to-Air	3.9	19.5	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1CS (with DX061)		Open Loop Water-to-Air	4.3	24.4	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1HZ		Closed Loop Water-to-Air	3.8	19.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1HZ		Open Loop Water-to-Air	4.5	22.9	2/20/2011	2/25/2011
					Closed Loop				
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1VT		Water-to-Air Open Loop	3.8	19.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE061	CE061-1VT		Water-to-Air Closed Loop	4.5	22.9	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE071	CE071-1CF		Water-to-Air	3.6	19.1	2/20/2011	2/25/2011

				Additional				Doto Aveilable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Bosch-Geo	CE071	CE071-1CF		Open Loop Water-to-Air	4.1	22.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE071	CE071-1CS		Open Loop Water-to-Air	4.1	22.0	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE071	CE071-1CS (with CE071-1AH/AV)		Closed Loop Water-to-Air	3.6	18.7	2/20/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE071	CE071-1HZ		Closed Loop Water-to-Air	3.6	19.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE071	CE071-1HZ		Open Loop Water-to-Air	4.1	22.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE071	CE071-1VT		Closed Loop Water-to-Air	3.6	19.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CE071	CE071-1VT		Open Loop Water-to-Air	4.1	22.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP024	CP024-1HZ		Closed Loop Water-to-Air	4.0	21.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP024	CP024-1HZ		Open Loop Water-to-Air	4.6	28.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP024	CP024-1VT		Closed Loop Water-to-Air	4.0	21.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP024	CP024-1VT		Open Loop Water-to-Air	4.6	28.1	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP030	CP030-1HZ		Closed Loop Water-to-Air	4.3	19.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP030	CP030-1HZ		Open Loop Water-to-Air	5.2	27.0	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP030	CP030-1VT		Closed Loop Water-to-Air	4.3	19.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP030	CP030-1VT		Open Loop Water-to-Air	5.2	27.0	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP036	CP036-1HZ		Closed Loop Water-to-Air	4.1	19.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP036	CP036-1HZ		Open Loop Water-to-Air	4.9	25.9	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP036	CP036-1VT		Closed Loop Water-to-Air	4.1	19.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP036	CP036-1VT		Open Loop Water-to-Air	4.9	25.9	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP042	CP042-1HZ		Closed Loop Water-to-Air	4.1	21.2	2/20/2011	2/25/2011
					Open Loop Water-to-Air				
FHP Manufacturing Bosch Group	Bosch-Geo	CP042	CP042-1HZ		Closed Loop	4.4	25.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP042	CP042-1VT		Water-to-Air Open Loop	4.1	21.2	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP042	CP042-1VT		Water-to-Air Closed Loop	4.4	25.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP048	CP048-1HZ		Water-to-Air Open Loop	3.7	19.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP048	CP048-1HZ		Water-to-Air	4.3	25.5	2/20/2011	2/25/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Bosch-Geo	CP048	CP048-1VT		Closed Loop Water-to-Air	3.7	19.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP048	CP048-1VT		Open Loop Water-to-Air	4.3	25.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP060	CP060-1HZ		Closed Loop Water-to-Air	4.3	19.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP060	CP060-1HZ		Open Loop Water-to-Air	4.9	24.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP060	CP060-1VT		Closed Loop Water-to-Air	4.3	19.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP060	CP060-1VT		Open Loop Water-to-Air	4.9	24.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP070	CP070-1HZ		Closed Loop Water-to-Air	4.2	18.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP070	CP070-1HZ		Open Loop Water-to-Air	5.0	22.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP070	CP070-1VT		Closed Loop Water-to-Air	4.2	18.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	CP070	CP070-1VT		Open Loop Water-to-Air	5.0	22.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1CF		Closed Loop Water-to-Air	4.4	23.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1CF		Open Loop Water-to-Air	5.2	28.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1CS		Closed Loop Water-to-Air	4.3	23.4	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1CS		Open Loop Water-to-Air	5.1	28.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1CS (with DX025)		Closed Loop Water-to-Air	4.0	20.6	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1CS (with DX025)		Open Loop Water-to-Air	4.5	24.7	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1HZ		Closed Loop Water-to-Air	4.4	23.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1HZ		Open Loop Water-to-Air	5.2	28.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1VT		Closed Loop Water-to-Air	4.4	23.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA025	TA025-1VT		Open Loop Water-to-Air	5.2	28.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1CF		Closed Loop Water-to-Air	4.5	23.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1CF		Open Loop Water-to-Air	5.0	28.8	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1CS		Closed Loop Water-to-Air	4.4	23.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1CS		Open Loop Water-to-Air	4.9	28.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1CS (with DX035)		Closed Loop Water-to-Air	3.9	23.0	11/11/2011	11/29/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
HP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1CS (with DX035)		Open Loop Water-to-Air	4.7	27.8	11/11/2011	11/29/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1HZ		Closed Loop Water-to-Air	4.5	23.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1HZ		Open Loop Water-to-Air	5.0	28.8	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1VT		Closed Loop Water-to-Air	4.5	23.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA035	TA035-1VT		Open Loop Water-to-Air	5.0	28.8	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1CF		Closed Loop Water-to-Air	4.4	23.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1CF		Open Loop Water-to-Air	4.9	28.3	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1CS		Closed Loop Water-to-Air	4.3	23.4	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1CS		Open Loop Water-to-Air	4.8	28.2	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1CS (with DX049)		Closed Loop Water-to-Air	4.4	23.5	11/11/2011	11/29/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1CS (with DX049)		Open Loop Water-to-Air	4.8	28.7	11/11/2011	11/29/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1HZ		Closed Loop Water-to-Air	4.4	23.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1HZ		Open Loop Water-to-Air	4.9	28.3	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1VT		Closed Loop Water-to-Air	4.4	23.5	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA049	TA049-1VT		Open Loop Water-to-Air	4.9	28.3	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1CF		Closed Loop Water-to-Air	4.4	23.1	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1CF		Open Loop Water-to-Air	5.1	28.4	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1CS		Closed Loop Water-to-Air	4.3	23.0	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1CS		Open Loop Water-to-Air	5.0	28.3	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1CS (with DX061)		Closed Loop Water-to-Air	4.0	20.4	11/11/2011	11/29/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1CS (with DX061)		Open Loop Water-to-Air	4.5	24.3	11/11/2011	11/29/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1HZ		Closed Loop Water-to-Air	4.4	23.1	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1HZ		Open Loop Water-to-Air	5.1	28.4	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1VT		Closed Loop Water-to-Air	4.4	23.1	2/20/2011	2/25/2011
HP Manufacturing Bosch Group	Bosch-Geo	TA061	TA061-1VT		Open Loop Water-to-Air	5.1	28.4	2/20/2011	2/25/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1CF		Closed Loop Water-to-Air	4.0	21.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1CF		Open Loop Water-to-Air	4.6	25.3	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1CS		Closed Loop Water-to-Air	3.9	21.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1CS		Open Loop Water-to-Air	4.6	25.2	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1CS (with DX071)		Closed Loop Water-to-Air	3.7	17.8	11/11/2011	11/29/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1HZ		Closed Loop Water-to-Air	4.0	21.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1HZ		Open Loop Water-to-Air	4.6	25.3	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1VT		Closed Loop Water-to-Air	4.0	21.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TA071	TA071-1VT		Open Loop Water-to-Air	4.6	25.3	2/20/2011	2/25/2011
EUD Manufacturing People Croup	Panch Coo	TW025	TM025 1		Closed Loop Water-to-	2.1	10.0	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	1 00025	TW025-1		Water Open Loop	3.1	19.0	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TW025	TW025-1		Water-to- Water	3.6	23.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TW035	TW035-1		Closed Loop Water-to- Water	3.1	17.6	2/20/2011	2/25/2011
Trii Maridiacturing Bosch Group	DOSCII-GEO	10000	1 0000-1		Open Loop	5.1	17.0	2/20/2011	2/23/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TW035	TW035-1		Water-to- Water	3.6	22.5	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TW049	TW049-1		Closed Loop Water-to- Water	3.1	17.5	2/20/2011	2/25/2011
					Open Loop Water-to-				
FHP Manufacturing Bosch Group	Bosch-Geo	TW049	TW049-1		Water Closed Loop	3.6	21.7	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TW061	TW061-1		Water-to- Water	3.2	17.3	2/20/2011	2/25/2011
EUD Manufacturing Booch Croup	Danch Can	TW064	TW064_4		Open Loop Water-to-	2.6	24.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TW061	TW061-1		Water Closed Loop	3.6	21.6	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TW071	TW071-1		Water-to- Water	3.1	16.8	2/20/2011	2/25/2011
EUD M f	D	TIMOT	TIMOTA		Open Loop Water-to-	0.5	00.0	0/00/2014	0/05/0044
FHP Manufacturing Bosch Group	Bosch-Geo	TW071	TW071-1		Water Closed Loop	3.5	20.3	2/20/2011	2/25/2011
FHP Manufacturing Bosch Group	Bosch-Geo	TW122	TW122-1CS/US		Water-to- Water	3.1	16.4	2/15/2012	2/10/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
FHP Manufacturing Bosch Group	Bosch-Geo	TW122	TW122-1CS/US		Open Loop Water-to- Water	3.6	20.2	2/15/2012	2/10/2012
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM024-1CF/VT/ HZ		Closed Loop Water-to-Air	4.2	24.0	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM024-1CF/VT/ HZ		Open Loop Water-to-Air	5.0	30.0	1/7/2013	1/22/2013
HP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM036-1CF/VT/ HZ		Closed Loop Water-to-Air	4.5	27.0	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM036-1CF/VT/ HZ		Open Loop Water-to-Air	5.1	32.5	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM048-1CF/VT/ HZ		Closed Loop Water-to-Air	4.2	23.5	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM048-1CF/VT/ HZ		Open Loop Water-to-Air	4.9	29.5	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM060-1CF/VT/ HZ		Closed Loop Water-to-Air	4.1	22.7	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM060-1CF/VT/ HZ		Open Loop Water-to-Air	4.7	27.8	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM070-1CF/VT/ HZ		Closed Loop Water-to-Air	4.0	21.9	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	BOSCH Geo	Green Source	SM070-1CF/VT/ HZ		Open Loop Water-to-Air	4.6	25.8	1/7/2013	1/22/2013
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1CF		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1CF		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1CF		Open Loop Water-to-Air	4.5	25.1	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1CF		Open Loop Water-to-Air	4.5	25.1	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1HZ		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1HZ		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1HZ		Open Loop Water-to-Air	4.5	25.1	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1HZ		Open Loop Water-to-Air	4.5	25.1	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1VT		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1VT		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1VT		Open Loop Water-to-Air	4.5	25.1	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES018	ES018-1VT		Open Loop Water-to-Air	4.5	25.1	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES024	ES024-1CF		Open Loop Water-to-Air	4.1	21.1	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES024	ES024-1CF		Open Loop Water-to-Air	4.1	21.1	1/1/2003	2/25/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
HP Manufacturing Bosch Group	Enviro-Saver	ES024	ES024-1HZ		Open Loop Water-to-Air	4.1	21.1	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES024	ES024-1HZ		Open Loop Water-to-Air	4.1	21.1	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES024	ES024-1VT		Open Loop Water-to-Air	4.1	21.1	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES024	ES024-1VT		Open Loop Water-to-Air	4.1	21.1	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1CF		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1CF		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1CF		Open Loop Water-to-Air	4.6	27.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1CF		Open Loop Water-to-Air	4.6	27.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1HZ		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1HZ		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1HZ		Open Loop Water-to-Air	4.6	27.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1HZ		Open Loop Water-to-Air	4.6	27.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1VT		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1VT		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1VT		Open Loop Water-to-Air	4.6	27.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES025	ES025-1VT		Open Loop Water-to-Air	4.6	27.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1CF		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1CF		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1CF		Open Loop Water-to-Air	4.6	23.4	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1CF		Open Loop Water-to-Air	4.6	23.4	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1HZ		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1HZ		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1HZ		Open Loop Water-to-Air	4.6	23.4	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1HZ		Open Loop Water-to-Air	4.6	23.4	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1VT		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	2/10/2011

				Additional				Data A il II	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1VT		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1VT		Open Loop Water-to-Air	4.6	23.4	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES030	ES030-1VT		Open Loop Water-to-Air	4.6	23.4	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1CF		Closed Loop Water-to-Air	3.9	20.9	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1CF		Closed Loop Water-to-Air	3.9	20.9	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1CF		Open Loop Water-to-Air	4.4	24.8	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1CF		Open Loop Water-to-Air	4.4	24.8	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1HZ		Closed Loop Water-to-Air	3.9	20.9	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1HZ		Closed Loop Water-to-Air	3.9	20.9	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1HZ		Open Loop Water-to-Air	4.4	24.8	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1HZ		Open Loop Water-to-Air	4.4	24.8	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1VT		Closed Loop Water-to-Air	3.9	20.9	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1VT		Closed Loop Water-to-Air	3.9	20.9	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1VT		Open Loop Water-to-Air	4.4	24.8	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES035	ES035-1VT		Open Loop Water-to-Air	4.4	24.8	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1CF		Closed Loop Water-to-Air	3.8	17.6	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1CF		Closed Loop Water-to-Air	3.8	17.6	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1CF		Open Loop Water-to-Air	4.6	22.8	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1CF		Open Loop Water-to-Air	4.6	22.8	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1HZ		Closed Loop Water-to-Air	3.8	17.6	1/1/2003	2/10/2011
	Enviro-Saver				Closed Loop				
FHP Manufacturing Bosch Group		ES036	ES036-1HZ		Water-to-Air Open Loop	3.8	17.6	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1HZ		Water-to-Air Open Loop	4.6	22.8	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1HZ		Water-to-Air Closed Loop	4.6	22.8	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1VT		Water-to-Air Closed Loop	3.8	17.6	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1VT		Water-to-Air	3.8	17.6	1/1/2003	2/25/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
HP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1VT		Open Loop Water-to-Air	4.6	22.8	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES036	ES036-1VT		Open Loop Water-to-Air	4.6	22.8	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES042	ES042-1CF		Open Loop Water-to-Air	4.2	22.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES042	ES042-1CF		Open Loop Water-to-Air	4.2	22.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES042	ES042-1HZ		Open Loop Water-to-Air	4.2	22.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES042	ES042-1HZ		Open Loop Water-to-Air	4.2	22.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES042	ES042-1VT		Open Loop Water-to-Air	4.2	22.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES042	ES042-1VT		Open Loop Water-to-Air	4.2	22.0	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES048	ES048-1CF		Open Loop Water-to-Air	4.4	22.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES048	ES048-1CF		Open Loop Water-to-Air	4.4	22.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES048	ES048-1HZ		Open Loop Water-to-Air	4.4	22.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES048	ES048-1HZ		Open Loop Water-to-Air	4.4	22.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES048	ES048-1VT		Open Loop Water-to-Air	4.4	22.0	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES048	ES048-1VT		Open Loop Water-to-Air	4.4	22.0	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1CF		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1CF		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1CF		Open Loop Water-to-Air	4.4	21.5	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1CF		Open Loop Water-to-Air	4.4	21.5	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1HZ		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1HZ		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1HZ		Open Loop Water-to-Air	4.4	21.5	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1HZ		Open Loop Water-to-Air	4.4	21.5	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1VT		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1VT		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1VT		Open Loop Water-to-Air	4.4	21.5	1/1/2003	2/10/2011

				Additional				B. ( . A !!)	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
FHP Manufacturing Bosch Group	Enviro-Saver	ES049	ES049-1VT		Open Loop Water-to-Air	4.4	21.5	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1CF		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1CF		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1CF		Open Loop Water-to-Air	4.5	22.9	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1CF		Open Loop Water-to-Air	4.5	22.9	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1HZ		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1HZ		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1HZ		Open Loop Water-to-Air	4.5	22.9	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1HZ		Open Loop Water-to-Air	4.5	22.9	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1VT		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1VT		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1VT		Open Loop Water-to-Air	4.5	22.9	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES061	ES061-1VT		Open Loop Water-to-Air	4.5	22.9	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES071	ES071-1CF		Open Loop Water-to-Air	4.1	22.4	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES071	ES071-1CF		Open Loop Water-to-Air	4.1	22.4	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES071	ES071-1HZ		Open Loop Water-to-Air	4.1	22.4	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES071	ES071-1HZ		Open Loop Water-to-Air	4.1	22.4	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES071	ES071-1VT		Open Loop Water-to-Air	4.1	22.4	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver	ES071	ES071-1VT		Open Loop Water-to-Air	4.1	22.4	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver Split	ES018	ES018-1CS		Closed Loop Water-to-Air	3.7	18.4	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver Split	ES018	ES018-1CS		Closed Loop Water-to-Air	3.7	18.4	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver Split	ES018	ES018-1CS		Open Loop Water-to-Air	4.5	24.8	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver Split	ES018	ES018-1CS		Open Loop Water-to-Air	4.5	24.8	1/1/2003	2/25/2011
FHP Manufacturing Bosch Group	Enviro-Saver Split	ES025	ES025-1CS		Closed Loop Water-to-Air	3.8	21.2	1/1/2003	2/10/2011
FHP Manufacturing Bosch Group	Enviro-Saver Split	ES025	ES025-1CS		Closed Loop Water-to-Air	3.8	21.2	1/1/2003	2/25/2011

				Additional Model				Date Available	
NERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
HP Manufacturing Bosch Group	Enviro-Saver Split	ES025	ES025-1CS		Open Loop Water-to-Air	4.5	26.5	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES025	ES025-1CS		Open Loop Water-to-Air	4.5	26.5	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES030	ES030-1CS		Closed Loop Water-to-Air	3.8	17.8	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES030	ES030-1CS		Closed Loop Water-to-Air	3.8	17.8	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES030	ES030-1CS		Open Loop Water-to-Air	4.6	23.2	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES030	ES030-1CS		Open Loop Water-to-Air	4.6	23.2	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES035	ES035-1CS		Closed Loop Water-to-Air	3.8	20.5	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES035	ES035-1CS		Closed Loop Water-to-Air	3.8	20.5	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES035	ES035-1CS		Open Loop Water-to-Air	4.3	24.8	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES035	ES035-1CS		Open Loop Water-to-Air	4.3	24.8	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES036	ES036-1CS		Closed Loop Water-to-Air	3.8	17.4	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES036	ES036-1CS		Closed Loop Water-to-Air	3.8	17.4	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES036	ES036-1CS		Open Loop Water-to-Air	4.6	22.6	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES036	ES036-1CS		Open Loop Water-to-Air	4.6	22.6	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES042	ES042-1CS		Open Loop Water-to-Air	4.2	21.8	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES042	ES042-1CS		Open Loop Water-to-Air	4.2	21.8	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES048	ES048-1CS		Open Loop Water-to-Air	4.4	21.8	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES048	ES048-1CS		Open Loop Water-to-Air	4.4	21.8	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES049	ES049-1CS		Closed Loop Water-to-Air	3.7	18.3	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES049	ES049-1CS		Closed Loop Water-to-Air	3.7	18.3	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES061	ES061-1CS		Closed Loop Water-to-Air	3.7	19.2	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES061	ES061-1CS		Closed Loop Water-to-Air	3.7	19.2	1/1/2003	2/25/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES061	ES061-1CS		Open Loop Water-to-Air	4.3	22.4	1/1/2003	2/10/2011
HP Manufacturing Bosch Group	Enviro-Saver Split	ES061	ES061-1CS		Open Loop Water-to-Air	4.3	22.4	1/1/2003	2/25/2011
SeoEnergy of New York	GeoNRG	DXS	DXS25		DGX	3.9	21.1	9/15/2012	10/12/2012
GeoEnergy of New York	GeoNRG	DXS	DXS45		DGX	4.0	19.3	9/15/2012	10/12/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoEnergy of New York	GeoNRG	DXS	DXS55		DGX	4.1	20.0	9/15/2012	10/12/2012
GeoEnergy of New York	GeoNRG	DXS	DXS65		DGX	3.7	17.6	9/15/2012	10/12/2012
GeoEnergy of New York	GeoNRG	DXTFS	DXTFS45		DGX	4.0	19.3	9/15/2012	10/12/2012
GeoEnergy of New York	GeoNRG	DXTFS	DXTFS55		DGX	4.1	20.0	9/15/2012	10/12/2012
GeoEnergy of New York	GeoNRG	DXTFS	DXTFS65		DGX	3.7	17.6	9/15/2012	10/12/2012
Geofinity Manufacturing	Elemental	Atlas	AT036XXDA- xxxxxxx		Closed Loop Water-to-Air	4.2	19.9	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Atlas	AT036XXDA- xxxxxxx		Open Loop Water-to-Air	4.8	24.8	3/31/2010	12/19/2012
Geofinity Manufacturing	Elemental	Atlas	AT048XXDA- xxxxxxx		Closed Loop Water-to-Air	4.3	18.6	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Atlas	AT048XXDA- xxxxxxx		Open Loop Water-to-Air	4.7	21.4	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Atlas	AT060XXDA- xxxxxxx		Closed Loop Water-to-Air	4.2	18.8	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Atlas	AT060XXDA- xxxxxxx		Open Loop Water-to-Air	4.6	22.1	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Atlas	AT066XXDA- xxxxxxx		Closed Loop Water-to-Air	4.2	17.9	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Atlas	AT066XXDA- xxxxxxx		Open Loop Water-to-Air	4.7	21.5	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Tangaroa	TG036WBXX- XXXX		Closed Loop Water-to- Water	3.1	16.5	2/12/2012	6/5/2012
Geofinity Manufacturing	Elemental	Tangaroa	TG036WBXX- XXXX		Open Loop Water-to- Water	3.6	22.4	2/12/2012	6/5/2012
Geofinity Manufacturing	Elemental	Tangaroa	TG048WBXX- XXXX		Open Loop Water-to- Water	3.6	21.4	2/19/2012	6/5/2012
Geofinity Manufacturing	Elemental	Tangaroa	TG060WBXX- XXXX		Closed Loop Water-to- Water	3.1	17.6	2/12/2012	6/5/2012
Geofinity Manufacturing	Elemental	Tangaroa	TG060WBXX- XXXX		Open Loop Water-to- Water	3.8	22.9	2/12/2010	6/5/2012
Geofinity Manufacturing	Elemental	Triakus	TK036WBXX- XXXX		Closed Loop Water-to- Water	3.3		3/17/2010	6/5/2012
Geofinity Manufacturing	Elemental	Triakus	TK036WBXX-		Open Loop Water-to- Water	3.9		3/17/2010	6/5/2012
Geofinity Manufacturing	Elemental	Triakus	TK048WBXX- XXXX		Open Loop Water-to- Water	3.6		2/13/2010	6/5/2012
Geofinity Manufacturing	Elemental	Triakus	TK060WBXX- XXXX		Closed Loop Water-to- Water	3.1		2/28/2010	6/5/2012
Geofinity Manufacturing	Elemental	Triakus	TK060WBXX- XXXX		Open Loop Water-to- Water	3.9		2/28/2010	6/5/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Geofinity Manufacturing	Elemental	Zephyrus	ZP018xxSA- xxxxxx		Closed Loop Water-to-Air	4.0	19.4	3/31/2010	6/5/2012
Geofinity Manufacturing	Elemental	Zephyrus-Split	ZP024SBDA-*** with Geofinity model AHZ024B** ZP024SBDA-***		Closed Loop Water-to-Air	3.8	20.0	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zephyrus-Split	with Geofinity model AHZ024B**		Open Loop Water-to-Air	4.4	26.1	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zephyrus	ZP024xxDA- xxxxxx		Closed Loop Water-to-Air	4.5	20.9	3/31/2010	12/20/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP024xxDA- xxxxxx		Open Loop Water-to-Air	4.9	24.5	3/31/2010	12/20/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP024xxSA- xxxxxx		Closed Loop Water-to-Air	4.5	20.9	3/31/2010	6/5/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP024xxSA- xxxxxx		Open Loop Water-to-Air	4.9	24.5	3/31/2010	6/5/2012
Geofinity Manufacturing	Elemental	Zephyrus-Split	ZP036SBDA-*** with Geofinity model AHZ036B**		Closed Loop Water-to-Air	3.8	21.5	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zephyrus-Split	ZP036SBDA-*** with Geofinity model AHZ036B**		Open Loop Water-to-Air	4.4	26.9	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zephyrus	ZP036xxDA- xxxxxx		Closed Loop Water-to-Air	4.0	19.0	3/31/2010	12/20/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP036xxDA- xxxxxx		Open Loop Water-to-Air	4.5	23.3	3/31/2010	12/20/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP036xxSA- xxxxxx		Closed Loop Water-to-Air	4.0	19.0	3/31/2010	6/5/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP036xxSA- xxxxxx		Open Loop Water-to-Air	4.5	23.3	3/31/2010	6/5/2012
Geofinity Manufacturing	Elemental	Zephyrus-Split	ZP048SBDA-*** with Geofinity model AHZ048B**		Closed Loop Water-to-Air	4.0	18.4	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zonhyrus Split	ZP048SBDA-*** with Geofinity model AHZ048B**		Open Loop Water-to-Air	4.6	22.8	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zephyrus-Split Zephyrus	ZP048xxDA- xxxxxx		Closed Loop Water-to-Air	4.5	20.8	3/31/2010	12/20/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP048xxDA- xxxxxx		Open Loop Water-to-Air	5.0	25.0	3/31/2010	12/20/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP048xxSA- xxxxxx		Closed Loop Water-to-Air	4.5	20.8	3/31/2010	6/5/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP048xxSA- xxxxxx		Open Loop Water-to-Air	5.0	25.0	3/31/2010	6/5/2012
Geofinity Manufacturing	Elemental	Zephyrus-Split	ZP060SBDA-*** with Geofinity model AHZ060B**		Closed Loop Water-to-Air	4.0	20.5	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zephyrus-Split	ZP060SBDA-*** with Geofinity model AHZ060B**		Open Loop Water-to-Air	4.5	24.7	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zephyrus	ZP060xxDA- xxxxxx		Closed Loop Water-to-Air	4.2	20.1	3/31/2010	12/20/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Geofinity Manufacturing	Elemental	Zephyrus	ZP060xxDA- xxxxxx		Open Loop Water-to-Air	4.9	25.8	3/31/2010	12/20/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP060xxSA- xxxxxx		Open Loop Water-to-Air	4.2	20.1	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP060xxSA- xxxxxx		Open Loop Water-to-Air	4.9	25.8	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Zephyrus-Split	ZP066SBDA-*** with Geofinity model AHZ066B**		Closed Loop Water-to-Air	3.7	18.4	3/31/2010	2/11/2013
Geofinity Manufacturing	Elemental	Zephyrus-Split	ZP066SBDA-*** with Geofinity model AHZ066B**		Open Loop Water-to-Air	4.1	21.4	3/31/2010	2/11/2013
Seofinity Manufacturing	Elemental	Zephyrus	ZP066xxDA- xxxxxx		Closed Loop Water-to-Air	4.2	18.3	3/31/2010	12/20/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP066xxSA- xxxxxx		Closed Loop Water-to-Air	4.2	18.3	3/31/2010	6/5/2012
Seofinity Manufacturing	Elemental	Zephyrus	ZP18xxSA-xxxxxx		Closed Loop Water-to-Air	4.0	19.4	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP18xxSA- xxxxxxx		Open Loop Water-to-Air	5.1	28.3	3/31/2010	6/4/2012
Seofinity Manufacturing	Elemental	Zephyrus	ZP24xxSA-xxxxxx		Closed Loop Water-to-Air	4.5	20.9	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP24xxSA-xxxxxx		Open Loop Water-to-Air	4.9	24.5	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP36xxSA-xxxxxx		Closed Loop Water-to-Air	4.0	19.0	3/31/2010	6/4/2012
Seofinity Manufacturing	Elemental	Zephyrus	ZP36xxSA-xxxxxx		Open Loop Water-to-Air	4.5	23.3	3/31/2010	6/4/2012
Seofinity Manufacturing	Elemental	Zephyrus	ZP48xxSA-xxxxxx		Closed Loop Water-to-Air	4.5	20.8	3/31/2010	6/4/2012
Seofinity Manufacturing	Elemental	Zephyrus	ZP48xxSA-xxxxxx		Open Loop Water-to-Air	5.0	25.0	3/31/2010	6/4/2012
Geofinity Manufacturing	Elemental	Zephyrus	ZP66xxDA-xxxxxx		Open Loop Water-to-Air	4.7	22.0	3/31/2010	12/20/2012
GeoMaster, LLC	G3	G3	GTC36S1-(A-C)D (C,N) with GTA3600UD(-, A-G)		Closed Loop Water-to-Air	4.1	21.6	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	GTC36S1-(A-C)D (C,N) with GTA3600UD(-, A-G)		Open Loop Water-to-Air	4.6	26.1	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	GTC36S1-(A-C)D (C,N) with GTA3600UD(-, A-G) and GTB1-(A, C)		Closed Loop Water-to-Air	4.1	21.2	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	GTC36S1-(A-C)D (C,N) with GTA3600UD(-, A-G) and GTB1-(A, C)		Open Loop Water-to-Air	4.7	25.6	8/1/2010	2/18/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
			GTC48S1-(A-C)D (C,N) with GTA4860UD(-, A-	Illiomation	Closed Loop				
GeoMaster, LLC	G3	G3	G) GTC48S1-(A-C)D		Water-to-Air	3.8	19.1	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	(C,N) with GTA4860UD(-, A- G)		Open Loop Water-to-Air	4.3	22.4	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	GTC48S1-(A-C)D (C,N) with GTA4860UD(-, A- G) and GTB1-(A, C)		Closed Loop Water-to-Air	3.8	18.7	8/1/2010	2/18/2011
Occiviastor, LEO	00	00	GTC48S1-(A-C)D		VVatci-to-Ali	3.0	10.7	0/1/2010	2/10/2011
GeoMaster, LLC	G3	G3	(C,N) with GTA4860UD(-, A-G) and GTB1-(A,C)		Open Loop Water-to-Air	4.3	21.8	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	GTC60S1-(A-C)D (C,N) with GTA4860UD(-, A-G)		Closed Loop Water-to-Air	3.7	19.8	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	GTC60S1-(A-C)D (C,N) with GTA4860UD(-, A-G)		Open Loop Water-to-Air	4.2	23.7	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	GTC60S1-(A-C)D (C,N) with GTA4860UD(-, A-G) and GTB1-(A, C)		Closed Loop Water-to-Air	3.7	18.1	8/1/2010	2/18/2011
GeoMaster, LLC	G3	G3	GTC60S1-(A-C)D (C,N) with GTA4860UD(-, A-G) and GTB1-(A, C)		Open Loop Water-to-Air	4.2	21.8	8/1/2010	2/18/2011
OMt 11 O	OFOFVOE	4 DOOF	A DOOF 4 OF		Closed Loop	4.4	00.5	4/7/0000	0/45/0044
GeoMaster, LLC	GEOEXCEL	AP025	AP025-1CF		Water-to-Air Open Loop	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP025	AP025-1CF		Water-to-Air	5.0	28.0	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP025	AP025-1CS		Closed Loop Water-to-Air	4.3	23.4	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP025	AP025-1CS		Open Loop Water-to-Air	5.0	28.0	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP025	AP025-1HZ		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP025	AP025-1HZ		Open Loop Water-to-Air	5.0	28.0	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP025	AP025-1VT		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP025	AP025-1VT		Open Loop Water-to-Air	5.0	28.0	1/7/2009	3/15/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoMaster, LLC	GEOEXCEL	AP035	AP035-1CF		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP035	AP035-1CF		Open Loop Water-to-Air	4.9	28.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP035	AP035-1CS		Closed Loop Water-to-Air	4.3	23.4	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP035	AP035-1CS		Open Loop Water-to-Air	4.9	28.5	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP035	AP035-1HZ		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP035	AP035-1HZ		Open Loop Water-to-Air	4.9	28.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP035	AP035-1VT		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP035	AP035-1VT		Open Loop Water-to-Air	4.9	28.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP049	AP049-1CF		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP049	AP049-1CF		Open Loop Water-to-Air	4.9	28.3	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP049	AP049-1CS		Closed Loop Water-to-Air	4.3	23.4	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP049	AP049-1CS		Open Loop Water-to-Air	4.8	28.2	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP049	AP049-1HZ		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP049	AP049-1HZ		Open Loop Water-to-Air	4.9	28.3	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP049	AP049-1VT		Closed Loop Water-to-Air	4.4	23.5	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP049	AP049-1VT		Open Loop Water-to-Air	4.9	28.3	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP061	AP061-1CF		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP061	AP061-1CF		Open Loop Water-to-Air	5.1	28.2	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP061	AP061-1CS		Closed Loop Water-to-Air	4.3	23.0	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP061	AP061-1CS		Open Loop Water-to-Air	5.1	28.2	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP061	AP061-1HZ		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP061	AP061-1HZ		Open Loop Water-to-Air	5.1	28.2	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP061	AP061-1VT		Closed Loop Water-to-Air	4.4	23.1	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP061	AP061-1VT		Open Loop Water-to-Air	5.1	28.2	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP071	AP071-1CF		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	3/15/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoMaster, LLC	GEOEXCEL	AP071	AP071-1CF		Open Loop Water-to-Air	4.6	25.3	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP071	AP071-1CS		Closed Loop Water-to-Air	3.9	21.5	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP071	AP071-1CS		Open Loop Water-to-Air	4.5	25.2	6/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP071	AP071-1HZ		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP071	AP071-1HZ		Open Loop Water-to-Air	4.6	25.3	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP071	AP071-1VT		Closed Loop Water-to-Air	4.0	21.6	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	AP071	AP071-1VT		Open Loop Water-to-Air	4.6	25.3	1/7/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	EP007	EP007-1HZ		Closed Loop Water-to-Air	3.6	18.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP007	EP007-1HZ		Open Loop Water-to-Air	4.9	25.1	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP007	EP007-1VT		Closed Loop Water-to-Air	3.6	18.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP007	EP007-1VT		Open Loop Water-to-Air	4.9	25.1	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP009	EP009-1HZ		Closed Loop Water-to-Air	3.6	19.3	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP009	EP009-1HZ		Open Loop Water-to-Air	4.5	25.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP009	EP009-1VT		Closed Loop Water-to-Air	3.6	19.3	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP009	EP009-1VT		Open Loop Water-to-Air	4.5	25.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP012	EP012-1HZ		Closed Loop Water-to-Air	3.6	17.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP012	EP012-1HZ		Open Loop Water-to-Air	4.3	22.7	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP012	EP012-1VT		Closed Loop Water-to-Air	3.6	17.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP012	EP012-1VT		Open Loop Water-to-Air	4.3	22.7	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP015	EP015-1HZ		Closed Loop Water-to-Air	3.9	20.6	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP015	EP015-1HZ		Open Loop Water-to-Air	4.6	28.8	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP015	EP015-1VT		Closed Loop Water-to-Air	3.9	20.6	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP015	EP015-1VT		Open Loop Water-to-Air	4.6	28.8	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP018	EP018-1HZ		Closed Loop Water-to-Air	3.8	19.0	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP018	EP018-1HZ		Open Loop Water-to-Air	4.5	25.6	6/1/2010	4/19/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoMaster, LLC	GEOEXCEL	EP018	EP018-1VT		Closed Loop Water-to-Air	3.8	19.0	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP018	EP018-1VT		Open Loop Water-to-Air	4.5	25.6	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP024	EP024-1HZ		Closed Loop Water-to-Air	4.0	21.1	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP024	EP024-1HZ		Open Loop Water-to-Air	4.6	28.1	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP024	EP024-1VT		Closed Loop Water-to-Air	4.0	21.1	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP024	EP024-1VT		Open Loop Water-to-Air	4.6	28.1	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP030	EP030-1HZ		Closed Loop Water-to-Air	4.3	19.4	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP030	EP030-1HZ		Open Loop Water-to-Air	5.2	27.0	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP030	EP030-1VT		Closed Loop Water-to-Air	4.3	19.4	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP030	EP030-1VT		Open Loop Water-to-Air	5.2	27.0	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP036	EP036-1HZ		Closed Loop Water-to-Air	4.1	19.7	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP036	EP036-1HZ		Open Loop Water-to-Air	4.9	25.9	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP036	EP036-1VT		Closed Loop Water-to-Air	4.1	19.7	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP036	EP036-1VT		Open Loop Water-to-Air	4.9	25.9	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP042	EP042-1HZ		Closed Loop Water-to-Air	4.1	21.2	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP042	EP042-1HZ		Open Loop Water-to-Air	4.4	25.7	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP042	EP042-1VT		Closed Loop Water-to-Air	4.1	21.2	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP042	EP042-1VT		Open Loop Water-to-Air	4.4	25.7	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP048	EP048-1HZ		Closed Loop Water-to-Air	3.7	19.8	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP048	EP048-1HZ		Open Loop Water-to-Air	4.3	25.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP048	EP048-1VT		Closed Loop Water-to-Air	3.7	19.8	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP048	EP048-1VT		Open Loop Water-to-Air	4.3	25.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP060	EP060-1HZ		Closed Loop Water-to-Air	4.3	19.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP060	EP060-1HZ		Open Loop Water-to-Air	4.9	24.4	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP060	EP060-1VT		Closed Loop Water-to-Air	4.3	19.5	6/1/2010	4/19/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoMaster, LLC	GEOEXCEL	EP060	EP060-1VT			4.9	24.4	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP070	EP070-1HZ		Closed Loop Water-to-Air	4.2	18.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP070	EP070-1HZ		Open Loop Water-to-Air	5.0	22.4	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP070	EP070-1VT		Closed Loop Water-to-Air	4.2	18.5	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	EP070	EP070-1VT		Open Loop Water-to-Air	5.0	22.4	6/1/2010	4/19/2012
GeoMaster, LLC	GEOEXCEL	ES018	ES018-1CF			3.7	18.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES018	ES018-1CF		Open Loop Water-to-Air	4.5	25.1	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES018	ES018-1CS		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES018	ES018-1CS		Open Loop Water-to-Air	4.5	25.1	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES018	ES018-1HZ		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES018	ES018-1HZ		Open Loop Water-to-Air	4.5	25.1	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES018	ES018-1VT		Closed Loop Water-to-Air	3.7	18.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES018	ES018-1VT		Open Loop Water-to-Air	4.5	25.1	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES024	ES024-1CF		Open Loop Water-to-Air	4.1	21.1	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES024	ES024-1HZ		Open Loop Water-to-Air	4.1	21.1	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES024	ES024-1VT		Open Loop Water-to-Air	4.1	21.1	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES025	ES025-1CF		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES025	ES025-1CF		Open Loop Water-to-Air	4.6	27.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES025	ES025-1CS		Closed Loop Water-to-Air	3.8	21.2	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES025	ES025-1CS		Open Loop Water-to-Air	4.5	26.5	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES025	ES025-1HZ		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES025	ES025-1HZ		Open Loop Water-to-Air	4.6	27.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES025	ES025-1VT		Closed Loop Water-to-Air	3.9	21.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES025	ES025-1VT		Open Loop Water-to-Air	4.6	27.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES030	ES030-1CF		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	3/15/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoMaster, LLC	GEOEXCEL	ES030	ES030-1CF		Open Loop Water-to-Air	4.6	23.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES030	ES030-1CS		Closed Loop Water-to-Air	3.8	17.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES030	ES030-1CS		Open Loop Water-to-Air	4.6	23.2	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES030	ES030-1HZ		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES030	ES030-1HZ		Open Loop Water-to-Air	4.6	23.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES030	ES030-1VT		Closed Loop Water-to-Air	3.8	18.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES030	ES030-1VT		Open Loop Water-to-Air	4.6	23.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES035	ES035-1CF		Closed Loop Water-to-Air	3.9	20.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES035	ES035-1CF		Open Loop Water-to-Air	4.3	24.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES035	ES035-1CS		Closed Loop Water-to-Air	3.8	20.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES035	ES035-1CS		Open Loop Water-to-Air	4.2	24.7	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES035	ES035-1HZ		Closed Loop Water-to-Air	3.9	20.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES035	ES035-1HZ		Open Loop Water-to-Air	4.3	24.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES035	ES035-1VT		Closed Loop Water-to-Air	3.9	20.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES035	ES035-1VT		Open Loop Water-to-Air	4.3	24.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES036	ES036-1CF		Closed Loop Water-to-Air	3.8	17.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES036	ES036-1CF		Open Loop Water-to-Air	4.6	22.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES036	ES036-1CS		Closed Loop Water-to-Air	3.8	17.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES036	ES036-1CS		Open Loop Water-to-Air	4.6	22.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES036	ES036-1HZ		Closed Loop Water-to-Air	3.8	17.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES036	ES036-1HZ		Open Loop Water-to-Air	4.6	22.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES036	ES036-1VT		Closed Loop Water-to-Air	3.8	17.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES036	ES036-1VT		Open Loop Water-to-Air	4.6	22.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES042	ES042-1CF		Open Loop Water-to-Air	4.2	22.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES042	ES042-1CS		Open Loop Water-to-Air	4.2	21.8	1/1/2003	3/15/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoMaster, LLC	GEOEXCEL	ES042	ES042-1HZ		Open Loop Water-to-Air	4.2	22.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES042	ES042-1VT		Open Loop Water-to-Air	4.2	22.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES048	ES048-1CF		Open Loop Water-to-Air	4.4	22.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES048	ES048-1CS		Open Loop Water-to-Air	4.4	21.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES048	ES048-1HZ		Open Loop Water-to-Air	4.4	22.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES048	ES048-1VT		Open Loop Water-to-Air	4.4	22.0	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES049	ES049-1CF		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES049	ES049-1CF		Open Loop Water-to-Air	4.4	21.5	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES049	ES049-1CS		Closed Loop Water-to-Air	3.7	18.3	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES049	ES049-1HZ		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES049	ES049-1HZ		Open Loop Water-to-Air	4.4	21.5	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES049	ES049-1VT		Closed Loop Water-to-Air	3.8	18.7	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES049	ES049-1VT		Open Loop Water-to-Air	4.4	21.5	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES061	ES061-1CF		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES061	ES061-1CF		Open Loop Water-to-Air	4.4	22.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES061	ES061-1CS		Closed Loop Water-to-Air	3.7	19.2	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES061	ES061-1CS		Open Loop Water-to-Air	4.3	22.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES061	ES061-1HZ		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES061	ES061-1HZ		Open Loop Water-to-Air	4.4	22.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES061	ES061-1VT		Closed Loop Water-to-Air	3.8	19.6	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES061	ES061-1VT		Open Loop Water-to-Air	4.4	22.8	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES071	ES071-1CF		Open Loop Water-to-Air	4.1	22.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES071	ES071-1HZ		Open Loop Water-to-Air	4.1	22.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	ES071	ES071-1VT		Open Loop Water-to-Air	4.1	22.4	1/1/2003	3/15/2011
GeoMaster, LLC	GEOEXCEL	WT025	WT025-1		Closed Loop Water-to- Water	3.1	19.0	1/1/2009	3/15/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoMaster, LLC	GEOEXCEL	WT025	WT025-1		Open Loop Water-to- Water	3.6	23.4	1/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	WT035	WT035-1		Open Loop Water-to- Water	3.5	22.5	1/1/2009	3/15/2011
SCOMIGSTON, LEO	GLOEAGLE	VV 1000	W1000 1		Closed Loop Water-to-	0.0	22.0	17 17 23 03	0/10/2011
GeoMaster, LLC	GEOEXCEL	WT049	WT049-1		Water	3.1	17.5	1/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	WT049	WT049-1		Open Loop Water-to- Water	3.5	21.6	1/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	WT061	WT061-1		Closed Loop Water-to- Water	3.1	17.3	1/1/2009	3/15/2011
GeoMaster, LLC	GEOEXCEL	WT071	WT071-1		Closed Loop Water-to- Water	3.1	16.7	1/1/2009	3/15/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS024		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS024		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS030		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS030		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS036		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS036		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS042		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS042		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS048		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS048		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc.	YS060		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Y	GeoSmart Energy Inc. GeoSmart	YS060		Open Loop Water-to-Air Closed Loop	4.1	23.0	12/1/2009	1/4/2012
GeoSmart Energy Inc.	ECO Y	Energy Inc. GeoSmart	YS070		Water-to-Air Open Loop	3.6	17.1	12/1/2009	1/4/2012
GeoSmart Energy Inc.	ECO Y	Energy Inc. GeoSmart	YS070		Water-to-Air Open Loop	4.1	21.1	12/1/2009	1/4/2012
GeoSmart Energy Inc.	ECO Z	Energy Inc. GeoSmart	ZS015****0		Water-to-Air Closed Loop	4.1	24.0	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Z	Energy Inc. GeoSmart	ZS015****1		Water-to-Air Closed Loop	3.7	17.5	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Z	Energy Inc.	ZS018****1		Water-to-Air	3.7	17.5	12/1/2009	2/24/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoSmart Energy Inc.	ECO Z	GeoSmart Energy Inc.	ZS024***1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Z	GeoSmart Energy Inc.	ZS030****1		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Z	GeoSmart Energy Inc.	ZS042****1		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Z	GeoSmart Energy Inc.	ZS048***1		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/24/2011
GeoSmart Energy Inc.	ECO Z	GeoSmart Energy Inc.	ZS060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS022		Closed Loop Water-to-Air	4.0	22.0	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS022		Closed Loop Water-to-Air	4.0	22.0	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS022		Open Loop Water-to-Air	5.3	30.0	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS022		Open Loop Water-to-Air	5.4	32.2	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS030		Closed Loop Water-to-Air	3.9	21.2	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS030		Closed Loop Water-to-Air	3.9	21.2	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS030		Open Loop Water-to-Air	5.1	30.0	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS030		Open Loop Water-to-Air	5.1	30.0	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS036		Closed Loop Water-to-Air	4.2	21.8	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS036		Closed Loop Water-to-Air	4.2	21.8	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS036		Open Loop Water-to-Air	5.2	29.8	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS036		Open Loop	5.2	29.8	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS042		Closed Loop Water-to-Air	4.1	22.2	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS042		Closed Loop Water-to-Air	4.1	22.2	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS042		Open Loop Water-to-Air	5.1	29.5	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS042		Open Loop Water-to-Air	5.1	29.5	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS042		Closed Loop Water-to-Air	4.0	19.5	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G	GeoSmart	GS048		Closed Loop Water-to-Air	4.0	19.5	6/1/2006	2/24/2011
*	Series Premium G	Energy Inc. GeoSmart			Open Loop				
GeoSmart Energy Inc.	Series Premium G	Energy Inc. GeoSmart Energy Inc.	GS048 GS048		Water-to-Air Open Loop Water-to-Air	4.9	27.0	6/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS060		Closed Loop Water-to-Air	3.8	19.2	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS060		Closed Loop Water-to-Air	3.8	19.2	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS060		Open Loop Water-to-Air	4.6	25.5	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS060		Open Loop Water-to-Air	4.6	25.5	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS070		Closed Loop Water-to-Air	3.7	17.9	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS070		Closed Loop Water-to-Air	3.7	17.9	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS070		Open Loop Water-to-Air	4.5	24.3	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GS070		Open Loop Water-to-Air	4.5	24.3	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT026		Closed Loop Water-to-Air	4.4	22.7	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT026		Closed Loop Water-to-Air	4.4	22.7	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT026		Open Loop Water-to-Air	5.2	27.6	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT026		Open Loop Water-to-Air	5.2	27.6	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT038		Closed Loop Water-to-Air	4.4	25.0	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT038		Closed Loop Water-to-Air	4.4	25.0	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT038		Open Loop Water-to-Air	5.2	28.1	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT038		Open Loop Water-to-Air	5.2	28.1	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT049		Closed Loop Water-to-Air	4.4	21.5	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT049		Closed Loop Water-to-Air	4.4	21.5	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT049		Open Loop Water-to-Air	5.0	25.5	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT049		Open Loop Water-to-Air	5.0	25.5	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT064		Closed Loop Water-to-Air	4.0	21.8	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT064		Closed Loop Water-to-Air	4.0	21.8	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT064		Open Loop Water-to-Air	4.7	26.0	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT064		Open Loop Water-to-Air	4.7	26.0	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT072		Closed Loop Water-to-Air	4.0	19.9	6/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT072		Closed Loop Water-to-Air	4.0	19.9	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT072		Open Loop Water-to-Air	4.5	23.2	6/1/2006	2/8/2011
GeoSmart Energy Inc.	Premium G Series	GeoSmart Energy Inc.	GT072		Open Loop Water-to-Air	4.5	23.2	6/1/2006	2/24/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HS018		Open Loop Water-to- Water	3.7	22.9	2/1/2010	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HS025		Open Loop Water-to- Water	3.8	21.2	2/1/2010	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HS040		Closed Loop Water-to- Water	3.1	17.5	2/1/2010	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HS040		Open Loop Water-to- Water	3.9	23.4	2/1/2010	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HS050		Closed Loop Water-to- Water	3.1	16.4	2/1/2010	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HS050		Open Loop Water-to- Water	3.7	21.6	2/1/2010	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HS060		Open Loop Water-to- Water	3.8	20.6	2/1/2010	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HT100		Closed Loop Water-to- Water	3.2	19.4	9/1/2009	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HT100		Open Loop Water-to- Water	3.5	23.3	9/1/2009	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HT120		Closed Loop Water-to- Water	3.2	19.0	9/1/2009	5/20/2011
GeoSmart Energy Inc.	Premium H Series	GeoSmart Energy Inc.	HT120		Open Loop Water-to- Water	3.5	22.3	9/1/2009	5/20/2011
GeoSmart Energy Inc.	Premium Q Series	GeoSmart Energy Inc.	QT038		Closed Loop Water-to-Air	4.2	20.8	9/1/2008	2/24/2011
GeoSmart Energy Inc.	Premium Q Series	GeoSmart Energy Inc.	QT038		Open Loop Water-to-Air	4.7	23.3	9/1/2008	2/24/2011
GeoSmart Energy Inc.	Premium Q Series	GeoSmart Energy Inc.	QT049		Closed Loop Water-to-Air	3.9	18.8	9/1/2008	2/24/2011
GeoSmart Energy Inc.	Premium Q Series	GeoSmart Energy Inc.	QT049		Open Loop Water-to-Air	4.5	23.3	9/1/2008	2/24/2011
GeoSmart Energy Inc.	Premium Q Series	GeoSmart Energy Inc.	QT064		Closed Loop Water-to-Air	3.6	17.8	9/1/2008	2/24/2011
GeoSmart Energy Inc.	Premium Q Series	GeoSmart Energy Inc.	QT064		Open Loop Water-to-Air	4.1	21.2	9/1/2008	2/24/2011

				Additional Model				Data Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
GeoSmart Energy Inc.	Premium Q Series	GeoSmart Energy Inc.	QT072		Closed Loop Water-to-Air	3.7	17.3	9/1/2008	2/24/2011
GeoSmart Energy Inc.	Premium Q Series	GeoSmart Energy Inc.	QT072		Open Loop Water-to-Air	4.1	21.1	9/1/2008	1/4/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEH024	HEH024		Open Loop Water-to-Air	4.2	22.1	1/3/2012	12/23/2011
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEH030	HEH030		Open Loop Water-to-Air	4.1	22.5	1/3/2012	12/23/2011
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEH036	HEH036		Open Loop Water-to-Air	4.2	22.3	1/3/2012	12/23/2011
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEH042	HEH042		Open Loop Water-to-Air	4.1	23.6	1/3/2012	12/23/2011
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEH048	HEH048		Open Loop Water-to-Air	4.4	23.6	1/3/2012	12/23/2011
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEH060	HEH060		Open Loop Water-to-Air	4.1	23.1	1/3/2012	12/23/2011
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV024	HEV024		Closed Loop Water-to-Air	3.6	17.5	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV024	HEV024		Open Loop Water-to-Air	4.2	22.1	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV030	HEV030		Closed Loop Water-to-Air	3.6	18.1	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV030	HEV030		Open Loop Water-to-Air	4.1	22.5	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV036	HEV036		Closed Loop Water-to-Air	3.7	17.5	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV036	HEV036		Open Loop Water-to-Air	4.2	22.3	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV042	HEV042		Closed Loop	3.6	18.8	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV042	HEV042		Open Loop Water-to-Air	4.1	23.6	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV048	HEV048		Closed Loop	3.8	18.1	1/3/2012	10/12/2012
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HEV048	HEV048		Open Loop Water-to-Air	4.4	23.6	1/3/2012	10/12/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
ENERGY GYART GRAIN	GeoLogix,	model Hame	incasi itanissi	mormation		John Hatting	LERTRAMING	On Markot	Dato Quamica
Heat Controller Inc.	Comfort Aire, Century	HEV060	HEV060		Closed Loop Water-to-Air	3.6	18.8	1/3/2012	10/12/2012
	GeoLogix, Comfort Aire,				Open Leep				
Heat Controller Inc.	Century	HEV060	HEV060		Open Loop Water-to-Air	4.1	23.1	1/3/2012	10/12/2012
	GeoLogix, Comfort Aire,				Closed Loop				
Heat Controller Inc.	Century	HTD024B	HTD024B		Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
	GeoLogix, Comfort Aire,				Open Loop				
Heat Controller Inc.	Century	HTD024B	HTD024B		Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
	GeoLogix, Comfort Aire,				Closed Loop				
Heat Controller Inc.	Century	HTD036C	HTD036C		Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
	GeoLogix, Comfort Aire,				Open Loop				
Heat Controller Inc.	Century GeoLogix,	HTD036C	HTD036C		Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Heat Controlled to	Comfort Aire,	LITDOADD	LITDOADD		Closed Loop	4.4	00.4	0/4/0040	0/44/0040
Heat Controller Inc.	Century GeoLogix,	HTD048B	HTD048B		Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Heat Controller Inc.	Comfort Aire, Century	HTD048B	HTD048B		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
rieat Controller Inc.	GeoLogix,	11100400	11100400		Water-to-Air	4.0	30.0	2/1/2013	2/14/2013
Heat Controller Inc.	Comfort Aire, Century	HTD060B	HTD060B		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
	GeoLogix,								
Heat Controller Inc.	Comfort Aire, Century	HTD060B	HTD060B		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
	GeoLogix, Comfort Aire,				Closed Loop				
Heat Controller Inc.	Century	HTD070B	HTD070B		Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
	GeoLogix, Comfort Aire,				Open Loop				
Heat Controller Inc.	Century	HTD070B	HTD070B		Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
	GeoLogix, Comfort Aire,				Closed Loop				
Heat Controller Inc.	Century	HTH024B	HTH024B		Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
	GeoLogix, Comfort Aire,				Open Loop				
Heat Controller Inc.	Century	HTH024B	HTH024B		Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
	GeoLogix, Comfort Aire,				Closed Loop				
Heat Controller Inc.	Century GeoLogix,	HTH036C	HTH036C		Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
I I t O trail	Comfort Aire,	LITHOGOG	LITHOGOG		Open Loop	5.0	20.5	0/4/0040	0/44/0040
Heat Controller Inc.	Century GeoLogix,	HTH036C	HTH036C		Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Hoot Controller Inc	Comfort Aire,	UTU040D	UTU040D		Closed Loop	4.1	22.4	2/1/2012	2/14/2012
Heat Controller Inc.	Century	HTH048B	HTH048B		Water-to-Air	4.1	23.4	2/1/2013	2/14/2013

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTH048B	HTH048B		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	НТН060В	HTH060B		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	НТН060В	HTH060B		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTH070B	НТН070В		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTH070B	НТН070В		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV024B	HTV024B		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV024B	HTV024B		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV036C	HTV036C		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV036C	HTV036C		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV048B	HTV048B		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV048B	HTV048B		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV060B	HTV060B		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV060B	HTV060B		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV070B	HTV070B		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogix, Comfort Aire, Century	HTV070B	HTV070B		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTH024	HTH024		Closed Loop Water-to-Air	4.3	22.2	1/1/2006	2/10/2011
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTH036	HTH036		Closed Loop Water-to-Air	4.2	22.6	1/1/2006	2/10/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTH048	HTH048		Closed Loop Water-to-Air	4.3	21.4	1/1/2006	2/10/2011
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTH060	HTH060		Closed Loop Water-to-Air	4.1	21.4	1/1/2006	2/10/2011
	GeoLogixPlus, Comfort Aire,				Closed Loop				
Heat Controller Inc. Heat Controller Inc.	Century GeoLogixPlus, Comfort Aire, Century	HTH070 HTS024A	HTS024A with MWG24		Water-to-Air Open Loop Water-to-Air	4.9	18.8 25.7	1/1/2007 6/18/2012	2/10/2011 9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS024B	HTS024B with		Open Loop Water-to-Air	4.9	25.7	6/18/2012	9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS024B	HTS024B with WDG24*A		Closed Loop Water-to-Air	4.2	21.7	6/18/2012	9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS024	HTS024 (with Heat Controller model HAGV24)		Closed Loop Water-to-Air	4.0	20.2	8/1/2008	2/10/2011
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS024	HTS024 (with Rheem model RHPL-HM2421)		Closed Loop Water-to-Air	4.1	21.0	10/1/2009	2/10/2011
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS036A	HTS036A with MWG36		Open Loop Water-to-Air	4.8	26.1	6/18/2012	9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS036B	HTS036B with MWG36		Open Loop Water-to-Air	4.8	26.1	6/18/2012	9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS036B	HTS036B with WDG36*A		Open Loop Water-to-Air	4.8	25.9	6/18/2012	9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS036	HTS036 (with Heat Controller model HAGV36)		Closed Loop Water-to-Air	4.0	19.1	8/1/2008	2/10/2011
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS036	HTS036 (with Rheem model RHPL-HM3621)		Closed Loop Water-to-Air	3.6	18.6	10/1/2009	2/10/2011
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS048A	HTS048A with MWG48		Open Loop Water-to-Air	4.8	25.1	6/18/2012	9/4/2012
leat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS048B	HTS048B with MWG48		Open Loop Water-to-Air	4.8	25.1	6/18/2012	9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS048B	HTS048B with WDG48*A		Open Loop Water-to-Air	4.9	23.9	6/18/2012	9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS048	HTS048 (with Heat Controller model HAGV48)		Closed Loop Water-to-Air	4.0	20.7	8/1/2008	2/10/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS048	HTS048 (with Rheem model RHPL-HM4824)		Closed Loop Water-to-Air	3.8	19.1	10/1/2009	2/10/2011
Heat Controller Inc.	GeoLogixPlus, Comfort Aire,		HTS060A with		Open Loop	4.2			
neat Controller Inc.	Century GeoLogixPlus,	HTS060A	MWG60		Water-to-Air	4.2	22.5	6/18/2012	9/4/2012
Heat Controller Inc.	Comfort Aire, Century	HTS060B	HTS060B with MWG60		Open Loop Water-to-Air	4.2	22.5	6/18/2012	9/4/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTS060B	HTS060B with WDG60*A		Open Loop Water-to-Air	4.2	23.5	6/18/2012	9/4/2012
Hoot Controller Inc	GeoLogixPlus, Comfort Aire,	HTS060	HTS060 (with Heat Controller		Closed Loop	3.9	10.0	9/1/2009	2/10/2011
Heat Controller Inc.	Century GeoLogixPlus,	1113000	model HAGV60) HTS060 (with		Water-to-Air	5.8	19.0	8/1/2008	2/10/2011
Heat Controller Inc.	Comfort Aire, Century	HTS060	Rheem model RHPL-HM6024)		Closed Loop Water-to-Air	3.6	18.3	10/1/2009	2/10/2011
Llast Cantrallar Inc	GeoLogixPlus, Comfort Aire,	LITY/024	LITV024		Closed Loop	4.2	22.2	4/4/2000	40/40/2040
Heat Controller Inc.	Century	HTV024	HTV024		Water-to-Air	4.3	22.2	1/1/2006	10/12/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTV024	HTV024		Open Loop Water-to-Air	4.9	27.6	1/1/2006	10/12/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTV036	HTV036		Closed Loop Water-to-Air	4.2	22.6	1/1/2006	10/12/2012
neat Controller Inc.	GeoLogixPlus,	H1 V030	H1 V030		water-to-Air	4.2	22.0	1/1/2000	10/12/2012
Heat Controller Inc.	Comfort Aire, Century	HTV036	HTV036		Open Loop Water-to-Air	4.9	27.2	1/1/2006	10/12/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire,	HTV048	HTV048		Closed Loop Water-to-Air	4.3	21.4	1/1/2006	10/12/2012
neat Controller Inc.	Century GeoLogixPlus,	П1 VU40	П1 VU40		water-to-Air	4.3	21.4	1/1/2006	10/12/2012
Heat Controller Inc.	Comfort Aire, Century	HTV048	HTV048		Open Loop Water-to-Air	4.9	25.6	1/1/2006	10/12/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTV060	HTV060		Closed Loop Water-to-Air	4.1	21.4	1/1/2006	10/12/2012
neat Controller IIIC.	GeoLogixPlus, Comfort Aire,	ПТООО	H1 V000		Open Loop	4.1	21.4	1/1/2000	10/12/2012
Heat Controller Inc.	Century	HTV060	HTV060		Water-to-Air	4.5	25.8	1/1/2006	10/12/2012
Heat Controller Inc.	GeoLogixPlus, Comfort Aire, Century	HTV070	HTV070		Closed Loop Water-to-Air	3.7	18.8	1/1/2007	10/12/2012
TOOL CONTROLL HIC.	GeoLogixPlus, Comfort Aire,	111 07 0	111 0070		Open Loop	J.1	10.0	17 172001	10/12/2012
Heat Controller Inc.	Century GeoMax2,	HTV070	HTV070		Water-to-Air	4.3	22.2	1/1/2007	10/12/2012
Heat Controller Inc.	Comfort Aire, Century	HPV018	HPV018		Open Loop Water-to-Air	4.4	24.2	2/1/2010	2/10/2011
Heat Controller Inc.	Heat Controller	HEH024	HEH024		Open Loop Water-to-Air	4.3	22.1	1/3/2012	8/21/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Heat Controller Inc.	Heat Controller	HEH030	HEH030		Open Loop Water-to-Air	4.2	22.6	1/3/2012	8/21/2012
Heat Controller Inc.	Heat Controller	HEH036	HEH036		Open Loop Water-to-Air	4.3	22.3	1/3/2012	8/21/2012
Heat Controller Inc.	Heat Controller	HEH042	HEH042		Open Loop Water-to-Air	4.1	23.7	1/3/2012	8/21/2012
Heat Controller Inc.	Heat Controller	HEH048	HEH048		Open Loop Water-to-Air	4.4	23.7	1/3/2012	8/21/2012
Heat Controller Inc.	Heat Controller	HEH060	HEH060		Open Loop Water-to-Air	4.1	23.2	1/3/2012	8/21/2012
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HPV018 1		Open Loop Water-to-Air	4.4	24.2	2/1/2010	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD024		Closed Loop Water-to-Air	4.3	22.3	1/1/2006	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD024		Open Loop Water-to-Air	5.0	27.7	1/1/2006	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD036		Closed Loop Water-to-Air	4.3	22.6	1/1/2006	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD036		Open Loop Water-to-Air	4.9	27.3	1/1/2006	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD048		Closed Loop Water-to-Air	4.3	21.4	1/1/2006	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD048		Open Loop Water-to-Air	4.9	25.6	1/1/2006	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD060		Closed Loop Water-to-Air	4.1	21.4	1/1/2006	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD060		Open Loop Water-to-Air	4.6	25.9	1/1/2006	2/10/2011
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTD070		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	2/10/2011
		GeoMax2, Comfort Aire,			Open Loop				
Heat Controller Inc.	Heat Controller	Century GeoMax2,	HTD070			4.3	22.2	1/1/2007	2/10/2011
Heat Controller Inc.	Heat Controller	Comfort Aire, Century	HTH024		Closed Loop Water-to-Air	4.3	22.3	1/1/2006	8/21/2012
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH024		Open Loop Water-to-Air	5.0	27.7	1/1/2006	8/21/2012
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH036		Closed Loop Water-to-Air	4.3	22.6	1/1/2006	8/21/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH036		Open Loop Water-to-Air	4.9	27.3	1/1/2006	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH048		Closed Loop Water-to-Air	4.3	21.4	1/1/2006	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH048		Open Loop Water-to-Air	4.9	25.6	1/1/2006	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH060		Closed Loop Water-to-Air	4.1	21.4	1/1/2006	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH060		Open Loop Water-to-Air	4.6	25.9	1/1/2006	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH070		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	8/21/2012
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTH070		Open Loop Water-to-Air	4.3	22.2	1/1/2007	8/21/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS024A with MWG24		Open Loop Water-to-Air	4.9	25.7	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS024B with MWG24		Open Loop Water-to-Air	4.9	25.7	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS024B with WDG24*A		Closed Loop Water-to-Air	4.3	21.8	6/18/2012	9/4/2012
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTS024 (with Heat Controller model HAGV24)		Closed Loop Water-to-Air	4.1	20.2	8/1/2008	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTS024 (with Rheem model RHPL-HM2421)		Closed Loop Water-to-Air	4.2	21.0	10/1/2009	8/21/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS036A with MWG36		Open Loop Water-to-Air	4.9	26.2	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS036B with MWG36		Open Loop Water-to-Air	4.9	26.2	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS036B with WDG36*A		Open Loop Water-to-Air	4.9	25.9	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTS036 (with Heat Controller model HAGV36)		Closed Loop Water-to-Air	4.1	19.1	8/1/2008	8/21/2012
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTS036 (with Rheem model RHPL-HM3621)		Closed Loop Water-to-Air	3.7	18.7	10/1/2009	8/21/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Heat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS048A with MWG48		Open Loop Water-to-Air	4.8	25.2	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS048B with MWG48		Open Loop Water-to-Air	4.8	25.2	6/18/2012	9/4/2012
Heat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS048B with WDG48*A		Open Loop Water-to-Air	5.0	23.9	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTS048 (with Heat Controller model HAGV48)		Closed Loop Water-to-Air	4.0	20.8	8/1/2008	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTS048 (with Rheem model RHPL-HM4824)		Closed Loop Water-to-Air	3.9	19.1	10/1/2009	8/21/2012
Heat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS060A with MWG60		Open Loop Water-to-Air	4.2	22.6	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS060B with MWG60		Open Loop Water-to-Air	4.2	22.6	6/18/2012	9/4/2012
leat Controller Inc.	Heat Controller	GeoLogix, Comfort Aire, Century	HTS060B with WDG60*A		Open Loop Water-to-Air	4.2	23.5	6/18/2012	9/4/2012
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTS060 (with Heat Controller model HAGV60)		Closed Loop Water-to-Air	3.9	19.1	8/1/2008	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTS060 (with Rheem model RHPL-HM6024)		Closed Loop Water-to-Air	3.6	18.4	10/1/2009	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTV024		Closed Loop Water-to-Air	4.3	22.3	1/1/2006	8/21/2012
Heat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTV036		Closed Loop Water-to-Air	4.3	22.6	1/1/2006	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTV048		Closed Loop Water-to-Air	4.3	21.4	1/1/2006	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTV060		Closed Loop Water-to-Air	4.1	21.4	1/1/2006	8/21/2012
leat Controller Inc.	Heat Controller	GeoMax2, Comfort Aire, Century	HTV070		Closed Loop Water-to-Air	3.8	18.8	1/1/2007	8/21/2012
leat Controller Inc.	Heat Controller	HWW036 1	HWW036 1		Closed Loop Water-to- Water	3.1	16.4	6/1/2009	4/1/2011
Heat Controller Inc.	Heat Controller	HWW036 1	HWW036 1		Open Loop Water-to- Water	4.0	23.1	6/1/2009	4/1/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Heat Controller Inc.	Heat Controller	HWW060 1	HWW060 1		Closed Loop Water-to- Water	3.1	16.2	3/15/2010	4/1/2011
Heat Controller Inc.	Heat Controller	HWW060 1	HWW060 1		Open Loop Water-to- Water	4.0	20.3	3/15/2010	4/1/2011
					Open Loop	-			-
Heat Controller Inc.	Heat Controller	HWW120 1	HWW120 1		Water-to- Water Open Loop	3.9	20.1	4/1/2010	4/1/2011
Johnson Controls, Inc.	JCI	JCI	RGSH015****0		Water-to-Air	4.1	24.0	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH015***1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH015****1		Open Loop Water-to-Air	4.4	24.3	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH018****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH023****1		Closed Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH023****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH024***1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH024***1		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH030****1		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH036****1		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
Johnson Controls, Inc.	JCI	JCI	RGSH036****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH042****1		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH042****1		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH048****1		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH048****1		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSH060****1		Open Loop Water-to-Air	4.1	23.0	12/1/2009	1/4/2012
Johnson Controls, Inc.	JCI	JCI	RGSH070****1		Closed Loop Water-to-Air	3.6	17.1	12/1/2009	1/4/2012
Johnson Controls, Inc.	JCI	JCI	RGSH070***1		Open Loop Water-to-Air	4.1	21.1	12/1/2009	1/4/2012
Johnson Controls, Inc.	JCI	JCI	RGSV015****0		Open Loop Water-to-Air	4.1	24.0	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSV015****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/24/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
lohnson Controls, Inc.	JCI	JCI	RGSV015****1		Open Loop Water-to-Air	4.4	24.3	12/1/2009	2/24/2011
ohnson Controls, Inc.	JCI	JCI	RGSV018****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/24/2011
ohnson Controls, Inc.	JCI	JCI	RGSV024****1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/24/2011
ohnson Controls, Inc.	JCI	JCI	RGSV024****1		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/24/2011
ohnson Controls, Inc.	JCI	JCI	RGSV030****1		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/24/2011
ohnson Controls, Inc.	JCI	JCI	RGSV036****1		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
ohnson Controls, Inc.	JCI	JCI	RGSV036****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
ohnson Controls, Inc.	JCI	JCI	RGSV042****1		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/24/2011
lohnson Controls, Inc.	JCI	JCI	RGSV042****1		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/24/2011
Johnson Controls, Inc.	JCI	JCI	RGSV048****1		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/24/2011
lohnson Controls, Inc.	JCI	JCI	RGSV048****1		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/24/2011
ohnson Controls, Inc.	JCI	JCI	RGSV060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/24/2011
lohnson Controls, Inc.	JCI	JCI	RGSV060****1		Open Loop Water-to-Air	4.1	23.0	12/1/2009	1/4/2012
lohnson Controls, Inc.	JCI	JCI	RGSV070****1		Closed Loop Water-to-Air	3.6	17.1	12/1/2009	1/4/2012
lohnson Controls, Inc.	JCI	JCI	RGSV070****1		Open Loop Water-to-Air	4.1	21.1	12/1/2009	1/4/2012
Johnson Controls, Inc.	JCI	JCI	RHSW018		Open Loop Water-to- Water	3.7	22.9	2/1/2010	5/20/2011
lohnson Controls, Inc.	JCI	JCI	RHSW025		Open Loop Water-to- Water	3.8	21.2	2/1/2010	5/20/2011
omison controls, mc.	JOI	JOI	KI 13W023		Closed Loop Water-to-	3.0	21.2	2/1/2010	3/20/2011
lohnson Controls, Inc.	JCI	JCI	RHSW040		Water Open Loop	3.1	17.5	2/1/2010	5/20/2011
Johnson Controls, Inc.	JCI	JCI	RHSW040		Water-to- Water	3.9	23.4	2/1/2010	5/20/2011
					Closed Loop Water-to-				
ohnson Controls, Inc.	JCI	JCI	RHSW050		Water Open Loop	3.1	16.4	2/1/2010	5/20/2011
ohnson Controls, Inc.	JCI	JCI	RHSW050		Water-to- Water Open Loop	3.7	21.6	2/1/2010	5/20/2011
ohnson Controls, Inc.	JCI	JCI	RHSW060		Water-to- Water	3.8	20.6	2/1/2010	5/20/2011
Maritime Geothermal Ltd.	Nordic	DXS	DXS25 (AH25)		DGX	3.9	21.1	1/1/1993	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type		EER Rating	On Market	Date Qualified
Maritime Geothermal Ltd.	Nordic	DXS	DXS45 (AH45)		DGX	4.0	19.3	1/1/1993	2/8/2011
Maritime Geothermal Ltd.	Nordic	DXS	DXS55 (AH55)		DGX	4.1	20.0	1/1/1993	2/8/2011
Maritime Geothermal Ltd.	Nordic	DXS	DXS65 (AH65)		DGX	3.7	17.6	1/1/1993	2/8/2011
Maritime Geothermal Ltd.	Nordic	DXTFS	DXTFS45 (AH45)		DGX	4.0	19.3	2/1/2000	2/8/2011
Maritime Geothermal Ltd.	Nordic	DXTFS	DXTFS55 (AH55)		DGX	4.1	20.0	2/1/2000	2/8/2011
Maritime Geothermal Ltd.	Nordic	DXTFS	DXTFS65 (AH65)		DGX	3.7	17.6	2/1/2000	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R25		Open Loop Water-to-Air	4.1	24.3	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R45		Closed Loop Water-to-Air	3.8	20.7	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R45		Open Loop Water-to-Air	4.4	24.3	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R55		Closed Loop Water-to-Air	4.3	20.3	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R55		Open Loop Water-to-Air	5.0	23.5	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R65		Closed Loop Water-to-Air	3.9	19.8	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R65		Open Loop Water-to-Air	4.6	24.7	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R75		Closed Loop Water-to-Air	4.0	18.9	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	R	R75		Open Loop Water-to-Air	4.6	22.5	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH25		Closed Loop Water-to-Air	4.0	24.2	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH25		Open Loop Water-to-Air	4.7	27.9	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH45		Closed Loop Water-to-Air	4.1	22.2	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH45		Open Loop Water-to-Air	4.7	26.1	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH55		Closed Loop Water-to-Air	4.3	20.3	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH55		Open Loop Water-to-Air	5.0	23.5	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH65		Closed Loop Water-to-Air	3.9	19.8	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH65		Open Loop Water-to-Air	4.6	24.7	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH75		Closed Loop Water-to-Air	4.0	18.9	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RH	RH75		Open Loop Water-to-Air	4.6	22.5	2/1/2007	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS25 (AH25)		Closed Loop Water-to-Air	4.0	24.2	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS25 (AH25)		Open Loop Water-to-Air	4.7	27.9	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS45 (AH45)		Closed Loop Water-to-Air	4.1	22.2	1/1/1997	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Maritime Geothermal Ltd.	Nordic	RS	RS45 (AH45)		Open Loop Water-to-Air	4.7	26.1	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS55 (AH55)		Closed Loop Water-to-Air	4.3	20.3	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS55 (AH55)		Open Loop Water-to-Air	5.0	23.5	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS65 (AH65)		Closed Loop Water-to-Air	3.9	19.8	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS65 (AH65)		Open Loop Water-to-Air	4.6	24.7	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS75 (AH75)		Closed Loop Water-to-Air	4.0	18.9	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	RS	RS75 (AH75)		Open Loop Water-to-Air	4.6	22.5	1/1/1997	2/8/2011
Maritime Geothermal Ltd.	Nordic	TF	TF45		Closed Loop Water-to-Air	4.0	21.7	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TF	TF45		Open Loop Water-to-Air	4.6	25.8	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TF	TF55		Closed Loop Water-to-Air	4.1	20.5	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TF	TF55		Open Loop Water-to-Air	4.7	24.4	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TF	TF65		Closed Loop Water-to-Air	4.2	20.9	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TF	TF65		Open Loop Water-to-Air	4.8	25.9	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TF	TF75		Closed Loop Water-to-Air	3.8	18.2	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TF	TF75		Open Loop Water-to-Air	4.4	22.2	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH25		Closed Loop Water-to-Air	3.8	23.0	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH25		Open Loop Water-to-Air	4.5	25.7	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH45		Closed Loop Water-to-Air	4.0	21.7	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH45		Open Loop Water-to-Air	4.6	25.8	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH55		Closed Loop Water-to-Air	4.1	20.5	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH55		Open Loop Water-to-Air	4.7	24.4	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH65		Closed Loop Water-to-Air	4.2	20.9	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH65		Open Loop Water-to-Air	4.8	25.9	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH75		Closed Loop Water-to-Air	3.8	18.2	3/1/1995	2/8/2011
Maritime Geothermal Ltd.	Nordic	TFH	TFH75		Open Loop Water-to-Air	4.4	22.2	3/1/1995	2/8/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
					Closed Loop				
Maritime Geothermal Ltd.	Nordic	W	W25		Water-to- Water	3.1	19.2	6/1/2011	8/22/2012
					Open Loop Water-to-				
Maritime Geothermal Ltd.	Nordic	W	W25		Water	3.8	23.8	6/1/2011	2/8/2011
Maritime Geothermal Ltd.	Nordic	W	W45		Closed Loop Water-to- Water	3.2	18.4	6/1/2011	2/8/2011
Mariano Godinomai Eta.	Nordio		VV 10		Open Loop	0.2	10.1	0/1/2011	2/3/2011
Maritime Geothermal Ltd.	Nordic	W	W45		Water-to- Water	3.9	23.0	6/1/2011	2/8/2011
Maritime Geothermal Ltd.	Nordic	W	W55		Closed Loop Water-to- Water	3.2	17.3	6/1/2011	2/8/2011
	10.1.0				Open Loop Water-to-			0.7.20.1	
Maritime Geothermal Ltd.	Nordic	W	W55		Water	3.8	22.0	6/1/2011	2/8/2011
Maritime Geothermal Ltd.	Nordic	W	W65		Closed Loop Water-to- Water	3.2	17.8	6/1/2011	2/8/2011
viantime Geothermai Ltd.	Nordic	VV	VV03		Open Loop	5.2	17.0	0/1/2011	2/6/2011
Maritime Geothermal Ltd.	Nordic	W	W65		Water-to- Water	3.8	22.3	6/1/2011	2/8/2011
Maritime Geothermal Ltd.	Nordic	W	W75		Closed Loop Water-to- Water	3.3	16.7	6/1/2011	2/8/2011
					Open Loop Water-to-				
Maritime Geothermal Ltd.	Nordic	W	W75		Water	4.0	20.7	6/1/2011	2/8/2011
Maritime Geothermal Ltd.	Nordic	W	W80		Open Loop Water-to- Water	3.9	20.5	5/1/2012	4/19/2012
Miami Heat Pump	Miami Heat Pump	HPX024	HPX024		Closed Loop Water-to-Air	3.6	19.7	8/1/2010	5/24/2011
Miami Heat Pump	Miami Heat Pump	HPX024	HPX024		Open Loop Water-to-Air	4.2	27.6	8/1/2010	5/24/2011
Miami Heat Pump	Miami Heat Pump	HPX031	HPX031		Open Loop Water-to-Air	4.1	26.0	8/1/2010	5/24/2011
Miami Heat Pump	Miami Heat Pump	HPX036	HPX036		Closed Loop Water-to-Air	3.6	17.9	8/1/2010	5/24/2011
Miami Heat Pump	Miami Heat Pump	HPX036	HPX036		Open Loop Water-to-Air	4.2	23.5	8/1/2010	5/24/2011
Miami Heat Pump	Miami Heat Pump	HPX041	HPX041		Open Loop Water-to-Air	4.1	21.4	8/1/2010	5/24/2011
Miami Heat Pump	Miami Heat Pump	HPX048	HPX048		Closed Loop Water-to-Air	3.6	20.0	8/1/2010	5/24/2011
Miami Heat Pump	Miami Heat Pump	HPX048	HPX048		Open Loop Water-to-Air	4.3	27.0	8/1/2010	5/24/2011
Miami Heat Pump	Miami Heat Pump	HPX060	HPX060		Open Loop Water-to-Air	4.1	22.0	8/1/2010	5/24/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Modine Manufacturing Company	Elemental	Atlas	AT036XXDA- xxxxxxx		Closed Loop Water-to-Air	4.2	19.9	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Atlas	AT036XXDA- xxxxxxx		Open Loop Water-to-Air	4.8	24.8	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Atlas	AT048XXDA- xxxxxxx		Closed Loop Water-to-Air	4.3	18.6	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Atlas	AT048XXDA- xxxxxxx		Open Loop Water-to-Air	4.7	21.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Atlas	AT060XXDA- xxxxxxx		Closed Loop Water-to-Air	4.2	18.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Atlas	AT060XXDA- xxxxxxx		Open Loop Water-to-Air	4.6	22.1	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Atlas	AT066XXDA- xxxxxxx		Closed Loop Water-to-Air	4.2	17.9	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Atlas	AT066XXDA- xxxxxxx		Open Loop Water-to-Air	4.7	21.5	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Tangaroa	TG036WBXX- XXXX		Closed Loop Water-to- Water	3.1	16.5	2/12/2012	1/21/2013
Modine Manufacturing Company	Elemental	Tangaroa	TG036WBXX- XXXX		Open Loop Water-to- Water	3.6	22.4	2/12/2012	1/21/2013
Modine Manufacturing Company	Elemental	Tangaroa	TG048WBXX-		Open Loop Water-to- Water	3.6	21.4	2/19/2012	1/21/2013
Modine Manufacturing Company	Elemental	Tangaroa	TG060WBXX-		Closed Loop Water-to- Water	3.1	17.6	2/12/2012	1/21/2013
Modine Manufacturing Company	Elemental	Tangaroa	TG060WBXX- XXXX		Open Loop Water-to- Water	3.8	22.9	2/12/2010	1/21/2013
Modine Manufacturing Company	Elemental	Triakus	TK036WBXX- XXXX		Closed Loop Water-to- Water	3.3		3/17/2010	1/21/2013
Modine Manufacturing Company	Elemental	Triakus	TK036WBXX- XXXX		Open Loop Water-to- Water	3.9		3/17/2010	1/21/2013
Modine Manufacturing Company	Elemental	Triakus	TK048WBXX- XXXX		Open Loop Water-to- Water	3.6		2/13/2010	1/21/2013
Modine Manufacturing Company	Elemental	Triakus	TK060WBXX- XXXX		Closed Loop Water-to- Water	3.1		2/28/2010	1/21/2013
Modine Manufacturing Company	Elemental	Triakus	TK060WBXX- XXXX		Open Loop Water-to- Water	3.9		2/28/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP018xxSA- xxxxxxx		Closed Loop Water-to-Air	4.0	19.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP018xxSA- xxxxxxx		Open Loop Water-to-Air	5.1	28.3	3/31/2010	1/21/2013

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP024SBDA-*** with Geofinity model AHZ024B**		Closed Loop Water-to-Air	3.8	20.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP024SBDA-*** with Geofinity model AHZ024B**		Open Loop Water-to-Air	4.4	26.1	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP024xxDA- xxxxxx		Closed Loop Water-to-Air	4.5	20.9	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP024xxDA- xxxxxx		Open Loop Water-to-Air	4.9	24.5	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP036SBDA-*** with Geofinity model AHZ036B**		Closed Loop Water-to-Air	3.8	21.5	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP036SBDA-*** with Geofinity model AHZ036B**		Open Loop Water-to-Air	4.4	26.9	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP036xxDA- xxxxxx		Closed Loop Water-to-Air	4.0	19.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP036xxDA- xxxxxx		Open Loop Water-to-Air	4.5	23.3	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP048SBDA-***		Open Loop Water-to-Air	4.6	22.8	3/31/2010	12/27/2012
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP048SBDA-*** with Geofinity model AHZ048B**		Closed Loop Water-to-Air	4.0	18.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP048SBDA-*** with Geofinity model AHZ048B**		Open Loop Water-to-Air	4.6	22.8	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP048xxDA- xxxxxx		Closed Loop Water-to-Air	4.5	20.8	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP048xxDA- xxxxxx		Open Loop Water-to-Air	5.0	25.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP060SBDA-***		Open Loop Water-to-Air	4.5	24.7	3/31/2010	12/27/2012
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP060SBDA-*** with Geofinity model AHZ060B**		Closed Loop Water-to-Air	4.0	20.5	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP060SBDA-*** with Geofinity model AHZ060B**		Open Loop Water-to-Air	4.5	24.7	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP060xxDA- xxxxxx		Closed Loop Water-to-Air	4.2	20.1	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP060xxDA- xxxxxx		Open Loop Water-to-Air	4.9	25.8	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP066SBDA-*** with Geofinity model AHZ066B**		Closed Loop Water-to-Air	3.7	18.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus-Split	ZP066SBDA-*** with Geofinity model AHZ066B**		Open Loop Water-to-Air	4.1	21.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Elemental	Zephyrus	ZP066xxDA- xxxxxx		Closed Loop Water-to-Air	4.2	18.3	3/31/2010	1/21/2013

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Modine Manufacturing Company	Elemental	Zephyrus	ZP066xxDA- xxxxxx		Open Loop Water-to-Air	4.7	22.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Combination	GCx036x202xxxx xExx,GCx036x40 2xxxxxExx		Closed Loop Water-to-Air	4.2	19.9	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Combination	GCx036x202xxxx xExx,GCx036x40 2xxxxxExx		Open Loop Water-to-Air	4.8	24.8	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Combination	GCx048x202xxxx xExx,GCx048x40 2xxxxxExx		Closed Loop Water-to-Air	4.3	18.6	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Combination	GCx048x202xxxx xExx,GCx048x40 2xxxxxExx		Open Loop Water-to-Air	4.7	21.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Combination	GCx060x202xxxx xExx,GCx060x40 2xxxxxExx		Closed Loop	4.2	18.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Combination	GCx060x202xxxx xExx,GCx060x40 2xxxxxExx		Open Loop	4.6	22.1	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Combination	GCx066x202xxxx xExx,GCx066x40 2xxxxxExx		Closed Loop Water-to-Air	4.2	17.9	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Combination	GCx066x202xxxx xExx,GCx066x40 2xxxxxExx		Open Loop	4.7	21.5	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx018x102xxxx xExx,GFx018x302 xxxxxExx		Closed Loop	4.0	19.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx018x102xxxx xExx,GFx018x302 xxxxxExx		Open Loop	5.1	28.3	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx024x202xxxx xExx,GFx024x402 xxxxxExx		Closed Loop	4.5	20.9	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx024x202xxxx xExx,GFx024x402 xxxxxExx		Open Loop Water-to-Air	4.9	24.5	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx036x202xxxx xExx,GFx036x402 xxxxxExx		Closed Loop Water-to-Air	4.0	19.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx036x202xxxx xExx,GFx036x402 xxxxxExx		Open Loop	4.5	23.3	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx048x202xxxx xExx,GFx048x402 xxxxxExx		Closed Loop Water-to-Air	4.5	20.8	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx048x202xxxx xExx,GFx048x402 xxxxxExx		Open Loop Water-to-Air	5.0	25.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx060x202xxxx xExx,GFx060x402 xxxxxExx		Closed Loop	4.2	20.1	3/31/2010	1/21/2013

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx060x202xxxx xExx,GFx060x402 xxxxxExx		Open Loop Water-to-Air	4.9	25.8	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx066x202xxxx xExx,GFx066x402 xxxxxExx		Closed Loop Water-to-Air	4.2	18.3	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Forced Air	GFx066x202xxxx xExx,GFx066x402 xxxxxExx		Open Loop Water-to-Air	4.7	22.0	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W REV	GHR036x202xxxx xExx,GHR036x40 2xxxxxExx		Closed Loop Water-to- Water	3.1	16.5	2/12/2012	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W REV	GHR036x202xxxx xExx,GHR036x40 2xxxxxExx		Open Loop Water-to- Water	3.6	22.4	2/12/2012	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W REV	GHR048x202xxxx xExx,GHR048x40 2xxxxxExx		Open Loop Water-to- Water	3.6	21.4	2/19/2012	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W REV	GHR060x202xxxx xExx,GHR060x40 2xxxxxExx		Closed Loop Water-to- Water	3.1	17.6	2/12/2012	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W REV	GHR060x202xxxx xExx,GHR060x40 2xxxxxExx		Open Loop Water-to- Water	3.8	22.9	2/12/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W NON-REV	GHW036x202xxx xxExx,GHW036x4 02xxxxxExx		Closed Loop Water-to- Water	3.3		3/17/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W NON-REV	GHW036x202xxx xxExx,GHW036x4 02xxxxxExx		Open Loop Water-to- Water	3.9		3/17/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W NON-REV	GHW048x202xxx xxExx,GHW048x4 02xxxxxExx		Open Loop Water-to- Water	3.6		2/13/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W NON-REV	GHW060x202xxx xxExx,GHW060x4 02xxxxxExx		Closed Loop Water-to- Water	3.1		2/28/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - W2W NON-REV	GHW060x202xxx xxExx,GHW060x4 02xxxxxExx		Open Loop Water-to- Water	3.9		2/28/2010	1/21/2013
g , y				,GSI060x202 xxxxxExx with Modine model					
Modine Manufacturing Company	Modine	Ground Source - Split	Ground Source - Split	GAH060*,G SI06,	Closed Loop Water-to-Air	4.0	20.5	3/31/2010	1/21/2013
	Modine	Ground Source - Split	GSI024x202xxxxx Exx with Modine model GAH024*,GSI024 x402xxxxxExx with Modine model GAH024*		Closed Loop Water-to-Air	3.8	20.0	3/31/2010	1/21/2013

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Modine Manufacturing Company	Modine	Ground Source - Split	GSI024x202xxxxx Exx with Modine model GAH024*,GSI024 x402xxxxxExx with Modine model GAH024*		Open Loop	4.4	26.1	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Split	GSI036x202xxxxx Exx with Modine model GAH036*,GSI036 x402xxxxxExx with Modine model GAH036*		Closed Loop Water-to-Air	3.8	21.5	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Split	GSI036x202xxxxx Exx with Modine model GAH036*,GSI036 x402xxxxxExx with Modine model GAH036*		Open Loop Water-to-Air	4.4	26.9	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Split	GSI048x202xxxxx Exx with Modine model GAH048*,GSI048 x402xxxxxExx with Modine model GAH048*		Closed Loop Water-to-Air	4.0	18.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Split	GSI048x202xxxxx Exx with Modine model GAH048*,GSI048 x402xxxxxExx with Modine model GAH048*		Open Loop	4.6	22.8	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Split	GSI060x202xxxxx Exx with Modine model GAH060*,GSI060 x402xxxxxExx with Modine model GAH060*		Open Loop	4.5	24.7	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	GSI066x202xxxx xExx with Modine model GAH066*	GSI066x202xxxxx Exx with Modine model GAH066*	GSI066x402 xxxxxExx with Modine model GAH066*,G SI066x402xx xxxExx with Modine model GAH066*,	Closed Loop	3.7	18.4	3/31/2010	1/21/2013

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Modine Manufacturing Company	Modine	Ground Source - Split	GSI066x202xxxxx Exx with Modine model GAH066*,GSI066 x402xxxxxExx with Modine model GAH066*	mormation	Closed Loop Water-to-Air	3.7	18.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Split	GSI066x202xxxxx Exx with Modine model GAH066*,GSI066 x402xxxxxExx with Modine model GAH066*		Open Loop Water-to-Air	4.1	21.4	3/31/2010	1/21/2013
Modine Manufacturing Company	Modine	Ground Source - Split	GSI066x402xxxxx Exx with Modine model GAH066*		Open Loop Water-to-Air	4.1	21.4	3/31/2010	1/18/2013
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-VE-028		Open Loop Water-to-Air	4.4	21.2	10/1/2009	2/18/2011
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-VE-041		Closed Loop Water-to-Air	3.7	17.5	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-VE-041		Closed Loop Water-to-Air	3.7	17.5	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-VE-041		Open Loop Water-to-Air	4.3	22.9	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-VE-053		Closed Loop Water-to-Air	3.6	17.1	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-VE-053		Open Loop Water-to-Air	4.1	22.2	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-VE-061		Closed Loop Water-to-Air	3.6	17.1	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-VE-061		Open Loop Water-to-Air	4.1	21.4	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-030		Closed Loop Water-to- Water	3.1	16.2	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-030		Open Loop Water-to- Water	3.7	21.5	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-036		Closed Loop Water-to- Water	3.1	16.1	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-036		Open Loop Water-to- Water	3.5	20.7	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-050		Closed Loop Water-to- Water	3.1	16.1	10/1/2009	8/17/2012
Northern Heat Pump Ltd.	Northern Heat	North Star Series	RA-WE-050		Open Loop Water-to- Water	3.5	20.1	10/1/2009	8/17/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-060		Closed Loop Water-to- Water	3.1	16.5	7/1/2012	9/27/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-060		Open Loop Water-to- Water	3.7	21.4	7/1/2012	9/27/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-072		Closed Loop Water-to- Water	3.1	16.1	7/1/2012	9/27/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RA-WE-072		Open Loop Water-to- Water	3.7	20.1	7/1/2012	9/27/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RD-WE-096		Closed Loop Water-to- Water	3.2	17.7	7/1/2012	9/27/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RD-WE-096		Open Loop Water-to- Water	3.6	21.4	7/1/2012	9/27/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RD-WE-120		Closed Loop Water-to- Water	3.1	17.0	7/1/2012	9/27/2012
Northern Heat Pump Ltd.	Northern Heat	North Star Series	RD-WE-120		Open Loop Water-to- Water	3.7	20.2	7/1/2012	9/27/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-026 (with_Air Handler_model_n umber: HE-A-**- **-24)		Closed Loop Water-to-Air	3.7	18.6	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-026 (with_Air Handler_model_n umber: HE-A-**- **-24)		Closed Loop Water-to-Air	3.8	17.6	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-026 (with_Air Handler_model_n umber: HE-A-**- **-24)		Open Loop Water-to-Air	4.2	21.6	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-033 (with_Air Handler_model_n umber: HE-A-**- **-36)		Closed Loop Water-to-Air	3.8	17.9	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat	North Star Series	RT-SE-033 (with_Air Handler_model_n umber: HE-A-**- **-36)		Open Loop Water-to-Air	4.2	21.7	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-040 (with_Air Handler_model_n umber: HE-A-**- **-36)		Closed Loop Water-to-Air	3.8	17.3	10/15/2010	8/17/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-040 (with_Air Handler_model_n umber: HE-A-**- **-36)		Closed Loop Water-to-Air	3.9	19.6	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-040 (with_Air Handler_model_n umber: HE-A-**- **-36)		Open Loop Water-to-Air	4.2	21.1	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-052 (with_Air Handler_model_n umber: HE-A-**- **-48)		Closed Loop Water-to-Air	3.8	18.1	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-052 (with_Air Handler_model_n umber: HE-A-**- **-48)		Open Loop Water-to-Air	4.2	21.6	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-062 (with_Air Handler_model_n umber: HE-A-**- **-60)		Closed Loop Water-to-Air	3.7	16.2	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-SE-062 (with_Air Handler_model_n umber: HE-A-**- **-60)		Open Loop Water-to-Air	4.2	21.1	10/15/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-026		Closed Loop Water-to-Air	3.8	19.1	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-026		Closed Loop Water-to-Air	3.9	18.6	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-026		Open Loop Water-to-Air	4.2	21.9	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-033		Closed Loop Water-to-Air	3.7	17.8	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-033		Closed Loop Water-to-Air	3.9	19.7	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-033		Open Loop Water-to-Air	4.2	21.4	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-040		Closed Loop Water-to-Air	4.0	18.6	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-040		Open Loop Water-to-Air	4.2	21.8	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-045		Closed Loop Water-to-Air	3.8	18.0	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-045		Closed Loop Water-to-Air	3.8	19.7	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-045		Open Loop Water-to-Air	4.2	21.7	10/1/2010	8/17/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-052		Closed Loop Water-to-Air	3.6	18.7	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-052		Open Loop Water-to-Air	4.1	21.9	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-062		Closed Loop Water-to-Air	3.8	19.9	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-062		Closed Loop Water-to-Air	4.0	17.9	10/1/2010	8/17/2012
lorthern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RT-VE-062		Open Loop Water-to-Air	4.2	21.5	10/1/2010	8/17/2012
lorthern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-026		Closed Loop Water-to-Air	3.5	16.5	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-026		Closed Loop Water-to-Air	3.9	18.6	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-026		Open Loop Water-to-Air	3.9	21.5	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-033		Closed Loop Water-to-Air	3.7	17.8	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-033		Closed Loop Water-to-Air	3.7	18.5	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-033		Open Loop Water-to-Air	4.1	21.9	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-040		Closed Loop Water-to-Air	3.8	18.5	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-040		Open Loop Water-to-Air	4.2	21.6	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-052		Closed Loop Water-to-Air	3.7	18.2	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-052		Open Loop Water-to-Air	4.1	21.7	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-062		Closed Loop Water-to-Air	3.8	17.7	10/1/2010	8/17/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-062		Closed Loop Water-to-Air	3.8	19.9	10/1/2009	8/21/2012
Northern Heat Pump Ltd.	Northern Heat Pump	North Star Series	RU-VE-062		Open Loop Water-to-Air	4.1	21.2	10/1/2010	8/17/2012
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD025		Open Loop Water-to-Air	4.9	27.5	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD025		Closed Loop Water-to-Air	4.2	22.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD036		Closed Loop Water-to-Air	4.2	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD036		Open Loop Water-to-Air	4.8	27.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD048		Closed Loop Water-to-Air	4.2	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD048		Open Loop Water-to-Air	4.8	25.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD062		Closed Loop Water-to-Air	4.0	21.2	6/1/2009	2/10/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD062		Open Loop Water-to-Air	4.5	25.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD069		Closed Loop Water-to-Air	3.7	18.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVD069		Open Loop Water-to-Air	4.2	22.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDB025		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDB025		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDB048		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDB048		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDB062		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDB062		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDB069		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDB069		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDC036		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVDC036		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVE025 (with Rheem model RHPL-HM2421)		Closed Loop Water-to-Air	4.2	21.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVE025 (with Rheem model RHPL-HM2421)		Open Loop Water-to-Air	4.5	25.9	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVE036 (with Rheem model RHPL-HM3621)		Closed Loop Water-to-Air	3.6	18.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVE036 (with Rheem model RHPL-HM3621)		Open Loop Water-to-Air	4.2	23.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVE048 (with Rheem model RHPL-HM4824)		Closed Loop Water-to-Air	3.9	19.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVE048 (with Rheem model RHPL-HM4824)		Open Loop Water-to-Air	4.4	23.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVE062 (with Rheem model RHPL-HM6024)		Closed Loop Water-to-Air	3.6	18.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVE062 (with Rheem model RHPL-HM6024)		Open Loop Water-to-Air	4.1	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH025		Open Loop Water-to-Air	4.9	27.5	6/1/2009	2/10/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH025		Closed Loop Water-to-Air	4.2	22.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH036		Closed Loop Water-to-Air	4.2	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH036		Open Loop Water-to-Air	4.8	27.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH048		Closed Loop Water-to-Air	4.2	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH048		Open Loop Water-to-Air	4.8	25.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH062		Closed Loop Water-to-Air	4.0	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH062		Open Loop Water-to-Air	4.5	25.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH069		Closed Loop Water-to-Air	3.7	18.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVH069		Open Loop Water-to-Air	4.2	22.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHB025		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHB025		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHB048		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHB048		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHB062		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHB062		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHB069		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHB069		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHC036		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVHC036		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
	. (ilooiii	. roongo	RPVS025 (with Rheem model		Closed Loop	5.2	30.0	2, 1, 2010	2.1.72010
Rheem-Ruud Manufacturing	Rheem	Prestige	RHPL-HM2421)		Water-to-Air	4.2	21.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVS025 (with Rheem model RHPL-HM2421)		Open Loop Water-to-Air	4.5	25.9	6/1/2009	2/10/2011
		-	RPVS036 (with Rheem model		Closed Loop				
Rheem-Ruud Manufacturing	Rheem	Prestige	RHPL-HM3621) RPVS036 (with Rheem model		Water-to-Air Open Loop	3.6	18.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RHPL-HM3621)		Water-to-Air	4.2	23.6	6/1/2009	2/10/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVS048 (with Rheem model RHPL-HM4824)		Closed Loop Water-to-Air	3.9	19.1	6/1/2009	2/10/2011
Trieem-roud Manufacturing	Miceili	i resuge	RPVS048 (with Rheem model		Open Loop	5.9	13.1	0/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RHPL-HM4824) RPVS062 (with		Water-to-Air	4.4	23.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	Rheem model RHPL-HM6024)		Closed Loop Water-to-Air	3.6	18.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVS062 (with Rheem model RHPL-HM6024)		Open Loop Water-to-Air	4.1	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV025		Open Loop Water-to-Air	4.9	27.5	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV025		Closed Loop Water-to-Air	4.2	22.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV036		Closed Loop Water-to-Air	4.2	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV036		Open Loop Water-to-Air	4.8	27.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV048		Closed Loop Water-to-Air	4.2	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV048		Open Loop Water-to-Air	4.8	25.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV062		Closed Loop Water-to-Air	4.0	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV062		Open Loop Water-to-Air	4.5	25.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV069		Closed Loop Water-to-Air	3.7	18.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVV069		Open Loop Water-to-Air	4.2	22.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVB025		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVB025		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVB048		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVB048		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVB062		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVB062		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVB069		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVB069	_	Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVC036		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Rheem-Ruud Manufacturing	Rheem	Prestige	RPVVC036		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD025		Closed Loop Water-to-Air	4.2	22.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD025		Open Loop Water-to-Air	4.9	27.5	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD036		Closed Loop Water-to-Air	4.2	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD036		Open Loop Water-to-Air	4.8	27.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD048		Closed Loop Water-to-Air	4.2	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD048		Open Loop Water-to-Air	4.8	25.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD062		Closed Loop Water-to-Air	4.0	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD062		Open Loop Water-to-Air	4.5	25.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD069		Closed Loop Water-to-Air	3.7	18.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVD069		Open Loop Water-to-Air	4.2	22.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDB025		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDB025		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDB048		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDB048		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDB062		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDB062		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDB069		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDB069		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDC036		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVDC036		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVE025 (with Ruud model RHPL-HM2421)		Closed Loop Water-to-Air	4.2	21.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVE025 (with Ruud model RHPL-HM2421)		Open Loop Water-to-Air	4.5	25.9	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVE036 (with Ruud model RHPL-HM3621)		Closed Loop Water-to-Air	3.6	18.7	6/1/2009	2/10/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVE036 (with Ruud model RHPL-HM3621)		Open Loop Water-to-Air	4.2	23.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVE048 (with Ruud model RHPL-HM4824)		Closed Loop Water-to-Air	3.9	19.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVE048 (with Ruud model RHPL-HM4824)		Open Loop Water-to-Air	4.4	23.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVE062 (with Ruud model RHPL-HM6024)		Closed Loop Water-to-Air	3.6	18.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVE062 (with Ruud model RHPL-HM6024)		Open Loop Water-to-Air	4.1	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH025		Closed Loop Water-to-Air	4.2	22.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH025		Open Loop Water-to-Air	4.9	27.5	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH036		Closed Loop Water-to-Air	4.2	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH036		Open Loop Water-to-Air	4.8	27.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH048		Closed Loop Water-to-Air	4.2	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH048		Open Loop Water-to-Air	4.8	25.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH062		Closed Loop Water-to-Air	4.0	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH062		Open Loop Water-to-Air	4.5	25.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH069		Closed Loop Water-to-Air Open Loop	3.7	18.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVH069		Water-to-Air Closed Loop	4.2	22.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHB025		Water-to-Air Open Loop	4.2	23.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHB025		Water-to-Air Closed Loop	5.0	31.1	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHB048		Water-to-Air Open Loop	4.1	23.4	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHB048		Water-to-Air Closed Loop	4.8	30.0	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHB062		Water-to-Air Open Loop	4.0	22.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHB062		Water-to-Air Closed Loop	4.8	28.2	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHB069		Water-to-Air Open Loop	3.7	19.8	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHB069		Water-to-Air	4.3	25.3	2/1/2013	2/14/2013

ENERGY OT ARR				Additional Model		000 8 4		Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type Closed Loop	COP Rating	EER Rating	On Market	Date Qualified
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHC036		Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVHC036		Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVS025 (with Ruud model RHPL-HM2421)		Closed Loop Water-to-Air	4.2	21.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVS025 (with Ruud model RHPL-HM2421)		Open Loop Water-to-Air	4.5	25.9	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVS036 (with Ruud model RHPL-HM3621)		Closed Loop Water-to-Air	3.6	18.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVS036 (with Ruud model RHPL-HM3621)		Open Loop Water-to-Air	4.2	23.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVS048 (with Ruud model RHPL-HM4824)		Closed Loop Water-to-Air	3.9	19.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVS048 (with Ruud model RHPL-HM4824)		Open Loop Water-to-Air	4.4	23.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVS062 (with Ruud model RHPL-HM6024)		Closed Loop Water-to-Air	3.6	18.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVS062 (with Ruud model RHPL-HM6024)		Open Loop Water-to-Air	4.1	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV025		Closed Loop Water-to-Air	4.2	22.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV025		Open Loop Water-to-Air	4.9	27.5	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV036		Closed Loop Water-to-Air	4.2	22.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV036		Open Loop Water-to-Air	4.8	27.1	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV048		Closed Loop Water-to-Air	4.2	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV048		Open Loop Water-to-Air	4.8	25.4	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV062		Closed Loop Water-to-Air	4.0	21.2	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV062		Open Loop Water-to-Air	4.5	25.7	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV069		Closed Loop Water-to-Air	3.7	18.6	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVV069		Open Loop Water-to-Air	4.2	22.0	6/1/2009	2/10/2011
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVB025		Closed Loop Water-to-Air	4.2	23.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVB025		Open Loop Water-to-Air	5.0	31.1	2/1/2013	2/14/2013

		_		Additional Model				Date Available	_
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVB048		Closed Loop Water-to-Air	4.1	23.4	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVB048		Open Loop Water-to-Air	4.8	30.0	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVB062		Closed Loop Water-to-Air	4.0	22.5	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVB062		Open Loop Water-to-Air	4.8	28.2	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVB069		Closed Loop Water-to-Air	3.7	19.8	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVB069		Open Loop Water-to-Air	4.3	25.3	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVC036		Closed Loop Water-to-Air	4.5	24.7	2/1/2013	2/14/2013
Rheem-Ruud Manufacturing	Ruud	Ultra	RPVVC036	F,F,; fb, 0,	Open Loop Water-to-Air	5.2	30.5	2/1/2013	2/14/2013
Spectrum Manufacturing LLC	Spectrum	Water to water models: SW	Water to water models: SW	1,fb, 0, 1,; fb, 024, 036, 048, 060,fb, 024, 036, 048, 060,; fb, 1,fb, 1,; fb, C, N, A,B,fb, C, N, A,B,; fb, H,fb, H,; fb, L, R,	Open Loop Water-to- Water	3.7	21.3	1/26/2011	6/4/2012
Sub Terra Energy Systems	Sub Terra Energy Systems	STEXP4T / BCS2M60V00N A1P-1	STEXP4T / BCS2M60V00NA 1P-1	,	DGX	3.8		1/1/2011	11/26/2012
Sub Terra Energy Systems	Sub Terra Energy Systems	STEXP5T / BCS2M60V00N A1P-1	STEXP5T / BCS2M60V00NA 1P-1		DGX	3.6		1/1/2011	10/24/2012
	Northern Heat	North Star			Closed Loop				
TERRA-THERM Inc.	Pump Northern Heat	Series North Star	RA-VE-041		Water-to-Air Open Loop	3.7	17.5	10/1/2009	2/18/2011
FERRA-THERM Inc.	Pump  Northern Heat	Series North Star	RA-VE-053		Water-to-Air Closed Loop	4.1	22.2	10/1/2009	2/18/2011
TERRA-THERM Inc.	Pump	Series	RT-SE-026		Water-to-Air	3.7	18.6	10/15/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RT-SE-040		Closed Loop Water-to-Air	3.8	17.3	10/15/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RT-SE-052		Closed Loop Water-to-Air	3.8	18.1	10/15/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RT-SE-062		Closed Loop Water-to-Air	3.7	16.2	10/15/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RT-VE-026		Closed Loop Water-to-Air	3.8	19.1	10/1/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RT-VE-033		Closed Loop Water-to-Air	3.9	19.7	10/1/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RT-VE-040		Closed Loop Water-to-Air	4.0	18.6	10/1/2010	2/18/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RT-VE-045		Closed Loop Water-to-Air	3.8	18.0	10/1/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RT-VE-062		Closed Loop Water-to-Air	4.0	17.9	10/1/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RU-VE-026		Closed Loop Water-to-Air	3.5	16.5	10/1/2010	2/18/2011
ΓERRA-THERM Inc.	Northern Heat Pump	North Star Series	RU-VE-033		Closed Loop Water-to-Air	3.7	18.5	10/1/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RU-VE-040		Closed Loop Water-to-Air	3.8	18.5	10/1/2010	2/18/2011
TERRA-THERM Inc.	Northern Heat Pump	North Star Series	RU-VE-062		Closed Loop Water-to-Air	3.8	17.7	10/1/2010	2/18/2011
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TCT-024		Closed Loop Water-to-Air	3.6	18.7	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TCT-024		Open Loop Water-to-Air	4.1	21.4	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TCT-036		Closed Loop Water-to-Air	3.8	18.5	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TCT-036		Open Loop Water-to-Air	4.1	21.6	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TCT-048		Closed Loop Water-to-Air	3.7	18.2	11/2/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TCT-048		Open Loop Water-to-Air	4.1	21.7	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TCT-060		Closed Loop Water-to-Air	3.8	17.7	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TCT-060		Open Loop Water-to-Air	4.1	21.2	1/1/2012	10/19/2012
					Closed Loop Water-to-				
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THA-036		Water	3.1	16.1	5/14/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THA-036		Open Loop Water-to- Water	3.5	20.7	5/14/2012	10/19/2012
TERMATHERWING.	THERW GEO	Terra mem	111A-030		Closed Loop Water-to-	0.0	20.1	0/14/2012	10/13/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THA-048		Water	3.1	16.1	5/14/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THA-048		Open Loop Water-to- Water	3.5	20.1	5/14/2012	10/19/2012
I EIXI VAT II IEIXIVI IIIU.	THERW GEO	TOTA THEIT	111/4-040		Closed Loop Water-to-	0.0	<b>2</b> 0. I	01 17120 12	10/13/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THA-060		Water	3.1	16.2	5/14/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THA-060		Open Loop Water-to- Water	3.7	21.4	5/14/2012	10/19/2012
					Closed Loop Water-to-				
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THA-072		Water	3.1	16.1	5/14/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THA-072		Open Loop Water-to- Water	3.7	20.1	5/14/2012	10/19/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
	Drana namo	model italiie			Closed Loop	- Truting		on marrior	Dato Quamiou
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THT-096		Water-to- Water	3.2	17.7	5/14/2012	10/19/2012
TENION-THENWING.	TITIERWOLO	Tena mem	1111-030		Open Loop	J.2	17.7	3/14/2012	10/19/2012
TEDDA THEDMIN	TTUEDMOEO	Terra Therm	THE OOC		Water-to-	2.0	04.4	E/4.4/0040	40/40/0040
TERRA-THERM Inc.	TTHERM GEO	rerra merm	THT-096		Water Closed Loop	3.6	21.4	5/14/2012	10/19/2012
					Water-to-				
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THT-120		Water Open Loop	3.1	17.0	5/14/2012	10/19/2012
					Water-to-				
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	THT-120		Water	3.7	20.2	5/14/2012	10/19/2012
			TST-024 (with_Air Handler model n						
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	umber: TT-A-**- **-24)		Closed Loop Water-to-Air	3.7	18.6	1/1/2012	10/19/2012
TERRA-THERIVITIIC.	TTHERWIGEO	Terra Trierrii	TST-024 (with Air		vvalei-to-Aii	3.1	16.0	1/1/2012	10/19/2012
			Handler_model_n						
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	umber: TT-A-**- **-24)		Open Loop Water-to-Air	4.2	21.6	1/1/2012	10/19/2012
			TST-036 (with_Air						
			Handler_model_n umber: TT-A-**-		Closed Loop				
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	**-36)		Water-to-Air	3.8	17.3	1/1/2012	10/19/2012
			TST-036 (with_Air Handler model n						
			umber: TT-A-**-		Open Loop				
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	**-36) TST-048 (with Air		Water-to-Air	4.2	21.1	1/1/2012	10/19/2012
			Handler_model_n						
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	umber: TT-A-**- **-48)		Closed Loop Water-to-Air	3.8	18.1	1/1/2012	10/19/2012
TERROV THERWING.	TITIETUV GEG	Tena mem	TST-048 (with Air		vater to 7th	0.0	10.1	17 172012	10/13/2012
			Handler_model_n umber: TT-A-**-		Open Loop				
ΓERRA-THERM Inc.	TTHERM GEO	Terra Therm	**-48)		Water-to-Air	4.2	21.6	1/1/2012	10/19/2012
			TST-060 (with_Air						
			Handler_model_n umber: TT-A-**-		Closed Loop				
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	**-60)		Water-to-Air	3.7	17.2	1/1/2012	10/19/2012
			TST-060 (with_Air Handler_model_n						
TEDDA THEDM Inc	TTUEDMOCO	Torro Theres	umber: TT-A-**-		Open Loop	4.2	24.4	1/1/2012	10/10/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	**-60)		Water-to-Air Closed Loop	4.2	21.1	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVA-036		Water-to-Air	3.7	17.5	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVA-036		Open Loop Water-to-Air	4.3	22.9	1/1/2012	10/19/2012
ILINIAT II ILINIVI IIIC.	I II IERWI GEO	Tella IIIellii	I VA-030		Closed Loop	т.Ј	22.3	1/ 1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVA-048		Water-to-Air	3.6	17.1	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVA-048		Open Loop Water-to-Air	4.1	22.2	1/1/2012	10/19/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVA-060		Closed Loop Water-to-Air	3.6	17.1	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVA-060		Open Loop Water-to-Air	4.1	21.4	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-024		Closed Loop Water-to-Air	3.8	19.1	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-024		Open Loop Water-to-Air	4.2	21.9	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-036		Closed Loop Water-to-Air	4.0	18.6	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-036		Open Loop Water-to-Air	4.2	21.8	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-042		Closed Loop Water-to-Air	3.8	18.0	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-042		Open Loop Water-to-Air	4.2	21.7	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-048		Closed Loop Water-to-Air	3.6	18.7	1/1/2012	10/19/2012
TERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-048		Open Loop Water-to-Air	4.1	21.9	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-060		Closed Loop Water-to-Air	4.0	17.9	1/1/2012	10/19/2012
ERRA-THERM Inc.	TTHERM GEO	Terra Therm	TVT-060		Open Loop Water-to-Air	4.2	21.5	1/1/2012	10/19/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC024***1**0		Open Loop Water-to-Air	4.0	22.8	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC024***1**4		Closed Loop Water-to-Air	3.8	17.5	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC024***1**4		Open Loop Water-to-Air	4.5	23.4	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC030***1**0		Open Loop Water-to-Air	4.0	23.0	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC030***1**4		Closed Loop Water-to-Air	3.8	18.3	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC030***1**4		Open Loop Water-to-Air	4.4	23.9	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC036***1**0		Open Loop Water-to-Air	3.9	21.2	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC036***1**4		Closed Loop Water-to-Air	3.6	17.3	6/15/2011	10/19/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC036***1**4		Open Loop Water-to-Air	4.3	23.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC042***1**0		Open Loop Water-to-Air	3.8	22.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC042***1**4		Closed Loop Water-to-Air	3.7	18.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC042***1**4		Open Loop Water-to-Air	4.3	23.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC048***1**4		Closed Loop Water-to-Air	3.6	18.1	6/15/2011	10/12/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC048***1**4		Open Loop Water-to-Air	4.2	23.4	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC060***1**4		Closed Loop Water-to-Air	3.6	17.9	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GC Series	A1GC060***1**4		Open Loop Water-to-Air	4.0	23.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC070***1**4		Closed Loop Water-to-Air	3.6	17.1	6/15/2011	10/19/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GC Series	A1GC070***1**4		Open Loop Water-to-Air	4.1	21.1	6/15/2011	10/19/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A1GN Series	A1GN022*1*		Closed Loop Water-to-Air	3.7	19.5	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GN Series	A1GN022*1*		Open Loop Water-to-Air	4.5	27.9	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GN Series	A1GN030*1*		Closed Loop Water-to-Air	4.0	19.8	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GN Series	A1GN030*1*		Open Loop Water-to-Air	4.9	24.9	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GN Series	A1GN036*1*		Closed Loop Water-to-Air	4.0	19.8	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GN Series	A1GN036*1*		Open Loop Water-to-Air	4.7	27.0	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GN Series	A1GN042*1*		Closed Loop Water-to-Air	3.7	19.9	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GN Series	A1GN042*1*		Open Loop Water-to-Air	4.5	25.3	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GN Series	A1GN048*1*		Closed Loop Water-to-Air	3.8	18.1	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GN Series	A1GN048*1*		Open Loop Water-to-Air	4.5	23.8	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GN Series	A1GN060*1*		Closed Loop Water-to-Air	3.6	17.1	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GN Series	A1GN060*1*		Open Loop Water-to-Air	4.1	21.1	3/1/2012	3/22/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A1GW Series	A1GW018NN*1		Closed Loop Water-to- Water	3.1	16.6	10/1/2009	10/19/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GW Series	A1GW018NN*1		Open Loop Water-to- Water	3.7	22.9	10/1/2009	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GW Series	A1GW025NN*1		Closed Loop Water-to- Water	3.1	16.1	10/1/2009	10/19/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GW Series	A1GW025NN*1		Open Loop Water-to- Water	3.8	21.2	10/1/2009	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GW Series	A1GW040NN*1		Closed Loop Water-to- Water	3.1	17.5	10/1/2009	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GW Series	A1GW040NN*1		Open Loop Water-to- Water	3.9	23.4	10/1/2009	10/12/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Frane and American Standard Heating and Air Conditioning	American Standard	A1GW Series	A1GW050NN*1		Closed Loop Water-to- Water	3.1	16.4	10/1/2009	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GW Series	A1GW050NN*1		Open Loop Water-to- Water	3.7	21.6	10/1/2009	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GW Series	A1GW060NN*1		Closed Loop Water-to- Water	3.1	16.1	10/1/2009	10/19/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GW Series	A1GW060NN*1		Open Loop Water-to- Water	3.8	20.6	10/1/2009	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX022***1**0		Closed Loop Water-to-Air	3.8	20.3	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX022***1**0		Open Loop Water-to-Air	5.0	28.0	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX022***1**1		Closed Loop Water-to-Air	4.0	21.0	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX022***1**1		Open Loop Water-to-Air	5.3	30.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX030***1**0		Closed Loop Water-to-Air	3.8	21.1	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX030***1**0		Open Loop Water-to-Air	4.8	27.1	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX030***1**1		Closed Loop Water-to-Air	4.0	21.9	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX030***1**1		Open Loop Water-to-Air	5.0	28.8	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX036***1**0		Closed Loop Water-to-Air	4.0	19.6	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX036***1**0		Open Loop Water-to-Air	4.7	25.7	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX036***1**1		Closed Loop Water-to-Air	4.4	22.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX036***1**1		Open Loop Water-to-Air	5.2	30.1	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX042***1**0		Closed Loop Water-to-Air	3.7	18.6	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX042***1**0		Open Loop Water-to-Air	4.6	24.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX042***1**1		Closed Loop Water-to-Air	4.2	21.4	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX042***1**1		Open Loop Water-to-Air	5.2	29.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX048***1**0		Closed Loop Water-to-Air	3.6	17.3	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX048***1**0		Open Loop Water-to-Air	4.3	22.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A1GX Series	A1GX048***1**1		Closed Loop Water-to-Air	4.0	19.7	6/15/2011	10/12/2012

				Additional				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Frane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX048***1**1		Open Loop Water-to-Air	4.8	26.1	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX060***1**0		Closed Loop Water-to-Air	3.7	18.5	6/15/2011	10/12/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX060***1**0		Open Loop Water-to-Air	4.4	24.6	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX060***1**1		Closed Loop Water-to-Air	3.9	19.5	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX060***1**1		Open Loop Water-to-Air	4.7	26.1	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX070***1**0		Open Loop Water-to-Air	4.0	21.6	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX070***1**1		Closed Loop Water-to-Air	3.7	18.2	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	American Standard	A1GX Series	A1GX070***1**1		Open Loop Water-to-Air	4.4	23.8	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE026*1*		Closed Loop Water-to-Air	4.1	20.7	3/1/2012	3/22/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE026*1*		Open Loop Water-to-Air	4.7	25.1	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE038*1*		Closed Loop Water-to-Air	4.0	21.2	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE038*1*		Open Loop Water-to-Air	4.4	23.7	3/1/2012	3/22/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE049*1*		Closed Loop Water-to-Air	4.1	19.5	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE049*1*		Open Loop Water-to-Air	4.5	23.0	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE064*1*		Closed Loop Water-to-Air	3.8	18.9	3/1/2012	3/22/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE064*1*		Open Loop Water-to-Air	4.3	22.1	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GE Series	A2GE072*1*		Closed Loop Water-to-Air	3.6	17.5	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GN Series	A2GN026*1*		Closed Loop Water-to-Air	4.1	20.7	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GN Series	A2GN026*1*		Open Loop Water-to-Air	4.7	25.1	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GN Series	A2GN038*1*		Closed Loop Water-to-Air	4.0	21.2	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GN Series	A2GN038*1*		Open Loop Water-to-Air	4.4	23.7	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GN Series	A2GN049*1*		Closed Loop Water-to-Air	4.1	19.5	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GN Series	A2GN049*1*		Open Loop Water-to-Air	4.5	23.0	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GN Series	A2GN064*1*		Closed Loop Water-to-Air	3.7	18.8	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GN Series	A2GN064*1*		Open Loop Water-to-Air	4.3	22.0	3/1/2012	3/22/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Frane and American Standard Heating and Air Conditioning	American Standard	A2GN Series	A2GN072*1*		Closed Loop Water-to-Air	3.6	17.5	3/1/2012	3/22/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A2GW Series	A2GW100*N*1		Closed Loop Water-to- Water	3.2	19.4	6/1/2009	10/12/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A2GW Series	A2GW100*N*1		Open Loop Water-to- Water	3.5	23.2	6/1/2009	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GW Series	A2GW120*N*1		Closed Loop Water-to- Water	3.2	18.6	6/1/2009	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GW Series	A2GW120*N*1		Open Loop Water-to- Water	3.5	22.0	6/1/2009	10/12/2012
Frane and American Standard Heating and Air Conditioning	American Standard	A2GX Series	A2GX026***1**1		Closed Loop Water-to-Air	4.4	22.7	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GX Series	A2GX026***1**1		Open Loop Water-to-Air	5.0	27.6	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	American Standard	A2GX Series	A2GX038***1**1		Closed Loop Water-to-Air	4.5	24.7	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GX Series	A2GX038***1**1		Open Loop Water-to-Air	5.2	28.1	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GX Series	A2GX049***1**1		Closed Loop Water-to-Air	4.4	21.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GX Series	A2GX049***1**1		Open Loop Water-to-Air	4.9	25.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GX Series	A2GX064***1**1		Closed Loop Water-to-Air	4.0	21.8	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GX Series	A2GX064***1**1		Open Loop Water-to-Air	4.7	26.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GX Series	A2GX072***1**1		Closed Loop Water-to-Air	4.0	19.9	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GX Series	A2GX072***1**1		Open Loop Water-to-Air	4.5	23.2	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GY Series	A2GY038***1*		Closed Loop Water-to-Air	4.2	21.1	7/1/2008	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GY Series	A2GY038***1*		Open Loop Water-to-Air	4.8	23.7	7/1/2008	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GY Series	A2GY049***1*		Closed Loop Water-to-Air	3.9	19.1	7/1/2008	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GY Series	A2GY049***1*		Open Loop Water-to-Air	4.6	23.7	7/1/2008	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GY Series	A2GY064***1*		Closed Loop Water-to-Air	3.7	18.1	7/1/2008	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GY Series	A2GY064***1*		Open Loop Water-to-Air	4.2	21.5	7/1/2008	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GY Series	A2GY072***1*		Closed Loop Water-to-Air	3.7	17.6	7/1/2008	10/12/2012
rane and American Standard Heating nd Air Conditioning	American Standard	A2GY Series	A2GY072***1*		Open Loop Water-to-Air	4.1	21.1	7/1/2008	10/19/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC024***1**0		Open Loop Water-to-Air	4.0	22.8	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC024***1**4		Closed Loop Water-to-Air	3.8	17.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC024***1**4		Open Loop Water-to-Air	4.5	23.4	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC030***1**0		Open Loop Water-to-Air	4.0	23.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC030***1**4		Closed Loop Water-to-Air	3.8	18.3	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC030***1**4		Open Loop Water-to-Air	4.4	23.9	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC036***1**0		Open Loop Water-to-Air	3.9	21.2	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC036***1**4		Closed Loop Water-to-Air	3.6	17.3	6/15/2011	10/19/2012
rane and American Standard Heating and Air Conditioning	Trane	T1GC Series	T1GC036***1**4		Open Loop Water-to-Air	4.3	23.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC042***1**0		Open Loop Water-to-Air	3.8	22.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC042***1**4		Closed Loop Water-to-Air	3.7	18.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC042***1**4		Open Loop Water-to-Air	4.3	23.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC048***1**4		Closed Loop Water-to-Air	3.6	18.1	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC048***1**4		Open Loop Water-to-Air	4.2	23.4	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC060***1**4		Closed Loop Water-to-Air	3.6	17.9	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC060***1**4		Open Loop Water-to-Air	4.0	23.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC070***1**4		Closed Loop Water-to-Air	3.6	17.1	6/15/2011	10/19/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GC Series	T1GC070***1**4		Open Loop Water-to-Air	4.1	21.1	6/15/2011	10/19/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GN Series	T1GN022*1*		Closed Loop Water-to-Air	3.7	19.5	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GN Series	T1GN022*1*		Open Loop Water-to-Air	4.5	27.9	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GN Series	T1GN030*1*		Closed Loop Water-to-Air	4.0	19.8	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GN Series	T1GN030*1*		Open Loop Water-to-Air	4.9	24.9	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	Trane	T1GN Series	T1GN036*1*		Closed Loop Water-to-Air	4.0	19.8	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	Trane	T1GN Series	T1GN036*1*		Open Loop Water-to-Air	4.7	27.0	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	Trane	T1GN Series	T1GN042*1*		Closed Loop Water-to-Air	3.7	19.9	3/1/2012	3/22/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Trane and American Standard Heating and Air Conditioning	Trane	T1GN Series	T1GN042*1*		Open Loop Water-to-Air	4.5	25.3	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GN Series	T1GN048*1*		Closed Loop Water-to-Air	3.8	18.1	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GN Series	T1GN048*1*		Open Loop Water-to-Air	4.5	23.8	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GN Series	T1GN060*1*		Closed Loop Water-to-Air	3.6	17.1	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GN Series	T1GN060*1*		Open Loop Water-to-Air	4.1	21.1	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW018NN*1		Closed Loop Water-to- Water	3.1	16.6	10/1/2009	10/19/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW018NN*1		Open Loop Water-to- Water	3.7	22.9	10/1/2009	10/12/2012
Trane and American Standard Heating		T1GW Series	T1GW025NN*1		Closed Loop Water-to- Water	3.1	16.1	10/1/2009	10/12/2012
and Air Conditioning  Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW025NN*1		Open Loop Water-to- Water	3.8	21.2	10/1/2009	10/19/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW040NN*1		Closed Loop Water-to- Water	3.1	17.5	10/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW040NN*1		Open Loop Water-to- Water	3.9	23.4	10/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW050NN*1		Closed Loop Water-to- Water	3.1	16.4	10/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW050NN*1		Open Loop Water-to- Water	3.7	21.6	10/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW060NN*1		Closed Loop Water-to- Water	3.1	16.1	10/1/2009	10/19/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GW Series	T1GW060NN*1		Open Loop Water-to- Water	3.8	20.6	10/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GX Series	T1GX022***1**0		Closed Loop Water-to-Air	3.8	20.3	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GX Series	T1GX022***1**0		Open Loop Water-to-Air	5.0	28.0	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GX Series	T1GX022***1**1		Closed Loop Water-to-Air	4.0	21.0	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GX Series	T1GX022***1**1		Open Loop Water-to-Air	5.3	30.0	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GX Series	T1GX030***1**0		Closed Loop Water-to-Air	3.8	21.1	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T1GX Series	T1GX030***1**0		Open Loop Water-to-Air	4.8	27.1	6/15/2011	10/12/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX030***1**1		Closed Loop Water-to-Air	4.0	21.9	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX030***1**1		Open Loop Water-to-Air	5.0	28.8	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX036***1**0		Closed Loop Water-to-Air	4.0	19.6	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX036***1**0		Open Loop Water-to-Air	4.7	25.7	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX036***1**1		Closed Loop Water-to-Air	4.4	22.0	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX036***1**1		Open Loop Water-to-Air	5.2	30.1	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX042***1**0		Closed Loop Water-to-Air	3.7	18.6	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX042***1**0		Open Loop Water-to-Air	4.6	24.5	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	Trane	T1GX Series	T1GX042***1**1		Closed Loop Water-to-Air	4.2	21.4	6/15/2011	10/12/2012
rane and American Standard Heating and Air Conditioning	Trane	T1GX Series	T1GX042***1**1		Open Loop Water-to-Air	5.2	29.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX048***1**0		Closed Loop Water-to-Air	3.6	17.3	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX048***1**0		Open Loop Water-to-Air	4.3	22.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX048***1**1		Closed Loop Water-to-Air	4.0	19.7	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX048***1**1		Open Loop Water-to-Air	4.8	26.1	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX060***1**0		Closed Loop Water-to-Air	3.7	18.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX060***1**0		Open Loop Water-to-Air	4.4	24.6	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX060***1**1		Closed Loop Water-to-Air	3.9	19.5	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX060***1**1		Open Loop Water-to-Air	4.7	26.1	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX070***1**0		Open Loop Water-to-Air	4.0	21.6	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX070***1**1		Closed Loop Water-to-Air	3.7	18.2	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T1GX Series	T1GX070***1**1		Open Loop Water-to-Air	4.4	23.8	6/15/2011	10/12/2012
rane and American Standard Heating nd Air Conditioning	Trane	T2GE Series	T2GE026*1*		Closed Loop Water-to-Air	4.1	20.7	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	Trane	T2GE Series	T2GE026*1*		Open Loop Water-to-Air	4.7	25.1	3/1/2012	3/22/2012
rane and American Standard Heating nd Air Conditioning	Trane	T2GE Series	T2GE038*1*		Closed Loop Water-to-Air	4.0	21.2	3/1/2012	3/22/2012
rane and American Standard Heating and Air Conditioning	Trane	T2GE Series	T2GE038*1*		Open Loop Water-to-Air	4.4	23.7	3/1/2012	3/22/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
Trane and American Standard Heating and Air Conditioning	Trane	T2GE Series	T2GE049*1*		Closed Loop Water-to-Air	4.1	19.5	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GE Series	T2GE049*1*		Open Loop Water-to-Air	4.5	23.0	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GE Series	T2GE064*1*		Closed Loop Water-to-Air	3.8	18.9	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GE Series	T2GE064*1*		Open Loop Water-to-Air	4.3	22.1	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GE Series	T2GE072*1*		Closed Loop Water-to-Air	3.6	17.5	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN026*1*		Closed Loop Water-to-Air	4.1	20.7	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN026*1*		Open Loop Water-to-Air	4.7	25.1	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN038*1*		Closed Loop Water-to-Air	4.0	21.2	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN038*1*		Open Loop Water-to-Air	4.4	23.7	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN049*1*		Closed Loop Water-to-Air	4.1	19.5	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN049*1*		Open Loop Water-to-Air	4.5	23.0	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN064*1*		Closed Loop Water-to-Air	3.7	18.8	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN064*1*		Open Loop Water-to-Air	4.3	22.0	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GN Series	T2GN072*1*		Closed Loop Water-to-Air	3.6	17.5	3/1/2012	3/22/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GW Series	T2GW100*N*1		Closed Loop Water-to- Water	3.2	19.4	6/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GW Series	T2GW100*N*1		Open Loop Water-to- Water	3.5	23.2	6/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GW Series	T2GW120*N*1		Closed Loop Water-to- Water	3.2	18.6	6/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GW Series	T2GW120*N*1		Open Loop Water-to- Water	3.5	22.0	6/1/2009	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX026***1**1		Closed Loop Water-to-Air	4.4	22.7	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX026***1**1		Open Loop Water-to-Air	5.0	27.6	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX038***1**1		Closed Loop Water-to-Air	4.5	24.7	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX038***1**1		Open Loop Water-to-Air	5.2	28.1	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX049***1**1		Closed Loop Water-to-Air	4.4	21.5	6/15/2011	10/12/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
Trane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX049***1**1		Open Loop Water-to-Air	4.9	25.5	6/15/2011	10/12/2012
Frane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX064***1**1		Closed Loop Water-to-Air	4.0	21.8	6/15/2011	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX064***1**1		Open Loop Water-to-Air	4.7	26.0	6/15/2011	10/12/2012
Frane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX072***1**1		Closed Loop Water-to-Air	4.0	19.9	6/15/2011	10/12/2012
Frane and American Standard Heating and Air Conditioning	Trane	T2GX Series	T2GX072***1**1		Open Loop Water-to-Air	4.5	23.2	6/15/2011	10/12/2012
Frane and American Standard Heating and Air Conditioning	Trane	T2GY Series	T2GY038***1*		Closed Loop Water-to-Air	4.2	21.1	7/1/2008	10/12/2012
Frane and American Standard Heating and Air Conditioning	Trane	T2GY Series	T2GY038***1*		Open Loop Water-to-Air	4.8	23.7	7/1/2008	10/12/2012
Frane and American Standard Heating and Air Conditioning	Trane	T2GY Series	T2GY049***1*		Closed Loop Water-to-Air	3.9	19.1	7/1/2008	10/12/2012
Trane and American Standard Heating and Air Conditioning	Trane	T2GY Series	T2GY049***1*		Open Loop Water-to-Air	4.6	23.7	7/1/2008	10/12/2012
Frane and American Standard Heating and Air Conditioning	Trane	T2GY Series	T2GY064***1*		Closed Loop Water-to-Air	3.7	18.1	7/1/2008	10/12/2012
rane and American Standard Heating and Air Conditioning	Trane	T2GY Series	T2GY064***1*		Open Loop Water-to-Air	4.2	21.5	7/1/2008	10/12/2012
rane and American Standard Heating and Air Conditioning	Trane	T2GY Series	T2GY072***1*		Closed Loop Water-to-Air	3.7	17.6	7/1/2008	10/12/2012
rane and American Standard Heating and Air Conditioning	Trane	T2GY Series	T2GY072***1*		Open Loop Water-to-Air	4.1	21.1	7/1/2008	10/19/2012
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH024*1*4		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH024*1*4		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH024*1*4		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH024*1*4		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH030*1*4		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH030*1*4		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH030*1*4		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH030*1*4		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH036*1*4		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH036*1*4		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH036*1*4		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH042*1*4		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/8/2011

				Additional				Data Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
WaterFurnace International, ncorporated	WaterFurnace	Legend	LSH042*1*4		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH042*1*4		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/8/2011
WaterFurnace International, ncorporated	WaterFurnace	Legend	LSH042*1*4		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH048*1*4		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH048*1*4		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH048*1*4		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH048*1*4		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH060*1*4		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH060*1*4		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH060*1*4		Open Loop Water-to-Air	4.1	23.0	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH070*1*4		Closed Loop Water-to-Air	3.6	17.1	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSH070*1*4		Open Loop Water-to-Air	4.1	21.1	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV024*1*4		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV024*1*4		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV024*1*4		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV024*1*4		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV030*1*4		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV030*1*4		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV030*1*4		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV030*1*4		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV036*1*4		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV036*1*4		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV036*1*4		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/18/2011
VaterFurnace International,	WaterFurnace	Legend	LSV042*1*4		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/8/2011
VaterFurnace International,	WaterFurnace	Legend	LSV042*1*4		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/18/2011

				Additional				Data Assailable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
NaterFurnace International, ncorporated	WaterFurnace	Legend	LSV042*1*4		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/8/2011
WaterFurnace International, ncorporated	WaterFurnace	Legend	LSV042*1*4		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/18/2011
NaterFurnace International, ncorporated	WaterFurnace	Legend	LSV048*1*4		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV048*1*4		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV048*1*4		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV048*1*4		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV060*1*4		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV060*1*4		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV060*1*4		Open Loop Water-to-Air	4.1	23.0	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV070*1*4		Closed Loop Water-to-Air	3.6	17.1	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Legend	LSV070*1*4		Open Loop Water-to-Air	4.1	21.1	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Console	NC_15		Open Loop Water-to-Air	4.1	22.0	5/1/2008	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Console	NC_15		Open Loop Water-to-Air	4.1	22.0	5/1/2008	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH026		Closed Loop Water-to-Air	4.4	22.7	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH026		Closed Loop Water-to-Air	4.4	22.7	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH026		Open Loop Water-to-Air	5.2	27.6	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH026		Open Loop Water-to-Air	5.2	27.6	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH026F1*1		Closed Loop Water-to-Air	4.6	24.2	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH026F1*1		Open Loop Water-to-Air	5.2	28.4	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH026F1*4		Closed Loop Water-to-Air	4.6	24.2	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH026F1*4		Open Loop Water-to-Air	5.2	28.4	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH038		Closed Loop Water-to-Air	4.6	25.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH038		Closed Loop Water-to-Air	4.6	25.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH038		Open Loop Water-to-Air	5.2	28.1	6/1/2006	2/8/2011
/aterFurnace International,	WaterFurnace	Envision Series	NDH038		Open Loop Water-to-Air	5.2	28.1	6/1/2006	2/18/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH038F1*1		Closed Loop Water-to-Air	4.5	25.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH038F1*1		Open Loop Water-to-Air	5.0	29.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH038F1*4		Closed Loop Water-to-Air	4.5	25.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH038F1*4		Open Loop Water-to-Air	5.0	29.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH049		Closed Loop Water-to-Air	4.4	21.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH049		Closed Loop Water-to-Air	4.4	21.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH049		Open Loop Water-to-Air	5.0	25.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH049		Open Loop Water-to-Air	5.0	25.5	6/1/2006	2/18/2011
NaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH049F1*1		Closed Loop Water-to-Air	4.3	24.3	3/1/2012	3/22/2012
NaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH049F1*1		Open Loop Water-to-Air	4.7	28.8	3/1/2012	3/22/2012
NaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH049F1*4		Closed Loop Water-to-Air	4.3	24.3	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH049F1*4		Open Loop Water-to-Air	4.7	28.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH064		Closed Loop Water-to-Air	4.0	21.8	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH064		Closed Loop Water-to-Air	4.0	21.8	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH064		Open Loop Water-to-Air	4.7	26.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH064		Open Loop Water-to-Air	4.7	26.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH064F1*1		Closed Loop Water-to-Air	4.2	22.3	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH064F1*1		Open Loop Water-to-Air	4.9	26.9	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH064F1*4		Closed Loop Water-to-Air	4.2	22.3	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH064F1*4		Open Loop Water-to-Air	4.9	26.9	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH072		Closed Loop Water-to-Air	4.0	19.9	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH072		Closed Loop Water-to-Air	4.0	19.9	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH072		Open Loop Water-to-Air	4.5	23.2	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDH072		Open Loop Water-to-Air	4.5	23.2	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH072F1*1		Closed Loop Water-to-Air	3.9	20.2	3/1/2012	3/22/2012

				Additional				Data Assallable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH072F1*1		Open Loop Water-to-Air	4.4	24.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH072F1*4		Closed Loop Water-to-Air	3.9	20.2	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDH072F1*4		Open Loop Water-to-Air	4.4	24.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS026		Closed Loop Water-to-Air	4.1	20.7	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS026		Closed Loop Water-to-Air	4.1	20.7	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS026		Open Loop Water-to-Air	4.7	25.1	6/1/2006	2/8/2011
/aterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS026		Open Loop Water-to-Air	4.7	25.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS038		Closed Loop Water-to-Air	4.0	21.2	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS038		Closed Loop Water-to-Air	4.0	21.2	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS038		Open Loop Water-to-Air	4.4	23.7	6/1/2006	2/8/2011
/aterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS038		Open Loop Water-to-Air	4.4	23.7	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS049		Closed Loop Water-to-Air	4.0	19.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS049		Closed Loop Water-to-Air	4.0	19.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS049		Open Loop Water-to-Air	4.5	23.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS049		Open Loop Water-to-Air	4.5	23.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS064		Closed Loop Water-to-Air	3.7	18.8	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS064		Closed Loop Water-to-Air	3.7	18.8	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS064		Open Loop Water-to-Air	4.3	22.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDS064		Open Loop Water-to-Air	4.3	22.0	6/1/2006	2/18/2011
/aterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV026		Closed Loop Water-to-Air	4.4	22.7	6/1/2006	2/8/2011
/aterFurnace International, corporated	WaterFurnace	Envision Series	NDV026		Closed Loop Water-to-Air	4.4	22.7	6/1/2006	2/18/2011
/aterFurnace International, corporated	WaterFurnace	Envision Series	NDV026		Open Loop Water-to-Air	5.2	27.6	6/1/2006	2/8/2011
/aterFurnace International, corporated	WaterFurnace	Envision Series	NDV026		Open Loop Water-to-Air	5.2	27.6	6/1/2006	2/18/2011
/aterFurnace International, corporated	WaterFurnace	5 Series	NDV026F1*1		Closed Loop Water-to-Air	4.6	24.2	3/1/2012	3/22/2012
/aterFurnace International, corporated	WaterFurnace	5 Series	NDV026F1*1		Open Loop Water-to-Air	5.2	28.4	3/1/2012	3/22/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV026F1*4		Closed Loop Water-to-Air	4.6	24.2	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV026F1*4		Open Loop Water-to-Air	5.2	28.4	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDV038		Closed Loop Water-to-Air	4.6	25.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDV038		Closed Loop Water-to-Air	4.6	25.0	6/1/2006	2/18/2011
WaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV038		Open Loop Water-to-Air	5.2	28.1	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDV038		Open Loop Water-to-Air	5.2	28.1	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV038F1*1		Closed Loop Water-to-Air	4.5	25.5	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV038F1*1		Open Loop Water-to-Air	5.0	29.8	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV038F1*4		Closed Loop Water-to-Air	4.5	25.5	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV038F1*4		Open Loop Water-to-Air	5.0	29.8	3/1/2012	3/22/2012
WaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV049		Closed Loop Water-to-Air	4.4	21.5	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDV049		Closed Loop Water-to-Air	4.4	21.5	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDV049		Open Loop Water-to-Air	5.0	25.5	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDV049		Open Loop Water-to-Air	5.0	25.5	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV049F1*1		Closed Loop Water-to-Air	4.3	24.3	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV049F1*1		Open Loop Water-to-Air	4.7	28.8	3/1/2012	3/22/2012
WaterFurnace International, ncorporated	WaterFurnace	5 Series	NDV049F1*4		Closed Loop Water-to-Air	4.3	24.3	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV049F1*4		Open Loop Water-to-Air	4.7	28.8	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDV064		Closed Loop Water-to-Air	4.0	21.8	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDV064		Closed Loop Water-to-Air	4.0	21.8	6/1/2006	2/18/2011
NaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV064		Open Loop Water-to-Air	4.7	26.0	6/1/2006	2/8/2011
NaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV064		Open Loop Water-to-Air	4.7	26.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV064F1*1		Closed Loop Water-to-Air	4.2	22.3	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV064F1*1		Open Loop Water-to-Air	4.9	26.9	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NDV064F1*4		Closed Loop Water-to-Air	4.2	22.3	3/1/2012	3/22/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
NaterFurnace International, ncorporated	WaterFurnace	5 Series	NDV064F1*4		Open Loop Water-to-Air	4.9	26.9	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV072		Closed Loop Water-to-Air	4.0	19.9	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV072		Closed Loop Water-to-Air	4.0	19.9	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV072		Open Loop Water-to-Air	4.5	23.2	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDV072		Open Loop Water-to-Air	4.5	23.2	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDV072F1*1		Closed Loop Water-to-Air	3.9	20.2	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NDV072F1*1		Open Loop Water-to-Air	4.4	24.5	3/1/2012	3/22/2012
WaterFurnace International, ncorporated	WaterFurnace	5 Series	NDV072F1*4		Closed Loop Water-to-Air	3.9	20.2	3/1/2012	3/22/2012
NaterFurnace International, ncorporated	WaterFurnace	5 Series	NDV072F1*4		Open Loop Water-to-Air	4.4	24.5	3/1/2012	3/22/2012
NaterFurnace International, ncorporated	WaterFurnace	Envision NDW Series Dual Capacity	NDW100		Closed Loop Water-to- Water	3.2	19.4	6/1/2009	5/20/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision NDW Series Dual Capacity	NDW100		Open Loop Water-to- Water	3.5	23.3	6/1/2009	5/20/2011
.  NaterFurnace International, ncorporated	WaterFurnace	Envision NDW Series Dual Capacity	NDW120		Closed Loop Water-to- Water	3.2	19.0	6/1/2009	5/20/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision NDW Series Dual Capacity	NDW120		Open Loop Water-to- Water	3.5	22.3	6/1/2009	5/20/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDZ026		Closed Loop Water-to-Air	4.1	20.7	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDZ026		Closed Loop Water-to-Air	4.1	20.7	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDZ026		Open Loop Water-to-Air	4.7	25.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDZ026		Open Loop Water-to-Air	4.7	25.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDZ038		Closed Loop Water-to-Air	4.0	21.2	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDZ038		Closed Loop Water-to-Air	4.0	21.2	6/1/2006	2/18/2011
VaterFurnace International,	WaterFurnace	Envision Series	NDZ038		Open Loop Water-to-Air	4.4	23.7	6/1/2006	2/8/2011
VaterFurnace International,	WaterFurnace	Envision Series	NDZ038		Open Loop Water-to-Air	4.4	23.7	6/1/2006	2/18/2011
VaterFurnace International,	WaterFurnace	Envision Series	NDZ049		Closed Loop Water-to-Air	4.0	19.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NDZ049		Closed Loop Water-to-Air	4.0	19.5	6/1/2006	2/18/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDZ049		Open Loop Water-to-Air	4.5	23.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDZ049		Open Loop Water-to-Air	4.5	23.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDZ064		Closed Loop Water-to-Air	3.7	18.8	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDZ064		Closed Loop Water-to-Air	3.7	18.8	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDZ064		Open Loop Water-to-Air	4.3	22.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDZ064		Open Loop Water-to-Air	4.3	22.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NDZ072		Closed Loop Water-to-Air	3.6	17.5	6/1/2006	5/12/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NHW084*1		Closed Loop Water-to- Water	3.3	17.5	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NHW084*1		Open Loop Water-to- Water	3.9	20.6	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH009		Open Loop Water-to-Air	4.4	22.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH009		Open Loop Water-to-Air	4.4	22.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH012		Open Loop Water-to-Air	4.5	25.5	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH012		Open Loop Water-to-Air	4.5	25.5	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH012F1*0		Closed Loop Water-to-Air	3.7	18.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH012F1*0		Open Loop Water-to-Air	4.5	25.5	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH015***0		Closed Loop Water-to-Air	3.7	18.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH015***0		Closed Loop Water-to-Air	3.7	18.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH015***1		Closed Loop Water-to-Air	3.8	18.5	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH015***1		Closed Loop Water-to-Air	3.8	18.5	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH015***1		Open Loop Water-to-Air	4.7	27.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH015***1		Open Loop Water-to-Air	4.7	27.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH018***0		Closed Loop Water-to-Air	3.6	18.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH018***0		Closed Loop Water-to-Air	3.6	18.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH018***0		Open Loop Water-to-Air	4.4	25.5	6/1/2006	2/8/2011

				Additional				Data Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH018***0		Open Loop Water-to-Air	4.4	25.5	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH018***1		Closed Loop Water-to-Air	3.9	19.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH018***1		Closed Loop Water-to-Air	3.9	19.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH018***1		Open Loop Water-to-Air	4.7	26.8	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH018***1		Open Loop Water-to-Air	4.7	26.8	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH018F1*0		Closed Loop Water-to-Air	3.8	18.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH018F1*0		Open Loop Water-to-Air	4.4	25.5	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH018F1*1		Closed Loop Water-to-Air	4.1	19.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH018F1*1		Open Loop Water-to-Air	4.7	26.8	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH018F1*4		Closed Loop Water-to-Air	4.1	19.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH018F1*4		Open Loop Water-to-Air	4.7	26.8	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH022***0		Closed Loop Water-to-Air	3.8	20.3	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH022***0		Closed Loop Water-to-Air	3.8	20.3	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH022***0		Open Loop Water-to-Air	5.0	28.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH022***0		Open Loop Water-to-Air	5.0	28.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH022***1		Closed Loop Water-to-Air	4.0	21.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH022***1		Closed Loop Water-to-Air	4.0	21.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH022***1		Open Loop Water-to-Air	5.3	30.0	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSH022***1		Open Loop Water-to-Air	5.3	30.0	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH022F1*0		Closed Loop Water-to-Air	3.7	20.5	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH022F1*0		Open Loop Water-to-Air	4.6	28.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH022F1*1		Closed Loop Water-to-Air	3.9	23.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH022F1*1		Open Loop Water-to-Air	4.8	30.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH022F1*4		Closed Loop Water-to-Air	3.9	23.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSH022F1*4		Open Loop Water-to-Air	4.8	30.0	3/1/2012	3/22/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH030***0		Closed Loop Water-to-Air	3.8	21.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH030***0		Closed Loop Water-to-Air	3.8	21.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH030***0		Open Loop Water-to-Air	4.8	27.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH030***0		Open Loop Water-to-Air	4.8	27.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH030***1		Closed Loop Water-to-Air	4.0	21.9	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH030***1		Closed Loop Water-to-Air	4.0	21.9	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH030***1		Open Loop Water-to-Air	5.0	28.8	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH030***1		Open Loop Water-to-Air	5.0	28.8	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH030F1*0		Closed Loop Water-to-Air	3.8	21.1	3/1/2012	3/22/2012
NaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH030F1*0		Open Loop Water-to-Air	4.7	27.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH030F1*1		Closed Loop Water-to-Air	4.0	21.9	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH030F1*1		Open Loop Water-to-Air	4.8	29.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH030F1*4		Closed Loop Water-to-Air	4.0	21.9	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH030F1*4		Open Loop Water-to-Air	4.8	29.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH036***0		Closed Loop Water-to-Air	4.0	19.6	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH036***0		Closed Loop Water-to-Air	4.0	19.6	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH036***0		Open Loop Water-to-Air	4.7	25.7	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH036***0		Open Loop Water-to-Air	4.7	25.7	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH036***1		Closed Loop Water-to-Air	4.4	22.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH036***1		Closed Loop Water-to-Air	4.4	22.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH036***1		Open Loop Water-to-Air	5.2	30.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH036***1		Open Loop Water-to-Air	5.2	30.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH036F1*0		Closed Loop Water-to-Air	4.0	19.6	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH036F1*0		Open Loop Water-to-Air	4.7	25.7	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH036F1*1		Closed Loop Water-to-Air	4.4	22.4	3/1/2012	3/22/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH036F1*1		Open Loop Water-to-Air	5.1	30.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH036F1*4		Closed Loop Water-to-Air	4.4	22.4	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH036F1*4		Open Loop Water-to-Air	5.1	30.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH042***0		Closed Loop Water-to-Air	3.7	18.6	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH042***0		Closed Loop Water-to-Air	3.7	18.6	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH042***0		Open Loop Water-to-Air	4.6	24.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH042***0		Open Loop Water-to-Air	4.6	24.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH042***1		Closed Loop Water-to-Air	4.2	21.4	6/1/2006	2/8/2011
NaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH042***1		Closed Loop Water-to-Air	4.2	21.4	6/1/2006	2/18/2011
NaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH042***1		Open Loop Water-to-Air	5.2	29.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH042***1		Open Loop Water-to-Air	5.2	29.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH042F1*0		Closed Loop Water-to-Air	3.7	18.6	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH042F1*0		Open Loop Water-to-Air	4.3	24.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH042F1*1		Closed Loop Water-to-Air	4.2	21.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH042F1*1		Open Loop Water-to-Air	4.9	29.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH042F1*4		Closed Loop Water-to-Air	4.2	21.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH042F1*4		Open Loop Water-to-Air	4.9	29.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH048***0		Closed Loop Water-to-Air	3.6	17.3	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH048***0		Closed Loop Water-to-Air	3.6	17.3	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH048***0		Open Loop Water-to-Air	4.3	22.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH048***0		Open Loop Water-to-Air	4.3	22.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH048***1		Closed Loop Water-to-Air	4.0	19.7	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH048***1		Closed Loop Water-to-Air	4.0	19.7	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH048***1		Open Loop Water-to-Air	4.8	26.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH048***1		Open Loop Water-to-Air	4.8	26.1	6/1/2006	2/18/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH048F1*0		Closed Loop Water-to-Air	3.6	17.3	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH048F1*0		Open Loop Water-to-Air	4.2	22.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH048F1*1		Closed Loop Water-to-Air	3.9	20.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH048F1*1		Open Loop Water-to-Air	4.7	26.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH048F1*4		Closed Loop Water-to-Air	3.9	20.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH048F1*4		Open Loop Water-to-Air	4.7	26.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH060***0		Closed Loop Water-to-Air	3.7	18.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH060***0		Closed Loop Water-to-Air	3.7	18.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH060***0		Open Loop Water-to-Air	4.4	24.6	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH060***0		Open Loop Water-to-Air	4.4	24.6	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH060***1		Closed Loop Water-to-Air	3.9	19.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH060***1		Closed Loop Water-to-Air	3.9	19.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH060***1		Open Loop Water-to-Air	4.7	26.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH060***1		Open Loop Water-to-Air	4.7	26.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH060F1*0		Closed Loop Water-to-Air	3.7	18.2	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH060F1*0		Open Loop Water-to-Air	4.4	23.2	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH060F1*1		Closed Loop Water-to-Air	4.0	19.2	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH060F1*1		Open Loop Water-to-Air	4.7	24.7	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH060F1*4		Closed Loop Water-to-Air	4.0	19.2	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH060F1*4		Open Loop Water-to-Air	4.7	24.7	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSH070***1		Closed Loop Water-to-Air	3.7	18.2	6/1/2006	2/8/2011
/aterFurnace International,	WaterFurnace	Envision Series	NSH070***1		Closed Loop Water-to-Air	3.7	18.2	6/1/2006	2/18/2011
VaterFurnace International, acorporated	WaterFurnace	Envision Series	NSH070***1		Open Loop Water-to-Air	4.4	23.8	6/1/2006	2/8/2011
/aterFurnace International,	WaterFurnace	Envision Series	NSH070***1		Open Loop Water-to-Air	4.4	23.8	6/1/2006	2/18/2011
/aterFurnace International,	WaterFurnace	5 Series	NSH070F1*1		Closed Loop Water-to-Air	3.7	18.0	3/1/2012	3/22/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH070F1*1		Open Loop Water-to-Air	4.4	23.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH070F1*4		Closed Loop Water-to-Air	3.7	18.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSH070F1*4		Open Loop Water-to-Air	4.4	23.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV009		Open Loop Water-to-Air	4.4	22.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV009		Open Loop Water-to-Air	4.4	22.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV012		Open Loop Water-to-Air	4.5	25.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV012		Open Loop Water-to-Air	4.5	25.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV012F1*0		Closed Loop Water-to-Air	3.7	18.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV012F1*0		Open Loop Water-to-Air	4.5	25.5	3/1/2012	3/22/2012
NaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV015***0		Closed Loop Water-to-Air	3.7	18.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV015***0		Closed Loop Water-to-Air	3.7	18.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV015***1		Closed Loop Water-to-Air	3.8	18.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV015***1		Closed Loop Water-to-Air	3.8	18.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV015***1		Open Loop Water-to-Air	4.7	27.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV015***1		Open Loop Water-to-Air	4.7	27.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV018***0		Closed Loop Water-to-Air	3.6	18.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV018***0		Closed Loop Water-to-Air	3.6	18.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV018***0		Open Loop Water-to-Air	4.4	25.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV018***0		Open Loop Water-to-Air	4.4	25.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV018***1		Closed Loop Water-to-Air	3.9	19.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV018***1		Closed Loop Water-to-Air	3.9	19.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV018***1		Open Loop Water-to-Air	4.7	26.8	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV018***1		Open Loop Water-to-Air	4.7	26.8	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV018F1*0		Closed Loop Water-to-Air	3.8	18.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV018F1*0		Open Loop Water-to-Air	4.4	25.5	3/1/2012	3/22/2012

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
NaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV018F1*1		Closed Loop Water-to-Air	4.1	19.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV018F1*1		Open Loop Water-to-Air	4.7	26.8	3/1/2012	3/22/2012
NaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV018F1*4		Closed Loop Water-to-Air	4.1	19.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV018F1*4		Open Loop Water-to-Air	4.7	26.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV022***0		Closed Loop Water-to-Air	3.8	20.3	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV022***0		Closed Loop Water-to-Air	3.8	20.3	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV022***0		Open Loop Water-to-Air	5.0	28.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV022***0		Open Loop Water-to-Air	5.0	28.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV022***1		Closed Loop Water-to-Air	4.0	21.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV022***1		Closed Loop Water-to-Air	4.0	21.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV022***1		Open Loop Water-to-Air	5.3	30.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV022***1		Open Loop Water-to-Air	5.3	30.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV022F1*0		Closed Loop Water-to-Air	3.7	20.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV022F1*0		Open Loop Water-to-Air	4.6	28.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV022F1*1		Closed Loop Water-to-Air	3.9	23.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV022F1*1		Open Loop Water-to-Air	4.8	30.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV022F1*4		Closed Loop Water-to-Air	3.9	23.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV022F1*4		Open Loop Water-to-Air	4.8	30.0	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV030***0		Closed Loop Water-to-Air	3.8	21.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV030***0		Closed Loop Water-to-Air	3.8	21.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV030***0		Open Loop Water-to-Air	4.8	27.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV030***0		Open Loop Water-to-Air	4.8	27.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV030***1		Closed Loop Water-to-Air	4.0	21.9	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV030***1		Closed Loop Water-to-Air	4.0	21.9	6/1/2006	2/18/2011
VaterFurnace International,	WaterFurnace	Envision Series	NSV030***1		Open Loop Water-to-Air	5.0	28.8	6/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV030***1		Open Loop Water-to-Air	5.0	28.8	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV030F1*0		Closed Loop Water-to-Air	3.8	21.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV030F1*0		Open Loop Water-to-Air	4.7	27.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV030F1*1		Closed Loop Water-to-Air	4.0	21.9	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV030F1*1		Open Loop Water-to-Air	4.8	29.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV030F1*4		Closed Loop Water-to-Air	4.0	21.9	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV030F1*4		Open Loop Water-to-Air	4.8	29.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV036***0		Closed Loop Water-to-Air	4.0	19.6	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV036***0		Closed Loop Water-to-Air	4.0	19.6	6/1/2006	2/18/2011
NaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV036***0		Open Loop Water-to-Air	4.7	25.7	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV036***0		Open Loop Water-to-Air	4.7	25.7	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV036***1		Closed Loop Water-to-Air	4.4	22.0	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV036***1		Closed Loop Water-to-Air	4.4	22.0	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV036***1		Open Loop Water-to-Air	5.2	30.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV036***1		Open Loop Water-to-Air	5.2	30.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV036F1*0		Closed Loop Water-to-Air	4.0	19.6	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV036F1*0		Open Loop Water-to-Air	4.7	25.7	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV036F1*1		Closed Loop Water-to-Air	4.4	22.4	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV036F1*1		Open Loop Water-to-Air	5.1	30.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV036F1*4		Closed Loop Water-to-Air	4.4	22.4	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV036F1*4		Open Loop Water-to-Air	5.1	30.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV042***0		Closed Loop Water-to-Air	3.7	18.6	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV042***0		Closed Loop Water-to-Air	3.7	18.6	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV042***0		Open Loop Water-to-Air	4.6	24.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV042***0		Open Loop Water-to-Air	4.6	24.5	6/1/2006	2/18/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV042***1		Closed Loop Water-to-Air	4.2	21.4	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV042***1		Closed Loop Water-to-Air	4.2	21.4	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV042***1		Open Loop Water-to-Air	5.2	29.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV042***1		Open Loop Water-to-Air	5.2	29.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV042F1*0		Closed Loop Water-to-Air	3.7	18.6	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV042F1*0		Open Loop Water-to-Air	4.3	24.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV042F1*1		Closed Loop Water-to-Air	4.2	21.8	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV042F1*1		Open Loop Water-to-Air	4.9	29.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV042F1*4		Closed Loop Water-to-Air	4.2	21.8	3/1/2012	3/22/2012
WaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV042F1*4		Open Loop Water-to-Air	4.9	29.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV048***0		Closed Loop Water-to-Air	3.6	17.3	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV048***0		Closed Loop Water-to-Air	3.6	17.3	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV048***0		Open Loop Water-to-Air	4.3	22.5	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV048***0		Open Loop Water-to-Air	4.3	22.5	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV048***1		Closed Loop Water-to-Air	4.0	19.7	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV048***1		Closed Loop Water-to-Air	4.0	19.7	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV048***1		Open Loop Water-to-Air	4.8	26.1	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV048***1		Open Loop Water-to-Air	4.8	26.1	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV048F1*0		Closed Loop Water-to-Air	3.6	17.3	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV048F1*0		Open Loop Water-to-Air	4.2	22.5	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV048F1*1		Closed Loop Water-to-Air	3.9	20.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV048F1*1		Open Loop Water-to-Air	4.7	26.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV048F1*4		Closed Loop Water-to-Air	3.9	20.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	5 Series	NSV048F1*4		Open Loop Water-to-Air	4.7	26.1	3/1/2012	3/22/2012
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSV060***0		Closed Loop Water-to-Air	3.7	18.5	6/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV060***0		Closed Loop Water-to-Air	3.7	18.5	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV060***0		Open Loop Water-to-Air	4.4	24.6	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV060***0		Open Loop Water-to-Air	4.4	24.6	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV060***1		Closed Loop Water-to-Air	3.9	19.5	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV060***1		Closed Loop Water-to-Air	3.9	19.5	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV060***1		Open Loop Water-to-Air	4.7	26.1	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV060***1		Open Loop Water-to-Air	4.7	26.1	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV060F1*0		Closed Loop Water-to-Air	3.7	18.2	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV060F1*0		Open Loop Water-to-Air	4.4	23.2	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV060F1*1		Closed Loop Water-to-Air	4.0	19.2	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV060F1*1		Open Loop Water-to-Air	4.7	24.7	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV060F1*4		Closed Loop Water-to-Air	4.0	19.2	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV060F1*4		Open Loop Water-to-Air	4.7	24.7	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV070***1		Closed Loop Water-to-Air	3.7	18.2	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV070***1		Closed Loop Water-to-Air	3.7	18.2	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV070***1		Open Loop Water-to-Air	4.4	23.8	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSV070***1		Open Loop Water-to-Air	4.4	23.8	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV070F1*1		Closed Loop Water-to-Air	3.7	18.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV070F1*1		Open Loop Water-to-Air	4.4	23.8	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV070F1*4		Closed Loop Water-to-Air	3.7	18.0	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	5 Series	NSV070F1*4		Open Loop Water-to-Air	4.4	23.8	3/1/2012	3/22/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision NSW Series	NSW018		Closed Loop Water-to- Water	3.1	16.6	10/1/2009	1/4/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision NSW Series	NSW018		Open Loop Water-to- Water	3.7	22.9	10/1/2009	5/20/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision NSW Series	NSW025		Closed Loop Water-to- Water	3.1	16.1	10/1/2009	1/4/2012

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
VaterFurnace International,	WaterFurnace	Envision NSW Series	NSW025		Open Loop Water-to- Water	3.8	21.2	10/1/2009	5/20/2011
/aterFurnace International,	WaterFurnace	Envision NSW Series	NSW040		Closed Loop Water-to- Water	3.1	17.5	10/1/2009	5/20/2011
/aterFurnace International,	WaterFurnace	Envision NSW Series	NSW040		Open Loop Water-to- Water	3.9	23.4	10/1/2009	5/20/2011
/aterFurnace International,	WaterFurnace	Envision NSW Series	NSW050		Closed Loop Water-to- Water	3.1	16.4	10/1/2009	5/20/2011
VaterFurnace International,	WaterFurnace	Envision NSW Series	NSW050		Open Loop Water-to- Water	3.7	21.6	10/1/2009	5/20/2011
VaterFurnace International,	WaterFurnace	Envision NSW Series	NSW060		Closed Loop Water-to- Water	3.1	16.1	10/1/2009	1/4/2012
VaterFurnace International,	WaterFurnace	Envision NSW Series	NSW060		Open Loop Water-to- Water	3.8	20.6	10/1/2009	5/20/2011
/aterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ022		Closed Loop Water-to-Air	3.7	19.5	6/1/2006	2/8/2011
/aterFurnace International, acorporated	WaterFurnace	Envision Series	NSZ022		Closed Loop Water-to-Air	3.7	19.5	6/1/2006	2/18/2011
/aterFurnace International, acorporated	WaterFurnace	Envision Series	NSZ022		Open Loop Water-to-Air	4.5	27.9	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ022		Open Loop Water-to-Air	4.5	27.9	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ030		Closed Loop Water-to-Air	4.0	19.8	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ030		Closed Loop Water-to-Air	4.0	19.8	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ030		Open Loop Water-to-Air	4.9	24.9	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ030		Open Loop Water-to-Air	4.9	24.9	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ036		Closed Loop Water-to-Air	4.0	19.8	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ036		Closed Loop Water-to-Air	4.0	19.8	6/1/2006	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ036		Open Loop Water-to-Air	4.7	27.0	6/1/2006	2/8/2011
/aterFurnace International, corporated	WaterFurnace	Envision Series	NSZ036		Open Loop Water-to-Air	4.7	27.0	6/1/2006	2/18/2011
/aterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ042		Closed Loop Water-to-Air	3.7	19.9	6/1/2006	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ042		Closed Loop Water-to-Air	3.7	19.9	6/1/2006	2/18/2011
/aterFurnace International, ncorporated	WaterFurnace	Envision Series	NSZ042		Open Loop Water-to-Air	4.5	25.3	6/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSZ042		Open Loop Water-to-Air	4.5	25.3	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSZ048		Closed Loop Water-to-Air	3.8	18.1	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSZ048		Closed Loop Water-to-Air	3.8	18.1	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSZ048		Open Loop Water-to-Air	4.5	23.8	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSZ048		Open Loop Water-to-Air	4.5	23.8	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSZ060		Closed Loop Water-to-Air	3.6	17.1	6/1/2006	1/4/2012
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSZ060		Open Loop Water-to-Air	4.1	21.1	6/1/2006	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Envision Series	NSZ060		Open Loop Water-to-Air	4.1	21.1	6/1/2006	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVH036A1*1		Closed Loop Water-to-Air	4.4	29.5	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVH036A1*1		Open Loop Water-to-Air	5.3	39.4	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVH048A1*1		Closed Loop Water-to-Air	4.5	31.4	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVH048A1*1		Open Loop Water-to-Air	5.1	42.5	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVH060A1*1		Closed Loop Water-to-Air	4.3	27.7	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVH060A1*1		Open Loop Water-to-Air	5.2	37.2	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVV036A1*1		Closed Loop Water-to-Air	4.4	29.5	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVV036A1*1		Open Loop Water-to-Air	5.3	39.4	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVV048A1*1		Closed Loop Water-to-Air	4.5	31.4	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVV048A1*1		Open Loop Water-to-Air	5.1	42.5	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVV060A1*1		Closed Loop Water-to-Air	4.3	27.7	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	7 Series	NVV060A1*1		Open Loop Water-to-Air	5.2	37.2	7/2/2012	8/17/2012
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV038		Closed Loop Water-to-Air	4.2	21.1	7/1/2008	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV038		Closed Loop Water-to-Air	4.2	21.1	7/1/2008	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV038		Open Loop Water-to-Air	4.8	23.7	7/1/2008	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV038		Open Loop Water-to-Air	4.8	23.7	7/1/2008	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV049		Closed Loop Water-to-Air	3.9	19.1	7/1/2008	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV049		Closed Loop Water-to-Air	3.9	19.1	7/1/2008	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV049		Open Loop Water-to-Air	4.6	23.7	7/1/2008	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV049		Open Loop Water-to-Air	4.6	23.7	7/1/2008	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV064		Closed Loop Water-to-Air	3.7	18.1	7/1/2008	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV064		Closed Loop Water-to-Air	3.7	18.1	7/1/2008	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV064		Open Loop Water-to-Air	4.2	21.5	7/1/2008	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV064		Open Loop Water-to-Air	4.2	21.5	7/1/2008	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV072		Closed Loop Water-to-Air	3.7	17.6	7/1/2008	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV072		Closed Loop Water-to-Air	3.7	17.6	7/1/2008	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV072		Closed Loop Water-to-Air	3.8	17.6	7/1/2008	1/4/2012
WaterFurnace International, Incorporated	WaterFurnace	Synergy 3D	SDV072		Open Loop Water-to-Air	4.1	21.1	7/1/2008	1/4/2012
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH015****0		Open Loop Water-to-Air	4.1	24.0	12/1/2009	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH015****0		Open Loop Water-to-Air	4.1	24.0	12/1/2009	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH015****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH015****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH015****1		Open Loop Water-to-Air	4.4	24.3	12/1/2009	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH015****1		Open Loop Water-to-Air	4.4	24.3	12/1/2009	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH018****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH018****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH018****1		Open Loop Water-to-Air	4.4	24.0	12/1/2009	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH018****1		Open Loop Water-to-Air	4.4	24.0	12/1/2009	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH023****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH023****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH024****1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USH024****1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/18/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH024***1		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH024***1		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH030****1		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH030****1		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH030****1		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH030****1		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH036***1		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH036****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH036****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH042***1		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH042***1		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH042***1		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH042***1		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH048****1		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH048****1		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH048****1		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH048***1		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH060***1		Open Loop Water-to-Air	4.1	23.0	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH070****1		Closed Loop Water-to-Air	3.6	17.1	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USH070****1		Open Loop Water-to-Air	4.1	21.1	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV015****0		Open Loop Water-to-Air	4.1	24.0	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV015****0		Open Loop Water-to-Air	4.1	24.0	12/1/2009	2/18/2011
/aterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV015***1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/8/2011

				Additional				Data Assilable	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
NaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV015****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV015***1		Open Loop Water-to-Air	4.4	24.3	12/1/2009	2/8/2011
WaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV015****1		Open Loop Water-to-Air	4.4	24.3	12/1/2009	2/18/2011
NaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV018****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV018****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/18/2011
NaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV018****1		Open Loop Water-to-Air	4.4	24.0	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV018****1		Open Loop Water-to-Air	4.4	24.0	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV024***1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/8/2011
WaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV024***1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/18/2011
WaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV024***1		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV024***1		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV030****1		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV030****1		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV030****1		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV030****1		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV036****1		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV036****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV036****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV042****1		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV042***1		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV042****1		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV042****1		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/18/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV048****1		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/8/2011
VaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV048****1		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/18/2011
VaterFurnace International,	WaterFurnace	Versatec Ultra	USV048****1		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USV048***1		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/18/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USV060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/8/2011
WaterFurnace International, Incorporated	WaterFurnace	Versatec Ultra	USV060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/18/2011
NaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV060****1		Open Loop Water-to-Air	4.1	23.0	12/1/2009	1/4/2012
NaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV070***1		Closed Loop Water-to-Air	3.6	17.1	12/1/2009	1/4/2012
NaterFurnace International, ncorporated	WaterFurnace	Versatec Ultra	USV070***1		Open Loop Water-to-Air	4.1	21.1	12/1/2009	1/4/2012
WFI Industries	GeoStar	GeoStar GS Series	GS009		Open Loop Water-to-Air	4.3	22.2	6/1/2006	2/8/2011
NFI Industries	GeoStar	GeoStar GS Series	GS009		Open Loop Water-to-Air	4.3	22.2	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS012		Open Loop Water-to-Air	4.2	25.5	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS012		Open Loop Water-to-Air	4.2	25.5	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS012****0		Closed Loop Water-to-Air	3.6	18.0	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS012****0		Closed Loop Water-to-Air	3.6	18.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS015****0		Closed Loop Water-to-Air	3.7	18.0	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS015****0		Closed Loop Water-to-Air	3.7	18.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS015****0		Open Loop Water-to-Air	4.4	26.0	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS015****0		Open Loop Water-to-Air	4.4	26.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS015****1		Closed Loop Water-to-Air	3.8	18.5	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS015****1		Closed Loop Water-to-Air	3.8	18.5	6/1/2006	2/18/2011
NFI Industries	GeoStar	GeoStar GS Series	GS015****1		Open Loop Water-to-Air	4.7	26.3	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS015****1		Open Loop Water-to-Air	4.7	26.3	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS018****0		Closed Loop Water-to-Air	3.6	18.0	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS018****0		Closed Loop Water-to-Air	3.6	18.0	6/1/2006	2/18/2011
NFI Industries	GeoStar	GeoStar GS Series	GS018****0		Open Loop Water-to-Air	4.4	25.5	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS018****0		Open Loop Water-to-Air	4.4	25.5	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS018****1		Closed Loop Water-to-Air	3.9	19.0	6/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WFI Industries	GeoStar	GeoStar GS Series	GS018****1		Closed Loop Water-to-Air	3.9	19.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS018****1		Open Loop Water-to-Air	4.7	26.3	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS018****1		Open Loop Water-to-Air	4.7	26.3	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS022****0		Closed Loop Water-to-Air	3.8	20.3	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS022****0		Closed Loop Water-to-Air	3.8	20.3	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS022****0		Open Loop Water-to-Air	5.0	28.0	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS022****0		Open Loop Water-to-Air	5.0	28.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS022****1		Closed Loop Water-to-Air	4.0	21.0	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS022****1		Closed Loop Water-to-Air	4.0	21.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS022****1		Open Loop Water-to-Air	5.3	30.0	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS022****1		Open Loop Water-to-Air	5.3	30.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS030****0		Closed Loop Water-to-Air	3.8	21.1	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS030****0		Closed Loop Water-to-Air	3.8	21.1	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS030****0		Open Loop Water-to-Air	4.8	27.1	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS030****0		Open Loop Water-to-Air	4.8	27.1	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS030****1		Closed Loop Water-to-Air	4.0	21.9	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS030****1		Closed Loop Water-to-Air	4.0	21.9	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS030****1		Open Loop Water-to-Air	5.0	28.8	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS030****1		Open Loop Water-to-Air	5.0	28.8	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS036****0		Closed Loop Water-to-Air	4.0	19.6	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS036****0		Closed Loop Water-to-Air	4.0	19.6	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS036****0		Open Loop Water-to-Air	4.7	25.7	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS036****0		Open Loop Water-to-Air	4.7	25.7	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS036****1		Closed Loop Water-to-Air	4.4	22.0	6/1/2006	2/8/2011
NFI Industries	GeoStar	GeoStar GS Series	GS036****1		Closed Loop Water-to-Air	4.4	22.0	6/1/2006	2/18/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WFI Industries	GeoStar	GeoStar GS Series	GS036****1		Open Loop Water-to-Air	5.2	30.1	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS036****1		Open Loop Water-to-Air	5.2	30.1	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS042****0		Closed Loop Water-to-Air	3.7	18.6	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS042****0		Closed Loop Water-to-Air	3.7	18.6	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS042****0		Open Loop Water-to-Air	4.6	24.5	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS042****0		Open Loop Water-to-Air	4.6	24.5	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS042***1		Closed Loop Water-to-Air	4.2	21.4	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS042***1		Closed Loop Water-to-Air	4.2	21.4	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS042***1		Open Loop Water-to-Air	5.2	29.5	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS042***1		Open Loop Water-to-Air	5.2	29.5	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS048****0		Closed Loop Water-to-Air	3.6	17.3	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS048****0		Closed Loop Water-to-Air	3.6	17.3	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS048****0		Open Loop Water-to-Air	4.3	22.5	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS048****0		Open Loop Water-to-Air	4.3	22.5	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS048****1		Closed Loop Water-to-Air	4.0	19.7	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS048****1		Closed Loop Water-to-Air	4.0	19.7	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS048****1		Open Loop Water-to-Air	4.8	26.1	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS048****1		Open Loop Water-to-Air	4.8	26.1	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS060****0		Closed Loop Water-to-Air	3.7	18.5	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS060****0		Closed Loop Water-to-Air	3.7	18.5	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS060****0		Open Loop Water-to-Air	4.4	24.6	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS060****0		Open Loop Water-to-Air	4.4	24.6	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS060****1		Closed Loop Water-to-Air	3.9	19.5	6/1/2006	2/8/2011
VFI Industries	GeoStar	GeoStar GS Series	GS060****1		Closed Loop Water-to-Air	3.9	19.5	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS060****1		Open Loop Water-to-Air	4.7	26.1	6/1/2006	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WFI Industries	GeoStar	GeoStar GS Series	GS060****1		Open Loop Water-to-Air	4.7	26.1	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GS Series	GS070****1		Closed Loop Water-to-Air	3.7	18.2	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS070****1		Closed Loop Water-to-Air	3.7	18.2	6/1/2006	2/18/2011
VFI Industries	GeoStar	GeoStar GS Series	GS070****1		Open Loop Water-to-Air	4.4	23.8	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GS Series	GS070****1		Open Loop Water-to-Air	4.4	23.8	6/1/2006	2/18/2011
NFI Industries	GeoStar	GeoStar GSW Series	GSW018		Closed Loop Water-to- Water	3.1	16.6	2/1/2010	1/4/2012
WFI Industries	GeoStar	GeoStar GSW Series	GSW018		Open Loop Water-to- Water	3.7	22.9	2/1/2010	5/20/2011
WFI Industries	GeoStar	GeoStar GSW Series	GSW025		Closed Loop Water-to- Water	3.1	16.1	2/1/2010	1/4/2012
WFI Industries	GeoStar	GeoStar GSW Series	GSW025		Open Loop Water-to- Water	3.8	21.2	2/1/2010	5/20/2011
WFI Industries	GeoStar	GeoStar GSW Series	GSW040		Closed Loop Water-to- Water	3.1	17.5	2/1/2010	5/20/2011
WFI Industries	GeoStar	GeoStar GSW Series	GSW040		Open Loop Water-to- Water	3.9	23.4	2/1/2010	5/20/2011
WFI Industries	GeoStar	GeoStar GSW Series	GSW050		Closed Loop Water-to- Water	3.1	16.4	2/1/2010	5/20/2011
WFI Industries	GeoStar	GeoStar GSW Series	GSW050		Open Loop Water-to- Water	3.7	21.6	2/1/2010	5/20/2011
WFI Industries	GeoStar	GeoStar GSW Series	GSW060		Closed Loop Water-to- Water	3.1	16.1	2/1/2010	1/4/2012
WFI Industries	GeoStar	GeoStar GSW Series	GSW060		Open Loop Water-to- Water	3.8	20.6	2/1/2010	5/20/2011
VFI Industries	GeoStar	GeoStar GSZ Series	GSZ022		Closed Loop Water-to-Air	3.7	19.5	9/1/2008	2/8/2011
VFI Industries	GeoStar	GeoStar GSZ Series	GSZ022		Closed Loop Water-to-Air	3.7	19.5	9/1/2008	2/18/2011
VFI Industries	GeoStar	GeoStar GSZ Series	GSZ022		Open Loop Water-to-Air	4.5	27.9	9/1/2008	2/8/2011
VFI Industries	GeoStar	GeoStar GSZ Series	GSZ022		Open Loop Water-to-Air	4.5	27.9	9/1/2008	2/18/2011
NFI Industries	GeoStar	GeoStar GSZ Series	GSZ030		Closed Loop Water-to-Air	4.0	19.8	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ030		Closed Loop Water-to-Air	4.0	19.8	9/1/2008	2/18/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ030		Open Loop Water-to-Air	4.9	24.9	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ030		Open Loop Water-to-Air	4.9	24.9	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ036		Closed Loop Water-to-Air	4.0	19.8	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ036		Closed Loop Water-to-Air	4.0	19.8	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ036		Open Loop Water-to-Air	4.7	27.0	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ036		Open Loop Water-to-Air	4.7	27.0	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ042		Closed Loop Water-to-Air	3.7	19.9	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ042			3.7	19.9	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ042		Open Loop Water-to-Air	4.5	25.3	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ042		Open Loop Water-to-Air	4.5	25.3	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ048		Closed Loop Water-to-Air	3.8	18.1	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ048		Closed Loop Water-to-Air	3.8	18.1	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ048		Open Loop Water-to-Air	4.5	23.8	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ048		Open Loop Water-to-Air	4.5	23.8	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ060		Closed Loop Water-to-Air	3.6	17.1	9/1/2008	1/4/2012
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ060		Open Loop Water-to-Air	4.1	21.1	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GSZ060		Open Loop Water-to-Air	4.1	21.1	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GT Series	GT026			4.4	22.7	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT026		Closed Loop Water-to-Air	4.4	22.7	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GT Series	GT026		Open Loop Water-to-Air	5.2	27.6	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT026		Open Loop Water-to-Air	5.2	27.6	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GT Series	GT038		Closed Loop Water-to-Air	4.4	25.0	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT038		Closed Loop Water-to-Air	4.4	25.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GT Series	GT038		Open Loop Water-to-Air	5.2	28.1	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT038		Open Loop Water-to-Air	5.2	28.1	6/1/2006	2/18/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
WFI Industries	GeoStar	GeoStar GT Series	GT049		Closed Loop Water-to-Air	4.4	21.5	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT049		Closed Loop Water-to-Air	4.4	21.5	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GT Series	GT049		Open Loop Water-to-Air	5.0	25.5	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT049		Open Loop Water-to-Air	5.0	25.5	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GT064		Open Loop Water-to-Air	4.7	26.0	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GSZ Series	GT064		Open Loop Water-to-Air	4.7	26.0	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GT Series	GT064		Closed Loop Water-to-Air	4.0	21.8	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT064		Closed Loop Water-to-Air	4.0	21.8	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GT Series	GT072		Closed Loop Water-to-Air	4.0	19.9	6/1/2006	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT072		Closed Loop Water-to-Air	4.0	19.9	6/1/2006	2/18/2011
WFI Industries	GeoStar	GeoStar GT Series	GT072		Open Loop Water-to-Air	4.5	23.2	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GT Series	GT072		Open Loop Water-to-Air	4.5	23.2	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GTW Series	GTW100		Closed Loop Water-to- Water	3.2	19.4	9/1/2009	5/20/2011
WFI Industries	GeoStar	GeoStar GTW Series	GTW100		Open Loop Water-to- Water	3.5	23.3	9/1/2009	5/20/2011
WFI Industries	GeoStar	GeoStar GTW Series	GTW120		Closed Loop Water-to- Water	3.2	19.0	9/1/2009	5/20/2011
WFI Industries	GeoStar	GeoStar GTW Series	GTW120		Open Loop Water-to- Water	3.5	22.3	9/1/2009	5/20/2011
WFI Industries	GeoStar	GeoStar GTZ Series	GTZ026		Closed Loop Water-to-Air	4.1	20.7	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GTZ Series	GTZ026		Closed Loop Water-to-Air	4.1	20.7	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GTZ Series	GTZ026		Open Loop Water-to-Air	4.7	25.1	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GTZ Series	GTZ026		Open Loop Water-to-Air	4.7	25.1	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GTZ Series	GTZ038		Closed Loop Water-to-Air	4.0	21.2	9/1/2008	2/8/2011
WFI Industries	GeoStar	GeoStar GTZ Series	GTZ038		Closed Loop Water-to-Air	4.0	21.2	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStar GTZ Series	GTZ038		Open Loop Water-to-Air	4.4	23.7	9/1/2008	2/8/2011

				Additional Model				Date Available	
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Information	Product Type	COP Rating	EER Rating	On Market	Date Qualified
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ038		Open Loop Water-to-Air	4.4	23.7	9/1/2008	2/18/2011
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ049		Closed Loop Water-to-Air	4.0	19.5	9/1/2008	2/8/2011
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ049		Closed Loop Water-to-Air	4.0	19.5	9/1/2008	2/18/2011
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ049		Open Loop Water-to-Air	4.5	23.0	9/1/2008	2/8/2011
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ049		Open Loop Water-to-Air	4.5	23.0	9/1/2008	2/18/2011
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ064		Closed Loop Water-to-Air	3.7	18.8	9/1/2008	2/8/2011
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ064		Closed Loop Water-to-Air	3.7	18.8	9/1/2008	2/18/2011
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ064		Open Loop Water-to-Air	4.3	22.0	9/1/2008	2/8/2011
VFI Industries	GeoStar	GeoStar GTZ Series	GTZ064		Open Loop Water-to-Air	4.3	22.0	9/1/2008	2/18/2011
WFI Industries	GeoStar	GeoStarQT Series	QT038		Closed Loop Water-to-Air	4.2	20.8	9/1/2008	2/24/2011
VFI Industries	GeoStar	GeoStarQT Series	QT038		Open Loop Water-to-Air	4.7	23.3	9/1/2008	2/24/2011
VFI Industries	GeoStar	GeoStarQT Series	QT049		Closed Loop Water-to-Air	3.9	18.8	9/1/2008	2/24/2011
VFI Industries	GeoStar	GeoStarQT Series	QT049		Open Loop Water-to-Air	4.5	23.3	9/1/2008	2/24/2011
VFI Industries	GeoStar	GeoStarQT Series	QT064		Closed Loop Water-to-Air	3.6	17.8	9/1/2008	2/24/2011
VFI Industries	GeoStar	GeoStarQT Series	QT064		Open Loop Water-to-Air	4.1	21.2	9/1/2008	2/24/2011
WFI Industries	GeoStar	GeoStar QT Series	QT072		Closed Loop Water-to-Air	3.7	17.3	9/1/2008	2/24/2011
VFI Industries	GeoStar	GeoStarQT Series	QT072		Open Loop Water-to-Air	4.1	21.1	9/1/2008	1/4/2012
VFI Industries	GeoStar	GeoStar Y Series	YS024***4		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/24/2011
VFI Industries	GeoStar	GeoStar Y Series	YS024***4		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/24/2011
VFI Industries	GeoStar	GeoStar Y Series	YS030****4		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/24/2011
VFI Industries	GeoStar	GeoStar Y Series	YS030****4		Open Loop Water-to-Air	4.4	23.9	12/1/2009	2/24/2011
VFI Industries	GeoStar	GeoStar Y Series	YS036***4		Closed Loop Water-to-Air	3.6	17.3	12/1/2009	1/4/2012
VFI Industries	GeoStar	GeoStar Y Series	YS036****4		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
VFI Industries	GeoStar	GeoStar Y Series	YS042***4		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/24/2011
VFI Industries	GeoStar	GeoStar Y Series	YS042***4		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/24/2011

				Additional					
ENERGY STAR Partner	Brand Name	Model Name	Model Number	Model Information	Product Type	COP Rating	EER Rating	Date Available On Market	Date Qualified
WFI Industries	GeoStar	GeoStar Y Series	YS048***4		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Y Series	YS048****4		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Y Series	YS060****4		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Y Series	YS060****4		Open Loop Water-to-Air	4.1	23.0	12/1/2009	1/4/2012
WFI Industries	GeoStar	GeoStar Y Series	YS070***4		Closed Loop Water-to-Air	3.6	17.1	12/1/2009	1/4/2012
WFI Industries	GeoStar	GeoStar Y Series	YS070***4		Open Loop Water-to-Air	4.1	21.1	12/1/2009	1/4/2012
WFI Industries	GeoStar	GeoStar Z Series	ZS015****0		Open Loop Water-to-Air	4.1	24.0	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS015****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS015****1		Open Loop Water-to-Air	4.4	24.3	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS018****1		Closed Loop Water-to-Air	3.7	17.5	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS018****1		Open Loop Water-to-Air	4.4	24.0	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS023****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS024****1		Closed Loop Water-to-Air	3.8	17.5	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS024***1		Open Loop Water-to-Air	4.5	23.4	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS030****1		Closed Loop Water-to-Air	3.8	18.3	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS030****1		Open Loop Water-to-Air	4.5	23.9	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS036****1		Open Loop Water-to-Air	4.3	23.0	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS042****1		Closed Loop Water-to-Air	3.7	18.5	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS042****1		Open Loop Water-to-Air	4.3	23.5	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS048****1		Closed Loop Water-to-Air	3.6	18.1	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS048****1		Open Loop Water-to-Air	4.2	23.4	12/1/2009	2/24/2011
WFI Industries	GeoStar	GeoStar Z Series	ZS060****1		Closed Loop Water-to-Air	3.6	17.9	12/1/2009	2/24/2011

## **Definitions for Column Headers**

Column Header	Definition
ENERGY STAR Partner	An organization that signed a Partnership Agreement with EPA to manufacture or private label ENERGY STAR qualified products.
Brand	An identifier assigned by the manufacturer or private labeler to a product or family/series of products for sales and marketing purposes.
Model Name	An identifier assigned by the manufacturer or private labeler to a product or family/series of products for sales and marketing purposes.
Model Number	A distinguishing identifier, usually alphanumeric, assigned to a product by the manufacturer or private labeler.
Additional Model Information	This column includes for the qualified model or family, family members, additional model names, model numbers and other identifying information associated with a product or family/series of products for sales and marketing purposes. Other identifying information includes, but is not limited to, SKUs, UPC codes, retail numbers, and/or descriptions of models included/not included in the reported Model Family.
COP Rating:	A measure of efficiency in the heating mode that represents the ratio of total heating capacity to electrical energy input.
EER Rating:	A measure of efficiency in the cooling mode that represents the ratio of total cooling capacity to electrical energy input.
Product Type:	A geothermal heat pump uses the thermal energy of the ground or groundwater to provide residential space conditioning and/or domestic water heating. A geothermal heat pump model normally consists of one or more factory-made assemblies that include indoor conditioning and/or domestic water heat exchanger(s), compressors, and a ground-side heat exchanger. A geothermal heat pump model may provide space heating, space cooling, domestic water heating, or a combination of these functions and may also include the functions of liquid circulation, thermal storage, air circulation, air cleaning, dehumidifying or humidifying. A geothermal heat pump system generally consists of one or more geothermal heat pump models, the ground heat exchanger(s), the air and/or hydronic space conditioning distribution system(s), temperature controls, and thermal storage tanks.
Closed Loop:	A ground heat exchange method in which the heat transfer fluid is permanently contained in a closed piping system. Also called a ground-loop system.
Open Loop:	A ground heat exchange method in which the heat transfer fluid is part of a larger environment. The most common open loop systems use ground water, reclaimed water, or surface water as the heat transfer medium. Also called a ground-water system.
Water-to-Air:	A geothermal heat pump model that provides space conditioning primarily by the use of an indoor air heat exchange coil. Water-to-air models may also provide domestic water heating and hydronic space heating by using desuperheater and/or demand water heating functions.
Water-to-Water:	A geothermal heat pump model that provides space conditioning and/or domestic water heating by the use of indoor refrigerant-to-water heat exchanger(s). Water-to-water models may provide domestic water heating by using desuperheater and/or demand water heating functions.
Direct Geoexchange (DGX)	A geothermal heat pump model in which the refrigerant is circulated in pipes buried in the ground or submerged in water that exchanges heat with the ground, rather than using a secondary heat transfer fluid, such as water or antifreeze solution in a separate closed loop.
Date Available on Market	The date that the model is available for purchase.
Date Qualified	The date on which the product was confirmed to meet the ENERGY STAR specification.

## **Key Efficiency Criteria**

Models must meet or exceed the energy efficiency ratio (EER) and coefficient of performance (COP) values in the tables below.

Table 1: Tier 1 Requirements (Effective December 1, 2009)           Product Type         EER         COP           Water-to-Air         14.1         3.3           Open Loop Water-to-Air         16.2         3.6           Water-to-Water         16.2         3.6           Water-to-Water         15.1         3           Open Loop Water-to-Water         19.1         3.4           DGX         15         3.5           Table 2: Tier 2 Requirements (Effective January 1, 2011)         Product Type         EER         COP           Water-to-Air         16.1         3.5         3.5           Open Loop Water-to-Air         18.2         3.8           Water-to-Water         15.1         3           Closed Loop Water-to-Water         15.1         3           Open Loop Water-to-Water         15.1         3.4           DGX         16         3.6	Energy Efficiency Requirements for Geothermal Heat Pumps - Version 3.1						
Water-to-Air         14.1         3.3           Open Loop Water-to-Air         16.2         3.6           Water-to-Water         15.1         3           Closed Loop Water-to-Water         19.1         3.4           DGX         15         3.5           Table 2: Tier 2 Requirements (Effective January 1, 2011)         Product Type         EER         COP           Water-to-Air         16.1         3.5         Open Loop Water-to-Air         18.2         3.8           Water-to-Water         Closed Loop Water-to-Water         15.1         3         3           Open Loop Water-to-Water         19.1         3.4         DGX	Table 1: Tier 1 Requirements (Effective December 1, 2009)						
Closed Loop Water-to-Air 14.1 3.3  Open Loop Water-to-Air 16.2 3.6  Water-to-Water  Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4  DGX  DGX 15 3.5  Table 2: Tier 2 Requirements (Effective January 1, 2011)  Product Type EER COP  Water-to-Air  Closed Loop Water-to-Air 16.1 3.5  Open Loop Water-to-Air 18.2 3.8  Water-to-Water  Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4  DGX	Product Type	EER	СОР				
Open Loop Water-to-Air         16.2         3.6           Water-to-Water         15.1         3           Open Loop Water-to-Water         19.1         3.4           DGX         15         3.5           Table 2: Tier 2 Requirements (Effective January 1, 2011)         Product Type         EER         COP           Water-to-Air         16.1         3.5         Open Loop Water-to-Air         18.2         3.8           Water-to-Water         Closed Loop Water-to-Water         15.1         3         3           Open Loop Water-to-Water         15.1         3         3         3           Open Loop Water-to-Water         19.1         3.4         3	Water-to-Air						
Water-to-Water         15.1         3           Open Loop Water-to-Water         19.1         3.4           DGX         15         3.5           Table 2: Tier 2 Requirements (Effective January 1, 2011)         Product Type         EER         COP           Water-to-Air         16.1         3.5           Open Loop Water-to-Air         18.2         3.8           Water-to-Water           Closed Loop Water-to-Water         15.1         3           Open Loop Water-to-Water         19.1         3.4           DGX	Closed Loop Water-to-Air	14.1	3.3				
Closed Loop Water-to-Water	Open Loop Water-to-Air	16.2	3.6				
Open Loop Water-to-Water         19.1         3.4           DGX         15         3.5           Table 2: Tier 2 Requirements (Effective January 1, 2011)         Product Type         EER         COP           Water-to-Air         16.1         3.5           Open Loop Water-to-Air         18.2         3.8           Water-to-Water         15.1         3           Closed Loop Water-to-Water         15.1         3           Open Loop Water-to-Water         19.1         3.4           DGX	Water-to-Water						
DGX  DGX  15  3.5  Table 2: Tier 2 Requirements (Effective January 1, 2011)  Product Type  EER  COP  Water-to-Air  Closed Loop Water-to-Air  16.1  3.5  Open Loop Water-to-Air  18.2  3.8  Water-to-Water  Closed Loop Water-to-Water  15.1  Open Loop Water-to-Water  19.1  3.4  DGX	Closed Loop Water-to-Water	15.1	3				
DGX 15 3.5  Table 2: Tier 2 Requirements (Effective January 1, 2011)  Product Type EER COP  Water-to-Air  Closed Loop Water-to-Air 16.1 3.5  Open Loop Water-to-Air 18.2 3.8  Water-to-Water  Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4  DGX	Open Loop Water-to-Water	19.1	3.4				
Table 2: Tier 2 Requirements (Effective January 1, 2011)  Product Type EER COP  Water-to-Air  Closed Loop Water-to-Air 16.1 3.5  Open Loop Water-to-Air 18.2 3.8  Water-to-Water  Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4  DGX	DGX						
Product Type EER COP  Water-to-Air  Closed Loop Water-to-Air 16.1 3.5  Open Loop Water-to-Air 18.2 3.8  Water-to-Water  Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4  DGX	DGX	15	3.5				
Water-to-Air  Closed Loop Water-to-Air  Open Loop Water-to-Air  18.2  3.8  Water-to-Water  Closed Loop Water-to-Water  15.1  Open Loop Water-to-Water  19.1  3.4  DGX	Table 2: Tier 2 Requirements	(Effective Janu	ary 1, 2011)				
Closed Loop Water-to-Air 16.1 3.5  Open Loop Water-to-Air 18.2 3.8 <b>Water-to-Water</b> Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4 <b>DGX</b>	Product Type	EER	СОР				
Open Loop Water-to-Air 18.2 3.8  Water-to-Water  Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4  DGX	Water-to-Air						
Water-to-Water  Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4  DGX	Closed Loop Water-to-Air	16.1	3.5				
Closed Loop Water-to-Water 15.1 3  Open Loop Water-to-Water 19.1 3.4  DGX	Open Loop Water-to-Air	18.2	3.8				
Open Loop Water-to-Water 19.1 3.4  DGX	Water-to-Water						
DGX	Closed Loop Water-to-Water	15.1	3				
	Open Loop Water-to-Water	19.1	3.4				
DGX 16 3.6	DGX						
	DGX	16	3.6				

Table 3: Tier 3 Requirements (Effective January 1, 2012)							
Product Type EER COP							
Water-to-Air							
Closed Loop Water-to-Air	17.1	3.6					
Open Loop Water-to-Air	21.1	4.1					
Water-to-Water							
Closed Loop Water-to-Water	16.1	3.1					
Open Loop Water-to-Water	20.1	3.5					
DGX							
DGX	16	3.6					

## Notes:

The specifications in the charts above apply to single stage models. Multi-stage models may be qualified based on: EER = (highest rated capacity EER + lowest rated capacity EER) / 2

COP = (highest rated capacity COP + lowest rated capacity COP) / 2