

November 14, 2001

Mr. Otto L. Maynard  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
Post Office Box 411  
Burlington, KS 66839

SUBJECT: BULLETIN 2001-01, "CIRCUMFERENTIAL CRACKING OF REACTOR PRESSURE VESSEL HEAD PENETRATION NOZZLES," RESPONSE FOR WOLF CREEK GENERATING STATION (TAC NO. MB2676)

Dear Mr. Maynard:

On August 3, 2001, the NRC staff issued Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles," to the industry requesting that addressees provide information related to the structural integrity of the reactor pressure vessel head penetration (VHP) nozzles for their respective facilities, including the extent of VHP nozzle leakage and cracking that has been found to date, the inspections and repairs that have been undertaken to satisfy applicable regulatory requirements, and the basis for concluding that their plans for future inspections will ensure compliance with applicable regulatory requirements at their respective pressurized water reactor (PWR) plants. You were requested to provide your response to Item 1 of the Bulletin within 30 days of its issuance.

You provided your response for Wolf Creek Generating Station (WCGS) by letter dated August 29, 2001(ET 01-0025). In your response, you stated that WCGS is in the category of plants with low susceptibility to circumferential cracking of the VHP nozzles and has not previously experienced either leakage from or cracking in the nozzles.

The NRC staff finds, after review of your response to the bulletin, that you have provided the information requested by the Bulletin and that the information is acceptable. Based on this information, the staff concludes that there is reasonable assurance that the public health and safety will be maintained. As you stated in response to Item 5 of the Bulletin, you have committed to provide the following information within 30 days after plant restart following the next refueling outage at WCGS, which is Spring 2002:

- a. a description of the extent of VHP nozzle leakage and cracking detected at your plant, including the number, location, size, and nature of each crack detected;
- b. if cracking is identified, a description of the inspections (type, scope, qualification requirements, and acceptance criteria), repairs, and other corrective actions you have taken to satisfy applicable regulatory requirements. This information is requested only if there are any changes from prior information submitted in accordance with this Bulletin.

Otto L. Maynard

- 2 -

This closes out the NRC staff's review of your response to Bulletin 2001-01 and closes out TAC No. MB2676. If you have any questions, contact me at 301-415-1307, or through the internet at [jnd@nrc.gov](mailto:jnd@nrc.gov).

Sincerely,

*/RA/*

Jack Donohew, Senior Project Manager, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-482

cc: See next page

Otto L. Maynard

- 2 -

This closes out the NRC staff's review of your response to Bulletin 2001-01 and closes out TAC No. MB2676. If you have any questions, contact me at 301-415-1307, or through the internet at [jnd@nrc.gov](mailto:jnd@nrc.gov).

Sincerely,

*/RA/*

Jack Donohew, Senior Project Manager, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-482

cc: See next page

DISTRIBUTION

PUBLIC

PDIV-2 Reading

RidsNrrDlpmPdiv(SRichards)

RidsNrrSCSDembek

RidsNrrPMJDonohew

RidsNrrLAEPeyton

RidsOGCRp

RidsAcrsAcnwMailCenter

WJohnson, RIV

WBateman (EMCB Reading)

RidsNrrPMJZimmerman

RidsNrrPMLBurkahrt

AHiser

JCollins

**ACCESSION NO.: ML013170148**

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	JDonohew:as	EPeyton	SDembek
DATE	11/14/2001	11/14/01	11/14/01

OFFICIAL RECORD COPY

Wolf Creek Generating Station

cc:

Jay Silberg, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, NW  
Washington, D.C. 20037

Vice President & Chief Operating Officer  
Wolf Creek Nuclear Operating Corporation  
P. O. Box 411  
Burlington, KS 66839

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Superintendent Licensing  
Wolf Creek Nuclear Operating Corporation  
P.O. Box 411  
Burlington, KS 66839

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 311  
Burlington, KS 66839

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
8201 NRC Road  
Steedman, MO 65077-1032

Chief Engineer  
Utilities Division  
Kansas Corporation Commission  
1500 SW Arrowhead Road  
Topeka, KS 66604-4027

Office of the Governor  
State of Kansas  
Topeka, KS 66612

Attorney General  
Judicial Center  
301 S.W. 10th  
2nd Floor  
Topeka, KS 66612

County Clerk  
Coffey County Courthouse  
Burlington, KS 66839

Vick L. Cooper, Chief  
Radiation Control Program, RCP  
Kansas Department of Health  
and Environment  
Bureau of Air and Radiation  
Forbes Field Building 283  
Topeka, KS 66620