

TOPIC: 291007  
KNOWLEDGE: K1.01 [2.6/2.7]  
QID: B637 (P2135)

High differential pressure in a demineralizer could be caused by all of the following except...

- A. resin exhaustion.
- B. resin overheating.
- C. crud buildup.
- D. high flow rate.

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.01 [2.6/2.7]  
QID: B737 (P935)

A demineralizer is being used in a water purification system. How will accumulation of suspended solids in the demineralizer affect performance of the demineralizer?

- A. The rate of resin depletion will increase.
- B. The flow rate of water through the demineralizer will increase.
- C. The differential pressure across the demineralizer will decrease.
- D. The rate of unwanted ion removal from the system will decrease.

ANSWER: D.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.8/2.9]  
QID: B152 (P1835)

The ion exchange efficiency of a condensate demineralizer can be determined by...

- A. sampling the inlet and outlet of the demineralizer to determine the change in conductivity.
- B. performing a calculation based on the ratio between the inlet pH divided by the outlet pH.
- C. sampling the inlet and outlet of the demineralizer to determine the difference in activity.
- D. performing a calculation based on the change in differential pressure across the demineralizer.

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B839 (P835)

The demineralization factor of a demineralizer can be expressed as...

- A. Inlet Conductivity minus Outlet Conductivity.
- B. Outlet Conductivity minus Inlet Conductivity.
- C. Inlet Conductivity divided by Outlet Conductivity.
- D. Outlet Conductivity divided by Inlet Conductivity.

ANSWER: C.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B1437 (P2236)

To determine the demineralization factor for a demineralizer, the two parameters that must be monitored are inlet and outlet...

- A. pH.
- B. conductivity.
- C. suspended solids.
- D. pressure.

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B2737 (P2735)

What percentage of impurities is being removed from the water passing through an ion exchanger if the ion exchanger has a decontamination factor of 25?

- A. 99%
- B. 96%
- C. 88%
- D. 75%

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B2837 (P936)

The ion exchange efficiency of a condensate demineralizer is determined by performing a calculation using the...

- A. change in conductivity at the outlet of the demineralizer over a period of time.
- B. change in pH at the outlet of the demineralizer over a period of time.
- C. demineralizer inlet and outlet conductivity.
- D. demineralizer inlet and outlet pH.

ANSWER: C.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B3238 (P3235)

What percentage of ionic impurities is being removed from the water passing through an ion exchanger if the ion exchanger has a decontamination factor of 50?

- A. 98%
- B. 96%
- C. 75%
- D. 50%

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B3437 (P3435)

The decontamination factor (also called the demineralization factor) of a condensate demineralizer has just been determined to be 50, based on conductivity measurements.

If condensate having a conductivity of 20  $\mu\text{mho/cm}$  is flowing into this demineralizer, which one of the following is the conductivity of the condensate at the outlet of the demineralizer?

- A. 0.4  $\mu\text{mho/cm}$
- B. 1.0  $\mu\text{mho/cm}$
- C. 4.0  $\mu\text{mho/cm}$
- D. 10.0  $\mu\text{mho/cm}$

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B3637 (P3636)

The decontamination factor (or demineralization factor) of a condensate demineralizer has just been determined to be 10, based on conductivity measurements.

If condensate having a conductivity of 20  $\mu\text{mho/cm}$  is flowing into this demineralizer, which one of the following is the conductivity of the condensate at the outlet of the demineralizer?

- A. 0.5  $\mu\text{mho/cm}$
- B. 2.0  $\mu\text{mho/cm}$
- C. 5.0  $\mu\text{mho/cm}$
- D. 10.0  $\mu\text{mho/cm}$

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B4219 (P4219)

The decontamination factor (or demineralization factor) of a condensate demineralizer has just been determined to be 5.0, based on conductivity measurements.

If condensate having a conductivity of 20  $\mu\text{mho/cm}$  is flowing into this demineralizer, which one of the following is the conductivity of the condensate at the outlet of the demineralizer?

- A. 0.4  $\mu\text{mho/cm}$
- B. 4.0  $\mu\text{mho/cm}$
- C. 10.0  $\mu\text{mho/cm}$
- D. 100.0  $\mu\text{mho/cm}$

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.02 [2.5/2.6]  
QID: B4719 (P4718)

What percentage of ionic impurities is being removed from the water passing through an ion exchanger if the ion exchanger has a decontamination factor of 1.0?

- A. 100%
- B. 99%
- C. 1%
- D. 0%

ANSWER: D.

TOPIC: 291007  
KNOWLEDGE: K1.03 [2.8/2.9]  
QID: B38

What adverse effect occurs due to channeling in a demineralizer?

- A. Increased demineralizer outlet conductivity because much of the resin is essentially bypassed
- B. Loss of resin due to agitation resulting from increased fluid velocity through the demineralizer
- C. Resin dryout and cracking because much of the resin is essentially bypassed
- D. Resin damage due to the increased velocity of fluid through the demineralizer

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.03 [2.5/2.6]  
QID: B236

Channeling in a demineralizer is undesirable because the...

- A. ability of the resin bed to remove undesirable ions will decrease and cause outlet conductivity to increase.
- B. ability of the resin bed to remove suspended solids will decrease and cause outlet pH to increase.
- C. resulting high velocity fluid flow will cause agitation of the resin beads and the release of unwanted ions.
- D. resulting high velocity fluid flow can cause significant damage to resin retention elements.

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.03 [2.8/2.9]  
QID: B838 (P1636)

Which one of the following, if processed through a demineralizer, will rapidly reduce the effectiveness of the demineralizer?

- A. Oily water
- B. Condensate
- C. Makeup water
- D. Radioactive water

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.03 [2.8/2.9]  
QID: B1038

Which one of the following refers to the condition in which large portions of a demineralizer resin bed are bypassed, thereby allowing waterborne impurities to reach the outlet?

- A. Channeling
- B. Leaching
- C. Exhaustion
- D. Mineralization

ANSWER: A.



TOPIC: 291007  
KNOWLEDGE: K1.03 [2.8/2.9]  
QID: B1237 (P2035)

Which one of the following conditions will lead to channeling in an operating demineralizer?

- A. Suspended solids and insoluble particles forming a mat on the surface of the resin bed.
- B. A sudden 10°F decrease in the temperature of the influent to the demineralizer.
- C. Exhaustion of the resin bed due to high conductivity of the demineralizer influent.
- D. Operation of the demineralizer with influent flow rate at 10% below design flow rate.

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.04 [2.8/2.9]  
QID: B118

The purpose of a mixed-bed demineralizer is to...

- A. raise the conductivity of water with little effect on pH.
- B. reduce the conductivity of water with little effect on pH.
- C. increase the pH of water by reducing the number of positively charged ions in it.
- D. decrease the pH of water by increasing the number of negatively charged ions in it.

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.05 [2.4/2.5]  
QID: B1138 (P1535)

A condensate demineralizer differential pressure (D/P) gauge indicates 4.0 psid at 50% flow rate. Over the next two days plant power changes have caused condensate flow rate to vary between 25% and 100%.

Which one of the following combinations of condensate flow rate and demineralizer D/P, observed during the power changes, indicates an increase in the accumulation of corrosion products in the demineralizer?

	<u>Condensate Flow Rate</u>	<u>Demineralizer D/P (psid)</u>
A.	100%	15.0
B.	75%	9.0
C.	60%	5.0
D.	25%	2.0

ANSWER: D.

TOPIC: 291007  
KNOWLEDGE: K1.05 [2.4/2.5]  
QID: B1539 (P1537)

A higher- than-expected differential pressure across an operating mixed-resin demineralizer can be caused by...

- A. exhaustion of the cation exchange resin.
- B. channeling through the resin bed.
- C. insufficient resin backwash.
- D. decreased demineralizer inlet conductivity.

ANSWER: C.

TOPIC: 291007  
KNOWLEDGE: K1.05 [2.4/2.5]  
QID: B1736 (P1736)

A condensate demineralizer differential pressure (D/P) gauge indicates 6.0 psid at 50% flow rate. Which one of the following combinations of condensate flow rate and demineralizer D/P observed at various power levels over the next few days indicates an increase in the accumulation of insoluble corrosion products in the demineralizer?

	<u>Condensate Flow Rate</u>	<u>Demineralizer D/P (psid)</u>
A.	100%	23.5
B.	75%	16.5
C.	60%	8.5
D.	25%	1.5

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.05 [2.4/2.5]  
QID: B2237 (P635)

How does demineralizer differential pressure indicate the condition of a demineralizer resin bed?

- A. Low differential pressure indicates flow blockage in the demineralizer.
- B. Low differential pressure indicates that the demineralizer resin bed is exhausted.
- C. High differential pressure indicates flow blockage in the demineralizer.
- D. High differential pressure indicates that the demineralizer resin bed is exhausted.

ANSWER: C.

TOPIC: 291007  
KNOWLEDGE: K1.05 [2.4/2.5]  
QID: B2338 (P2335)

A condensate demineralizer differential pressure (D/P) gauge indicates 4.0 psid at 50% flow rate. Over the next two days plant power changes have caused condensate flow rate to vary between 25% and 100%.

Which one of the following combinations of condensate flow and demineralizer D/P, observed during the power changes, indicates an increased accumulation of corrosion products in the demineralizer?

	<u>Condensate Flow Rate</u>	<u>Demineralizer D/P (psid)</u>
A.	100%	15.0
B.	75%	9.0
C.	40%	3.0
D.	25%	1.0

ANSWER: C.

TOPIC: 291007  
KNOWLEDGE: K1.05 [2.4/2.5]  
QID: B2638 (P2235)

A condensate demineralizer differential pressure (D/P) gauge indicates 4.0 psid at 50% flow rate. Which one of the following combinations of condensate flow and demineralizer D/P observed at various power levels over the next few days indicates an increase in the accumulation of insoluble corrosion products in the demineralizer?

	<u>Condensate Flow Rate</u>	<u>Demineralizer D/P (psid)</u>
A.	25%	0.9
B.	60%	6.3
C.	75%	8.7
D.	100%	15.6

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.05 [2.4/2.5]  
QID: B2938

A condensate demineralizer differential pressure (D/P) gauge indicates 9.0 psid at 50% flow. Over the next two days, plant power changes cause condensate flow to vary between 10% and 100%.

Which one of the following combinations of condensate flow and demineralizer D/P, if observed during the power changes, would indicate a detectable increase in the accumulation of corrosion products in the demineralizer?

	<u>Condensate Flow Rate</u>	<u>Demineralizer D/P (psid)</u>
A.	10%	0.3
B.	25%	3.3
C.	75%	20.3
D.	100%	35.3

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.06 [2.7/2.7]  
QID: B238

The temperature of the water passing through a demineralizer must be controlled because excessively hot water will...

- A. increase the ion exchange rate for hydronium ions, thereby changing effluent pH.
- B. degrade the corrosion inhibitor applied to the inner wall of the demineralizer.
- C. result in excessive demineralizer retention element thermal expansion, thereby releasing resin.
- D. reduce the affinity of the demineralizer resin for ion exchange.

ANSWER: D.

TOPIC: 291007  
KNOWLEDGE: K1.06 [2.7/2.7]  
QID: B438

There is a temperature limit on the water entering a demineralizer because excessively hot water...

- A. will decompose the resin beads.
- B. increases the potential for channeling.
- C. causes the filter element to swell and release the resin.
- D. will dislodge and wash the resin fines off the filter element.

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B938

The cation exchange resin in a mixed-bed demineralizer releases desirable \_\_\_\_\_ ions into solution while removing undesirable \_\_\_\_\_ ions from solution.

- A. negative; negative
- B. negative; positive
- C. positive; negative
- D. positive; positive

ANSWER: D.

TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B1039

The anion exchange resin in a mixed-bed demineralizer releases desirable \_\_\_\_\_ ions into solution while removing undesirable \_\_\_\_\_ charged ions from solution.

- A. hydroxide; negatively
- B. hydroxide; positively
- C. hydrogen; negatively
- D. hydrogen; positively

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B1639

If a dilute sodium chloride water solution is passed through an ideal mixed-bed demineralizer, the effluent stream would consist of...

- A. a sodium hydroxide solution.
- B. a hydrogen chloride solution.
- C. a sodium hypochlorite solution.
- D. pure water.

ANSWER: D.



TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B1738

Which one of the following describes the process of backwashing a mixed-resin deep bed demineralizer?

- A. Alternating the flow of dilute acidic and caustic solutions through the demineralizer to remove suspended solids and colloidal matter
- B. Alternating the flow of dilute acidic and caustic solutions through the demineralizer to remove ionic impurities
- C. Reversing flow of pure water through the demineralizer to remove suspended solids and colloidal matter
- D. Reversing flow of pure water through the demineralizer to remove ionic impurities

ANSWER: C.

TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B1838

When a mixed-bed demineralizer resin is exhausted, the resin should be replaced or regenerated because...

- A. ions previously removed by the resin will be released into solution.
- B. the resin will fracture and possibly escape through the retention screens.
- C. particles previously filtered out of solution will be released.
- D. the resin will physically bond together, thereby causing a flow blockage.

ANSWER: A.

TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B2438

Which one of the following describes the process of regenerating a mixed-resin deep bed demineralizer? (Assume the demineralizer has already been backwashed.)

- A. Alternating the flow of acidic and caustic solutions through the demineralizer to remove suspended solids and colloidal matter.
- B. Alternating the flow of acidic and caustic solutions through the demineralizer to remove ionic impurities.
- C. Reversing the flow of pure water through the demineralizer to remove suspended solids and colloidal matter.
- D. Reversing the flow of pure water through the demineralizer to remove ionic impurities.

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B5419

Water is passing through an ion exchanger that contains only anion exchange resin. Currently, every available ion exchange site in the resin has exchanged its original anion and is occupied by a chloride ( $\text{Cl}^-$ ) anion. Assuming that water temperature does not change, what will be the effect on the ion exchanger if a new anion impurity is introduced into the water entering the ion exchanger?

- A. The new anions will bypass the occupied ion exchange sites under all circumstances.
- B. The new anions will take the place of the  $\text{Cl}^-$  anions on the ion exchange sites under all circumstances.
- C. The new anions will take the place of the  $\text{Cl}^-$  anions on the ion exchange sites only if the new anions have a greater negative charge than the  $\text{Cl}^-$  anions.
- D. The new anions will take the place of the  $\text{Cl}^-$  anions on the ion exchange sites only if the new anions have a greater affinity for the anion exchange resin.

ANSWER: D.

TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B5720

If water containing positively-charged ionic impurities passes through a mixed-bed ion exchanger, the positively-charged ionic impurities will be removed by the \_\_\_\_\_ exchange resin, with the corresponding release of \_\_\_\_\_ ions into the water.

- A. anion; negative
- B. anion; positive
- C. cation; negative
- D. cation; positive

ANSWER: D.

TOPIC: 291007  
KNOWLEDGE: K1.07 [2.3/2.5]  
QID: B5820 (P5819)

During a nuclear power plant cooldown, the reactor experiences a large crud burst. After 10 minutes, with stable reactor coolant chemistry parameters, the operators begin to record parameters for the in-service reactor coolant purification ion exchanger. The ion exchanger was recently filled with fresh resin.

Assuming no additional operator actions, what trend will the recorded parameters show during the next few hours?

- A. Increasing ion exchanger inlet water conductivity.
- B. Increasing ion exchanger outlet water conductivity.
- C. Increasing flow rate through the ion exchanger.
- D. Increasing radiation levels around the ion exchanger.

ANSWER: D.

TOPIC: 291007  
KNOWLEDGE: K1.08 [2.6/2.6]  
QID: B337 (P1836)

A demineralizer that continuously receives flowing water with a high concentration of suspended solids will first develop an increase in the...

- A. conductivity at the demineralizer outlet.
- B. decontamination factor of the demineralizer.
- C. differential pressure across the demineralizer.
- D. pH at the demineralizer outlet.

ANSWER: C.

TOPIC: 291007  
KNOWLEDGE: K1.08 [2.6/2.6]  
QID: B539 (P836)

A lower than expected differential pressure across a mixed-bed demineralizer is an indication of...

- A. depletion of the resin.
- B. channeling through the resin bed.
- C. improper resin regeneration.
- D. a decrease in inlet conductivity.

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.08 [2.6/2.6]  
QID: B639 (P1036)

As the operating time of a demineralizer resin bed increases, the differential pressure across the bed...

- A. increases due to depletion of the resin ion exchange sites.
- B. increases due to trapping of suspended solids.
- C. decreases due to gradual resin breakdown.
- D. decreases due to erosion of the resin ion exchange sites.

ANSWER: B.

TOPIC: 291007  
KNOWLEDGE: K1.09 [2.7/2.7]  
QID: B39 (P535)

Which one of the following is an indication of resin exhaustion in a demineralizer:

- A. An increase in suspended solids in the effluent
- B. A decrease in the flow rate through the demineralizer
- C. An increase in the conductivity of the effluent
- D. An increase in the differential pressure across the demineralizer

ANSWER: C.

TOPIC: 291007  
KNOWLEDGE: K1.09 [2.7/2.7]  
QID: B239 (P2637)

A result of proper demineralizer operation on water with ionic impurities is that the exiting water will always have a...

- A. higher pH.
- B. lower pH.
- C. higher conductivity.
- D. lower conductivity.

ANSWER: D.