

ENERGY STAR Performance Ratings Methodology for Incorporating Source Energy Use

The purpose of this document is to provide technical detail on the methodology undertaken by EPA to incorporate source energy into the national energy performance ratings. This document is structured as follows:

| | | |
|------|--|----|
| I. | Overview | 2 |
| II. | The Value of Source Energy | 3 |
| | Energy Consumption in ENERGY STAR Buildings | 3 |
| | Source Energy in Different Heating Scenarios | 4 |
| III. | Methodology | 6 |
| | Use of National Average Source-Site Ratios | 7 |
| | Treatment of On-Site Generation | 7 |
| | Treatment of Renewable Energy | 8 |
| | Timeframe for Updating Source-Site Ratios | 8 |
| IV. | Source-Site Ratios by Energy Type | 8 |
| | Electricity | 9 |
| | Natural Gas | 9 |
| | Fuel Oil | 10 |
| | Propane | 11 |
| | District Systems | 11 |
| | Wood | 14 |
| | Coal | 14 |
| | Other | 14 |

I. Overview

EPA's national energy performance ratings evaluate the performance of buildings that use all types of energy. To compare this diverse set of commercial buildings equitably, the ratings must express the consumption of each type of energy in a single common unit. EPA has determined that **source energy** is the most equitable unit of evaluation. Source energy represents the total amount of raw fuel that is required to operate the building. It incorporates all transmission, delivery, and production losses, thereby enabling a complete assessment of energy efficiency in a building.

Most building managers are familiar with **site energy**, the amount of heat and electricity consumed by a building as reflected in utility bills. Site energy may be delivered to a facility in one of two forms: primary and/or secondary energy. **Primary energy** is the *raw fuel* that is burned to create heat and electricity, such as natural gas or fuel oil used in onsite generation. **Secondary energy** is the energy product (heat or electricity) created from a raw fuel, such as electricity purchased from the grid or heat received from a district steam system. A unit of primary and a unit of secondary energy consumed at the site are not directly comparable because one represents a raw fuel while the other represents a converted fuel. Therefore, in order to assess the relative efficiencies of buildings with varying proportions of primary and secondary energy consumption, it is necessary to convert these two types of energy into equivalent units of raw fuel consumed to generate that one unit of energy consumed on-site. To achieve this equivalency, EPA uses the convention of source energy.

When primary energy is consumed on site, the conversion to source energy must account for losses that are incurred in the storage, transport and delivery of fuel to the building. When secondary energy is consumed on site, the conversion must account for losses incurred in the production, transmission, and delivery to the site. The factors used to restate primary and secondary energy in terms of the total equivalent source energy units are called the **source-site ratios**. EPA uses national average ratios to accomplish the conversion to source energy because ENERGY STAR is a national program and because the use of national average source-site ratios ensures that no specific building will be credited (or penalized) for the relative efficiency of its energy provider(s).

Whether heat and electricity used at a building come from fuel burned on or off-site, there is always a potential for inefficiency in the conversion of primary fuels, and there is also a potential for loss when either primary or secondary fuels are transmitted/distributed to individual sites. These inefficiencies represent energy that was embodied in an original primary fuel, but that was not ultimately used at the building: potential heat, work, or electricity was sacrificed. If the losses were reduced, the building could operate with less overall fuel consumption, produce lower CO₂ emissions, and cost less to operate. The EPA comparison of buildings using source energy accounts for these losses, providing a complete energy assessment of the building. In addition, source energy comparisons generally reflect energy costs and carbon emissions more accurately than site energy.

Source-site energy ratios are applied to convert each kBtu of energy used on site into the total kBtu of equivalent source energy consumed. **Table 1**, following, summarizes the source-site ratios for each fuel in Portfolio Manager. Specific calculations and reference documents for each fuel are presented in Section IV.

| Table 1 | |
|---|--------------------------|
| Source-Site Ratios for all Portfolio Manager Fuels | |
| Fuel Type | Source-Site Ratio |
| Electricity | 3.340 |
| Natural Gas | 1.047 |
| Fuel Oil (1,2,4,5,6,Diesel, Kerosene) | 1.01 |
| Propane & Liquid Propane | 1.01 |
| Steam | 1.45 |
| Hot Water | 1.35 |
| Chilled Water | 1.05 |
| Wood | 1.0 |
| Coal/Coke | 1.0 |
| Other | 1.0 |

II. The Value of Source Energy

The purpose of the conversion from site energy to source energy is to provide an equitable assessment of building-level energy efficiency. Because billed site energy use includes a combination of primary and secondary forms of energy, a comparison using site energy does not provide an equivalent thermodynamic assessment for buildings with different fuel mixes. In contrast, source energy incorporates all transmission, delivery, and production losses, which accounts for all primary fuel consumption and enables a complete assessment of energy efficiency in a building.

When source energy is used to evaluate energy performance, an individual building's performance does not receive either a credit or a penalty for using any particular fuel type. The following discussion and analysis demonstrate this neutrality. For example, one quarter of the buildings that earned the ENERGY STAR in 2006 operate using 100% electricity. This is equivalent to the percent of buildings in the national population that use 100% electricity. Moreover, the building comparison presented in **Table 3** shows that source energy will correctly recognize efficient heating systems independent of fuel choice. Therefore, because EPA adopts source energy as the primary unit of comparison, using a particular fuel does not in itself make a building more or less likely to earn the ENERGY STAR.

Energy Consumption in ENERGY STAR Buildings

Source energy conversions are needed to account for the fact that buildings use different mixes of fuels, and primary and secondary energy cannot be compared directly. When the conversions are applied correctly, a building is no more or less likely to earn the ENERGY STAR based on the type of fuel consumed. **Table 2** compares the types of fuels used by the office buildings that

earned the ENERGY STAR in 2006 with the office buildings in the Commercial Building Energy Consumption Survey (CBECS). CBECS is a nationally representative quadrennial survey completed by the Department of Energy’s Energy Information Administration. EPA uses the data in this survey to develop the energy performance ratings.

| Table 2 Comparison of Fuel Use ENERGY STAR Office Buildings and National Commercial Office Building Population | | |
|--|---------------------|---------------------------|
| | CBECS 2003 Data Set | ENERGY STAR Class of 2006 |
| Number of Buildings | 498 | 332 |
| Average Percent Electricity Used | 68% | 85% |
| Average Percent Natural Gas Used | 29% | 7% |
| Percent of Buildings Using 100% Electricity | 25% | 25% |
| <i>Note</i> - <u>CBECS 2003</u> – The Commercial Building Energy Consumption Survey. This is a national survey conducted every four years by the Energy Information Administration. Complete information on the survey, including public data files, is available at: http://www.eia.doe.gov/emeu/cbecs/contents.html . The average values presented are weighted using the survey sampling weights and are computed using Office buildings only, applying the standard set of filters used to create the ENERGY STAR performance rating model. Information on these filters is available in the document: Technical Methodology for Office, Bank/Financial Institution, and Courthouse . - <u>ENERGY STAR</u> – These values are averages, weighted by floor space, and computed across those office buildings which earned the ENERGY STAR during the year 2006. | | |

On average, ENERGY STAR office buildings have a fuel mix that is approximately 85% electricity. This is a higher average percent of electricity than the national commercial building population, which on average uses 68% electricity. The higher percent of electric use among ENERGY STAR offices may reflect the fact that offices that have applied for the ENERGY STAR are more likely to be large buildings with high plug loads. Generally, the fuel profile of ENERGY STAR buildings is similar to the fuel profile of the national population, with electricity accounting for the majority of on-site fuel consumption. Moreover, the percent of ENERGY STAR office buildings that use only electricity (25%) is equivalent to the percent of office buildings in the country that use only electricity. Hence, on a national basis an all-electric building is no more (or less) likely to earn the ENERGY STAR.

Source Energy in Different Heating Scenarios

Because most buildings use electricity for lighting and other equipment, the reason that fuel mix varies by building is usually due to the choice of heating system. Another way to understand the relationship between fuel choice, source energy, and energy performance is to consider six different scenarios for heating systems in buildings. For each scenario, assume that the building has the same operation and the same thermal envelope. Therefore, the heat load for each building is identical. The differences among the buildings are solely in the type of fuel and the equipment used for heating. The six scenarios are as follows:

- **Building A** is heated using natural gas. The boiler has a combustion efficiency of 90%. With standby and distribution losses, the overall system efficiency is 80%. This is considered a highly efficient natural gas system.

- **Building B** is heated using natural gas. The boiler has a combustion efficiency of 70%. With standby and distribution losses, the overall system efficiency is 55%. This is considered a relatively inefficient natural gas system, which might be found in an older building with poor maintenance, unsophisticated controls, and limited insulation.
- **Building C** is heated using district steam. Minor losses occur onsite due to steam distribution, resulting in an on-site system efficiency of 95%. This is a highly efficient steam system.
- **Building D** is heated with electricity using a geothermal system, incorporating heat pumps with a coefficient of performance (COP) of 4.0. This is considered a highly efficient system.
- **Building E** is heated with electricity using an air source heat pump system, incorporating heat pumps with a COP of 2.5. This is considered an efficient heat pump system.
- **Building F** is heated using electric resistance heating. While minor line losses can occur with resistance heating, electric resistance converts nearly 100% of the electricity received from the utility into heat. However, due to the large amount of primary fuel required to generate the electricity for resistance heating, it is considered to be the least efficient form of electric heat based on a complete thermodynamic assessment.

If the buildings are identical (i.e. have the same construction, thermal envelope, and operation), and each has the same heating load of 1000 MBtu, then the site and source energy consumption can be expressed as shown in **Table 3**. These site and source energy values demonstrate the key differences and illustrate why source energy is the more equitable comparative metric.

| Table 3 Comparison of Alternate Heating Scenarios | | | | | | |
|---|----------------------------------|----------------------------------|---------------------------------------|--------------------|-------------------------------|--------------------------|
| | Building A | Building B | Building C | Building D | Building E | Building F |
| Heating System | NG Boiler, 80% system efficiency | NG Boiler, 55% system efficiency | District Steam, 95% system efficiency | Geothermal COP=4.0 | Air Source Heat Pump, COP=2.5 | Electric Resistance Heat |
| Heating Fuel | Natural Gas | Natural Gas | District Steam | Electric | Electric | Electric |
| Heat delivered to Space (MBtu) | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 |
| Site Energy (MBtu) | 1250 | 1818 | 1053 | 250 | 400 | 1000 |
| Source Energy (MBtu) | 1309 | 1903 | 1527 | 835 | 1336 | 3340 |
| <i>Note that the following source-site ratios were applied:</i> - Electricity: 1 unit site = 3.340 units source - Natural Gas: 1 unit site = 1.047 units source - Steam: 1 unit site = 1.45 units source | | | | | | |

A comparison of these building scenarios using site energy fails to recognize highly efficient systems and improperly rewards inefficient systems, as described below:

- A site energy comparison suggests that all types of electric heating systems are more efficient than natural gas and steam systems. While geothermal systems (Building D) and air source heat pumps (Building E) can be more efficient or comparable to natural gas and steam, the electric resistance heating system (Building F) requires far more

primary fuel in its operation. From a thermodynamic perspective, this building would be falsely rewarded using a site energy system.

- A site energy evaluation suggests that the district steam system is more efficient than all natural gas boiler systems. It is true that district steam systems can be comparable to some natural gas heating systems. However, there are heat losses associated with the production and distribution of steam to the site that are not accounted for in a site energy evaluation. A conventional district steam utility delivers heat to the building with an efficiency of 69% (see Section IV). When these losses are incorporated into a complete assessment, a conventional district steam system does not offer superior performance when compared with a highly efficient on-site gas boiler (Building A).

In contrast, source energy provides an accurate and equitable comparison of these building scenarios, as described below:

- A source energy comparison correctly classifies the geothermal heat pump (Building D) as the most efficient technology. At the same time, source energy provides a more equitable comparison of this efficient technology with the most efficient natural gas technologies (Building A).
- Source energy captures the inefficiencies inherent in the generation and distribution of electricity. Therefore, a source energy comparison shows that electric resistance heating provides the worst energy performance. Source energy also incorporates on-site inefficiencies, which is why the less efficient on-site natural gas system (Building B) has the second worst energy performance.
- Source energy shows that a conventional district steam system (Building C) can offer benefit over less efficient on-site natural gas systems (Building B).

The EPA energy performance ratings are developed to express the complete energy efficiency of a building. In this context the preceding heating scenarios illustrate that source energy provides a more accurate and equitable assessment than site energy.

III. Methodology

Ultimately, the goal of the conversion to source energy is to account for the total primary fuel needed to deliver heat and electricity to the site. Generally this means the methodology should perform the following adjustments for energy consumed on site:

- **Primary Energy** (e.g. natural gas, fuel oil) – Account for losses that occur in the distribution, storage and dispensing of the primary fuel.
- **Secondary Energy** (e.g. electricity, district steam) – Account for conversion losses at the plant in addition to losses incurred during transmission and distribution of secondary energy to the building.

Specific details on the application of this methodology to each type of energy are provided in Section IV.

These adjustments quantify the total energy content of the primary fuel. In this assessment, the primary fuels are considered refined products such as coal, natural gas and oil. The analysis does not account for the energy that is consumed in mining, transporting, and refining crude products. While this type of analysis may provide an instructive look at the lifecycle costs of energy use, it is beyond the scope of a building-level assessment.

Use of National Average Source-Site Ratios

The efficiency of secondary energy (e.g. electricity) production depends on the types of primary fuels that are consumed and the specific equipment that is used. These characteristics are unique to specific power plants and differ across regions of the country. For example, some states have a higher percentage of hydroelectric power, while others consume greater quantities of coal. Because ENERGY STAR is a national program for energy efficiency, EPA has determined that it is most equitable to employ national-level source-site ratios. As such, there is only one source-site ratio for each of the primary and secondary fuels in Portfolio Manager, including electricity.

There are a few reasons why national source-site ratios provide the most equitable approach:

- 1) The geographic location is fixed for most buildings; there is no opportunity to relocate the building to a region with more efficient electrical production.
- 2) For most buildings it is not possible to trace each kWh of electricity back to a specific power plant. Across a given utility region, the grid is connected and the electric consumption of a specific building cannot be associated with any individual plant.
- 3) The key unit of analysis for Portfolio Manager is the building. It is the efficiency of the building, not the utility, which is evaluated. Two buildings with identical operation and energy consumption will receive the same rating regardless of their geographic location or utility company.

The use of national source-site ratios ensures that no specific building will be credited (or penalized) for the relative efficiency of its utility provider.

Treatment of On-Site Generation

The objective of the conversion to source energy is to quantify the total amount of raw fuel consumed by the building. For a facility with on-site generation, the building is assessed based on the quantities of primary fuel that are purchased, not on the quantities of secondary energy that are produced. In an example building that uses natural gas to generate electricity, the building will be evaluated based on the total consumption of natural gas. In this case, if the building produces electricity more efficiently than the national electric grid, then it will rate higher than a building purchasing electricity that is generated off-site. If the on-site production is less efficient, then it will rate lower.

Treatment of Renewable Energy

Off-site renewable energy generation:

The electric grid in the United States includes a variety of renewable sources of electricity, including wind power, solar power, and hydroelectric power. These renewable sources of energy do not depend on the consumption of any primary fuel. However, as described above, at an individual building or facility it is typically not possible to trace each kWh of electricity to a specific power generation plant. Therefore, a building may be located in a utility region that includes multiple forms of electric generation including wind, hydroelectric, and coal but because the grid is interconnected, it is not possible to assign a specific production method to a specific building. Moreover, as noted above, individual buildings do not have control over the available power supply options in their geographic area. Therefore, EPA uses national source-site ratios, which reflect the proportion of renewable electric generation on the national grid.

On-site renewable energy generation:

When renewable energy is produced at a building through solar photovoltaic panels or wind turbines, the goal of the source energy conversion is still to quantify the amount of primary fuel consumed. For on-site solar power or wind power, conversion of energy from the sun or the wind into useful energy for a building does not require the consumption of any primary fuels. In this case, a source-site ratio of zero is equivalent to not entering these forms of generation into Portfolio Manager at all. The application of these on-site technologies will lower (or eliminate) the electric demand from the grid, and therefore is associated with higher energy performance ratings.

The case of the onsite use of renewable fuels such as wood and bio-mass differs slightly. These fuels are equivalent to primary fuels and have embodied heat content. Hence, a source-site ratio is applied to these fuels, as it would be applied to any other fuel purchased off-site and burned to produce heat and/or electricity.

Timeframe for Updating Source-Site Ratios

The most recent revision of source-site ratios occurred in October 2007. The source-site ratios computed and applied in the Portfolio Manager tool depend on several characteristics, including the quality of the fuels, the average efficiency of conversion from primary to secondary energy, and the distribution efficiency. Therefore, over time the ratios are expected to change as the national infrastructure and fuel mix evolve. Characteristics that impact the ratios do not change drastically from one year to the next, but may be expected to change over time. Therefore, EPA plans to review the ratios every 3 to 5 years, and update accordingly.

IV. Source-Site Ratios by Energy Type

This section presents the specific reference documents and calculations used to derive the source-site ratios for each type of energy available in Portfolio Manager.

Electricity

Electricity is a secondary form of energy that is consumed at a building. Electricity is generated through the burning of fossil fuels (e.g. coal, natural gas, fuel oil), from nuclear plants, and from renewable sources including wind, hydropower, and biomass. The source-site ratio for electricity must reflect the losses that are incurred when these fuels are converted from their primary form into electricity, and also for any losses that occur on the electric grid as the electricity is transported to specific buildings.

These values can be computed directly from the Electricity Flow Diagram, included in the Energy Information Administration's Annual Energy Review¹. As shown in the diagram, the mix of electric production in the United States is approximately 70% fossil fuel, 20% nuclear, and 10% renewable (hydropower, biomass, solar, wind, geothermal). The source-site ratio is calculated as Primary Energy (i.e. the total primary energy involved in electricity generation) divided by Net Generation less Transmission and Distribution (T&D) Losses. This calculation is summarized in **Table 4**. As shown, the source-site ratio can be calculated separately for any given year, and varies slightly over time. Because a building in Portfolio Manager can have multiple years of data and different buildings have energy data for different time periods, EPA has computed an average over the five years to apply as the standard conversion in the development of rating models and the rating of individual buildings. The source-site ratio for electricity is 3.340.

| Table 4 | | | | |
|--|---|-----------------------|-----------------------|--------------------------|
| Source-Site Ratio Calculations for Electricity | | | | |
| Year | Primary Energy Consumed for Generation | Net Generation | T&D Losses | Source-Site Ratio |
| 2001 | 38.56 | 12.69 | 1.20 | 3.356 |
| 2002 | 39.56 | 13.10 | 1.24 | 3.336 |
| 2003 | 39.62 | 13.13 | 1.24 | 3.332 |
| 2004 | 40.77 | 13.49 | 1.28 | 3.339 |
| 2005 | 41.60 | 13.78 | 1.31 | 3.336 |
| Average (2001-2005) | | | | 3.340 |
| <i>Source:</i> <i>Electricity Flow (Diagram 5) in the Annual Energy Review. Values in Quadrillion Btus (Quads). http://www.eia.doe.gov/emeu/aer/contents.html</i> | | | | |

Natural Gas

Natural gas is a type of primary energy that is burned on-site to produce heat and/or electricity. Because natural gas is a type of primary energy, the source-site ratio must account for losses incurred in pipeline transmission and distribution of natural gas from the provider to the customer. These values are obtained from the Natural Gas Annual, a regular publication of the Energy Information Administration. The source-site ratio can be computed directly from the

¹ Every year, the Energy Information Administration publishes the Annual Energy Review at: <http://www.eia.doe.gov/emeu/aer/contents.html>. This web page also provides links to reports for previous years. Each report contains and Electric Flow Diagram: <http://www.eia.doe.gov/aer/diagram5.html>

information in Table 1 of the Natural Gas Annual, Summary Statistics for Natural Gas in the United States, 2001-2005².

The source-site ratio is obtained first by computing the sum of the delivery to consumers, the pipeline and distribution use, and the plant use, and then dividing this sum by the total delivery to consumers. This calculation indicates the total amount of gas that is used at the distribution plant or lost in transmission, for each unit of gas that is delivered to a consumer. As shown in **Table 5**, the source-site ratio for natural gas can be calculated separately for any given year, and varies slightly over time. Because a building in Portfolio Manager can have multiple years of data and different buildings have energy data for different time periods, EPA has computed an average over the five years to apply as the standard conversion in the development of rating models and the rating of individual buildings. The source-site ratio for natural gas is 1.047.

| Table 5 | | | | |
|---|--|---|--|--------------------------|
| Source-Site Ratio Calculations for Natural Gas | | | | |
| Year | Sum of Pipeline and Distribution Use, Plant Fuel, and Delivery to Consumers (MM ft³) | Sum of Pipeline and Distribution Use, Plant Fuel (MM ft³) | Delivery to Consumers (MM ft³) | Source-Site Ratio |
| 2001 | 21,491,213 | 996,105 | 20,495,108 | 1.049 |
| 2002 | 22,276,435 | 1,049,423 | 21,227,012 | 1.049 |
| 2003 | 21,518,122 | 955,395 | 20,562,727 | 1.046 |
| 2004 | 21,657,411 | 932,528 | 20,724,883 | 1.045 |
| 2005 | 21,484,879 | 939,972 | 20,544,907 | 1.046 |
| Average (2001-2005) | | | | 1.047 |
| Source: Table 1. Summary Statistics for Natural Gas in the United States, 2001-2005. <i>Natural Gas Annual 2005</i> . Excludes Lease Fuel to be consistent with the method for electricity. http://www.eia.doe.gov/oil_gas/natural_gas/data_publications/natural_gas_annual/nga.html | | | | |

Fuel Oil

Refined petroleum products are considered primary energy; they are burned on-site to produce heat and/or electricity. These products include fuel oil (# 1, 2, 4, 5, 6), diesel, and kerosene. As with other primary fuels, the source-site ratio for fuel oil must account for the losses occurred in fuel distribution, storage, and dispensing.

EIA does not produce an annual report that quantifies the losses associated with fuel oil distribution, storage and dispensing. However, several other detailed reports were reviewed to explore the lifecycle energy requirements for producing transportation fuels. The most suitable report for the desired estimate was determined to be A Lifecycle Emissions Study (LEM)

² Every year the Energy Information Administration publishes the Natural Gas Annual at: http://www.eia.doe.gov/oil_gas/natural_gas/data_publications/natural_gas_annual/nga.html. This web page also provides links to reports for previous years. Each report contains a Table, *Summary Statistics for Natural Gas in the United States* http://www.eia.doe.gov/pub/oil_gas/natural_gas/data_publications/natural_gas_annual/historical/2005/pdf/table_001.pdf

conducted at the University of California, Davis³. From this study, estimates relating to the production and distribution of highway diesel fuel were determined to be the most analogous to the types of heating fuels found in commercial buildings⁴. The LEM study identifies the energy required for distribution and storage, and fuel dispensing, and the relative proportion of this energy use to the total end use. These figures are presented in **Table 6**. The proportion of diesel fuel that is used in distribution and storage and fuel dispensing is approximately 1% of the total delivery to customers. Therefore, the source-site ratio for fuel oil is 1.01.

| Table 6 | | |
|---|-----------------------------------|--|
| Summary of LEM Study Figures for Highway Diesel Fuel | | |
| Highway Diesel Fuel Lifecycle | Energy Required (Btu/mile) | Energy Proportion Relative to End Use |
| Fuel Distribution and Storage | 189 | 0.8% |
| Fuel Dispensing | 45 | 0.2% |
| End Use | 24,600 | 100.0% |
| Total | 24,834 | 101.0% |
| <i>Source: Table 51B, LEM Study, p. 400. Excludes feedstock recovery, transmission, and refining to be consistent with the method used for electricity.</i> | | |

Propane

Propane is a fuel that can be generated either as a bi-product of petroleum-refining or natural gas processing. Once created, propane is considered a primary fuel that is burned on site to produce heat and/or electricity. Because propane is a primary fuel, the source-site ratio must account for losses occurred in fuel distribution, storage, and dispensing. EIA does not produce an annual report that quantifies the losses associated with propane distribution, storage and dispensing. Propane is considered to be most analogous to that of fuel oil. Therefore, the source-site ratio for propane is 1.01.

District Systems

District energy is secondary energy that is generated off-site and delivered to a facility in the form of steam, hot water, or chilled water. For secondary sources of energy, the source-site ratio must account for the losses that occur when the primary fuel is converted into the secondary form of energy (the production efficiency) and any losses that occur when the secondary energy is distributed to the facility (the distribution efficiency). Properties of these district systems, including ranges for the production and distribution efficiencies are referenced in a report titled *District Energy Services: Commercial Data Analysis for EIA's National Energy Modeling*

³ A Lifecycle Emissions Model (LEM): Lifecycle Emissions from Transportation Fuels, Motor Vehicles, Transportation Modes, Electricity Use, Heating and Cooking Fuels, and Materials, Mark DeLucchi, Institution of Transportation Studies, University of California, Davis, December 2003. Found at: <http://repositories.cdlib.org/cgi/viewcontent.cgi?article=1064&context=itsdavis> (LEM Study).

⁴ Highway diesel fuel is a more refined product than fuel oil that may be used in buildings. However, the primary contributors to the source-site ratio (energy for distribution, storage, and dispensing of the fuel) are expected to be similar.

System. This report was compiled for the Energy Information Administration by Energy and Environmental Analysis, Inc. (EEA) and the International District Energy Association (IDEA)⁵. The specific calculations for each of type of district energy system are discussed below.

District Steam

The efficiency of steam generation is dictated by the boiler. Typical boiler efficiencies range from 80% to 85% at full load (i.e. design) conditions. However, at partial load the efficiency will be lower, on the range of 90% to 95% of the design efficiency. The steam production efficiency can be evaluated at the midpoint of each of these ranges:

$$(\text{Boiler Efficiency}) * (\text{Partial Load Efficiency}) = (82.5\% * 92.5\%) = 76.3\%$$

Once steam is generated, some of the heat will be lost in transit between the production facility and the site of use. This distribution heat loss ranges from approximately 6% to 9%. Again, the midpoint of this range (7.5%) can be used to evaluate the overall system efficiency:

$$\text{Production Efficiency} - \text{Distribution Loss} = 76.3\% - 7.5\% = 68.8\%$$

Therefore steam production delivers heat to the site with a thermal efficiency of approximately 69%. Because only 69% of the thermal content of the original fuel is delivered to the building in the form of heat, it takes 1.45 kBtu of source energy to provide 1 kBtu of energy to the building. Hence, the source-site ratio for district steam is 1.45.

District Hot Water

The efficiency of hot water generation is also dictated by the boiler and distribution losses. As with steam generation, boilers are designed to operate with an efficiency of 80% to 85%, and operational efficiencies are expected to be lower due to partial load operation. Thus the production efficiency for hot water is expected to have an identical range as for steam, with a midpoint at 76.3% efficiency.

For hot water, distribution losses are smaller than they are for steam, because hot water distribution is not subject to condensate loss. As such, the distribution losses associated with hot water range from 2% to 3%. Using the midpoint of this range (2.5%), the overall system efficiency can be computed:

$$\text{Production Efficiency} - \text{Distribution Loss} = 76.3\% - 2.5\% = 73.8\%$$

Therefore hot water production delivers heat to the site with a thermal efficiency of approximately 74%. Because only 74% of the thermal content of the original fuel is delivered to the building in the form of heat, it takes 1.35 kBtu of source energy to provide 1 kBtu of energy to the building. Hence, the source-site ratio for district hot water is 1.35.

⁵ Energy and Environmental Analysis, Inc. and International District Energy Association. *District Energy Services: Commercial Data Analysis for EIA's National Energy Modeling System*. Submitted to: Decision Analysis Corporation and Energy Information Administration. August 2007.

District Chilled Water

Chilled water generation is characterized by two main technologies: electric chillers and gas fired chillers. Electric chillers make up the majority of chilled water generation, but each technology is discussed below.

The efficiency of electric chillers is described in terms of kW of electricity required per ton of cooling. In other words, the number of units of output cooling to input power is known as the Coefficient of Performance (COP) and ranges from 2.9 to 4.4. This range of output cooling (2.9 to 4.4 kW) is generated from each kW of input power⁶. Electric chillers will also be subject to a loss of up to 10% due to partial load operation. As such, the COP range is better stated as 2.6 to 4.0, which expresses the net production efficiency. The source-site ratio must also account for the distribution losses, which range from 2% to 3%. Subtracting this percent from the COP values, yields a range of 2.5 to 3.9. The midpoint of this range is 3.3; for each kBtu of energy required by the electric chiller, approximately 3.3 kBtu of energy is delivered to the building. This net COP can be restated:

$$1 \text{ kBtu cooling at the building} = 0.3125 \text{ kBtu of electricity required at chiller}$$

However, it is important to recall that the Btu requirement to drive the chiller is electric, and electricity is a secondary form of energy. Therefore, in order to quantify the total energy requirement, the energy requirement of the chiller must itself be multiplied by the source-site ratio for electricity (which is 3.34):

$$1 \text{ kBtu on-site cooling} = 1.04 \text{ kBtu source energy}$$

Thus for electric chillers (which constitute the majority), the source-site ratio is 1.04.

Natural gas fired chillers constitute a much smaller portion of total chilled water generation. These chillers are typically characterized by COP values of 0.7 to 1.4, indicating that 0.7 to 1.4 Btu of energy is provided for every Btu of natural gas that is consumed. As with electric chillers, actual operation is typically at partial load, which will reduce the production COP to 0.6 to 1.3. As with electric chillers, the distribution losses are estimated to be 2% to 3%. Subtracting these losses from the COP values yields a range of 0.6 to 1.2; the middle of this net range is 0.9, indicating that for each Btu of gas required by the chiller, 0.9 Btu are delivered to the building. This net COP can be restated:

$$1 \text{ kBtu cooling at the building} = 1.11 \text{ kBtu of natural gas required at chiller}$$

Because natural gas is a form of primary energy, an additional source-site calculation is not required. This primary energy consumption occurs at the power plant and therefore is not subject to the same distribution losses as at a commercial building.

Although the exact technology breakdown between natural gas and electric chillers is not well documented by either EIA or IDEA, electric chillers are known to be the dominant technology.

⁶ This range is based on an assumption of 0.8 to 1.2 kW per ton of cooling, with 1 ton of cooling equaling 12,000Btu/hr or 3.517 kW.

The electric chilled water source-site ratio is 1.04, while the natural gas chilled water source-site ratio is 1.11. Assuming as much as 10 to 20% of chilled water comes from natural gas; the average ratio across the two technologies is 1.05. Therefore, the source-site ratio for district chilled water is 1.05.

Wood

Wood is a renewable fuel that is purchased and burned on-site. Wood is considered to be a primary fuel, which is combusted on-site to produce heat and/or electricity. Because wood is a primary fuel, the source-site ratio should account for any loss that occurs in the storage, transportation and distribution of wood. There is no direct quantifiable loss of wood that occurs when it is stored, transported, or delivered to a site. Therefore, the source-site ratio for wood is 1.0.

Coal

Coal is a fossil fuel that can be combusted at an individual facility to create heat and/or electricity. Because coal is a primary fuel, the source-site ratio must account for any losses that occur in the storage, transportation and delivery of coal to a building. There is no direct quantifiable loss of coal that occurs when it is stored, transported, or delivered to a facility. Therefore, the source-site ratio for coal is 1.0.

Other

In Portfolio Manager, EPA has built capacity for 17 types of fuels, each of which falls into one of the preceding categories. However, in the event that a building using a different fuel on-site (e.g., waste biomass), then a user may select the “Other” category. In these situations, because the primary fuel source is not reported, EPA cannot quantify any losses that are associated with conversion, transportation, or distribution. Hence, the source-site ratio is 1.0