Fort Knox Fire and Emergency Services Division Special Event Checklist								
Event Name:								
Event Dates:								
Event Time:								
Event Point of Contact (POC):								
Event POC Phone Number:	Event POC Phone Number:							
Facility Name and Building number:								
Facility Point of Contact (POC):								
Facility POC Phone number:								
Inspector's Name:								
Date of Initial Inspection:								
Date of Final Inspection:								
Fire Prevention Inspection Office: Directorate of Emergency Services (DES) Fire and Emergency Services Division Building xxx (502) 624-4208								
Event Staff:	YES	NO	N/A	REMARKS				
Have responsibilities for execution of emergency evacuation procedures been addressed?								
Will event staff be clearly identifiable so that guests may request help or information?								
How many event staff will be working the event?								
Have arrangements been made to maintain radio communication between the organizers and staff?								
Have responsible individuals been identified to conduct roving inspections during event? (Note: Aware of general and specific crowd control, suspicious activity, hazards)								
Have security arrangements been confirmed?								
Will any Special Equipment, High Risk Activity or Animals be involved in the event? (Note: if YES explain in the remarks section).								

FK FORM 5121, MAY 2013 Page 1 of 5

FORT KNOX FIRE AND EMERGENCY SERVICES DIVISION Special Event Checklist							
Tents:	`	YES		NO	N/A	REMARKS	
Is propane used for any part of this function?			T				
Will tents be used? (Note: Assembly and maintenance of tents must comply with requirements of NFPA)							
Is there a Flame Resistance Certificate for floor coverings and/or Tents on file with our office?							
Open or Exposed Flame < 20' from tent/buildings:							
Combusitble Material < 20' from tent/buildings:							
Do guy wires or ropes cross an exit at a height of less than 7 feet?							
Are tent stakes railed off, capped or covered?							
Do bracing or support ropes impede the means of egress or create a tripping hazard?							
Smoking:	١	YES		NO	N/A	REMARKS	
Are "No Smoking" signs posted?							
Is there a designated smoking area?							
Are procedures in place to enforce the statute which prohibits smoking in public buildings?							
Occupancy Load:	Υ	/ES		NO	N/A	REMARKS	
Has the site plan and event layout been completed and given to the Fire Prevention Office?							
Has the occupancy load/limit been determined for location to be used?							
Occupancy Load Capacity for this event and layout is:							
Stage and Stairs:	Y	/ES		NO	N/A	REMARKS	
Are stages and platforms appropriately guarded and edges and steps highlighted for clear visibility?							
Have stairs/stairwell and handrails been inspected to assure that they are in good working condition? (No storage shall be permitted in stairwells or under stairs at any time).							

FK FORM 5121, MAY 2013 Page 2 of 5

FORT KNOX FIRE AND EMERGENCY SERVICES DIVISION Special Event Checklist

Exit Egress Y Have responsibilities for execution of emergency evacuation procedures been addressed?	'ES	NO		
Have responsibilities for execution of emergency evacuation procedures been	E5	NO		DEMARKO
			N/A	REMARKS
audiessed:				
Has a designated emergency evacuation assembly area been established? (Note area in the remarks section).				
Is event setup planned; that aisle ways and doorways are free of cords, protrusions and other obstructions that could cause tripping and/or struck-by-injuries?				
Have walkways leading to and from the event site been inspected for potential slip, fall and trip hazards? (Note: Slip/trip/fall hazards must be corrected or exposure of participants to these hazards must be prevented prior to and during the event).				
Have grassy areas to be used or in close proximity of event been inspected for holes and other hazards?				
Have procedures been established for effective crowd control?				
Have arrangements been made to setup barricades to clearly delineate areas for pedestrian and vehicular traffic?				
ADA: Y	/ES	NO	N/A	REMARKS
Have ADA accommodations been made to assist persons with disabilities to fully participate in the event as planned? (Mobility Impairments, Sight Impairments, Speech Impairments, Hearing Impairments, Others).				
Have appropriate accommodations been made for emergency evacuation for a person with disabilities?				
Exits: Y	'ES	NO	N/A	REMARKS
Are exits spaced at approximate equal intervals around the perimeter of the tent building or area?				
Are exits located so all points are < 100' to an exit?				
Is the minimum width of an exit not less than 32"?				
Is there a clear exit path near fences or other obstructions?				
Are aisle ways clear and unobstructed?				
Does the location have at least two means of egress that are remote from each other?				

FK FORM 5121, MAY 2013 Page 3 of 5

FORT KNOX FIRE AND EMERGENCY SERVICES DIVISION Special Event Checklist							
Exits (Continued):	YES	NO	N/A	REMARKS			
Are exits so arranged and maintained as to provide free and unobstructed egress from all occupied areas? (Note: No exit may be blocked with furniture, conecessions, or locked from the inside; rugs, electrical extensions cords or other cables may not be placed across exit corridors so that they impede clear access to the exit doors and corridor).							
Cooking:	YES	NO	N/A	REMARKS			
Is cooking or heating equipment located a distance of < 10' of an exit or combustible materials?							
Is commercial cooking equipment such as grills and broilers used with proper ventilation, fire suppression systems and minimum of 20' from the occupied tent and/or building?							
Are LP gas containers having a capacity of 500 gallons or less properly secured at least 10' away from tent/building?							
Are appliances isolated from the public by at least 4'? Are cooking appliances U.L. listed and have clearances of not < 36" at the back and 48" at the front?							
Fire Protection Equipment:	YES	NO	N/A	REMARKS			
Is there a portable fire extinguisher (ABC type) at each exit of an enclosed tent/building?							
Do cooking areas have a minimum of a 20 BC rated fire extinguisher? (Note: If using a deep fat fryer; a class "K" rated fire extinguisher will also be required).							
Electrical:	YES	NO	N/A	REMARKS			
Are electrical systems and equipment isolated from the public by proper elevation or guarding? Are cables on the ground in areas traveled by the public placed in trenches or protected by approved covers?							
Are all electrical systems properly grounded?							
Are there two seperate circuits for occupant loads of 300 or less? For occupant loads greater than 300, one of two circuits must be from an approved emergency system.							
Are generators a minimum of 20' from the tent and/or building and taped off with caution tape and cones?							
Are portable generators U.L. listed or equivalent?							
Are generators capable of running continuously without refueling for the entire length of the event?							

FK FORM 5121, MAY 2013 Page 4 of 5

FORT KNOX FIRE AND EMERGENCY SERVICES DIVISION Special Event Checklist								
Site:	YES	NO	N/A	REMARKS				
Is the access to fire hydrants and FDC's for Fire Department vehicles unobstructed at all times?								
Does the building have a sprinkler system?								
Are fire lanes must be unobstructed at all times?								
Lighting:	YES	NO	N/A	REMARKS				
Have interior emergency lights been tested and are working properly?								
Have exterior emergency lights been tested and are working properly?								
Is the location adequately illuminated for the time and type of event?								
Is the lighting > 6' away from combustibles or protected by non-combustible material?								
Fire Alarm (FA):	YES	NO	N/A	REMARKS				
Has the Fire alarm panel and all devices been checked to ensure it is functioning properly?								
Is the event setup such that access to alarm activation and warning devices are kept clear and accessible?								
Location of FA panel:								
Events Involving Fire, Flame and/or Heat:	YES	NO	N/A	REMARKS				
Have all combustible decorative materials that will be used in builling been treated with flame retardant?								
Will there be a firework display at the event?								
Do you plan on having a bonfire at the event?								
Do you plan on having a barbeque at the event?								
Are open flames inside the building prohibited for this event? (Note: Burning candles and all other forms of open flames shall be prohibited inside buildings without approval of the AHJ).								
Will a post-event arena inspection be conducted to insure that no fire or other hazards are left on site? (e.g. lit cigarette butts or othe burning/smoldering material).								
Has a request for the use of pyrotechnic devices been submitted to the Ft. Knox Fire Chief (AHJ) for this event?								

FK FORM 5121, MAY 2013 Page 5 of 5