


US Army Corps
of Engineers



2002-2003

Northwestern Division
Missouri River Basin
Water Management Division

Missouri River Mainstem System 2002-2003 Annual Operating Plan

Missouri River Basin



*Annual Operating Plan Process 50 Years
Serving the Missouri River Basin*

January 2003



DEPARTMENT OF THE ARMY
NORTHWESTERN DIVISION, CORPS OF ENGINEERS
12565 WEST CENTER ROAD
OMAHA, NEBRASKA 68144-3869

REPLY TO
ATTENTION OF:

This Annual Operating Plan (AOP) presents information regarding the Corps of Engineers' operation of the Missouri River Mainstem Reservoir System (System) through December 2003. The information provided in this AOP is based on water management guidelines designed to meet the operational objectives of the existing Missouri River Master Water Control Manual. These guidelines are applied to computer simulations of System operation assuming inflow scenarios based on water supply records from 1898 to 1997. This approach provides a good range of water management simulations for dry, average, and wet conditions.

The AOP provides a framework for the development of detailed monthly, weekly, and daily regulation schedules for the System's six individual dams during the upcoming year to serve its Congressionally authorized project purposes. In addition, 5-year extensions to the AOP water management simulations, through March 2009, are presented to serve as guides for longer range planning. System water management is provided by my staff at the Missouri River Basin Water Management Division, Northwestern Division, U.S. Army Corps of Engineers located in Omaha, Nebraska.

The AOP presents a "steady release" schedule during the nesting season of the interior least tern and piping plover, which are listed for protection under the Endangered Species Act. Under a steady release schedule, enough water would be released to meet minimum navigation flow targets, support river recreation, and meet water quality standards. A release of 30,000 cubic feet per second from Gavins Point Dam, near Yankton, South Dakota, would provide minimum navigation service at least 90 percent of the time between June 15 and August 15. Downstream tributary contributions could provide enough water to allow for lower releases.

The U.S. Fish and Wildlife Service (USFWS) has confirmed to the Corps that steady to declining releases from June 15 through August 15 would comply with the ESA. The Corps is currently consulting with the USFWS on a slightly different plan for the tern and plover nesting season, which is referred to as a "flow-to-target" operation. Under this plan, releases would be gradually increased throughout the nesting season to meet minimum flow targets as the downstream tributaries dry up. The flow-to-target plan simultaneously meets downstream needs and conserves nearly 250,000 acre-feet of water in the three large upstream reservoirs. The outcome of this consultation will assist in determining the final operation during the nesting season.

A draft of this AOP was made available to the public in late September 2002. As part of the Corps' government-to-government consultation on the AOP, two meetings were held at reservations at the request of Tribes with the Three Affiliated Tribes on October 15, 2002 at New Town, North Dakota and the Cheyenne River Sioux Tribe on October 16, 2002 at Eagle Butte, South Dakota. Three fall public meetings on the Draft AOP were held on October 15, 2002 at Bismarck, North Dakota; October 16, 2002 at Omaha, Nebraska; and October 17, 2002 at Jefferson City, Missouri. The primary purposes of these five meetings were to present a synopsis

of the Draft AOP and to allow those in attendance to make comments in person to Corps of Engineers staff. Attendees included representatives from the Tribes, Missouri River Basin states, public and industry interest groups and private citizens. Copies of the comment letters received on the Draft AOP and a report on the comments received at the five meetings are available upon request, as outlined below. A press release announcing the publication of the 2002-2003 AOP was provided on January 15, 2003 and is shown as Exhibit 1.

In addition to the AOP, two separate documents are also available entitled: "System Description and Operation" and "Summary of Actual 2001-2002 Operations." To receive copies of those documents you may contact the Water Management Division at 12565 West Center Road, Omaha, Nebraska 68144-3869, phone (402) 697-2676. Both documents are also available at the "Reports and Publications" link on our web site at: www.nwd.usace.army.mil/rcc.

I thank you for your interest in the operation of the System. With your help, I trust we can ensure that the System is operated for all Congressionally authorized project purposes, and meets the contemporary needs of the people who benefit from it.

Sincerely,

A large black rectangular redaction box covering the signature of David A. Fastabend.

David A. Fastabend
Brigadier General, U.S. Army
Division Engineer

MISSOURI RIVER MAINSTEM RESERVOIR SYSTEM

**Annual Operating Plan
2002-2003**

List of Tables ii
List of Plates.....ii
List of Abbreviationsiii
Definition of Terms.....iv

I. FOREWORD 1

II. PURPOSE AND SCOPE.....2

III. MASTER MANUAL REVIEW AND UPDATE
AND ESA CONSULTATIONS2

IV. FUTURE WATER SUPPLY – AUGUST 2002 – DECEMBER 20033

V. ANNUAL OPERATING PLAN FOR 2002-20035

 A. General.....5
 B. Operation Plans for the Balance of the 2002 Navigation Season.....8
 C. Operating Plan for the Winter of 2002-200310
 D. Operations During the 2003 Navigation Season.....12

VI. SUMMARY OF RESULTS EXPECTED IN 2002-200318

 A. Flood Control.....18
 B. Water Supply and Water Quality Control.....18
 C. Irrigation.....18
 D. Navigation.....18
 E. Power19
 F. Recreation, Fish and Wildlife19
 G. System Storage.....22
 H. Summary of Water Use by Functions22

VII. TENTATIVE PROJECTION OF OPERATIONS THROUGH
MARCH 200926

TABLES

I	Natural and Gross Water Supply at Sioux City	4
II	Gavins Point Releases Needed to Meet Full Service Flow Targets.....	6
III	Navigation Service Support for the 2003 Season	14
IV	Reservoir Unbalancing Schedule	15
V	MRNRC Recommended Reservoir Elevation Guidelines for Unbalancing.....	16
VI	Peaking Capability and Sales	20
VII	Energy Generation and Sales	21
VIII	Anticipated December 31, 2003 Storage in System	23
IX	Missouri River Mainstem System Water Use for Calendar Years 2001, 2002, and 2003 Above Sioux City, Iowa - Steady-Release	24
X	Missouri River Mainstem System Water Use for Calendar Years 2001, 2002, and 2003 Above Sioux City, Iowa - Flow-to-Target	25
XI	Navigation Service Support	27
XII	March 1 Reservoir Unbalancing, AOP Extensions – Steady-Release	28
XIII	March 1 Reservoir Unbalancing, AOP Extensions – Flow-to-Target-Release	28

PLATES

1	Missouri River Basin Map
2	Summary of Engineering Data – Missouri River Mainstem System Reservoirs
3	System Storage
4	Gavins Point Releases
5	Fort Peck Elevations and Releases
6	Garrison Elevations and Releases
7	Oahe Elevations and Releases
8	Fort Randall Elevations and Releases
9	Reservoir Release and Unregulated Flow
10	System Gross Capability and Average Monthly Generation
11	Tentative Five Year Extension of 2002-2003 AOP System Storage
12	Tentative Five Year Extension of 2002-2003 AOP Fort Peck

Exhibits

1	Press Release
---	---------------

ABBREVIATIONS

AOP	-	annual operating plan
ac.ft.	-	acre-feet
AF	-	acre-feet
B	-	Billion
cfs	-	cubic feet per second
COE	-	Corps of Engineers
CY	-	calendar year (January 1 to December 31)
elev	-	elevation
ft	-	feet
FY	-	fiscal year (October 1 to September 30)
GIS	-	Geographic Information System
GWh	-	gigawatt hour
KAF	-	1,000 acre-feet
Kcfs	-	1,000 cubic feet per second
kW	-	kilowatt
kWh	-	kilowatt hour
M	-	million
MAF	-	million acre- feet
MRBA	-	Missouri River Basin Association
MRNRC	-	Missouri River Natural Resources Committee
msl	-	mean sea level
MW	-	megawatt
MWh	-	megawatt hour
plover	-	piping plover
pp	-	powerplant
RCC	-	Reservoir Control Center
RM	-	river mile
tern	-	interior least tern
tw	-	tailwater
USFWS	-	United States Fish and Wildlife Service
USGS	-	United States Geological Survey
yr	-	year

DEFINITION OF TERMS

Acre-foot (AF, ac-ft) is the quantity of water required to cover 1 acre to a depth of 1 foot and is equivalent to 43,560 cubic feet or 325,850 gallons.

Cubic foot per second (cfs) is the rate of discharge representing a volume of 1 cubic foot passing a given point during 1 second and is equivalent to approximately 7.48 gallons per second or 448.8 gallons per minute. The volume of water represented by a flow of 1 cubic foot per second for 24 hours is equivalent to 86,400 cubic feet, approximately 1.983 acre-feet, or 646,272 gallons.

Discharge is the volume of water (or more broadly, volume of fluid plus suspended sediment) that passes a given point within a given period of time.

Drainage area of a stream at a specific location is that area, measured in a horizontal plane, enclosed by a topographic divide from which direct surface runoff from precipitation normally drains by gravity into the river above the specified point. Figures of drainage area given herein include all closed basins, or noncontributing areas, within the area unless otherwise noted.

Drainage basin is a part of the surface of the earth that is occupied by drainage system, which consists of a surface stream or body of impounded surface water together with all tributary surface streams and bodies of impounded water.

Gaging station is a particular site on a stream, canal, lake, or reservoir where systematic observations of hydrologic data are obtained.

Runoff in inches shows the depth to which the drainage area would be covered if all the runoff for a given time period were uniformly distributed on it.

Streamflow is the discharge that occurs in a natural channel. Although the term "discharge" can be applied to the flow of a canal, the word "streamflow" uniquely describes the discharge in a surface stream course. The term "streamflow" is more general than "runoff" as streamflow may be applied to discharge whether or not it is affected by diversion or regulation.

MISSOURI RIVER MAINSTEM RESERVOIR SYSTEM

Annual Operating Plan 2002 - 2003

I. FOREWORD

This Annual Operating Plan (AOP) presents pertinent information and plans for operating the Missouri River Mainstem Reservoir System (System) through December 2003 under widely varying water supply conditions. It provides a framework for the development of detailed monthly, weekly, and daily regulation schedules for the System's six individual dams during the upcoming year to serve the Congressionally authorized project purposes. Regulation is directed by the Missouri River Basin Water Management Division (formerly the Reservoir Control Center), Northwestern Division, U.S. Army Corps of Engineers (Corps). A map of the Missouri River Basin (Basin) is shown on *Plate 1* and the summary of engineering data for the six System reservoirs is shown on *Plate 2*.

This plan may require adjustments when substantial departures from expected runoff occur, to meet emergencies, or to meet the provisions of other applicable law, including the Endangered Species Act (ESA) and the conclusion of ongoing Corps and USFWS consultation under Section 7 of that Act. Results of a 5-year extension to the AOP studies (March 2004 to March 2009) are presented to serve as a guide for Western Area Power Administration's (WAPA) power marketing activities and those other interests that require information on reservoir conditions for long term planning.

Prior to the 1998-1999 AOP, a System description and discussion of the typical operation, a historic summary of the previous year's operation, and the plan for future operation was included in one document. Since the 1998-1999 AOP this information has been published in separate reports available upon request. This document provides the plan for future operation of the System. To receive a copy of either the updated version of the "System Description and Operation," dated Spring 2002, or the "Summary of Actual 2001-2002 Operations," contact the Missouri River Basin Water Management Division at 12565 West Center Road, Omaha, Nebraska 68144-3869, phone (402) 697-2676. Both reports will be available at the "Reports and Publications" link on our web site at: www.nwd-mr.usace.army.mil/rcc in early 2003. As the cover reflects, this year represents the 50th year that an AOP has been prepared for the operation of the System. This process has served the Corps and the Basin well as a forum for discussion of the next year's operating plan.

II. PURPOSE AND SCOPE

Beginning in 1953, projected System operation for the year ahead was developed annually as a basis for advance coordination with the various interested Federal, state, and local agencies and private citizens. Also beginning in 1953, a coordinating committee was organized to make recommendations on each upcoming year's System operation. The Coordinating Committee on Missouri River Mainstem Reservoir Operations held meetings semiannually until 1981 and provided recommendations to the Corps. In 1982, the Committee was dissolved because it did not conform to the provisions of the Federal Advisory Committee Act. Since 1982, to continue providing a forum for public participation, one or more open public meetings are held semiannually in the spring and fall. The fall public meeting is conducted to take public input on a draft of the AOP, which typically is published in early October each year. The spring meetings are conducted to update the public on the current hydrologic conditions and projected System operation for the remainder of the year.

The spring public meetings were held in Pierre, South Dakota on April 9, 2002, Omaha, Nebraska on April 10, 2002 and Kansas City, Missouri on April 11, 2002. The attendees were given an update regarding the outlook for 2002 runoff and projected operation for the remainder of 2002. Three fall public meetings on the Draft AOP were held on October 15, 2002 at Bismarck, North Dakota, October 16, 2002 at Omaha, Nebraska and October 17, 2002 at Jefferson City, Missouri. As part of the Corps' government-to-government consultation on the AOP, two meetings were held at reservations at the request of Tribes. One was held at the Three Affiliated Tribes Reservation on October 15, 2002 at New Town, North Dakota and the second was at the Cheyenne River Reservation on October 16, 2002 at Eagle Butte, South Dakota.

Preliminary Draft AOP data was presented to the Missouri River Natural Resources Committee (MRNRC) on August 15, 2002. The MRNRC chose not to provide pre-draft comments.

III. MASTER MANUAL REVIEW AND UPDATE AND ESA CONSULTATIONS

In August 2001, the Corps released the Revised Draft Missouri River Environmental Impact Statement (RDEIS) on the Missouri River Master Water Control Manual Review and Update (Review and Update), which presented the impacts associated with a number of potential Water Control Plan alternatives. The Corps is in the process of re-initiating formal consultation with the United States Fish and Wildlife Service (USFWS) on the current Water Control Plan. Completion of formal consultation and a Biological Opinion is anticipated within the 135 days allowed by regulation, which will be followed by completion of the Final Environmental Impact Statement (FEIS) for the Review and Update and preparation of a Record of Decision. Implementation of a revised Water Control Plan is anticipated in 2004.

This AOP presents a “steady-release” schedule during the nesting season of the interior least tern and piping plover. The two birds are listed for protection under the ESA. The System release rate shown of 30,000 cubic per second (cfs) from Gavins Point Dam, near Yankton, South Dakota, would provide minimum navigation service at least 90 percent of the time between June 15 and August 15. Downstream tributary contributions could provide enough water to allow for lower releases. The USFWS has confirmed to the Corps that steady to declining releases from June 15 through August 15 would comply with the ESA.

The Corps is also currently in the process of initiating formal consultation with the USFWS under Section 7 of the ESA on a slightly different plan for the tern and plover nesting season, which is referred to as a “flow-to-target” operation. Under this plan, releases would be gradually increased throughout the nesting season to meet minimum flow targets as the tributaries dry up. Nests threatened by rising water or erosion would be moved to higher ground when possible. Threatened chicks and eggs would be collected by biologists for captive rearing at our “bird house” at Gavins Point Dam and subsequently released. We prefer the flow-to-target plan because it simultaneously meets downstream needs and saves nearly 250,000 acre feet of water in the three biggest reservoirs that could reduce the anticipated decline in the reservoirs by 4 to 18 inches, depending on the contributions by the downstream tributaries. Based on the results of the consultation, the flow-to-target plan could possibly replace the steady-release plan for the 2003 nesting season.

IV. FUTURE WATER SUPPLY - AUGUST 2002 - DECEMBER 2003

Due to continued drought throughout much of the Missouri River Basin, Simulation forecasts for the regulation of the six System reservoirs were updated to reflect December 1 rather than August 1, 2002 conditions. The August 1 forecast of annual runoff above Sioux City, Iowa was 17.0 million acre-feet (MAF), but the December 1 forecast and actual 2002 runoff above Sioux City was 16.0 MAF. The December 1 most likely runoff scenario was used as input to the Basic reservoir regulation Simulation (Simulation) in the AOP studies for December 2002. Normal runoff was used in the Basic Simulation for January and February 2003. Two other runoff scenarios based on the December 1 most likely runoff scenario were developed for the same period. These are the 80 percent and 120 percent of the most likely runoff scenarios, which are input to the 80 percent and 120 percent of Basic Simulations for the December 2002 to February 2003 period.

Simulations for the March 1, 2003 to February 29, 2004 time period use five statistically derived inflow scenarios based on an analysis of water supply records from 1898 to 1997. This approach provides a good range of simulations for dry, average, and wet conditions, and eliminates the need to forecast future precipitation, which is very difficult.

The Upper Decile and Upper Quartile Simulations extend from the end of the 120 percent of Basic Simulation through February 2004. Likewise, the Median Simulation extends from the end of the

Basic Simulation, and the Lower Quartile and Lower Decile Simulations extend from the end of the 80 percent of Basic Simulation through February 2004.

Upper Decile runoff (34.5 MAF) has a 1 in 10 chance of being exceeded, Upper Quartile (30.6 MAF) has a 1 in 4 chance of being exceeded, and Median (24.6 MAF) has a 1 in 2 chance of being exceeded. Lower Quartile runoff (19.5 MAF) has a 1 in 4 chance of the occurrence of less runoff, and Lower Decile (15.5 MAF) has a 1 in 10 chance of the occurrence of less runoff. There is still a 20 percent chance that a runoff condition may occur that has not been simulated; i.e., 10 percent chance runoff could be lower than Lower Decile, and a 10 percent chance runoff could be greater than Upper Decile.

The estimated natural flow 1/ at Sioux City, the corresponding post-1949 water use effects, and the net flow 2/ available above Sioux City are shown in **Table I**, where several water supply conditions are quantified for the periods December 2002 through February 2003 and the runoff year March 2003 through February 2004. The natural water supply for CY 2002 (actual January 2002 through November 2002 runoff plus the December 1 most likely runoff scenario is estimated to total approximately 16.0 MAF.

TABLE I
NATURAL AND GROSS WATER SUPPLY AT SIOUX CITY

	<u>Natural 1/</u>	<u>Post-1949 Depletions</u>	<u>Net 2/</u>
	(Volumes in 1,000 Acre-Feet)		
December through February 2003 (Most Likely Runoff Scenario)			
Basic	2,600	+100	2,700
120% Basic	2,900	+200	3,100
80% Basic	2,000	0	2,000
Runoff Year March 2003 through February 2004 (Statistical Analysis of Past Records)			
Upper Decile	34,500	-2,500	32,000
Upper Quartile	30,600	-2,400	28,200
Median	24,600	-2,600	22,000
Lower Quartile	19,500	-2,400	17,100
Lower Decile	15,500	-2,200	13,300

1/ The word “Natural” is used to designate flows adjusted to the 1949 level of basin development, except that regulation and evaporation effects of the Fort Peck Reservoir have also been eliminated during its period of operation prior to 1949. 2/ The word “Net” represents the total streamflow after deduction of the post-1949 irrigation, upstream storage, and other use effects.

V. ANNUAL OPERATING PLAN FOR 2002-2003

A. General. The anticipated operation described in this AOP is designed to meet the operational objectives presented in the current Missouri River Master Water Control Manual (Master Manual), which was first published in the 1960's. Consideration has been given to all of the authorized project purposes, and to the needs of threatened and endangered (T&E) species, and relies on a wealth of operational experience. Operational experience available for preparation of the 2002-2003 AOP includes 13 years of operation at Fort Peck Reservoir (1940) by itself plus 49 years of System experience as Fort Randall (1953), Garrison (1955), Gavins Point (1955), Oahe (1962), and Big Bend (1964) have been brought progressively into System operation. This operational experience includes lessons learned during the 6 consecutive years of drought of the late 1980's through 1992 as well as the high runoff period that followed. Runoff during the period 1993 to 1999 was greater than Upper Quartile level during 5 of those 7 years, including the record 49.0 MAF of runoff in 1997. In addition to the long period of actual operational experience, many background operational studies for the completed System are available for reference.

This operational experience has shown that additional water conservation measures, beyond the specific technical criteria published in the current Master Manual, may be required to meet the operational objectives of the current Master Manual, if System water-in-storage (storage) is below 52 MAF on July 1 of any year. These additional conservation measures may be necessary during drought to offset increased release requirements for water supply due to degradation (lowering) of the channel bed, and to serve navigation, while meeting the Corps' obligations, in consultation with the USFWS, under the ESA. After each runoff year (March 1 through February 28) an analysis is performed to determine how much additional water conservation, if any, is needed to compensate for releases in excess of the specific technical criteria in that runoff year. If additional water conservation measures are called for, they are applied to the next runoff year's operation. Although July 1, 2002 System storage was only 48.8 MAF, no additional System releases were made for any project purpose above the specific technical criteria in the 2001 runoff year. Therefore, no additional conservation measures beyond the specific technical criteria presented in the Master Manual will be implemented in the 2002 runoff year.

Two sets of Simulations for the 2003 runoff year are shown in the final section of this AOP. The first set, studies 4 through 8 assume a steady-release from Gavins Point Dam from mid-May through August to prevent T&E bird species from nesting at low elevations and thereby help protect them from inundation. The Upper Decile and Upper Quartile runoff Simulations shown as studies 4 and 5 have a 27,200 cfs system release to meet minimum service targets from mid-May through August 2003. The Median, Lower Quartile, and Lower Decile Simulations assume a steady 30,000 cfs System release, reflecting continued dry conditions below Gavins Point Dam. System releases shown in previous AOPs were not absolute and adjustments were made as necessary to meet the navigation service level as determined by the March 15 and July 1 System storage checks. The assumption for this AOP is that the 30,000 cfs steady release would not be exceeded, and therefore, target flows may not be met at all

times if extremely dry conditions persist downstream. An analysis of previous drought years indicates a 30,000 cfs Gavins Point Dam release will provide minimum service or greater flows at Kansas City 90 percent of the time. Temporary reductions in releases will be made during this period if significant runoff occurs below the System. Steady-Release Simulations for Median, Lower Quartile, and Lower Decile extensions from March 1, 2004 through March 1, 2009 are shown in studies 9 through 23. The second set of Simulations, studies 24 through 28, assume a flow-to-target regulation that was used during the 2001 and portions of the 2002 T&E bird species nesting season. A flow-to-target regulation would typically result in increased System releases as the T&E nesting season progresses. This is due to reduced tributary inflows downstream as the summer heat builds, evaporation increases and precipitation wanes. Increasing releases as the nesting season progresses can inundate nests and chicks on low-lying habitat. Because fledge ratio (numbers of chicks reared to flight stage) goals for the Missouri River are being met, the Corps is continuing to consult with the USFWS to determine whether under the flow-to-target scenario, low-lying T&E species' nests and chicks at risk of inundation from increasing releases could be moved to higher terrain or a captive rearing facility. Flow-to-target extensions are shown as studies 29 through 43.

System releases during the navigation season except for the mid-May through August Median, Lower Quartile, and Lower Decile Steady-Release Simulations are based on a service level determination in accordance with the March 15 and July 1 storage checks presented in the current Master Manual. Average releases necessary to meet full service flow targets during the navigation season are shown in *Table II*. Under the Steady-Release Simulation, System release would be set in mid-May to the level expected to be required to meet downstream flow targets through August. This results in releases that exceed the amount necessary to meet downstream flow targets during the early portion of the T&E bird nesting season.

TABLE II
GAVINS POINT RELEASES NEEDED TO MEET
FULL SERVICE FLOW TARGETS
1950 - 1996
(Discharges in 1,000 cfs)

Runoff Scenario	<u>Month</u>								<u>Average</u>
	<u>Apr</u>	<u>May</u>	<u>Jun</u>	<u>Jul</u>	<u>Aug</u>	<u>Sep</u>	<u>Oct</u>	<u>Nov</u>	
Median, Upper Quartile, Upper Decile	26.7	28.0	27.9	31.6	33.2	32.6	32.0	31.1	30.4
Lower Quartile, Lower Decile	29.8	31.3	31.2	34.3	34.0	33.5	33.1	31.2	32.3

System releases under the Flow-to-Target Simulation would be set at only the level necessary to meet downstream flow targets. The flow-to-target regulation would conserve more water in the

System, which would keep the lake levels at the upper three System projects at relatively higher levels. Although the maximum mid-May through August flow-to-target release for Median runoff is shown as 27,200 cfs in study 26 and 28,300 cfs in the Lower Quartile and Lower Decile runoff studies 27 and 28, releases could be greater if needed to maintain the appropriate level of downstream flow support. A flow-to-target regulation would conserve approximately 200,000 to 800,000 AF as compared to a steady-release regulation.

The specific technical criteria for the September 1 storage check to determine winter release rates were not used in the Simulations. A minimum release of 13,000 cfs was used for all Simulations for the winter 2002-2003 and the winter 2003-2004. This will provide downstream winter flows sufficient to allow the operation of downstream powerplants, as provided for in the current Master Manual, and is based on past operational experience.

Application of the specific technical criteria for the September 1 storage check would result in winter releases in 2003-2004 for the Upper Decile and Upper Quartile Simulations above the 13,000 cfs level, but System winter releases will be held to 13,000 cfs as a water conservation measure during the current drought.

The 13,000 cfs winter release will reduce System storage an additional 536,000 AF for both the Basic and 80 percent Simulations for winter 2002-2003 compared to the application of the specific technical criteria. Because releases in July and August 2002 were lower than those needed to provide minimum service, 378,000 AF of storage was conserved as compared to regulation under the specific technical criteria. Therefore, the net reduction in storage in the 2002 runoff year, as compared to regulation under the specific technical criteria, is 158,000 AF.

Only the Median, Lower Quartile, and Lower Decile Simulations show System storage below 52 MAF on July 1, 2003. The Simulations for those three runoff scenarios also show that application of the specific technical criteria result in minimum service throughout the 2003 navigation season. Shortening of the 2003 navigation season is therefore the only available option for additional water conservation. If the Simulations verify, the 2003 navigation season would be shortened by 5 days for Median, Lower Quartile and Lower Decile runoff to compensate for the additional water released during the winter 2002-2003. The Upper Quartile and Upper Decile Simulations show that System storage on July 1 will be above 52 MAF, and therefore would follow the specific technical criteria.

During the late 1980's to early 1990's drought years, a two-day-down, one-day-up peaking cycle was utilized. This regulation provided for lower flows for two out of three days to conserve water in the System while ensuring that T&E bird species did not nest on low-lying habitat. We have not included a peaking cycle in any of the Simulations because of concerns voiced by the USFWS regarding negative impacts to river fish. Intrasystem releases are adjusted to best serve the multiple-purpose functions of the projects with special emphasis placed on regulation for non-listed fisheries starting in early April and for T&E bird species beginning in early May and continuing through August. System releases for all runoff conditions are at less than full service flows due to low System storage.

A reanalysis of the average monthly Gavins Point releases needed to meet service level target requirements was completed in 1999. The study used the Daily Routing Model (DRM) for the period 1950 to 1996. As part of this study, the relationship between annual runoff upstream of Sioux City and the average Gavins Point Dam release required for the navigation season was analyzed. The study concluded that generally more water was needed downstream to support navigation during years with below normal upper basin runoff than during years with higher upper basin runoff. Therefore, regulation studies since 1999 use two levels of System release requirements; one for Median, Upper Quartile, and Upper Decile runoff scenarios, and another for Lower Quartile and Lower Decile scenarios.

The updated release requirements for full service navigation used in the development of the 2002-2003 AOP are given in **Table II**. Releases required for minimum service navigation support are 6,000 cfs less than the numbers provided in **Table II**. A final report detailing the procedures used in this study is available on our web site. As explained previously, the Steady-Release Median, Lower Quartile, and Lower Decile Simulations utilize a 30,000 cfs release from mid-May through August rather than the minimum service releases computed from **Table II**. This release is higher than the **Table II** values and reflects lower downstream tributary flow contributions than was used when the table was prepared.

None of the Simulations reach the desired 57.1 MAF System storage level on March 1, 2004. The Median and above Simulations include releases that provide a steady to rising lake level in the three large upper reservoirs during the spring fish spawn period. Similar regulation in the past has resulted in a higher fish reproduction success. As previously stated, Gavins Point releases will not be cycled to conserve water under any of the five studied runoff scenarios. However, it may be necessary to cycle releases for flood control operations during the T&E species nesting season.

Actual System operation from January 1 through November 30, 2002 and the operating plans for each project for the remainder of 2002 with the Basic Simulation and for CY 2003 using the five runoff scenarios described on page 3 are presented on **Plates 3 through 8**, inclusive. An exception is the omission of Big Bend, since storage at that project is relatively constant and average monthly releases are essentially the same as those at Oahe. These plates also show, on a condensed scale, actual operations during the period 1953 through 2001.

Plate 9 illustrates for Fort Peck, Garrison, Oahe, and Gavins Point Dams the actual reservoir releases (Regulated Flow) as well as the Missouri River flows (Unregulated Flow) that would have resulted if the reservoirs were not in place during the period January 2001 through November 2002. **Plate 10** presents past and simulated gross monthly, average power generation, and gross peaking capability for the System.

B. Operation for the Balance of the 2002 Navigation Season. Gavins Point releases were held to a rate of 25,500 cfs from July 1 through August 14 due to T&E bird species nesting below Fort Randall and Gavins Point Dams. This nesting activity resulted in flows of up to 7,000 cfs less than minimum service being provided at Kansas City and downstream on the Missouri River. After T&E bird species nesting activity concluded, releases were increased from 25,500 cfs to 31,000 cfs by

August 15 to meet downstream minimum service flow requirements. Releases through the fall season were adjusted as needed to provide minimum service (6,000 cfs less than full service) flow support to navigation as computed by the July 1 System storage check. System storage was 48.2 MAF on July 1, 2002, substantially less than the 59.0 MAF minimum storage required to provide full service flows. The current storage is also much less than the 50.5 MAF 1 July check for greater than minimum service flows; therefore, a significant System storage gain will have to occur before a service level greater than minimum service is provided. A full 8-month navigation season was provided in 2002.

System storage declined to 49.3 MAF on December 1 at the close of the 2001 navigation season. The winter of 2001-2002 brought virtually no significant plains snowpack. The mountain snowpack peaked in the reach above Fort Peck at 91 percent of normal on May 11th, which was about 26 days later than normal. The mountain snowpack in the reach between Fort Peck and Garrison peaked at 85 percent of normal on April 22nd. The total runoff for 2002 was 16.0 MAF, the 10th lowest in 105 years of record, and is near a lower decile runoff. January and February were 116 and 85 percent of normal, respectively. March fell to only 41 percent, and April was 60 percent of normal with no plains snowpack to melt. The months of May, June, and July were well below average at 52, 79, and 62 percent of normal, respectively, because of the below normal mountain snowmelt. Runoff for August was 65 percent of normal and September was only 66 percent of normal. October was only 61 percent of normal and November was only 76 percent of normal. The closing dates for ending the 2002 navigation season were November 22 at Sioux City, November 24 at Omaha, November 25 at Nebraska City, November 27 at Kansas City, and December 1 at the mouth of the Missouri River near St. Louis.

Energy generation by the System powerplants for the period August 1 to December 1 was 2.9 billion kilowatt hours (kWh), 0.9 billion kWh below normal.

Fort Peck Dam releases ranged from 4,000 to 9,300 cfs for the remainder of the 2002 navigation season. Fort Peck Lake declined 2.2 feet from elevation 2219.0 feet mean sea level (msl) to 2216.8 feet msl by the end of the navigation season, 17.5 feet lower than the 1967-2001 long-term average.

Garrison Dam releases ranged from 12,800 to 21,700 cfs through the remainder of the 2002 navigation season. The level of Lake Sakakawea declined by 6.8 feet from elevation 1831.4 feet msl to 1824.6 feet msl by November 30, 13.6 feet below the long-term average.

Oahe Dam releases were reduced from an August average of 29,200 cfs to 9,300 cfs in late November as the navigation season ended. Lake Oahe lowered 7.4 feet from an August 1 elevation of 1590.8 feet msl to the November 30 elevation of 1583.4 feet msl, 18.4 feet below the long-term average.

Big Bend Dam releases paralleled those from Oahe. Lake Sharpe generally fluctuated between 1420.0 and 1421.0 feet msl for weekly cycling during high power load periods. Actual elevations ranged from 1419.3 feet msl to 1421.1 feet msl during the period of August through November. Reservoir fluctuations of a foot are scheduled during most weeks in order to follow peaking power

demands. Storage lost during the week is regained during the succeeding weekend period of lower power demands.

Fort Randall Dam releases generally paralleled those from Gavins Point. Lake Francis Case was lowered one month early to elevation 1338.2 feet msl by October 31 to permit the permanent protection of a Native American gravesite located at White Swan. Project personnel requested a further lowering to elevation 1335.0 feet msl by November 11, 2002 to permit placement of rock below the normal annual minimum elevation. The lowering of Lake Francis Case will provide sufficient capacity to store a reasonable level of power releases from Oahe and Big Bend during the winter season.

Gavins Point Dam releases ranged from 25,500 to 31,000 cfs during the remainder of the navigation season. Lewis and Clark Lake rose about 3 feet from elevation 1205.2 to elevation 1208.0 feet msl during the remainder of the navigation season that ended December 1. Prior to 1992, Lewis and Clark Lake was maintained at a target elevation of 1208.0 feet msl from September to mid-February when it was lowered to elevation 1205.0 feet msl, the beginning of the runoff season. The September to mid-February target was lowered to elevation 1207.0 feet msl in 1992 to reduce shoreline erosion and displacement of riprap on the dam. The March-August elevation was raised to elevation 1206.0 feet msl to improve recreational access. After modification of the riprap and coordination with the States of South Dakota and Nebraska, a decision was made to return to the 1208.0 feet msl elevation for the late summer through winter 2001-2002 periods. The State of South Dakota experienced damage to recreation areas last winter and an agreement was reached between the Corps and the State to lower the target elevation by one-half foot to elevation 1207.5 feet msl from late summer through winter 2002-2003.

C. Operating Plan for the Winter of 2002-2003. Due to low System storage, the specific technical criteria presented in the current Master Manual for the September 1 storage check were not used to determine winter 2002-2003 and winter 2003-2004 System releases in the Simulations. At a System storage level of 58.0 MAF or above on September 1, the specific technical criteria calls for a full service release rate for the following winter, and minimum service releases if system storage is at or below 43.0 MAF. Average full and minimum service winter release rates from Fort Randall Dam are 15,000 and 5,000 cfs, respectively. The storage on September 1, 2002 was 46.9 MAF, 11.1 MAF less than the 58.0 MAF required to provide a full service release of 15,000 cfs from Fort Randall Dam. The September 1 storage check specifies a Fort Randall Dam winter release rate of only 7,600 cfs. This corresponds to a Gavins Point Dam winter release of 9,000 cfs, which is much too low based on operational experience with winter ice. Therefore, winter System releases in all Simulations are set to a minimum of 13,000 cfs for the winter of 2002-2003 and the winter of 2003-2004. It may be necessary at times to increase System releases to provide adequate downstream flows if ice jams or blockages form which temporarily restrict flows. These events are expected to occur infrequently and be of short duration based on past experiences. It is anticipated that this year's winter release will be adequate to serve all downstream water intakes except for very short periods that may be impacted below rapidly forming ice jams.

For the winter period from the close of the 2002 navigation season on December 1, 2002 until the opening of the 2003 navigation season on April 1, 2003, operations are expected to be as follows:

Fort Peck Dam releases are expected to average 10,000 cfs in December and 11,000 cfs in January and February. The December release is equal to the 1967-2001 average and the January and February releases are 500 cfs and 1,000 cfs below average, respectively. The Basic Simulation shows Fort Peck Lake will lower 4.6 feet to elevation 2212.2 feet msl by the end of the winter period. Carryover multiple purpose storage in the three large upper reservoirs will be near a balanced condition on March 1, 2003. The lake is expected to rise 1.3 feet to elevation 2213.5 feet msl by March 31, 19.2 feet below normal.

Garrison Dam releases will be adjusted to serve winter power loads and balance System storage. Releases will follow a more typical pattern than last year's record low 13,000 cfs winter release. Releases will be scheduled at 20,000 cfs at the time of normal freeze-in and likely will have to be reduced for a short period to 18,000 cfs during the freeze-in in the Bismarck area in an attempt to not exceed the target 13-foot stage at the Bismarck gage. Flood stage is 16 feet. Garrison Dam releases are expected to average 20,000 cfs at the beginning of the winter period and gradually increase to 23,000 cfs in January and February, 1,200 to 2,500 cfs less than normal. Lake Sakakawea is expected to lower from near elevation 1824.6 feet msl to elevation 1819.5 feet msl by March 1, 18.0 feet below the base of the annual flood control storage zone. The Median Simulation indicates the lake will rise to elevation 1820.8 feet msl by March 31, which would be 14.9 feet below normal.

Oahe Dam releases for the winter season will provide backup for the Fort Randall and Gavins Point Dam releases plus fill the recapture space available in Lake Francis Case consistent with anticipated winter power loads. Monthly average releases may vary substantially with fluctuations in power loads occasioned by weather conditions but, in general, are expected to average between 13,000 and 16,000 cfs. Daily releases will vary widely to best meet power loads. Peak hourly releases, as well as daily energy generation, will be constrained to prevent urban flooding in the Pierre and Fort Pierre areas if severe ice problems develop downstream of Oahe Dam. This potential reduction has been coordinated with the Western Area Power Administration.

The Lake Oahe level is expected to gradually rise from elevation 1583.6 feet msl at the end of the 2002 navigation season to elevation 1589.0 by March 1, then rise to elevation 1592.3 feet msl by the end of March, 14.3 feet below normal.

Lake Sharpe at Big Bend will be maintained in the normal 1420.0 to 1421.0 feet msl range during the winter.

Fort Randall Dam releases will average near 11,000 cfs. Lake Francis Case is expected to rise from 1338.2 feet msl at the end of the 2002 navigation season to near elevation 1350.0 feet msl, the seasonal base of flood control, by March 1. However, if the plains snowpack flood potential downstream of Oahe Dam is quite low at that time, measures will be taken to raise Lake Francis Case to near elevation 1353.0 feet msl by March 1. It is likely that a Lake Francis Case level above

elevation 1353.0 feet msl, to as high as 1355.2, will be reached by the end of the winter period on March 31, if runoff conditions permit. The level of Lake Francis Case above the White River delta near Chamberlain, South Dakota will likely remain at a higher elevation than the lake below the delta from mid-October through December, due to the damming effect of this delta area.

Gavins Point Dam releases were gradually reduced beginning the last week of November to a winter level of 13,000 cfs. These releases should be adequate to maintain water levels necessary during freeze-in for downstream water intakes; however, adjustments to the releases may be required if significant reduction in flows occurs downstream due to ice blockages. Lewis and Clark Lake will generally be near elevation 1207.5 feet msl until late February when it will be lowered to elevation 1206.0 feet msl for controlling spring floods, primarily from the Niobrara River and Ponca Creek along the Fort Randall Dam to Gavins Point Dam reach.

System storage for all five runoff conditions will be substantially below the base of the annual flood control zone by March 1, 2003, the beginning of next year's runoff season.

D. Operations During the 2003 Navigation Season. The Upper Decile, Upper Quartile, Median, Lower Quartile, and Lower Decile runoff scenarios studied for this year's AOP follow the specific technical criteria presented in the current Master Manual for navigation service flow support. The normal 8-month navigation season length is shortened for Median, Lower Quartile, and Lower Decile as shown in **Table III** to compensate for the extra water released during winter 2002-2003. Releases from Fort Peck, Garrison, and Fort Randall Dams will follow repetitive daily patterns from early May, at the beginning of the T&E species nesting season, to the end of the nesting in late August. As previously stated, steady System releases for all five runoff scenarios are shown during the tern and plover nesting season (mid-May to the end of August) to keep birds from nesting at low elevations for the Steady-Release Simulations. The Flow-to-Target Simulations follow March 15 and July 1 System storage checks. All runoff scenarios except Lower Quartile and Lower Decile would provide steady to rising pool levels in the spring fish spawn period.

All five runoff scenarios studied for this year's AOP are based on gradually increasing System releases to provide navigation season flow rates at the mouth of the Missouri near St. Louis by April 1, 2003, the normal navigation season opening date. The corresponding dates at upstream locations are: Sioux City, March 23; Omaha, March 25; Nebraska City, March 26; and Kansas City, March 28. The studies illustrated on **Plates 3 through 8** and summarized in **Table III** are based on providing less than full service flows, a full 8-month season for Upper Decile and Upper Quartile runoff scenarios, and a shortened season for Median, Lower Quartile, and Lower Decile runoff. Upper Decile releases are 6,000 cfs less than full service (minimum service) in the spring and 3,100 cfs less than full service in the summer and fall for the Steady-Release Simulations. July 1 System storage in the Upper Decile Flow-to-Target Simulation specifies 2,800 less than full service in the summer and fall. Releases for Upper Quartile runoff are 6,000 cfs below full service in the spring and 4,500 cfs less than full service during the summer and fall for the Steady-Release Simulation. Summer and fall Upper Quartile flow-to-target releases are 4,200 cfs below full service. Minimum service flows for less than an 8-month navigation season will be provided should Median, Lower Quartile, or Lower Decile runoff occur.

Navigation flow support for the 2003 season will be determined by actual System storage on March 15 and July 1. Gavins Point Dam releases may be quite variable during the 2003 navigation season but are expected to range from 21,000 to 30,000 cfs. Release reductions necessary to minimize downstream flooding are not reflected in these monthly averages but will be instituted as conditions warrant.

Simulated storages and releases for the System and individual reservoirs within the System are shown on *Plates 3 through 8* for the Steady-Release Simulations. Flow-to-target plots are not shown because the difference cannot be seen at the scale provided except for the median Gavins Point Dam release shown on *Plate 4*. Ample storage space exists in the System to control flood inflows under all conditions studied. *Table III* summarizes the navigation service support projected for the 2003 navigation season for the Steady-Release and Flow-to-Target Simulations.

The two modified reservoir operations shown in the previous two AOPs cannot be accomplished in 2003 due to low System storage. When System storage recovers sufficiently, both these operations will be pursued based on recommendations presented to the Corps by the USFWS.

The first of these two modified operations are tests of flow modifications for T&E species. When Fort Peck Lake has adequate water above the spillway crest by mid to late May of any year, a T&E flow modification “mini-test” will be conducted in early June to monitor effects of higher spring releases and warmer water released from the spillway. It will also allow for an evaluation of the integrity of the spillway structure if it were used more frequently. Streambank erosion and fishing impacts will also be monitored.

During the Fort Peck “mini-test,” which will last about 4 weeks, flows will vary from 8,000 to 15,000 cfs as various combinations of spillway and powerplant releases are monitored. The maximum spillway release of 11,000 cfs will combine with a minimum powerplant release of 4,000 cfs for 6 days. This operation will be timed to avoid lowering the lake during the forage fish spawn. The “mini-test” will not be conducted if sufficient flows will not pass over the spillway crest (elevation 2225 feet msl). A minimum lake elevation of about 2229 feet msl is needed during the test to avoid unstable flows over the spillway. Results of the Simulations show that this elevation will not be achieved in 2003 for any of the five runoff scenarios. A more extensive test with a combined 20,000 to 30,000 cfs release from Fort Peck is scheduled to be conducted beginning in early June in the year following the “mini-test” to determine if warm water releases will benefit the native river fishery. Peak outflows during the full test would be maintained for 2 weeks within the 4-week test period.

**TABLE III
NAVIGATION SERVICE SUPPORT
FOR THE 2003 SEASON**

STEADY-RELEASE

	Runoff Scenario (MAF)	2003 System Storage		Flow Level Above or Below Full Service (in cfs)		Length of Season (Months)
		March 15 (MAF)	July 1 (MAF)	Spring	Summer/Fall	
U.D.	34.5	45.2	54.6	-6,000	-3,100	8
U.Q.	30.6	45.0	52.6	-6,000	-4,500	8
Med	24.6	44.0	49.0	-6,000	-6,000	8 - 5 days
L.Q.	19.5	43.3	46.0	-6,000	-6,000	8 - 5 days
L.D.	15.5	43.1	43.8	-6,000	-6,000	8 - 5 days

FLOW-TO-TARGET

	Runoff Scenario (MAF)	2003 System Storage		Flow Level Above or Below Full Service (in cfs)		Length of Season (Months)
		March 15 (MAF)	July 1 (MAF)	Spring	Summer/Fall	
U.D.	34.5	45.2	55.1	-6,000	-2,800	8
U.Q.	30.6	45.0	53.0	-6,000	-4,200	8
Med	24.6	44.0	49.7	-6,000	-6,000	8 - 5 days
L.Q.	19.5	43.3	46.5	-6,000	-6,000	8 - 5 days
L.D.	15.5	43.1	44.3	-6,000	-6,000	8 - 5 days

The second modified operation involves unbalancing the three large upper reservoirs to benefit reservoir fishery and the T&E species as shown on *Table IV*. AOP studies indicate the large reservoirs will be balanced on March 1, 2003. Should Upper Decile or Upper Quartile runoff occur in 2003, studies indicate Fort Peck Lake will be 4.0 feet above a balanced condition, Lake Sakakawea will be nearly 3.0 feet below a balanced condition, and Lake Oahe will be balanced on March 1, 2004. Reservoir unbalancing is computed based on the percentage of the carryover multiple purpose pool that remains in Fort Peck Lake, Lake Sakakawea, and Lake Oahe. This would permit the Fort Peck Dam T&E flow modification “mini-test” in the spring of 2004, as described in the previous paragraph. Median or lower runoff does not sufficiently refill the reservoirs in 2003 and no unbalancing or “mini-test” would occur in spring 2004. The unbalancing would alternate at each project; high one year, float (normal operation) the next year, and low the third year as shown on *Table IV*. *Table V* shows the lake elevations proposed by the MRNRC at which the unbalancing would be terminated. *Table V* indicates that no reservoir unbalancing should occur for any of the five runoff scenarios in 2003. The AOP Extension Simulations shown as studies 9-13 for Median runoff with steady-release indicate no

unbalancing can occur until March 1, 2007 if the *Table V* guidelines are followed. Studies 29-33 indicated unbalancing would be possible by March 1, 2006 for Median flow-to-target.

Summary of Reservoir Regulation Activities for T&E Species and Fish Propagation Enhancement

As discussed in the section above, the 2002-2003 AOP includes no provisions for unbalancing the Fort Peck, Garrison, and Oahe reservoirs for any of the runoff scenarios. The criteria for unbalancing are based on recommendations provided by the MRNRC and the USFWS. Under all Simulations, System storage will be below the minimum levels under which unbalancing is recommended by either the MRNRC or the USFWS.

As stated previously, this AOP presents a steady-release schedule during the nesting season of the interior least tern and piping plover. The USFWS has confirmed to the Corps that steady-to-declining releases from June 15 through August 15 would comply with the ESA. The Corps is also currently in the process of initiating formal consultation with the USFWS under Section 7 of the ESA on a flow-to-target operation. Based on the results of the consultation, the flow-to-target plan could possibly replace the steady-release plan for the 2003 nesting season.

**TABLE IV
RESERVOIR UNBALANCING SCHEDULE**

	Fort Peck		Garrison		Oahe	
<i>Year</i>	<i>March 1</i>	<i>Rest of Year</i>	<i>March 1</i>	<i>Rest of Year</i>	<i>March 1</i>	<i>Rest of year</i>
1	High	Float	Low	Hold Peak	Raise & hold during spawn	Float
2	Raise & hold during spawn	Float	High	Float	Low	Hold peak
3	Low	Hold peak	Raise & hold during spawn	Float	High	Float

Notes:

Float year: Normal operation, then unbalance 1 foot during low pool years or 3 feet when System storage is near 57.1 MAF on March 1.

Low year: Begin low, then hold peak the remainder of the year.

High year: Begin high, raise and hold pool during spawn, then float.

TABLE V
MRNRC RECOMMENDED
RESERVOIR ELEVATION GUIDELINES
FOR UNBALANCING

	Fort Peck	Garrison	Oahe
Implement unbalancing if March 1 reservoir elevation is above this level.	2234 feet msl	1837.5 feet msl	1607.5 feet msl
Implement unbalancing if March 1 reservoir elevation is in this range and the pool is expected to raise more than 3 feet after March 1.	2227-2234 feet msl	1827-1837.5 feet msl	1600-1607.5 feet msl
Scheduling Criteria	Avoid lake level decline during spawn period which ranges from April 15 – May 30	Schedule after spawn period of April 20 – May 20	Schedule after spawn period of April 8 – May 15

Also, as previously stated, the Corps is in the process of re-initiating formal consultation with the USFWS on the current Water Control Plan. Completion of formal consultation and a Biological Opinion is anticipated within the 135 days allowed by regulation, which will be followed by completion of the Final Environmental Impact Statement (FEIS) for the Review and Update and preparation of a Record of Decision. Implementation of a revised Water Control Plan is anticipated in 2004. In addition to water management, other activities are also being undertaken by the Corps to assist in the survival of the endangered species on the Missouri River. Habitat creation for terns, plovers and pallid sturgeon, pallid sturgeon hatchery propagation, and a variety of studies are examples of some of these activities. A complete discussion of these activities can be found in the report entitled “Annual Report for the Missouri River Biological Opinion for 2001” prepared by the Omaha District, U.S. Army Corps of Engineers.

Fort Peck releases during the bird nesting season will range from 8,000 cfs for Upper Decile runoff to 10,000 cfs for Median and below runoff. This regulation should result in habitat conditions for nesting terns and plovers similar to what was available in 2002.

If flood flows enter the Missouri River below the project during the nesting season, hourly releases will be lowered to no less than 3,000 cfs in order to keep traditional riverine fish rearing areas continuously inundated while helping to lower river stages at downstream nesting sites. April releases should be adequate for trout spawning below the project. A rising pool in the April-to-May sport fish spawning season will be dependent upon the ever-changing daily inflow pattern to the reservoir but appears possible with all AOP Simulations. The T&E flow modification “mini-test” will not be run under

any runoff scenario. Fort Peck Lake must be at elevation 2229 msl to allow releases through the spillway.

Garrison Dam releases will be reduced during the tern and plover nesting season under all runoff scenarios. The reductions will be in the 500 to 1,000 cfs range. Hourly peaking will be limited to no more than 30,000 cfs for 6 hours if the daily average release is lower than 28,000 cfs. This will limit peak stages below the project for nesting birds.

Lake Sakakawea elevations will not reach levels considered necessary for optimum fish spawning during the month of May for any of the runoff scenarios. In addition to the runoff conditions, the actual timing of the rise in lake elevation will be dependent upon the pattern of inflow at that time.

Oahe Dam releases in the spring and summer will back up those from Gavins Point Dam. Oahe Reservoir elevation in the spring will be steady or rising given Median or higher runoff. The actual timing of the rise in lake elevation will be dependent upon the pattern of inflow at that time. Under all AOP Simulations, the Oahe pool will fall during the summer.

Fort Randall Dam will be operated to provide for a pool elevation near 1355 feet msl during the fish spawn period, provided water can be supplied from other reservoirs for downstream uses, and the lake will not be drawn down below elevation 1337.5 feet msl in the fall to ensure adequate supply for water intakes. Hourly releases from Fort Randall Dam during the 2003 nesting season will be limited to 37,000 cfs. Daily average flows may be increased every third day to preserve the capability of increasing releases later in the summer if conditions turn dry.

Gavins Point Dam. Under the steady-release plan, Gavins Point Dam releases will be increased in May for all runoff scenarios when terns and plovers begin to initiate nesting. The release rate will be no more than 30,000 cfs, but could be set at a lower level, based on an assessment in mid-May of flows needed to support the service level targets in August. This will result in steady flows during the nesting season. Based on 2002 nesting season results, it is anticipated that sufficient habitat will be available above the release rates to provide for successful nesting. The resulting steady release prevents inundation of nests and chicks. Cycling releases every third day is not planned during the 2003 nesting season except during downstream flood control operations. If the results of ESA consultation allows for the replacement of the steady-release plan with the flow-to-target regulation, releases will be set to meet the specified navigation service level with increases made as necessary during the T&E bird species nesting season.

The Gavins Point pool will be operated near 1206.0 feet msl in the spring and early summer with variations day to day due to rainfall runoff. Greater fluctuations occur in the river, increasing the risk of nest inundation in the upper end of the Gavins Point pool. Several factors contribute to the increased risk of nest inundation in the upper end of the Gavins Point pool. First, because there are greater numbers of T&E species nesting below the Gavins Point Dam project that must be preserved, Gavins Point Dam releases are restricted during the nesting season. Second, unexpected rainfall runoff between Fort Randall Dam and Gavins Point Dam can result in sudden pool rises because the Gavins Point

project has a smaller storage capacity than the other System reservoirs. Third, the operation of Gavins Point for downstream flood control may necessitate sudden release reductions to prevent downstream bird losses. And finally, high releases required in wet years make nest inundation more likely. When combined, all these factors make it difficult and sometimes impossible to prevent inundation of nests in the upper end of Lewis and Clark Lake. The pool will be increased to elevation 1207.5 feet msl following the nesting season.

VI. SUMMARY OF RESULTS EXPECTED IN 2002-2003

With System operations in accordance with the 2002-2003 AOP outlined in the preceding pages, the following results can be expected.

A. Flood Control. All runoff scenarios studied will begin next year's runoff season on March 1, 2003, substantially below the desired 57.1 MAF base of annual flood control and multiple use zone. Therefore, the entire System flood control zone plus an additional 13.5 to 14.6 MAF of the carryover multiple use zone will be available to store runoff. The System will be available to significantly reduce peak discharges for all floods that may originate above the System.

Remaining storage in the carryover multiple use zone will be adequate to provide support for all of the other multiple purposes of the System, although recreation access may be difficult at some locations for the lower runoff scenarios.

B. Water Supply and Water Quality Control. Although below normal winter releases are being provided for all five runoff scenarios, all water supply and water quality requirements on the Missouri River both below Gavins Point Dam and between System reservoirs should be met for all flow conditions studied. It is possible with the low winter releases that ice formation or ice jams may temporarily reduce river stages to levels below which some intakes can draw water. Therefore, during severe cold spells, experience has shown that for brief periods it may be necessary to increase Gavins Point releases to help alleviate water supply problems.

C. Irrigation. Scheduled releases from the System reservoirs will be ample to meet the volumes of flow required for irrigation diversions from the Missouri River. Some access problems may be experienced, however, if drought conditions persist. Tributary irrigation water usage is fully accounted for in the estimates of water supply.

D. Navigation. Service to navigation in 2003 would be scheduled below full service flow support for all five runoff scenarios. Reductions below full service for the Steady-Release and Flow-to-Target Simulations are shown in **Table III**. Although these Simulations provide a comparison of typical flow support under varying runoff conditions that cover 80 percent of the historic runoff conditions, the actual rate of flow support for the 2003 navigation season will be based on actual System storage on March 15 and July 1, 2003.

Upper Decile and Upper Quartile Simulations show an 8-month navigation season. The Median, Lower Quartile and Lower Decile Simulations shorten the season 5 days. The anticipated service level and season length for all runoff conditions simulated are shown in *Table III*.

E. Power. *Tables VI and VII* give the estimated monthly System load requirements and hydropower supply of the Eastern Division, Pick-Sloan Missouri Basin Program (P-S MBP), from December 2002 through December 2003. Estimates of monthly peak demands and energy include customer requirements for firm, short-term firm, summer firm, peaking, and various other types of power sales, System losses, and the effects of diversity. Also included in the estimated requirements are deliveries of power to the Western Division, P-S MBP, to help meet its firm power commitments.

F. Recreation, Fish and Wildlife. The basic operations of the System will continue to provide recreation and fish and wildlife opportunities in the project areas and along the Missouri River as well as other benefits of a managed system. Special operational adjustments incorporating specific objectives for these purposes will be accomplished whenever possible. Conditions should be favorable for the many visitors who enjoy the camping, boating, fishing, hunting, swimming, picnicking, and other recreational activities associated with the System reservoirs and for increasing usage of the regulated reaches of the Missouri River downstream of the reservoirs.

Boat ramps that were lowered and low water ramps that were constructed during the drought of the late 1980's to early 1990's should be adequate to provide lake access next year even under the Lower Decile runoff scenario. However, boat ramps in a few areas where the ramps could not be extended may become unusable. This will affect the normal use patterns, as visitors will have to seek out areas with usable boat ramps. Boat ramp elevations for Fort Peck, Garrison, Oahe and Fort Randall Reservoirs were added in 2001 to the Missouri River Basin Water Management Division web site at: www.nwd-mr.usace.army.mil/rcc.

The effects of the simulated System operation during 2002-2003 on fish and wildlife are included in the section entitled, "Summary of Reservoir Regulation Activities for T&E Species and Fish Propagation Enhancement."

TABLE VI
PEAKING CAPABILITY AND SALES (Steady Release Regulation)
 (1,000 kW at plant)

2002	Estimated Committed Sales*	Expected C of E Capability					Expected Bureau Capability**					Expected Total System Capability				
		120%	Basic	80%			120%	Basic	80%			120%	Basic	80%		
Aug	2133															
Sep	1475															
Oct	1400															
Nov	1783															
Dec	1965	1993	1989	1989			190	181	170			2183	2170	2159		
<u>2003</u>																
Jan	2214	2016	2007	2007			185	178	167			2201	2185	2174		
Feb	1837	2034	2018	2018			183	177	164			2217	2195	2182		
		<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>	<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>	<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>
Mar	1678	2106	2099	2082	2064	2061	192	192	182	163	163	2298	2291	2264	2227	2224
Apr	1480	2130	2118	2091	2063	2058	195	195	190	164	164	2325	2313	2281	2227	2222
May	1385	2153	2134	2100	2064	2051	201	203	199	174	174	2354	2337	2299	2238	2225
Jun	1660	2194	2169	2128	2087	2057	211	212	207	182	182	2405	2381	2335	2269	2239
Jul	2276	2209	2181	2129	2081	2044	213	213	209	184	180	2422	2394	2338	2265	2224
Aug	2124	2205	2175	2113	2061	2020	209	209	206	182	176	2414	2384	2319	2243	2196
Sep	1475	2201	2172	2108	2051	2007	208	208	206	184	178	2409	2380	2314	2235	2185
Oct	1400	2191	2161	2093	2019	1974	207	207	208	187	180	2398	2368	2301	2206	2154
Nov	1769	2160	2128	2062	1993	1947	206	206	204	187	179	2366	2334	2266	2180	2126
Dec	1960	2147	2114	2038	1974	1919	200	200	198	185	177	2347	2314	2236	2159	2096

* Estimated sales, including system reserves. Power in addition to hydro production needed for these load requirements will be obtained from other power systems by interchange or purchase.

** Total output of Canyon Ferry and 1/2 of the output of Yellowtail powerplant.

TABLE VI
PEAKING CAPABILITY AND SALES (Flow to Target Regulation)
 (1,000 kW at plant)

2002	Estimated Committed Sales*	Expected C of E Capability					Expected Bureau Capability**					Expected Total System Capability				
		120%	Basic	80%			120%	Basic	80%			120%	Basic	80%		
Aug	2133															
Sep	1475															
Oct	1400															
Nov	1783															
Dec	1965	1993	1989	1989			190	181	170			2183	2170	2159		
<u>2003</u>																
Jan	2214	2016	2007	2007			185	178	167			2201	2185	2174		
Feb	1837	2034	2018	2018			183	177	164			2217	2195	2182		
		<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>	<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>	<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>
Mar	1678	2106	2099	2082	2064	2061	192	192	182	163	163	2298	2291	2264	2227	2224
Apr	1480	2130	2118	2091	2063	2058	195	195	190	164	164	2325	2313	2281	2227	2222
May	1385	2156	2137	2103	2066	2054	201	203	199	174	174	2357	2340	2302	2240	2228
Jun	1660	2203	2178	2140	2094	2066	211	212	207	182	182	2414	2390	2347	2276	2248
Jul	2276	2216	2189	2144	2090	2054	213	213	209	184	180	2429	2402	2353	2274	2234
Aug	2124	2208	2181	2132	2071	2032	209	209	206	182	176	2417	2390	2338	2253	2208
Sep	1475	2204	2177	2126	2062	2020	208	208	206	184	178	2412	2385	2332	2246	2198
Oct	1400	2193	2165	2111	2031	1987	207	207	208	187	180	2400	2372	2319	2218	2167
Nov	1769	2161	2132	2079	2005	1960	206	206	204	187	179	2367	2338	2283	2192	2139
Dec	1960	2148	2118	2055	1987	1931	200	200	198	185	177	2348	2318	2253	2172	2108

* Estimated sales, including system reserves. Power in addition to hydro production needed for these load requirements will be obtained from other power systems by interchange or purchase.

** Total output of Canyon Ferry and 1/2 of the output of Yellowtail powerplant.

TABLE VII
ENERGY GENERATION AND SALES (Steady Release Regulation)
(Million kWh at plant)

2002	Estimated Committed Sales*	Expected C of E Generation					Expected Bureau Generation **					Expected Total System Generation				
		120%	Basic	80%			120%	Basic	80%			120%	Basic	80%		
Aug	829															
Sep	714															
Oct	722															
Nov	774															
Dec	910	515	519	527			59	48	41			574	567	568		
<u>2003</u>																
Jan	896	588	578	566			58	48	37			646	626	603		
Feb	850	526	519	517			51	43	32			577	562	549		
		<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>	<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>	<u>U.D.</u>	<u>U.Q.</u>	<u>Med</u>	<u>L.Q.</u>	<u>L.D.</u>
Mar	785	391	420	435	480	488	68	70	48	38	38	459	490	483	518	526
Apr	737	479	502	555	631	623	77	77	44	36	36	556	579	599	667	659
May	685	642	660	720	783	774	108	102	47	40	40	750	762	767	823	814
Jun	745	717	740	819	832	816	118	122	53	54	54	835	862	872	886	870
Jul	829	802	819	904	909	889	143	131	77	52	51	945	950	981	961	940
Aug	835	821	831	867	899	877	99	93	73	51	50	920	924	940	950	927
Sep	713	744	725	692	672	680	95	88	70	49	48	839	813	762	721	728
Oct	720	606	582	556	558	568	93	89	69	49	48	699	671	625	607	616
Nov	774	651	532	451	471	469	89	85	79	52	45	740	617	530	523	514
Dec	<u>884</u>	<u>593</u>	<u>589</u>	<u>566</u>	<u>586</u>	<u>543</u>	<u>91</u>	<u>91</u>	<u>80</u>	<u>53</u>	<u>46</u>	<u>684</u>	<u>680</u>	<u>646</u>	<u>639</u>	<u>589</u>
CY TOT	9453	7560	7514	7662	7904	7810	1090	1057	731	543	525	8650	8571	8393	8447	8335

* Estimated sales including system reserves and losses. Power in addition to hydro production needed for these load requirements will be obtained from other systems by interchange or purchase.

** Total output Canyon Ferry and 1/2 output of Yellowtail powerplant.

TABLE VII
ENERGY GENERATION AND SALES (Flow to Target Regulation)
(Million kWh at plant)

2002	Estimated Committed Sales*	Expected C of E Generation					Expected Bureau Generation **					Expected Total System Generation				
		120%	Basic	80%			120%	Basic	80%			120%	Basic	80%		
Aug	829															
Sep	714															
Oct	722															
Nov	774															
Dec	910	515	519	527			59	48	41			574	567	568		
<u>2003</u>																
Jan	896	588	578	566			58	48	37			646	626	603		
Feb	850	526	519	517			51	43	32			577	562	549		
		<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>	<u>U.D.</u>	<u>U.Q.</u>	<u>Med.</u>	<u>L.Q.</u>	<u>L.D.</u>	<u>U.D.</u>	<u>U.Q.</u>	<u>Med</u>	<u>L.Q.</u>	<u>L.D.</u>
Mar	785	391	420	435	480	488	68	70	48	38	38	459	490	483	518	526
Apr	737	479	502	551	631	623	77	77	44	36	36	556	579	595	667	659
May	685	585	603	613	715	715	108	102	47	40	40	693	705	660	755	755
Jun	745	606	630	633	720	714	118	122	53	54	54	724	752	686	774	768
Jul	829	843	824	796	862	851	143	131	77	52	51	986	955	873	914	902
Aug	835	890	867	822	845	828	99	93	73	51	50	989	960	895	896	878
Sep	713	749	722	694	687	687	95	88	70	49	48	844	810	764	736	735
Oct	720	606	581	546	569	560	93	89	69	49	48	699	670	615	618	608
Nov	774	552	531	448	477	466	89	85	79	52	45	641	616	527	529	511
Dec	<u>884</u>	<u>589</u>	<u>590</u>	<u>570</u>	<u>588</u>	<u>545</u>	<u>91</u>	<u>91</u>	<u>80</u>	<u>53</u>	<u>46</u>	<u>680</u>	<u>681</u>	<u>650</u>	<u>641</u>	<u>591</u>
CY TOT	9453	7404	7384	7205	7657	7560	1090	1057	731	543	525	8494	8441	7936	8200	8085

* Estimated sales including system reserves and losses. Power in addition to hydro production needed for these load requirements will be obtained from other systems by interchange or purchase.

** Total output Canyon Ferry and 1/2 output of Yellowtail powerplant.

G. System Storage. System storage totaled 42.7 MAF on December 31, 2002, exactly the same as occurred on December 31, 1992, which was near the end of the last drought. This year-end storage is 6.2 MAF less than the 48.9 MAF experienced on December 31, 2001, and 12.6 MAF less than the 1967 to 2001 average. Since the System first filled to normal operating levels in 1967, the lowest end-of-December storage was 40.9 MAF in 1990. The previous lowest storage prior to the 1988-1992 drought was 50.9 MAF in 1981. The end-of-year storages have ranged from a maximum of 60.9 MAF, which occurred in 1975, to the 1990 minimum of 40.9 MAF. Total System storage on December 31, 2003 is presented in *Table VIII*.

H. Summary of Water Use by Functions. Anticipated water use in CY 2002, under the Basic Simulation, is shown in *Tables IX and X*. Actual water use data for CY 2001 are included for information and comparison.

Under the simulated operations, estimated water use in CY 2003, which will be subject to reappraisal next year, also is shown in *Table IX* for the Steady-Release Simulations and in *Table X* for the Flow-to-Target Simulations. Note that System releases are lower for the Flow-to-Target Simulation since no additional releases are made for T&E bird species.

**TABLE VIII
ANTICIPATED DECEMBER 31, 2003 STORAGE IN SYSTEM**

STEADY-RELEASE SIMULATIONS

Water Supply Condition	Total (12/31/03)	Above Minimum Pools 1/	Unfilled Carryover Storage 2/	Total Change CY 2003
(Volumes in 1,000 Acre-Feet)				
Upper Decile	55,100	37,000	2,000	12,100
Upper Quartile	52,200	34,100	4,900	9,200
Median	46,200	28,100	10,900	3,400
Lower Quartile	41,200	23,100	15,900	-1,500
Lower Decile	38,000	19,900	19,100	-4,700

FLOW-TO-TARGET SIMULATIONS

Water Supply Condition	Total (12/31/03)	Above Minimum Pools 1/	Unfilled Carryover Storage 2/	Total Change CY 2003/3
(Volumes in 1,000 Acre-Feet)				
Upper Decile	55,200	37,100	1,900	12,200
Upper Quartile	52,500	34,400	4,600	9,500
Median	47,300	29,200	9,800	4,500
Lower Quartile	41,800	23,700	15,300	-900
Lower Decile	38,600	20,500	18,500	-4,100

1/ Net usable storage above 18.1 MAF System minimum pool level established for power, recreation, irrigation diversions, and other purposes.

2/ System base of flood control zone containing 57.1 MAF.

3/ Less storage is saved than is indicated for Median, Lower Quartile, and Lower Decile Flow-to-Target Simulations compared to Steady-Release Simulations due to differences in mid-May through August releases.

TABLE IX
MISSOURI RIVER MAINSTEM SYSTEM
WATER USE FOR CALENDAR YEARS 2001, 2002, AND 2003 ABOVE SIOUX CITY, IOWA
in Million Acre-Feet (MAF)

	CY 2001 Actual	CY 2002 Basic Simulation	Steady-Release Simulations for Calendar Year 2003					
			Upper Decile	Upper Quartile	Median	Lower Quartile	Lower Decile	
Upstream Depletions (1)								
Irrigation, Tributary Reservoir Evaporation & Other Uses	2.0	2.0						
Tributary Reservoir Storage Change	<u>-0.1</u>	<u>-0.4</u>						
Total Upstream Depletions	1.9	1.6	2.6	2.5	3.0	2.6	2.2	
System Reservoir Evaporation (2)	2.7	2.1	1.1	1.1	1.6	1.8	1.7	
Sioux City Flows								
Navigation Season								
Unregulated Flood Inflows Between Gavins Point & Sioux City (3)	0.0	0.0						
Navigation Service Requirement	14.6	15.2	15.1	14.2	13.0	13.0	12.9	
Supplementary Releases								
T&E Species (4)	0.0	-0.4	0.6	0.5	0.5	0.2	0.2	
Flood Evacuation (5)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Non-navigation Season								
Flows	3.8	3.5	3.3	3.3	3.1	3.4	3.2	
Flood Evacuation Releases (6)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
System Storage Change	<u>-0.5</u>	<u>-6.0</u>	<u>11.8</u>	<u>9.0</u>	<u>3.4</u>	<u>-1.5</u>	<u>-4.7</u>	
Total	22.5	16.0	34.5	30.6	24.6	19.5	15.5	
Project Releases								
Fort Peck	4.3	4.8	5.1	5.3	6.0	5.7	5.8	
Garrison	9.6	11.8	14.0	14.0	13.8	13.8	13.4	
Oahe	11.2	14.9	12.6	13.0	13.8	15.1	15.2	
Big Bend	10.5	14.0	12.6	12.9	13.7	15.0	15.1	
Fort Randall	12.0	15.2	13.8	13.8	14.4	15.1	15.1	
Gavins Point	13.9	16.0	15.8	15.6	15.7	16.2	16.2	

- (1) Tributary uses, above the 1949 level of development including agricultural depletions and tributary storage effects.
- (2) Net evaporation is shown for 2003.
- (3) Incremental inflows to reach which exceed those usable in support of navigation at the target level, even if Gavins Point Dam releases were held to as low as 6,000 cfs.
- (4) Increased releases required to maintain navigation release flexibility during the T&E species nesting season. During 2002, releases fell below minimum service support flows because of T&E nesting resulting in a negative value instead of zero.
- (5) Includes flood control releases for flood control storage evacuation and releases used to extend the navigation season beyond the normal December 1 closing date at the mouth of the Missouri River.
- (6) Releases for flood control storage evacuation in excess of a 15,000 cfs Fort Randall Dam release.

TABLE X
MISSOURI RIVER MAINSTEM SYSTEM
WATER USE FOR CALENDAR YEARS 2001, 2002, AND 2003 ABOVE SIOUX CITY, IOWA
in Million Acre-Feet (MAF)

	CY 2001 Actual	CY 2002 Basic Simulation	Flow-to-Target Simulations for Calendar Year 2003					
			Upper Decile	Upper Quartile	Median	Lower Quartile	Lower Decile	
Upstream Depletions (1)								
Irrigation, Tributary Reservoir Evaporation & Other Uses	2.0	2.0						
Tributary Reservoir Storage Change	<u>-0.1</u>	<u>-0.4</u>						
Total Upstream Depletions	1.9	1.6	2.7	2.6	2.8	2.4	2.1	
System Reservoir Evaporation (2)	2.7	2.1	1.2	1.2	1.5	1.7	1.5	
Sioux City Flows								
Navigation Season								
Unregulated Flood Inflows Between Gavins Point & Sioux City (3)	0.0	0.0						
Navigation Service Requirement	14.6	15.2	15.1	14.0	12.4	12.9	12.7	
Supplementary Releases								
T&E Species (4)	0.0	-0.4	0.0	0.0	0.0	0.0	0.0	
Flood Evacuation (5)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
Non-navigation Season								
Flows	3.8	3.5	3.3	3.3	3.4	3.4	3.3	
Flood Evacuation Releases (6)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
System Storage Change	<u>-0.5</u>	<u>-6.0</u>	<u>12.2</u>	<u>9.5</u>	<u>4.5</u>	<u>-0.9</u>	<u>-4.1</u>	
Total	22.5	16.0	34.5	30.6	24.6	19.5	15.5	
Project Releases								
Fort Peck	4.3	4.8	5.1	5.3	5.6	5.6	5.7	
Garrison	9.6	11.8	14.0	13.9	13.3	13.6	13.2	
Oahe	11.2	14.9	12.5	12.7	12.6	14.5	14.5	
Big Bend	10.5	14.0	12.4	12.6	12.5	14.3	14.4	
Fort Randall	12.0	15.2	13.6	13.5	13.3	14.5	14.5	
Gavins Point	13.9	16.0	15.7	15.3	14.6	15.6	15.6	

- (1) Tributary uses, above the 1949 level of development including agricultural depletions and tributary storage effects.
- (2) Net evaporation is shown for 2003.
- (3) Incremental inflows to reach which exceed those usable in support of navigation at the target level, even if Gavins Point Dam releases were held to as low as 6,000 cfs.
- (4) Increased releases required to maintain navigation release flexibility during the T&E species nesting season. During 2002, releases fell below minimum service support flows because of T&E nesting resulting in a negative value instead of zero.
- (5) Includes flood control releases for flood control storage evacuation and releases used to extend the navigation season beyond the normal December 1 closing date at the mouth of the Missouri River.
- (6) Releases for flood control storage evacuation in excess of a 15,000 cfs Fort Randall Dam release.

VII. TENTATIVE PROJECTION OF OPERATIONS THROUGH MARCH 2009

The 5-year extension to the AOP (March 2004 to March 2009) has been prepared to serve as a guide for Western Area Power Association's (WAPA) marketing activities and to provide data to allow basin interests to conduct long term planning. As discussed in Section IV, Chapter A, adjustments to the specific technical criteria presented in the existing Master Manual are necessary to continue to meet the operational objectives of the existing Master Manual during drought periods. This is due to increased release requirements for water supply during low runoff periods. The specific details of these adjustments are not certain, absent the completion of review of possible options by the Tribes, Missouri River Basin Association, the MRNRC, and any other interested parties.

The navigation service level and season length criteria described in Section IV, Chapter A were applied to the extensions. Two sets of Simulations, Steady-Release and Flow-to-Target, are shown as studies 9-23 and 35-43 with pertinent data in graphical form on *Plates 11* and *12*. The minimum winter release of 13,000 cfs for downstream water supply discussed in Section IV is shown in the Lower Quartile and Lower Decile extensions and for Median Steady-Release. System storage recovers sufficiently in the Median Flow-to-Target Simulations to provide a 17,000 cfs release during winter 2007-2008 and 2008-2009. For any given year, when July 1 System storage is less than 52 MAF and the previous winter's System release is in excess of the September 1 storage check, the extra water released is recovered by shortening the navigation season. This difference is limited to 3,000 cfs during the winter months (13,000 cfs current water supply minimum compared to a 10,000 cfs practical open water minimum assumed by the existing Master Manual). The extra water released from mid-May through August by the Steady-Release Lower Quartile and Lower Decile Extension Simulations is compensated with a further shortening of the navigation season the following year. Navigation service support and season length, end of year system storage, and the winter release rate for the extensions are shown on *Table XI*.

**TABLE XI
NAVIGATION SERVICE SUPPORT**

	2004		2005		2006		2007		2008	
	Steady Release	Flow to Target	Steady Release	Flow to Target	Steady Release	Flow to Target	Steady Release	Flow to Target	Steady Release	Flow to Target
MEDIAN										
Flow Level Below Full Service (kcfs) Spring	-5.0	-4.1	-2.7	-1.8	-1.1	-0.2	0	0	0	0
Summer/Fall	-4.6	-3.6	-2.7	-1.6	-1.4	-0.3	0	0	0	0
Season Length (Months)	8	8	8	8	8	8	8	8	8	8
Dec 31 Storage (MAF)	49.5	50.8	51.7	53.0	53.1	54.3	55.2	54.4	55.3	55.3
Winter Release (kcfs)	13.0	13.0	13.0	13.0	13.0	13.0	17.0	13.0	13.0	17.0
LOWER QUARTILE										
Flow Level Below Full Service (kcfs) Spring	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-5.8	-5.1	-4.7	-4.7
Summer/Fall	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-5.4	-4.9	-4.9
Season Length (Months)	8-20 days	8-16 days	8-24 days	8-16 days	8-24 days	8-16 days	8-16 days	8-24 days	8-24 days	8-14 days
Dec 31 Storage (MAF)	41.6	42.7	42.9	43.6	44.6	45.2	46.8	48.4	48.5	48.5
Winter Release (kcfs)	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0
LOWER DECILE										
Flow Level Below Full Service (kcfs) Spring	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0
Summer/Fall	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0	-6.0
Season Length (Months)	8-38 days	8-24 days	8-53 days	8-37 days	8-69 days	8-46 days	8-46 days	8-53 days	8-53 days	8-46 days
Dec 31 Storage (MAF)	35.0	35.3	33.9	33.9	34.0	33.4	33.7	34.7	34.0	34.0
Winter Release (kcfs)	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0

A. Median Runoff – Steady-Release. System storage would begin in March 2004 at 46.4 MAF and would rise to 54.5 MAF by March 2009. Winter System releases remain at 13,000 cfs throughout the study period. Fort Peck Lake, Lake Sakakawea, and Lake Oahe rise to the elevations described in *Table V* that permit unbalancing by March 1, 2007. This follows the pattern of “high,” “float,” “low” described in *Table IV*. The amount of unbalancing was generally 4 feet at Fort Peck Lake and 3 feet at Lakes Sakakawea and Oahe. Fort Peck releases were set at 12,800 cfs in June 2006, reflecting the “mini-test” described in Section IV, Chapter D. The full test, in which up to 19,000 cfs would be spilled for 5 days, is shown in June 2007. An 8-month navigation season is shown. Full service flows are not provided until 2008.

TABLE XII
MARCH 1 RESERVOIR UNBALANCING, AOP EXTENSIONS
STEADY-RELEASE SIMULATIONS (Feet)

Year	Fort Peck	Garrison	Oahe
2007	+4.3	-3.0	0.0
2008	0.0	+3.0	-3.0
2009	-4.3	0.0	+3.0

B. Median Runoff – Flow-to-Target. System storage would begin in March 2004 at 47.6 MAF and would rise to 55.0 MAF by March 2009. Winter releases remain at 13,000 cfs through winter 2006-2007, then rise to 17,000 cfs for winter 2007-2008 and 2008-2009. Reservoir unbalancing is initiated by March 1, 2006, one year earlier than the Steady-Release Simulation. The Fort Peck “mini-test” and full test are also accomplished one year earlier compared to the Steady-Release Simulation, in 2005 and 2006, respectively. Full service flows are provided in 2007 and 2008.

TABLE XIII
MARCH 1 RESERVOIR UNBALANCING, AOP EXTENSIONS
FLOW-TO-TARGET SIMULATIONS (Feet)

Year	Fort Peck	Garrison	Oahe
2006	0.0	+3.0	-3.0
2007	-3.5	-0.8	+3.0
2008	+4.2	-3.0	0.0
2009	0.0	+3.0	-3.0

C. Lower Quartile Runoff – Steady-Release. System storage begins the period at 40.9 MAF and rises to 48.4 MAF by March 2009 with navigation service levels increasing from minimum service to 900 cfs above minimum service during the simulation period. The navigation season is shortened 20 days in 2004 and 24 days from 2005 through 2008. A 13,000 cfs winter release is shown for the entire study period. Since the upper three reservoirs do not refill under Lower Quartile and Lower Decile runoff, their percent of remaining carryover multiple use storage is balanced each March 1.

D. Lower Quartile Runoff – Flow-to-Target. System storage begins the period at 41.5 MAF and rises to 48.5 MAF by March 2009 with navigation service levels increasing from minimum service to 1,100 cfs above minimum service during the simulation period. The navigation season is shortened 16 days from 2004 through 2007 and 14 days in 2008. A 13,000 cfs winter release is shown for the entire study period.


E. Lower Decile Runoff – Steady-Release. System storage begins the period at 37.5 MAF and falls to 34.7 MAF by March 2009. The navigation season is shortened 38 days in 2004, 53 days in 2005, 2007, and 2008 and 69 days in 2006. System storage recovers sufficiently after the 69-day shortening in 2006 to permit the lesser 53-day shortening in 2007 and 2008. Service level is minimum service, 2003 through 2007. A 13,000 cfs winter release is shown for the entire study period.

F. Lower Decile Runoff – Flow-to-Target. System storage begins the period at 38.2 MAF and falls to 34.0 MAF by March 2009. The navigation season is shortened 24 days in 2004, 37 days in 2005, and 46 days in 2006, 2007, and 2008. A 13,000 cfs winter release is shown for the entire study period.

Plate 11 presents System storage, Gavins Point, and System peaking capability for Median, Lower Quartile, and Lower Decile for both sets of guidelines, for the period 2004 through March 2009. Peak power, or peaking capability, is the amount of power available when all powerplants are operating at maximum.

Plate 12 presents reservoir elevations for Fort Peck, Garrison, Oahe, and Fort Randall for Median, Lower Quartile, and Lower Decile for the period 2004 through March 2009.

A Summary of Engineering Data for the System is shown on **Plate 2**.





MISSOURI RIVER BASIN

Summary of Engineering Data -- Missouri River Mainstem System							
Item No.	Subject	Fort Peck Lake		Garrison Dam - Lake Sakakawea		Oahe Dam - Lake Oahe	
1	Location of Dam	Near Glasgow, Montana		Near Garrison, ND		Near Pierre, SD	
2	River Mile - 1960 Mileage	Mile 1771.5		Mile 1389.9		Mile 1072.3	
3	Total & incremental drainage areas in square miles	57,500		181,400 (2) 123,900		243,490 (1) 62,090	
4	Approximate length of full reservoir (in valley miles)	134, ending near Zortman, MT		178, ending near Trenton, ND		231, ending near Bismarck, ND	
5	Shoreline in miles (3)	1520 (elevation 2234)		1340 (elevation 1837.5)		2250 (elevation 1607.5)	
6	Average total & incremental inflow in cfs	10,200		25,600 15,400		28,900 3,300	
7	Max. discharge of record near damsite in cfs	137,000 (June 1953)		348,000 (April 1952)		440,000 (April 1952)	
8	Construction started - calendar yr.	1933		1946		1948	
9	In operation (4) calendar yr.	1940		1955		1962	
Dam and Embankment							
10	Top of dam, elevation in feet msl	2280.5		1875		1660	
11	Length of dam in feet	21,026 (excluding spillway)		11,300 (including spillway)		9,300 (excluding spillway)	
12	Damming height in feet (5)	220		180		200	
13	Maximum height in feet (5)	250.5		210		245	
14	Max. base width, total & w/o berms in feet	3500, 2700		3400, 2050		3500, 1500	
15	Abutment formations (under dam & embankment)	Bearpaw shale and glacial fill		Fort Union clay shale		Pierre shale	
16	Type of fill	Hydraulic & rolled earth fill		Rolled earth filled		Rolled earth fill & shale berms	
17	Fill quantity, cubic yards	125,628,000		66,500,000		55,000,000 & 37,000,000	
18	Volume of concrete, cubic yards	1,200,000		1,500,000		1,045,000	
19	Date of closure	24 June 1937		15 April 1953		3 August 1958	
Spillway Data							
20	Location	Right bank - remote		Left bank - adjacent		Right bank - remote	
21	Crest elevation in feet msl	2225		1825		1596.5	
22	Width (including piers) in feet	820 gated		1336 gated		456 gated	
23	No., size and type of gates	16 - 40' x 25' vertical lift gates		28 - 40' x 29' Tainter		8 - 50' x 23.5' Tainter	
24	Design discharge capacity, cfs	275,000 at elev 2253.3		827,000 at elev 1858.5		304,000 at elev 1644.4	
25	Discharge capacity at maximum operating pool in cfs	230,000		660,000		80,000	
Reservoir Data (6)							
26	Max. operating pool elev. & area	2250 msl 246,000 acres		1854 msl 380,000 acres		1620 msl 374,000 acres	
27	Max. normal op. pool elev. & area	2246 msl 240,000 acres		1850 msl 364,000 acres		1617 msl 360,000 acres	
28	Base flood control elev & area	2234 msl 212,000 acres		1837.5 msl 307,000 acres		1607.5 msl 312,000 acres	
29	Min. operating pool elev. & area	2160 msl 90,000 acres		1775 msl 128,000 acres		1540 msl 117,000 acres	
Storage allocation & capacity							
30	Exclusive flood control	2250-2246 975,000 a.f.		1854-1850 1,489,000 a.f.		1620-1617 1,102,000 a.f.	
31	Flood control & multiple use	2246-2234 2,717,000 a.f.		1850-1837.5 4,222,000 a.f.		1617-1607.5 3,201,000 a.f.	
32	Carryover multiple use	2234-2160 10,785,000 a.f.		1837.5-1775 13,130,000 a.f.		1607.5-1540 13,461,000 a.f.	
33	Permanent	2160-2030 4,211,000 a.f.		1775-1673 4,980,000 a.f.		1540-1415 5,373,000 a.f.	
34	Gross	2250-2030 18,688,000 a.f.		1854-1673 23,821,000 a.f.		1620-1415 23,137,000 a.f.	
35	Reservoir filling initiated	November 1937		December 1953		August 1958	
36	Initially reached min. operating pool	27 May 1942		7 August 1955		3 April 1962	
37	Estimated annual sediment inflow	18,100 a.f. 1030 yrs.		25,900 a.f. 920 yrs.		19,800 a.f. 1170 yrs.	
Outlet Works Data							
38	Location	Right bank		Right Bank		Right Bank	
39	Number and size of conduits	2 - 24' 8" diameter (nos. 3 & 4)		1 - 26' dia. and 2 - 22' dia.		6 - 19.75' dia. upstream, 18.25' dia. downstream	
40	Length of conduits in feet (8)	No. 3 - 6,615, No. 4 - 7,240		1529		3496 to 3659	
41	No., size, and type of service gates	1 - 28' dia. cylindrical gate 6 ports, 7.6' x 8.5' high (net opening) in each control shaft		1 - 18' x 24.5' Tainter gate per conduit for fine regulation		1 - 13' x 22' per conduit, vertical lift, 4 cable suspension and 2 hydraulic suspension (fine regulation)	
42	Entrance invert elevation (msl)	2095		1672		1425	
43	Avg. discharge capacity per conduit & total	Elev. 2250 22,500 cfs - 45,000 cfs		Elev. 1854 30,400 cfs - 98,000 cfs		Elev. 1620 18,500 cfs - 111,000 cfs	
44	Present tailwater elevation (ft msl)	2032-2036 5,000 - 35,000 cfs		1670-1680 15,000- 60,000 cfs		1423-1428 20,000-55,000 cfs	
Power Facilities and Data							
45	Avg. gross head available in feet (14)	194		161		174	
46	Number and size of conduits	No. 1-24'8" dia., No. 2-22'4" dia.		5 - 29' dia., 25' penstocks		7 - 24' dia., imbedded penstocks	
47	Length of conduits in feet (8)	No. 1 - 5,653, No. 2 - 6,355		1829		From 3,280 to 4,005	
48	Surge tanks	PH#1: 3-40' dia., PH#2: 2-65' dia.		65' dia. - 2 per penstock		70' dia., 2 per penstock	
49	No., type and speed of turbines	5 Francis, PH#1-2: 128.5 rpm, 1-164 rpm, PH#2-2: 128.6 rpm		5 Francis, 90 rpm		7 Francis, 100 rpm	
50	Discharge cap. at rated head in cfs	PH#1, units 1&3 170', 2-140' 8,800 cfs, PH#2-4&5 170'-7,200 cfs		150' 41,000 cfs		185' 54,000 cfs	
51	Generator nameplate rating in kW	1&3: 43,500; 2: 18,250; 4&5: 40,000		3 - 109,250, 2 - 95,000		112,290	
52	Plant capacity in kW	185,250		517,750		786,030	
53	Dependable capacity in kW (9)	181,000		388,000		534,000	
54	Avg. annual energy, million kWh (12)	1,142		2,429		2,867	
55	Initial generation, first and last unit	July 1943 - June 1961		January 1956 - October 1960		April 1962 - June 1963	
56	Estimated cost September 1999 completed project (13)	\$158,428,000		\$305,274,000		\$346,521,000	





Summary of Engineering Data -- Missouri River Mainstem System

Big Bend Dam - Lake Sharpe		Fort Randall Dam - Lake Francis Case		Gavins Point Dam - Lewis & Clark Lake		Total	Item No.	Remarks
21 miles upstream Chamberlain, SD Mile 987.4 249,330 (1)	5,840	Near Lake Andes, SD Mile 880.0 263,480 (1)	14,150	Near Yankton, SD Mile 811.1 279,480 (1)	16,000		1	(1) Includes 4,280 square miles of non-contributing areas. (2) Includes 1,350 square miles of non-contributing areas. (3) With pool at base of flood control. (4) Storage first available for regulation of flows. (5) Damming height is height from low water to maximum operating pool. Maximum height is from average streambed to top of dam. (6) Based on latest available storage data. (7) River regulation is attained by flows over low-crested spillway and through turbines. (8) Length from upstream face of outlet or to spiral case. (9) Based on 8th year (1961) of drought drawdown (From study 8-83-1985). (10) Affected by level of Lake Francis case. Applicable to pool at elevation 1350.
80, ending near Pierre, SD		107, ending at Big Bend Dam		25, ending near Niobrara, NE		755 miles	2 3 4	
200 (elevation 1420) 28,900		540 (elevation 1350) 30,000	1,100	90 (elevation 1204.5) 32,000	2,000	5,940 miles	5 6	
440,000 (April 1952)		447,000 (April 1952)		480,000 (April 1952)			7	
1959		1946		1952			8	
1964		1953		1955			9	
1440 10,570 (including spillway) 78 95 1200, 700		1395 10,700 (including spillway) 140 165 4300, 1250		1234 8,700 (including spillway) 45 74 850, 450		71,596 863 feet	10 11 12 13 14	
Pierre shale & Niobrara chalk		Niobrara chalk		Niobrara chalk & Carlile shale			15	
Rolled earth, shale, chalk fill 17,000,000 540,000 24 July 1963		Rolled earth fill & chalk berms 28,000,000 & 22,000,000 961,000 20 July 1952		Rolled earth & chalk fill 7,000,000 308,000 31 July 1955		358,128,000 cu. yds 5,554,000 cu. yds.	16 17 18 19	
Left bank - adjacent 1385 376 gated 8 - 40' x 38' Tainter 390,000 at elev 1433.6 270,000		Left bank - adjacent 1346 1000 gated 21 - 40' x 29' Tainter 620,000 at elev 1379.3 508,000		Right bank - adjacent 1180 664 gated 14 - 40' x 30' Tainter 584,000 at elev 1221.4 345,000			20 21 22 23 24 25	
1423 msl 61,000 acres 1422 msl 60,000 acres 1420 msl 57,000 acres 1415 msl 51,000 acres		1375 msl 102,000 acres 1365 msl 95,000 acres 1350 msl 77,000 acres 1320 msl 38,000 acres		1210 msl 31,000 acres 1208 msl 28,000 acres 1204.5 msl 24,000 acres 1204.5 msl 24,000 acres		1,194,000 acres 1,147,000 acres 989,000 acres 450,000 acres	26 27 28 29	
1423-1422 60,000 a.f. 1422-1420 117,000 a.f.		1375-1365 985,000 a.f. 1365-1350 1,309,000 a.f. 1350-1320 1,607,000 a.f.		1210-1208 59,000 a.f. 1208-1204.5 90,000 a.f.		4,670,000 a.f. 11,656,000 a.f. 38,983,000 a.f.	30 31 32	
1420-1345 1,682,000 a.f. 1423-1345 1,859,000 a.f. November 1963 25 March 1964 4,300 a.f.	430 yrs.	1320-1240 1,517,000 a.f. 1375-1240 5,418,000 a.f. January 1953 24 November 1953 18,300 a.f.	250 yrs.	1204.5-1160 321,000 a.f. 1210-1160 470,000 a.f. August 1955 22 December 1955 2,600 a.f.	180 yrs.	18,084,000 a.f. 73,393,000 a.f. 92,500 a.f.	33 34 35 36 37	
None (7)		Left Bank 4 - 22' diameter 1013 2 - 11' x 23' per conduit, vertical lift, cable suspension		None (7)			38 39 40 41	
1385 (11)		1229 Elev 1375		1180 (11)			42 43	
1351-1355(10) 25,000-100,000 cfs		32,000 cfs - 128,000 cfs 1228-1239 5,000-60,000 cfs		1155-1163 15,000-60,000 cfs			44	
70 None: direct intake 1,074 None 8 Fixed blade, 81.8 rpm		117 8 - 28' dia., 22' penstocks 59' dia, 2 per alternate penstock 8 Francis, 85.7 rpm		48 None: direct intake None 3 Kaplan, 75 rpm		764 feet 55,083 36 units	45 46 47 48 49	
67' 103,000 cfs		112' 44,500 cfs		48' 36,000 cfs			50	
3 - 67,276, 5 - 58,500 494,320 497,000 1,041 October 1964 - July 1966		40,000 320,000 293,000 1,843 March 1954 - January 1956		44,100 132,300 74,000 754 September 1956 - January 1957		2,435,650 kw 1,967,000 kw 10,077 million kWh July 1943 - July 1966	51 52 53 54 55	
\$107,498,000		\$199,066,000		\$49,617,000		\$1,166,404,000	56	Corps of Engineers, U.S. Army Compiled by Northwestern Division Missouri River Region May 2001





System Storage







Fort Peck Elevations and Releases







Garrison Elevations and Releases



Oahe Elevations and Releases




Fort Randall Elevations and Releases




Reservoir Release and Unregulated Flow


Fort Peck




Garrison





Oahe




Gavins Point




System Gross Capability and Average Monthly Generation




Tentative Five Year Extensions of 2002-2003 AOP System Storage



Gavins Point Regulated Flows



Peaking Capability





News Release

**US Army Corps
of Engineers**
Northwestern Division
Public Affairs Office

12565 West Center Road
Omaha, Nebraska 68144-3869

Phone: (402) 697-2552
Fax: (402) 697-2554

Contact: Paul Johnston
(402) 697-2552
Larry Cieslik
(402) 697-2675
Date: Jan. 15, 2003

OMAHA – The Army Corps of Engineers will release its 2003 Annual Operating Plan for the Missouri River reservoir system by the end of January.

It will describe how releases from the system of reservoirs will be managed throughout the year. Given low water levels in the reservoirs due to the current drought, the plan will provide only minimum flows for navigation. It is anticipated that the season will be shortened by five days in November. A final determination of the length of the shortening will be made after the water-in-storage check on March 1.

The AOP will present a “steady release” schedule during the nesting season of the interior least tern and piping plover. The two birds are listed for protection under the Endangered Species Act.

Enough water would be released to meet minimum navigation flow targets, support river recreation and meet water quality standards. A release rate of 30,000 cubic per second (cfs) from Gavins Point Dam, near Yankton, S.D., would provide minimum navigation service at least 90 percent of the time between June 15 and August 15. Downstream tributary contributions could provide enough water to allow for lower releases.

The U.S. Fish and Wildlife Service has confirmed to the Corps that steady to declining releases from June 15 through August 15 would comply with the Endangered Species Act.

The Corps informed the USFWS that it prefers a slightly different plan for the tern and plover nesting season, which is referred to as a “flow-to-target” operation. Under this plan, releases would be gradually increased throughout the nesting season to meet minimum flow targets as the tributaries dry up. Nests threatened by rising water or erosion would be moved to higher ground when possible.

Threatened chicks and eggs would be collected by biologists for captive rearing at the Corps’ “bird house” at Gavins Point and subsequently released.

“We prefer the ‘flow to target’ option because it simultaneously meets downstream needs and saves nearly 250,000 acre feet of water in the three biggest reservoirs,” said Brig. Gen. David Fastabend, Northwestern Division Engineer. “That could reduce the anticipated decline in the reservoirs by 4 to 18 inches, depending on the contributions by the downstream tributaries,” he said.

The Corps and the USFWS have agreed to consult on the flow-to-target plan to see if it could possibly replace the steady release plan for the 2003 nesting season.

“We will await the results of our consultation with the USFWS before the operation during the nesting season is finalized, said General Fastabend.”

The final Annual Operating Plan will be published late this month. Copies will be provided to an extensive mailing list. It will also be available at www.nwd.usace.army.mil or by writing to: Water Management Division, 12565 West Center Road, Omaha, NE 68144.

	30NOV02		2002	
	INI-SUM	31DEC	31JAN	28FEB
-- FORT PECK--				
NAT INFLOW	960	280	315	365
DEPLETION	-205	-72	-84	-49
EVAPORATION	41	41		
MOD INFLOW	1124	311	399	414
RELEASE	1902	615	676	611
STOR CHANGE	-778	-304	-277	-197
STORAGE	11715	11411	11134	10937
ELEV FTMSL	2216.8	2215.0	2213.4	2212.2
DISCH KCFS	5.6	10.0	11.0	11.0
POWER				
AVE POWER MW		126	134	133
PEAK POW MW		145	143	142
ENERGY GWH	283.4	93.9	100.0	89.6
-- GARRISON--				
NAT INFLOW	840	220	260	360
DEPLETION	21	-18	7	32
CHAN STOR	-57	-46	-11	0
EVAPORATION	46	46		
REG INFLOW	2618	761	919	939
RELEASE	3909	1230	1402	1277
STOR CHANGE	-1291	-469	-483	-338
STORAGE	14442	13973	13490	13151
ELEV FTMSL	1824.6	1822.7	1820.8	1819.5
DISCH KCFS	18.0	20.0	22.8	23.0
POWER				
AVE POWER MW		228	256	255
PEAK POW MW		334	329	325
ENERGY GWH	531.8	169.6	190.6	171.7
-- OAHE--				
NAT INFLOW	100		10	90
DEPLETION	61	13	18	30
CHAN STOR	-25	-10	-14	-1
EVAPORATION	41	41		
REG INFLOW	3882	1166	1380	1336
RELEASE	2611	793	945	872
STOR CHANGE	1272	373	435	464
STORAGE	12495	12868	13303	13767
ELEV FTMSL	1583.6	1585.2	1587.1	1589.0
DISCH KCFS	23.5	12.9	15.4	15.7
POWER				
AVE POWER MW		147	177	183
PEAK POW MW		596	606	616
ENERGY GWH	363.8	109.4	131.6	122.8
-- BIG BEND--				
EVAPORATION	11	11		
REG INFLOW	2599	782	945	872
RELEASE	2629	812	945	872
STORAGE	1712	1682	1682	1682
ELEV FTMSL	1420.5	1420.0	1420.0	1420.0
DISCH KCFS	21.2	13.2	15.4	15.7
POWER				
AVE POWER MW		67	76	75
PEAK POW MW		538	538	529
ENERGY GWH	156.4	49.5	56.2	50.6
-- FORT RANDALL--				
NAT INFLOW	90	20	20	50
DEPLETION	9	3	3	3
EVAPORATION	10	10		
REG INFLOW	2700	819	962	919
RELEASE	1951	695	701	555
STOR CHANGE	749	124	261	364
STORAGE	2375	2499	2760	3124
ELEV FTMSL	1338.9	1341.0	1345.0	1350.0
DISCH KCFS	22.9	11.3	11.4	10.0
POWER				
AVE POWER MW		84	87	80
PEAK POW MW		299	318	338
ENERGY GWH	181.4	62.7	65.0	53.7
-- GAVINS POINT--				
NAT INFLOW	305	80	100	125
DEPLETION	11	10	1	
CHAN STOR	24	21	0	3
EVAPORATION	4	4		
REG INFLOW	2264	782	800	683
RELEASE	2318	797	800	722
STOR CHANGE	-54	-15	-39	-39
STORAGE	412	397	397	358
ELEV FTMSL	1208.0	1207.5	1207.5	1206.0
DISCH KCFS	24.2	13.0	13.0	13.0
POWER				
AVE POWER MW		46	46	46
PEAK POW MW		78	78	76
ENERGY GWH	99.5	34.3	34.4	30.8
-- GAVINS POINT - SIOUX CITY--				
NAT INFLOW	150	30	35	85
DEPLETION	36	11	12	13
REGULATED FLOW AT SIOUX CITY				
KAF	2432	816	823	794
KCFS		13.3	13.4	14.3
-- TOTAL--				
NAT INFLOW	2445	630	740	1075
DEPLETION	-67	-53	-43	29
CHAN STOR	-58	-35	-25	2
EVAPORATION	154	154		
STORAGE	43151	42830	42765	43019
SYSTEM POWER				
AVE POWER MW		698	776	773
PEAK POW MW		1991	2012	2025
ENERGY GWH	1616.3	519.5	577.7	519.1
DAILY GWH		16.8	18.6	18.5
INI-SUM	31DEC	31JAN	28FEB	

	30NOV02	2002		
	INI-SUM	31DEC	31JAN	28FEB
--FORT PECK--				
NAT INFLOW	1152	336	378	438
DEPLETION	-382	-127	-150	-105
EVAPORATION	31	31		
MOD INFLOW	1503	432	528	543
RELEASE	2105	615	769	722
STOR CHANGE	-602	-183	-241	-179
STORAGE	11715	11532	11292	11113
ELEV FTMSL	2216.8	2215.7	2214.3	2213.3
DISCH KCFS	5.6	10.0	12.5	13.0
POWER				
AVE POWER MW		126	145	143
PEAK POW MW		146	144	143
ENERGY GWH	298.1	94.1	107.7	96.3
--GARRISON--				
NAT INFLOW	1008	264	312	432
DEPLETION	38	-12	12	38
CHAN STOR	-78	-46	-26	-5
EVAPORATION	35	35		
REG INFLOW	2963	810	1042	1111
RELEASE	4038	1230	1476	1333
STOR CHANGE	-1076	-420	-434	-222
STORAGE	14442	14022	13589	13366
ELEV FTMSL	1824.6	1822.9	1821.2	1820.4
DISCH KCFS	18.0	20.0	24.0	24.0
POWER				
AVE POWER MW		228	270	268
PEAK POW MW		335	330	327
ENERGY GWH	550.3	169.7	200.8	179.8
--OAHE--				
NAT INFLOW	120		12	108
DEPLETION	61	13	18	30
CHAN STOR	-30	-10	-20	
EVAPORATION	31	31		
REG INFLOW	4037	1176	1450	1411
RELEASE	2529	773	912	845
STOR CHANGE	1508	403	538	566
STORAGE	12495	12898	13437	14003
ELEV FTMSL	1583.6	1585.4	1587.7	1590.0
DISCH KCFS	23.5	12.6	14.8	15.2
POWER				
AVE POWER MW		143	171	178
PEAK POW MW		597	609	621
ENERGY GWH	353.3	106.6	127.2	119.4
--BIG BEND--				
EVAPORATION	9	9		
REG INFLOW	2520	764	912	845
RELEASE	2550	794	912	845
STORAGE	1712	1682	1682	1682
ELEV FTMSL	1420.5	1420.0	1420.0	1420.0
DISCH KCFS	21.2	12.9	14.8	15.2
POWER				
AVE POWER MW		65	73	73
PEAK POW MW		538	538	529
ENERGY GWH	151.7	48.4	54.3	49.0
--PORT RANDALL--				
NAT INFLOW	108	24	24	60
DEPLETION	9	3	3	3
EVAPORATION	8	8		
REG INFLOW	2642	808	933	902
RELEASE	1893	683	683	528
STOR CHANGE	749	125	250	374
STORAGE	2375	2500	2750	3124
ELEV FTMSL	1338.9	1341.0	1344.8	1350.0
DISCH KCFS	22.9	11.1	11.1	9.5
POWER				
AVE POWER MW		83	85	76
PEAK POW MW		299	317	338
ENERGY GWH	175.9	61.6	63.3	51.0
--GAVINS POINT--				
NAT INFLOW	366	96	120	150
DEPLETION	11	10	1	
CHAN STOR	25	22		3
EVAPORATION	3	3		
REG INFLOW	2269	787	802	681
RELEASE	2323	802	802	720
STOR CHANGE	-54	-15		-39
STORAGE	412	397	397	358
ELEV FTMSL	1208.0	1207.5	1207.5	1206.0
DISCH KCFS	24.2	13.0	13.0	13.0
POWER				
AVE POWER MW		46	46	46
PEAK POW MW		78	78	76
ENERGY GWH	99.7	34.5	34.4	30.7
--GAVINS POINT - SIOUX CITY--				
NAT INFLOW	180	36	42	102
DEPLETION	36	11	12	13
REGULATED FLOW AT SIOUX CITY				
KAF	2467	827	832	809
KCFS		13.4	13.5	14.6
--TOTAL--				
NAT INFLOW	2934	756	888	1290
DEPLETION	-227	-102	-104	-21
CHAN STOR	-83	-35	-46	-2
EVAPORATION	116	116		
STORAGE	43151	43032	43146	43646
SYSTEM POWER				
AVE POWER MW		692	790	783
PEAK POW MW		1993	2016	2034
ENERGY GWH	1629.0	515.0	587.8	526.2
DAILY GWH		16.6	19.0	18.8
	INI-SUM	31DEC	31JAN	28FEB

	30NOV02	31DEC	2002	
	INI-SUM		31JAN	28FEB
-- FORT PECK--				
NAT INFLOW	768	224	252	292
DEPLETION	-96	83	-19	6
EVAPORATION	51	51		
MOD INFLOW	813	256	271	286
RELEASE	1745	615	603	528
STOR CHANGE	-932	-359	-332	-242
STORAGE	11715	11356	11025	10783
ELEV FTMSL	2216.8	2214.7	2212.8	2211.3
DISCH KCFS	5.6	10.0	9.8	9.5
POWER				
AVE POWER MW		126	123	118
PEAK POW MW		144	142	141
ENERGY GWH	264.8	93.8	91.4	79.6
-- GARRISON--				
NAT INFLOW	672	176	208	288
DEPLETION	-50	-39	-14	3
CHAN STOR	-41	-46	2	3
EVAPORATION	58	58		
REG INFLOW	2368	726	827	816
RELEASE	3832	1230	1353	1250
STOR CHANGE	-1464	-504	-526	-434
STORAGE	14442	13938	13412	12978
ELEV FTMSL	1824.6	1822.6	1820.5	1818.8
DISCH KCFS	18.0	20.0	22.0	22.5
POWER				
AVE POWER MW		228	247	249
PEAK POW MW		334	328	323
ENERGY GWH	520.6	169.5	183.7	167.4
-- OAHE--				
NAT INFLOW	80		8	72
DEPLETION	61	13	18	30
CHAN STOR	-22	-10	-10	-2
EVAPORATION	51	51		
REG INFLOW	3778	1156	1333	1289
RELEASE	2699	822	956	920
STOR CHANGE	1079	333	376	369
STORAGE	12495	12828	13205	13574
ELEV FTMSL	1583.6	1585.0	1586.7	1588.2
DISCH KCFS	23.5	13.4	15.6	16.6
POWER				
AVE POWER MW		152	179	192
PEAK POW MW		595	604	612
ENERGY GWH	375.3	113.3	132.9	129.0
-- BIG BEND--				
EVAPORATION	14	14		
REG INFLOW	2685	808	956	920
RELEASE	2715	838	956	920
STORAGE	1712	1682	1682	1682
ELEV FTMSL	1420.5	1420.0	1420.0	1420.0
DISCH KCFS	21.2	13.6	15.6	16.6
POWER				
AVE POWER MW		69	77	79
PEAK POW MW		538	538	529
ENERGY GWH	161.4	51.1	56.9	53.4
-- FORT RANDALL--				
NAT INFLOW	72	16	16	40
DEPLETION	9	3	3	3
EVAPORATION	13	13		
REG INFLOW	2765	838	969	957
RELEASE	2016	713	719	583
STOR CHANGE	749	125	250	374
STORAGE	2375	2500	2750	3124
ELEV FTMSL	1338.9	1341.0	1344.8	1350.0
DISCH KCFS	22.9	11.6	11.7	10.5
POWER				
AVE POWER MW		87	90	84
PEAK POW MW		300	317	338
ENERGY GWH	187.3	64.4	66.7	56.3
-- GAVINS POINT--				
NAT INFLOW	244	64	80	100
DEPLETION	11	10	1	
CHAN STOR	23	21	0	2
EVAPORATION	5	5		
REG INFLOW	2266	783	798	685
RELEASE	2320	798	798	724
STOR CHANGE	-54	-15		-39
STORAGE	412	397	397	358
ELEV FTMSL	1208.0	1207.5	1207.5	1206.0
DISCH KCFS	24.2	13.0	13.0	13.0
POWER				
AVE POWER MW		46	46	46
PEAK POW MW		78	78	76
ENERGY GWH	99.6	34.4	34.3	30.9
-- GAVINS POINT - SIOUX CITY--				
NAT INFLOW	120	24	28	68
DEPLETION	36	11	12	13
REGULATED FLOW AT SIOUX CITY				
KAF	2404	811	814	779
KCFS		13.2	13.2	14.0
-- TOTAL--				
NAT INFLOW	1956	504	592	860
DEPLETION	-29	-85	1	55
CHAN STOR	-41	-36	-8	3
EVAPORATION	192	192		
STORAGE	43151	42701	42470	42499
SYSTEM POWER				
AVE POWER MW		708	761	769
PEAK POW MW		1989	2007	2018
ENERGY GWH	1609.0	526.5	565.9	516.6
DAILY GWH		17.0	18.3	18.5
INI-SUM		31DEC	31JAN	28FEB

DATE OF STUDY 01/10/03

2002-2003 AOP UPPER QUARTILE RUNOFF SIMULATION 99001 9901 9901 PAGE 1

TIME OF STUDY 09:56:43

CWCP, STEADY RELEASE VALUES IN 1000 AF EXCEPT AS INDICATED

STUDY NO 5

	28FEB03	15MAR	2003	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	2004	30NOV	31DEC	31JAN	29FEB	
	INI-SUM		22MAR										2004					
-- FORT PECK--																		
NAT INFLOW	8901	296	138	178	739	1487	2309	1130	423	351	492	195	91	104	321	276	371	
DEPLETION	215	-31	-15	-19	69	291	489	139	-95	-105	-73	-27	-12	-14	-125	-150	-107	
EVAPORATION	330							19	62	79	69	32	15	17	37			
MOD INFLOW	8356	328	153	196	670	1196	1820	972	456	377	496	190	89	101	409	426	478	
RELEASE	4869	179	56	71	238	369	536	553	553	303	259	125	58	95	492	523	489	
STOR CHANGE	3487	179	97	125	432	827	1284	418	-98	75	237	65	30	6	-83	-97	-11	
STORAGE	11113	11292	11389	11514	11946	12773	14058	14476	14378	14453	14690	14754	14784	14790	14707	14611	14600	
ELEV FTMSL	2213.3	2214.3	2214.9	2215.6	2218.1	2222.7	2229.4	2231.5	2231.0	2231.4	2232.5	2232.8	2233.0	2233.0	2232.6	2232.2	2232.1	
DISCH KCFS	13.0	5.0	4.0	4.0	4.0	6.0	9.0	9.0	9.0	5.1	4.2	4.2	4.2	6.0	8.0	8.5	8.5	
POWER																		
AVE POWER MW		63	51	51	51	78	120	121	122	69	57	57	57	82	109	115	115	
PEAK POW MW		144	145	145	148	153	159	160	160	160	161	161	161	162	161	161	161	
ENERGY GWH	788.8	22.7	8.5	11.0	36.9	58.1	86.1	90.2	90.5	49.6	42.5	20.6	9.6	15.7	80.8	85.8	80.2	
-- GARRISON--																		
NAT INFLOW	12901	482	225	289	1250	1723	3207	2405	764	522	593	236	110	126	260	316	394	
DEPLETION	1206	34	16	20	9	310	907	514	51	-121	-2	-94	-44	-50	-138	-120	-87	
CHAN STOR	48	85	11			-21	-31			39	9			-18	-20	-5	0	
EVAPORATION	354							21	68	85	74	34	16	18	39			
REG INFLOW	16258	682	275	340	1479	1761	2804	2423	1199	900	788	421	197	235	831	954	970	
RELEASE	13890	476	208	268	1071	1261	1339	1353	1322	1015	827	400	187	286	1230	1383	1265	
STOR CHANGE	2368	206	67	72	408	500	1465	1071	-123	-116	-38	21	10	-51	-399	-430	-296	
STORAGE	13366	13572	13639	13711	14119	14619	16085	17155	17032	16916	16878	16899	16909	16858	16459	16029	15734	
ELEV FTMSL	1820.4	1821.2	1821.4	1821.7	1823.3	1825.2	1830.6	1834.3	1833.9	1833.5	1833.4	1833.4	1833.5	1833.3	1831.9	1830.4	1829.3	
DISCH KCFS	24.0	16.0	15.0	15.0	18.0	20.5	22.5	22.0	21.5	17.1	13.4	13.4	13.4	18.0	20.0	22.5	22.0	
POWER																		
AVE POWER MW		179	169	169	204	235	263	265	262	208	164	164	164	219	242	269	261	
PEAK POW MW		330	331	331	336	342	357	368	367	366	365	366	366	365	361	357	354	
ENERGY GWH	1995.1	64.5	28.4	36.5	146.8	174.5	189.7	197.4	195.1	149.9	122.1	59.1	27.6	42.0	179.9	200.2	181.6	
-- OAHE--																		
NAT INFLOW	3200	460	214	276	394	285	749	246	103	135	85	91	42	48	18	5	49	
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2	1	1	11	15	25	
CHAN STOR	11	38	5	0	-14	-11	-9	2	2	19	16	0		-20	-9	-11	2	
EVAPORATION	340							21	66	82	71	32	15	17	37			
REG INFLOW	16192	952	417	530	1406	1472	1959	1442	1271	1065	864	457	213	296	1191	1363	1292	
RELEASE	12927	434	70	249	792	1140	1228	1477	1541	1430	933	451	209	198	1093	948	734	
STOR CHANGE	3264	518	347	282	614	332	731	-35	-269	-365	-69	6	5	98	98	414	557	
STORAGE	14003	14521	14868	15150	15764	16096	16827	16792	16522	16158	16089	16095	16099	16198	16296	16710	17267	
ELEV FTMSL	1590.0	1592.1	1593.5	1594.5	1596.9	1598.1	1600.7	1600.6	1599.7	1598.3	1598.1	1598.1	1598.1	1598.5	1598.8	1600.3	1602.3	
DISCH KCFS	15.2	14.6	5.1	13.9	13.3	18.5	20.6	24.0	25.1	24.0	15.2	15.2	15.0	12.5	17.8	15.4	12.8	
POWER																		
AVE POWER MW		173	61	168	162	227	255	299	311	296	187	187	185	154	219	191	160	
PEAK POW MW		631	638	643	655	661	675	674	669	662	661	661	661	663	665	672	683	
ENERGY GWH	1928.7	62.2	10.2	36.2	116.5	169.1	183.9	222.5	231.3	213.3	139.0	67.2	31.1	29.5	163.1	142.4	111.4	
-- BIG BEND--																		
EVAPORATION	78							5	15	19	16	7	3	4	9			
REG INFLOW	12850	434	70	249	792	1140	1228	1473	1526	1411	916	444	205	194	1084	948	734	
RELEASE	12850	434	70	249	792	1140	1228	1473	1526	1411	916	444	205	194	1084	948	734	
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	
DISCH KCFS	15.2	14.6	5.1	13.9	13.3	18.5	20.6	23.9	24.8	23.7	14.9	14.9	14.8	12.2	17.6	15.4	12.8	
POWER																		
AVE POWER MW		68	24	65	62	87	97	112	116	112	73	75	75	62	87	75	61	
PEAK POW MW		510	509	509	509	509	509	509	509	517	538	538	538	538	538	538	529	
ENERGY GWH	741.9	24.6	4.0	14.1	44.9	64.6	69.6	83.4	86.4	80.9	54.5	27.0	12.5	11.8	64.8	56.0	42.7	
-- FORT RANDALL--																		
NAT INFLOW	1200	142	66	85	239	150	195	89	65	64	38	3	1	1	18	5	39	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3	
EVAPORATION	88							6	19	24	19	7	3	3	8			
REG INFLOW	13882	575	136	333	1027	1281	1411	1538	1557	1444	935	438	203	192	1092	950	770	
RELEASE	13882	167	119	333	1027	1281	1411	1538	1557	1588	1565	748	349	213	726	713	546	
STOR CHANGE	0	408	17					0	-144	-630	-310	-147	-22	366	237	224		
STORAGE	3124	3532	3549	3549	3549	3549	3549	3549	3549	3405	2775	2465	2319	2297	2663	2900	3124	
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.2	1340.4	1337.9	1337.5	1343.5	1347.0	1350.0	
DISCH KCFS	9.5	5.6	8.5	18.6	17.3	20.8	23.7	25.0	25.3	26.7	25.4	25.1	25.2	13.4	11.8	11.6	9.5	
POWER																		
AVE POWER MW		47	73	158	146	176	200	211	213	223	204	190	184	98	88	91	77	
PEAK POW MW		354	355	355	355	355	355	355	355	349	318	297	285	284	311	327	338	
ENERGY GWH	1376.4	16.9	12.2	34.1	105.3	131.0	144.0	156.8	158.7	160.7	151.9	68.6	31.0	18.8	65.8	67.5	53.3	
-- GAVINS POINT--																		
NAT INFLOW	1899	93	44	56	207	257	237	178	144	114	132	51	24	27	86	89	161	
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1		
CHAN STOR	-1	7	-6	-19	3	-7	-6	-2	-1	-3	2	1	0	22	3	0	4	
EVAPORATION	28							2	5	7	6	3	1	1	3			
REG INFLOW	15637	268	157	370	1232	1513	1619	1672	1685	1698	1691	791	369	258	801	802	711	
RELEASE	15637	268	157	370	1232	1513	1619	1672	1672	1672	1691	791	369	258	801	802	750	
STOR CHANGE								13	26								-39	

DATE OF STUDY 01/10/03

2002-2003 AOP LOWER QUARTILE RUNOFF SIMULATION 99001 9901 9901 PAGE 1

TIME OF STUDY 09:49:35

CWCP, STEADY RELEASE, 5-DAY SHORTENED SEASON VALUES IN 1000 AF EXCEPT AS INDICATED STUDY NO 7

	28FEB03	15MAR	2003	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	2004	30NOV	31DEC	31JAN	29FEB	
	INI-SUM		22MAR										2004					
--FORT PECK--																		
NAT INFLOW	6000	242	113	145	525	925	1454	633	263	252	324	167	78	89	295	212	283	
DEPLETION	114	15	7	9	73	206	171	173	-25	-91	-61	-28	-13	-15	-102	-117	-88	
EVAPORATION	456							28	88	109	95	43	20	23	49			
MOD INFLOW	5430	227	106	136	452	719	1283	432	200	234	290	152	71	81	348	329	371	
RELEASE	5899	149	69	89	357	461	595	615	615	375	265	128	97	127	615	707	633	
STOR CHANGE	-468	78	36	47	95	258	688	-183	-415	-142	24	23	-26	-46	-267	-378	-262	
STORAGE	10783	10861	10898	10945	11040	11298	11986	11802	11388	11246	11271	11294	11268	11222	10955	10576	10315	
ELEV FTMSL	2211.3	2211.8	2212.0	2212.3	2212.8	2214.4	2218.3	2217.3	2214.9	2214.1	2214.2	2214.3	2214.2	2213.9	2212.3	2210.1	2208.5	
DISCH KCFS	9.5	5.0	5.0	5.0	6.0	7.5	10.0	10.0	10.0	6.3	4.3	4.3	7.0	8.0	10.0	11.5	11.0	
POWER																		
AVE POWER MW		62	63	63	75	94	127	128	126	80	55	55	88	101	124	136	131	
PEAK POW MW		141	141	142	142	144	149	147	145	144	144	144	144	144	142	139	137	
ENERGY GWH	887.7	22.5	10.5	13.5	54.2	70.2	91.1	94.9	94.0	57.5	40.6	19.7	14.9	19.4	92.5	101.4	90.8	
--GARRISON--																		
NAT INFLOW	9400	443	207	266	712	1197	2521	1765	496	417	400	164	76	87	222	165	262	
DEPLETION	1276	24	11	15	58	133	547	446	93	-61	73	-49	-23	-26	-6	13	27	
CHAN STOR	-16	48			-11	-16	-27			39	21		-28	-11	-21	-16	5	
EVAPORATION	534									129	112	50	23	27	57			
REG INFLOW	13473	616	265	341	1000	1509	2542	1901	914	763	502	290	145	203	765	843	873	
RELEASE	14040	476	208	268	1041	1291	1398	1414	1383	897	751	363	236	286	1230	1445	1352	
STOR CHANGE	-567	140	57	73	-41	218	1144	487	-469	-134	-249	-73	92	-83	-465	-602	-479	
STORAGE	12978	13118	13175	13248	13207	13425	14569	15056	14586	14452	14204	14131	14039	13956	13491	12889	12411	
ELEV FTMSL	1818.8	1819.4	1819.6	1819.9	1819.7	1820.6	1825.0	1826.9	1825.1	1824.6	1823.6	1823.4	1823.0	1822.7	1820.9	1818.4	1816.5	
DISCH KCFS	22.5	16.0	15.0	15.0	17.5	21.0	23.5	23.0	22.5	15.1	12.2	12.2	17.0	18.0	20.0	23.5	23.5	
POWER																		
AVE POWER MW		177	167	167	195	234	266	266	260	174	140	140	194	204	225	260	256	
PEAK POW MW		324	325	326	326	328	341	346	341	340	337	336	335	334	329	322	316	
ENERGY GWH	1914.9	63.8	28.0	36.1	140.1	173.7	191.3	197.7	193.5	125.2	104.4	50.3	32.5	39.2	167.4	193.4	178.2	
--OAHE--																		
NAT INFLOW	1449	154	72	92	229	130	577	102	24	65	9				-35	-6	36	
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2	1	1	11	15	25	
CHAN STOR	-6	31	5	0	-12	-17	-12	2	2	37	14				-10	-18		
EVAPORATION	461							30	91	111	95	42	20	23	49			
REG INFLOW	14452	639	275	347	1213	1343	1843	1351	1229	865	686	319	191	257	1124	1406	1363	
RELEASE	15034	373	251	369	1237	1550	1552	1818	1818	1345	993	449	223	116	1147	1012	781	
STOR CHANGE	-582	266	24	-22	-23	-208	291	-467	-589	-480	-307	-129	-32	141	-23	394	582	
STORAGE	13574	13840	13863	13842	13818	13611	13902	13435	12846	12366	12059	11930	11898	12039	12016	12410	12992	
ELEV FTMSL	1588.2	1589.3	1589.4	1589.3	1589.2	1588.4	1589.6	1587.6	1585.1	1583.0	1581.6	1581.0	1580.9	1581.5	1581.4	1583.2	1585.8	
DISCH KCFS	16.6	12.6	18.1	20.7	20.8	25.2	26.1	29.6	29.6	22.6	16.2	15.1	16.1	7.3	18.7	16.5	13.6	
POWER																		
AVE POWER MW		147	212	242	243	294	304	343	339	256	182	169	179	82	209	185	155	
PEAK POW MW		618	618	618	617	613	619	609	596	585	577	574	573	577	576	586	599	
ENERGY GWH	2087.0	52.8	35.6	52.2	175.0	218.4	218.8	255.4	252.1	184.5	135.1	60.7	30.1	15.8	155.2	137.6	107.7	
--BIG BEND--																		
EVAPORATION	129							8	24	31	27	12	6	7	14			
REG INFLOW	14905	373	251	369	1237	1550	1552	1810	1793	1314	966	436	218	110	1133	1012	781	
RELEASE	14905	373	251	369	1237	1550	1552	1810	1793	1314	966	436	218	110	1133	1012	781	
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	
DISCH KCFS	16.6	12.6	18.1	20.7	20.8	25.2	26.1	29.4	29.2	22.1	15.7	14.7	15.7	6.9	18.4	16.5	13.6	
POWER																		
AVE POWER MW		59	85	97	97	118	122	138	137	105	78	74	79	35	91	80	65	
PEAK POW MW		517	510	509	509	509	509	509	509	523	538	538	538	538	538	538	529	
ENERGY GWH	859.3	21.4	14.3	20.9	70.1	87.8	87.9	102.5	101.6	75.5	58.1	26.6	13.3	6.7	67.7	59.6	45.4	
--FORT RANDALL--																		
NAT INFLOW	500	68	32	41	64	51	130	26	49	23	1				5	-5	15	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1				3	3	3	
EVAPORATION	144							10	32	39	29	11	5	5	13			
REG INFLOW	15182	440	282	409	1297	1592	1670	1808	1796	1291	937	424	212	105	1122	1004	793	
RELEASE	15182	167	148	392	1297	1592	1670	1808	1796	1606	1571	709	230	104	756	732	604	
STOR CHANGE	0	274	134	17				0	0	-315	-634	-285	-18	0	366	272	189	
STORAGE	3124	3398	3532	3549	3549	3549	3549	3549	3549	3234	2600	2315	2297	2297	2663	2935	3124	
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.4	1342.6	1337.8	1337.5	1337.5	1343.5	1347.5	1350.0	
DISCH KCFS	10.5	5.6	10.7	21.9	21.8	25.9	28.1	29.4	29.2	27.0	25.5	23.8	16.6	6.6	12.3	11.9	10.5	
POWER																		
AVE POWER MW		47	90	185	184	218	236	247	245	224	201	177	121	48	92	93	85	
PEAK POW MW		349	354	355	355	355	355	355	355	342	306	285	284	283	311	329	338	
ENERGY GWH	1503.3	16.7	15.1	40.0	132.5	162.2	170.0	183.8	182.6	161.0	149.4	63.6	20.3	9.3	68.6	69.4	59.0	
--GAVINS POINT--																		
NAT INFLOW	1251	91	43	55	124	138	143	81	80	58	105	47	22	25	70	68	101	
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1		
CHAN STOR	-1	9	-10	-22	0	-8	-4	-3	0	4	3	3	13	19	-11	1	3	
EVAPORATION	47							3	9	11	10	5	2	2	5			
REG INFLOW	16271	268	181	425	1416	1703	1785	1845	1858	1662	1666	750	261	143	800	799	708	
RELEASE	16271	268	181	425	1416	1703	1785	1845	1858	1662	1666	750	261	143	800	799	747	
STOR CHANGE								13	26									
STORAGE	358	358	358	358</														

	28FEB06	15MAR	2006	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2007	31DEC	31JAN	28FEB
	INI-SUM		22MAR											30NOV			
--FORT PECK--																	
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349
DEPLETION	389	-2	-1	-1	56	331	556	190	-75	-143	-78	-40	-18	-21	-133	-139	-93
EVAPORATION	448							27	85	107	94	43	20	23	49		
MOD INFLOW	6563	266	124	160	572	879	1295	612	314	355	382	184	86	98	394	400	442
RELEASE	5281	179	69	89	417	492	762	492	461	324	261	125	83	127	492	492	417
STOR CHANGE	1282	88	55	70	155	387	533	120	-147	31	121	59	3	-29	-98	-92	25
STORAGE	13503	13590	13645	13716	13871	14258	14792	14912	14765	14796	14917	14976	14978	14950	14851	14760	14785
ELEV FTMSL	2226.6	2227.0	2227.3	2227.7	2228.5	2230.4	2233.0	2233.6	2232.9	2233.0	2233.6	2233.9	2233.9	2233.8	2233.3	2232.9	2233.0
DISCH KCFS	11.0	6.0	5.0	5.0	7.0	8.0	12.8	8.0	7.5	5.4	4.2	4.2	6.0	8.0	8.0	8.0	7.5
POWER																	
AVE POWER MW		80	67	67	93	107	96	109	102	74	58	57	82	109	109	108	102
PEAK POW MW		203	203	204	204	206	208	208	207	208	208	208	208	208	208	207	208
ENERGY GWH	808.3	28.7	11.2	14.4	67.3	79.8	69.0	80.8	75.7	53.2	42.9	20.6	13.7	20.9	80.8	80.7	68.3
--GARRISON--																	
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326
DEPLETION	968	-7	-3	-4	-8	214	816	569	35	-135	-8	-107	-50	-57	-119	-102	-67
CHAN STOR	35	51	10		-20	-10	-48	47	5	20	12	0	-18	-20			5
EVAPORATION	498							31	97	120	104	46	22	25	53		
REG INFLOW	14850	706	302	375	1257	1691	2855	2006	915	856	631	377	183	241	811	831	815
RELEASE	15210	476	222	286	1131	1476	1488	1506	1476	1044	971	470	219	317	1230	1537	1361
STOR CHANGE	-360	230	80	89	127	215	1368	499	-561	-189	-340	-93	-37	-76	-419	-706	-546
STORAGE	16299	16528	16608	16697	16824	17039	18407	18906	18345	18156	17816	17723	17686	17610	17191	16485	15939
ELEV FTMSL	1831.4	1832.2	1832.4	1832.7	1833.2	1833.9	1838.5	1840.0	1838.3	1837.6	1836.5	1836.2	1836.1	1835.9	1834.4	1832.0	1830.1
DISCH KCFS	24.0	16.0	16.0	16.0	19.0	24.0	25.0	24.5	24.0	17.6	15.8	15.8	15.8	20.0	20.0	25.0	24.5
POWER																	
AVE POWER MW		192	192	193	229	289	306	306	300	218	196	195	195	245	244	301	291
PEAK POW MW		447	448	449	451	453	470	476	469	467	463	462	461	460	455	446	439
ENERGY GWH	2261.9	69.0	32.3	41.6	164.8	215.3	220.6	227.8	223.0	157.2	145.7	70.2	32.7	47.1	181.7	223.7	195.3
--OAHE--																	
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20		40
DEPLETION	613	23	11	14	47	66	129	151	100	25	-8	2	1	1	11	16	26
CHAN STOR	-3	34			-12	-21	-4	2	2	8				-18	0	-22	2
EVAPORATION	463							29	91	112	96	43	20	23	49		
REG INFLOW	16432	804	359	462	1435	1625	2044	1490	1320	1053	905	431	201	278	1149	1499	1377
RELEASE	15940	582	145	349	1268	1523	1582	1872	1884	1686	1175	556	256	226	1112	939	783
STOR CHANGE	492	222	215	113	167	102	461	-382	-564	-634	-270	-126	-55	52	37	560	593
STORAGE	16978	17200	17415	17528	17694	17797	18258	17876	17312	16678	16409	16283	16228	16280	16317	16877	17470
ELEV FTMSL	1601.3	1602.0	1602.8	1603.2	1603.7	1604.1	1605.6	1604.4	1602.4	1600.2	1599.2	1598.8	1598.6	1598.8	1598.9	1600.9	1603.0
DISCH KCFS	14.6	19.5	10.4	19.5	21.3	24.8	26.6	30.4	30.6	28.3	19.1	18.7	18.5	14.3	18.1	15.3	14.1
POWER																	
AVE POWER MW		245	132	247	270	314	338	387	386	353	237	231	228	176	223	190	177
PEAK POW MW		682	685	687	690	692	701	694	684	672	667	664	663	664	665	676	686
ENERGY GWH	2422.9	88.2	22.1	53.3	194.1	233.4	243.6	288.0	287.4	254.5	176.3	83.2	38.3	33.8	166.2	141.3	119.2
--BIG BEND--																	
EVAPORATION	103							6	20	25	22	10	5	5	11		
REG INFLOW	15836	582	145	349	1268	1523	1582	1866	1864	1662	1153	546	252	221	1101	939	783
RELEASE	15836	582	145	349	1268	1523	1582	1866	1864	1662	1153	546	252	221	1101	939	783
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	14.6	19.5	10.4	19.5	21.3	24.8	26.6	30.3	30.3	27.9	18.8	18.4	18.1	13.9	17.9	15.3	14.1
POWER																	
AVE POWER MW		92	49	91	100	116	124	142	142	132	92	92	91	70	88	75	68
PEAK POW MW		510	509	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	912.5	33.0	8.2	19.8	71.9	86.2	89.6	105.6	105.6	95.3	68.5	33.2	15.3	13.5	65.8	55.5	45.5
--FORT RANDALL--																	
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	118							8	25	31	25	10	4	4	10		
REG INFLOW	16539	703	201	421	1379	1654	1755	1914	1881	1665	1130	537	248	217	1098	936	799
RELEASE	16539	295	184	421	1379	1654	1755	1914	1881	1809	1767	842	393	239	732	719	555
STOR CHANGE	0	408	17					0	0	-144	-637	-304	-145	-22	366	217	244
STORAGE	3124	3532	3549	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2680	3124
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1346.7
DISCH KCFS	10.0	9.9	13.3	23.6	23.2	26.9	29.5	31.1	30.6	30.4	28.7	28.3	28.3	15.1	11.9	11.7	10.0
POWER																	
AVE POWER MW		82	113	199	196	226	248	261	257	254	230	214	207	110	89	91	80
PEAK POW MW		354	355	355	355	355	355	355	355	349	318	297	285	284	311	326	338
ENERGY GWH	1639.4	29.7	18.9	43.0	140.8	168.4	178.4	194.3	191.1	182.5	171.0	76.9	34.8	21.1	66.4	68.0	54.0
--GAVINS POINT--																	
NAT INFLOW	1450	92	43	55	148	174	166	86	103	77	122	50	23	27	77	79	127
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	0	-6	-20	1	-7	-5	-3	1	0	3	1	0	25	6	0	
EVAPORATION	38							2	7	9	8	4	2	2	4		
REG INFLOW	17836	388	221	457	1523	1802	1892	1955	1968	1883	1882	884	412	286	800	798	686
RELEASE	17836	388	221	457	1523	1802	1892	1955	1955	1857	1882	884	412	286	800	798	686
STOR CHANGE									13								

	28FEB07	15MAR	2007 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2008 30NOV	31DEC	31JAN	29FEB
	INI-SUM																
-- FORT PECK --																	
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349
DEPLETION	410	-2	-1	-1	55	332	565	205	-66	-144	-78	-40	-18	-21	-133	-139	-104
EVAPORATION	453							28	87	109	95	43	20	23	49		
MOD INFLOW	6537	266	124	160	573	878	1286	596	303	354	381	184	86	98	394	400	453
RELEASE	7195	179	83	107	476	553	1083	646	615	549	442	208	111	159	615	707	661
STOR CHANGE	-659	88	41	53	97	325	203	-49	-312	-195	-61	-24	-25	-60	-221	-307	-208
STORAGE	14785	14873	14914	14966	15063	15388	15591	15541	15229	15034	14972	14948	14923	14863	14642	14335	14126
ELEV FTMSL	2233.0	2233.4	2233.6	2233.9	2234.3	2235.8	2236.8	2236.5	2235.1	2234.2	2233.9	2233.8	2233.7	2233.4	2232.3	2230.8	2229.8
DISCH KCFS	7.5	6.0	6.0	6.0	8.0	9.0	18.2	10.5	10.0	9.2	7.2	7.0	8.0	10.0	10.0	11.5	11.5
POWER																	
AVE POWER MW		81	82	82	109	123	56	144	137	126	98	95	109	136	135	155	154
PEAK POW MW		208	208	208	209	210	210	210	209	208	208	208	208	208	207	206	205
ENERGY GWH	1045.0	29.3	13.7	17.6	78.4	91.3	40.6	107.0	101.7	90.5	72.8	34.3	18.3	26.0	100.7	115.3	107.4
-- GARRISON --																	
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326
DEPLETION	981	-6	-3	-4	-8	214	826	585	40	-138	-12	-110	-51	-58	-119	-101	-74
CHAN STOR	-42	15			-20	-10	-93	76	5	7	20	2	-10	-20	0	-15	
EVAPORATION	523							31	100	126	110	50	23	26	57		
REG INFLOW	16650	670	305	392	1317	1752	3122	2171	1060	1066	819	462	219	273	930	1030	1061
RELEASE	14605	476	222	286	1071	1322	1428	1445	1414	1087	919	445	236	286	1230	1414	1323
STOR CHANGE	2045	194	83	107	246	430	1694	726	-354	-21	-101	17	-17	-12	-300	-384	-261
STORAGE	15939	16133	16216	16322	16568	16998	18692	19418	19064	19043	18942	18959	18942	18929	18630	18246	17984
ELEV FTMSL	1830.1	1830.8	1831.1	1831.4	1832.3	1833.8	1839.4	1841.6	1840.5	1840.5	1840.1	1840.2	1840.1	1840.1	1839.2	1837.9	1837.1
DISCH KCFS	24.5	16.0	16.0	16.0	18.0	21.5	24.0	23.5	23.0	18.3	15.0	15.0	17.0	18.0	20.0	23.0	23.0
POWER																	
AVE POWER MW		190	191	191	215	259	295	296	291	231	189	189	215	227	251	286	285
PEAK POW MW		442	443	444	447	453	473	481	477	477	476	476	476	476	472	468	465
ENERGY GWH	2190.7	68.4	32.0	41.3	155.2	192.5	212.4	220.2	216.3	166.3	140.6	68.0	36.1	43.6	186.8	213.1	198.1
-- OAHE --																	
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20	17	40
DEPLETION	626	23	11	14	47	67	132	156	103	25	-9	2	1	1	12	17	26
CHAN STOR	6	35			-8	-14	-10	2	2	20	14	2	-1	-1	-9	-13	
EVAPORATION	457							29	90	111	94	42	19	22	48		
REG INFLOW	15827	805	359	462	1380	1477	1975	1424	1256	1090	862	406	209	261	1141	1384	1337
RELEASE	16381	464	253	383	1322	1578	1630	1921	1933	1734	1224	580	268	231	1112	889	859
STOR CHANGE	-554	341	106	79	58	-101	345	-497	-677	-644	-362	-174	-58	30	28	495	478
STORAGE	17470	17811	17917	17996	18054	17953	18298	17801	17124	16479	16118	15944	15885	15915	15944	16438	16916
ELEV FTMSL	1603.0	1604.1	1604.5	1604.8	1605.0	1604.6	1605.8	1604.1	1601.8	1599.5	1598.2	1597.5	1597.3	1597.4	1599.5	1599.3	1601.0
DISCH KCFS	14.1	15.6	18.2	21.4	22.2	25.7	27.4	31.2	31.4	29.1	19.9	19.5	19.3	14.5	18.1	14.5	14.9
POWER																	
AVE POWER MW		198	232	273	283	327	349	397	395	362	246	239	236	178	222	178	186
PEAK POW MW		693	694	696	697	695	701	692	680	668	661	658	657	658	658	667	676
ENERGY GWH	2487.2	71.2	39.0	58.9	203.8	242.9	251.3	295.4	294.1	260.6	182.8	86.1	39.6	34.2	164.9	132.7	129.4
-- BIG BEND --																	
EVAPORATION	103							6	20	25	22	10	5	5	11		
REG INFLOW	16278	464	253	383	1322	1578	1630	1915	1914	1709	1202	570	263	225	1101	889	859
RELEASE	16278	464	253	383	1322	1578	1630	1915	1914	1709	1202	570	263	225	1101	889	859
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	14.1	15.6	18.2	21.4	22.2	25.7	27.4	31.1	31.1	28.7	19.6	19.2	18.9	14.2	17.9	14.5	14.9
POWER																	
AVE POWER MW		74	86	100	104	120	128	146	146	136	96	96	95	72	88	71	72
PEAK POW MW		517	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	938.1	26.6	14.4	21.7	74.9	89.4	92.3	108.4	108.4	98.0	71.4	34.6	16.0	13.8	65.8	52.7	49.9
-- FORT RANDALL --																	
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	118							8	25	31	25	10	4	4	10		
REG INFLOW	16981	585	310	455	1433	1709	1803	1963	1930	1713	1179	561	259	222	1098	886	875
RELEASE	16981	295	192	438	1433	1709	1803	1963	1930	1857	1816	865	404	244	732	719	581
STOR CHANGE	0	291	117	17	0	0	0	0	-144	-637	-304	-145	-22	366	167	294	
STORAGE	3124	3415	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2830	3124
ELEV FTMSL	1350.0	1353.6	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1346.0	1350.0
DISCH KCFS	10.0	9.9	13.9	24.5	24.1	27.8	30.3	31.9	31.4	31.2	29.5	29.1	29.1	15.4	11.9	11.7	10.1
POWER																	
AVE POWER MW		82	117	207	203	234	254	268	263	260	236	220	213	112	89	91	81
PEAK POW MW		350	354	355	355	355	355	355	355	349	318	297	285	284	311	322	338
ENERGY GWH	1682.0	29.5	19.6	44.6	146.2	173.9	183.2	199.2	196.0	187.3	175.7	79.1	35.8	21.5	66.4	67.8	56.4
-- GAVINS POINT --																	
NAT INFLOW	1450	92	43	55	148	174	166	86	103	77	122	50	23	27	77	79	127
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-2	0	-8	-20	1	-7	-5	-3	1	0	3	1	0	25	6	0	
EVAPORATION	38							2	7	9	8	4	2	2	4		
REG INFLOW	18277	388	228	473	1577	1857	1940	2005	2018	1930	1931	907	423	291	801	798	711
RELEASE	18277	388	228	473	1577	1857	1940	2005	2005	1904	1931	907	423	291	801	798	750
STOR CHANGE																	

	29FEB08	15MAR	2008	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2009	31DEC	31JAN	28FEB	
	INI-SUM		22MAR											30NOV				
-- FORT PECK --																		
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349	
DEPLETION	422	-2	-1	-1	55	333	569	212	-62	-144	-82	-42	-19	-22	-136	-141	-95	
EVAPORATION	436							27	84	104	91	-41	19	22	47			
REG INFLOW	6542	266	124	160	573	877	1282	590	302	359	389	188	88	100	399	402	444	
RELEASE	7242	179	69	89	417	615	833	830	799	536	356	172	80	159	615	799	694	
STOR CHANGE	-700	88	55	70	156	262	449	-240	-498	-177	33	16	7	-58	-216	-397	-250	
STORAGE	14126	14214	14269	14339	14496	14758	15207	14966	14469	14292	14325	14341	14348	14289	14073	13676	13426	
ELEV FTMSL	2229.8	2230.2	2230.5	2230.8	2231.6	2232.9	2235.0	2233.9	2231.5	2230.6	2230.8	2230.8	2230.9	2230.6	2229.5	2227.5	2226.2	
DISCH KCFS	11.5	6.0	5.0	5.0	7.0	10.0	14.0	13.5	13.0	9.0	5.8	5.8	5.8	10.0	10.0	13.0	12.5	
POWER																		
AVE POWER MW		81	67	67	94	135	187	182	175	121	78	78	78	134	134	173	166	
PEAK POW MW		206	206	206	207	207	209	208	206	206	206	206	206	206	205	203	202	
ENERGY GWH	1176.2	29.0	11.3	14.6	68.0	100.5	134.8	135.3	130.3	87.3	58.0	28.1	13.1	25.8	99.8	128.7	111.4	
-- GARRISON --																		
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326	
DEPLETION	1205	-6	-3	-3	-6	215	836	601	46	-141	-17	-89	-41	-47	-69	-50	-21	
CHAN STOR	-11	55	10		-20	-30	-39	5	5	39	31	0	0	-42	0	-30	5	
EVAPORATION	529							33	104	129	111	49	23	26	55			
REG INFLOW	16498	708	301	374	1256	1793	2916	2267	1235	1083	748	403	188	241	882	1057	1046	
RELEASE	17352	536	250	321	1250	1537	1696	1722	1691	1454	1352	654	305	317	1230	1537	1500	
STOR CHANGE	-853	173	51	53	6	256	1220	545	-456	-371	605	-251	-117	-77	-348	-481	-453	
STORAGE	17984	18157	18208	18261	18267	18523	19743	20289	19833	19462	18857	18606	18489	18413	18065	17584	17131	
ELEV FTMSL	1837.1	1837.7	1837.8	1838.0	1838.0	1838.8	1842.6	1844.2	1842.9	1841.7	1839.9	1839.1	1838.7	1838.5	1837.4	1835.8	1834.2	
DISCH KCFS	23.0	18.0	18.0	21.0	25.0	28.5	28.0	27.5	24.4	22.0	22.0	22.0	20.0	20.0	25.0	27.0		
POWER																		
AVE POWER MW		223	224	224	261	311	358	356	350	310	278	275	275	249	248	307	328	
PEAK POW MW		467	467	468	468	471	488	499	490	481	475	472	471	470	466	460	454	
ENERGY GWH	2625.6	80.3	37.6	48.4	187.9	231.2	258.1	265.1	260.6	222.9	206.7	99.2	46.1	47.9	184.9	228.5	220.5	
-- OAHE --																		
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20		40	
DEPLETION	641	23	11	14	48	68	135	160	106	26	-9	2	1	1	12	17	27	
CHAN STOR	-16	21			-12	-16	-14	2	2	13	10	0	0	8	0	-21	-8	
EVAPORATION	479							30	92	115	100	45	21	24	52			
REG INFLOW	18516	850	387	497	1553	1689	2236	1696	1528	1444	1286	613	286	303	1145	1499	1504	
RELEASE	16618	498	221	386	1334	1609	1666	1958	1970	1770	1261	598	276	236	1115	861	861	
STOR CHANGE	1898	353	166	111	219	79	570	-262	-442	-326	25	15	10	68	30	638	644	
STORAGE	16916	17269	17435	17546	17765	17845	18415	18153	17710	17385	17409	17424	17434	17502	17532	18170	18814	
ELEV FTMSL	1601.0	1602.3	1602.8	1603.2	1604.0	1604.2	1606.1	1605.3	1603.8	1602.7	1602.8	1602.8	1602.8	1603.1	1603.2	1605.3	1607.4	
DISCH KCFS	14.9	16.7	15.9	21.6	22.4	26.2	28.0	31.8	32.0	29.7	20.5	20.1	19.9	14.9	18.1	14.0	15.5	
POWER																		
AVE POWER MW		210	200	273	284	332	357	406	406	375	258	253	251	188	229	178	200	
PEAK POW MW		683	686	688	692	693	703	699	691	685	685	686	686	687	688	699	710	
ENERGY GWH	2549.6	75.5	33.7	58.9	204.3	246.8	256.8	302.3	302.3	269.8	192.3	91.2	42.1	36.1	170.6	132.7	134.1	
-- BIG BEND --																		
EVAPORATION	103							6	20	25	22	10	5	5	11			
REG INFLOW	16515	498	221	386	1334	1609	1666	1952	1950	1745	1239	588	271	230	1104	861	861	
RELEASE	16515	498	221	386	1334	1609	1666	1952	1950	1745	1239	588	271	230	1104	861	861	
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	
DISCH KCFS	14.9	16.7	15.9	21.6	22.4	26.2	28.0	31.7	31.7	29.3	20.2	19.8	19.5	14.5	18.0	14.0	15.5	
POWER																		
AVE POWER MW		79	75	101	105	123	131	149	148	139	99	99	98	73	89	69	74	
PEAK POW MW		515	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529	
ENERGY GWH	951.7	28.4	12.5	21.9	75.6	91.2	94.3	110.5	110.4	100.0	73.5	35.7	16.5	14.1	66.0	51.1	50.0	
-- FORT RANDALL --																		
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	0	0	1	3	3	3	
EVAPORATION	118							8	25	31	25	10	4	4	10			
REG INFLOW	17218	619	277	459	1445	1740	1839	2000	1967	1749	1216	579	268	227	1101	858	877	
RELEASE	17218	293	194	442	1445	1740	1839	2000	1967	1893	1853	883	413	249	735	721	553	
STOR CHANGE	0	325	83	17				0	0	-144	-637	-304	-145	-22	366	137	324	
STORAGE	3124	3449	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2800	3124	
ELEV FTMSL	1350.0	1354.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1345.6	1350.0	
DISCH KCFS	10.1	9.9	14.0	24.7	24.3	28.3	30.9	32.5	32.0	31.8	30.1	29.7	29.7	15.7	12.0	11.7	10.0	
POWER																		
AVE POWER MW		82	118	208	205	238	259	273	268	265	241	224	217	114	90	91	80	
PEAK POW MW		351	354	355	355	355	355	355	355	349	318	297	285	284	311	320	338	
ENERGY GWH	1705.1	29.5	19.8	45.0	147.4	177.1	186.7	202.9	199.7	190.8	179.2	80.7	36.5	21.9	66.6	67.8	53.5	
-- GAVINS POINT --																		
NAT INFLOW	1450	92	43	55	148	174	166	86	103	77	122	50	23	27	77	79	127	
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1		
CHAN STOR	-1	0	-8	-21	1	-8	-5	-3	1	0	3	1	0	26	7	0	3	
EVAPORATION	38							2	7	9	8	4	2	2	4			
REG INFLOW	18515	387	230	477	1589	1888	1976	2041	2054	1966	1968	925	432	297	804	799	683	
RELEASE	18515	387	230	477	1589	1888	1976	2041	2041	1940	1968	925	432	297	804	799	722	
STOR CHANGE																		

	29FEB04	15MAR	2004	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2005	31DEC	31JAN	28FEB
	INI-SUM		22MAR											30NOV			
-- FORT PECK--																	
NAT INFLOW	6556	264	123	158	574	1011	1589	692	287	275	354	183	85	98	322	231	309
DEPLETION	345	3	2	2	74	295	438	167	-60	-130	-68	-32	-15	-17	-110	-121	-83
EVAPORATION	451							28	86	108	94	43	20	23	49		
MOD INFLOW	5760	261	122	156	500	716	1151	497	261	297	328	172	80	92	383	352	392
RELEASE	5557	134	62	80	417	492	565	553	328	275	133	63	143	143	615	615	528
STOR CHANGE	203	127	59	76	83	224	586	-56	-293	-31	52	39	17	-51	-232	-263	-136
STORAGE	10315	10442	10501	10577	10661	10885	11470	11414	11122	11091	11143	11182	11199	11148	10916	10653	10518
ELEV FTMSL	2208.5	2209.2	2209.6	2210.1	2210.6	2211.9	2215.4	2215.0	2213.3	2213.1	2213.5	2213.7	2213.8	2213.5	2212.1	2210.5	2209.7
DISCH KCFS	11.0	4.5	4.5	4.5	7.0	8.0	9.5	9.0	9.0	5.5	4.5	4.5	4.6	9.0	10.0	10.0	9.5
POWER																	
AVE POWER MW		55	55	56	86	99	119	114	113	69	56	56	58	113	125	124	117
PEAK POW MW		182	182	183	183	185	190	189	187	187	187	187	188	187	185	183	182
ENERGY GWH	837.7	19.9	9.3	12.0	62.2	73.7	85.6	84.5	84.1	49.7	41.8	20.3	9.7	21.6	92.7	92.0	78.5
-- GARRISON--																	
NAT INFLOW	10069	475	221	285	763	1282	2701	1891	532	446	428	175	82	93	238	177	280
DEPLETION	1463	45	21	27	84	234	815	571	57	-105	25	-81	-38	-43	-69	-52	-28
CHAN STOR	16	70			-27	-11	-16	5	37	11	0	-1	-47	-11			5
EVAPORATION	527							32	101	127	110	50	23	27	57		
REG INFLOW	13652	635	263	338	1069	1529	2435	1847	927	789	579	339	158	206	854	844	841
RELEASE	13404	476	222	286	1071	1230	1309	1322	1291	898	722	349	167	286	1230	1353	1194
STOR CHANGE	248	159	41	53	-3	299	1126	525	-364	-109	-143	-10	-8	-80	-376	-509	-353
STORAGE	12411	12569	12610	12663	12661	12960	14086	14611	14246	14137	13994	13984	13976	13896	13521	13012	12659
ELEV FTMSL	1816.5	1817.1	1817.3	1817.5	1817.5	1818.7	1823.2	1825.2	1823.8	1823.4	1822.8	1822.8	1822.8	1822.5	1821.0	1818.9	1817.5
DISCH KCFS	23.5	16.0	16.0	16.0	18.0	20.0	22.0	21.5	21.0	15.1	11.7	11.7	12.0	18.0	20.0	22.0	21.5
POWER																	
AVE POWER MW		174	175	175	197	219	246	246	241	172	134	137	137	204	225	244	236
PEAK POW MW		318	318	319	319	323	336	342	337	336	335	334	334	333	329	323	319
ENERGY GWH	1815.4	62.8	29.4	37.8	141.8	163.2	177.0	182.8	179.0	124.2	99.7	48.2	23.0	39.2	167.3	181.6	158.4
-- OAHE--																	
NAT INFLOW	1761	187	87	112	278	158	701	124	29	79	11				-42	-7	44
DEPLETION	585	22	10	13	46	64	123	143	93	23	-8				11	16	25
CHAN STOR	10	37			-10	-10	-10	2	2	29	17	2	1	-1	-30	-10	2
EVAPORATION	466							30	91	112	96	43	20	23	51		
REG INFLOW	14124	678	299	384	1293	1314	1877	1276	1139	871	661	304	144	231	1116	1320	1216
RELEASE	13870	348	239	353	1211	1456	1385	1682	1676	1306	736	343	110	135	1140	852	900
STOR CHANGE	254	329	60	31	83	-142	493	-406	-537	-434	-74	-38	35	97	-24	468	315
STORAGE	12992	13321	13381	13412	13495	13353	13845	13439	12902	12468	12393	12355	12390	12486	12462	12930	13246
ELEV FTMSL	1585.8	1587.2	1587.4	1587.6	1587.9	1587.3	1589.3	1587.7	1585.4	1583.5	1583.1	1582.9	1583.1	1582.9	1583.4	1585.5	1586.8
DISCH KCFS	13.6	11.7	17.2	19.8	20.3	23.7	23.3	27.4	27.3	21.9	12.0	11.5	7.9	8.5	18.5	13.8	16.2
POWER																	
AVE POWER MW		135	199	229	236	274	270	318	313	249	136	130	89	96	210	158	186
PEAK POW MW		607	608	609	610	607	618	609	597	587	585	584	585	587	587	598	605
ENERGY GWH	1928.6	48.6	33.4	49.5	169.8	203.9	194.7	236.3	232.8	179.5	100.8	46.9	15.0	18.5	156.1	117.5	125.3
-- BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	13741	348	239	353	1211	1456	1385	1674	1651	1275	709	330	104	128	1126	852	900
RELEASE	13741	348	239	353	1211	1456	1385	1674	1651	1275	709	330	104	128	1126	852	900
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	13.6	11.7	17.2	19.8	20.3	23.7	23.3	27.2	26.9	21.4	11.5	11.1	7.5	8.1	18.3	13.8	16.2
POWER																	
AVE POWER MW		55	81	93	95	111	109	127	126	102	58	56	38	41	90	68	78
PEAK POW MW		517	510	509	509	509	509	509	509	525	538	538	538	538	538	538	529
ENERGY GWH	792.8	20.0	13.6	20.0	68.6	82.5	78.4	94.8	93.5	73.5	43.3	20.2	6.4	7.9	67.3	50.7	52.3
-- FORT RANDALL--																	
NAT INFLOW	643	88	41	53	82	66	167	33	63	30	2				6	-6	19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	141							10	32	38	27	10	5	5	13		
REG INFLOW	14159	434	279	405	1289	1513	1540	1679	1668	1259	677	319	99	122	1116	843	916
RELEASE	14160	161	145	388	1289	1513	1540	1679	1668	1606	1564	338	99	122	750	726	572
STOR CHANGE	-1	274	134	17				0	0	-347	-886	-19	0	0	366	117	344
STORAGE	3124	3398	3532	3549	3549	3549	3549	3549	3549	3202	2315	2296	2296	2296	2662	2779	3123
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.0	1337.8	1337.5	1337.5	1337.5	1343.5	1345.3	1350.0
DISCH KCFS	10.5	5.4	10.4	21.7	21.7	24.6	25.9	27.3	27.1	27.0	25.4	11.4	7.1	7.7	12.2	11.8	10.3
POWER																	
AVE POWER MW		45	88	183	183	207	218	230	228	223	195	83	52	56	91	92	82
PEAK POW MW		349	354	355	355	355	355	355	355	341	284	283	283	283	311	319	338
ENERGY GWH	1401.3	16.1	14.8	39.6	131.7	154.3	156.9	170.9	169.8	160.8	145.4	29.9	8.8	10.8	68.0	68.1	55.3
-- GAVINS POINT--																	
NAT INFLOW	1335	98	46	59	132	147	153	87	85	62	112	50	23	27	75	73	107
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	10	-10	-22	0	-6	-2	-3	0	0	3	26	8	-1	-8	1	
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15333	269	181	425	1416	1636	1666	1722	1735	1662	1666	405	126	143	802	798	682
RELEASE	15333	269	181	425	1416	1636	1666	1722	1722	1636	1666	405	126	143	802	798	682
STOR CHANGE								13	26								
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	-39
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	26.6	28.0	28.0	28.0	27.5	27.1	13.6	9.1	9.0	13.0	13.0	13.0
POWER																	
AVE POWER MW		32	46	82	82	91	95	95	96	95	95	48	32	32	46	46	46
PEAK POW MW		114	114	114	114	114	114	114	115	117	117	117	117	117	78	78	76
ENERGY GWH	641.6	11.4	7.7	17.6	58.7	67.5	68.6	70.9	71.3	68.7	70.6	17.4	5.4	6.2	34.4	34.3	30.7
-- GAVINS POINT - SIOUX CITY--																	
NAT INFLOW	1135	145	68	87	113	219	158	95	70	44	31	16	7	9	16	-3	60
DEPLETION	247	6	3	4	20	34	30	36	34	22	9	6	3	3	12	13	13
REGULATED FLOW AT SIOUX CITY	16221	408	246	509	1509	1821	1794	1781	1758	1658	1688	415	131	1			

	28FEB05 INI-SUM	15MAR	2005 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2006 30NOV	31DEC	31JAN	28FEB
-- FORT PECK --																	
NAT INFLOW	6613	267	124	160	579	1019	1603	698	289	278	357	185	86	98	325	233	312
DEPLETION	387	-11	-5	-6	50	311	513	174	-57	-131	-72	-33	-15	-17	-110	-121	-83
EVAPORATION	457							28	87	109	96	43	20	23	50		
REG INFLOW	5769	277	129	166	529	708	1090	496	259	300	333	174	81	93	385	354	395
RELEASE	5372	134	62	80	417	492	565	584	553	274	264	124	58	127	553	584	500
STOR CHANGE	398	143	67	86	112	216	525	-88	-294	26	69	50	23	-34	-168	230	-105
STORAGE	10518	10661	10728	10814	10926	11143	11667	11579	11285	11311	11380	11431	11453	11419	11250	11020	10915
ELEV FTMSL	2209.7	2210.6	2211.0	2211.5	2212.2	2213.4	2216.5	2216.0	2214.3	2214.4	2214.8	2215.1	2215.3	2215.1	2214.1	2212.7	2212.1
DISCH KCFS	9.5	4.5	4.5	4.5	7.0	8.0	9.5	9.5	9.0	4.6	4.3	4.2	4.2	8.0	9.0	9.5	9.0
POWER																	
AVE POWER MW		56	56	56	87	100	120	120	114	58	54	53	53	101	113	119	112
PEAK POW MW		183	184	185	185	187	191	191	188	188	189	189	190	189	188	186	185
ENERGY GWH	816.0	20.0	9.4	12.1	62.7	74.3	86.2	89.6	84.5	41.8	40.4	18.9	8.9	19.4	84.2	88.4	75.3
-- GARRISON --																	
NAT INFLOW	10134	478	223	287	768	1290	2718	1903	535	449	431	176	82	94	240	178	282
DEPLETION	983	14	7	8	28	202	732	491	55	-103	-1	-100	-46	-53	-105	-87	-59
CHAN STOR	5	54							5	46	3	1	-1	-40	-10	-5	5
EVAPORATION	542								33	105	131	114	51	24	27	58	
REG INFLOW	13986	652	279	359	1130	1569	2535	1963	934	741	586	349	163	207	830	844	846
RELEASE	13505	476	194	250	1012	1230	1339	1353	1322	886	768	368	172	301	1230	1383	1222
STOR CHANGE	480	176	85	109	118	339	1196	610	-388	-145	-183	-18	-9	-95	-400	-540	-376
STORAGE	12659	12835	12919	13028	13146	13486	14682	15293	14904	14759	14576	14558	14549	14455	14055	13515	13139
ELEV FTMSL	1817.5	1818.2	1818.6	1819.0	1819.5	1820.8	1825.5	1827.7	1826.3	1825.8	1825.1	1825.0	1825.0	1824.6	1823.1	1820.9	1819.5
DISCH KCFS	21.5	16.0	14.0	14.0	17.0	20.0	22.5	22.0	21.5	14.9	12.5	12.4	12.4	19.0	20.0	22.5	22.0
POWER																	
AVE POWER MW		176	155	155	188	223	255	254	249	172	144	142	142	217	227	252	243
PEAK POW MW		321	322	323	325	329	342	431	425	423	421	421	420	419	413	406	400
ENERGY GWH	1848.2	63.3	26.0	33.5	135.6	165.6	183.7	188.8	185.1	123.8	107.1	51.1	23.8	41.7	168.7	187.1	163.3
-- OAHE --																	
NAT INFLOW	1794	190	89	114	283	161	714	127	30	80	11				-43	-7	45
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25
CHAN STOR	-3	27	10		-14	-14	-12	2	2	32	12	1	0	-33	-5	-12	2
EVAPORATION	475							30	92	113	98	44	21	24	52		
REG INFLOW	14225	671	282	351	1234	1311	1915	1305	1166	861	701	322	150	244	1119	1348	1244
RELEASE	13728	347	238	352	1208	1454	1380	1681	1673	1305	716	235	116	134	1139	1008	744
STOR CHANGE	497	324	44	-1	26	-143	535	-376	-507	-444	-14	88	34	110	20	341	500
STORAGE	13246	13570	13614	13613	13639	13496	14031	13656	13149	12705	12691	12778	12812	12922	12902	13243	13743
ELEV FTMSL	1586.8	1588.2	1588.4	1588.4	1588.5	1587.9	1590.1	1588.6	1586.4	1584.5	1584.4	1584.8	1585.0	1585.5	1585.4	1586.8	1588.9
DISCH KCFS	16.2	11.7	17.1	19.7	20.3	23.7	23.2	27.3	27.2	21.9	11.6	7.9	8.4	8.4	18.5	16.4	13.4
POWER																	
AVE POWER MW		135	200	229	236	275	270	319	314	251	133	90	96	97	212	188	156
PEAK POW MW		612	613	613	614	610	622	614	603	592	592	594	595	598	597	605	616
ENERGY GWH	1921.1	48.8	33.5	49.5	170.1	204.3	194.7	237.3	233.7	180.5	98.8	32.5	16.1	18.5	157.7	140.2	104.7
-- BIG BEND --																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	13599	347	238	352	1208	1454	1380	1673	1648	1274	689	222	111	127	1125	1008	744
RELEASE	13599	347	238	352	1208	1454	1380	1673	1648	1274	689	222	111	127	1125	1008	744
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	16.2	11.7	17.1	19.7	20.3	23.7	23.2	27.2	26.8	21.4	11.2	7.5	8.0	8.0	18.3	16.4	13.4
POWER																	
AVE POWER MW		55	80	92	95	111	109	127	125	102	57	38	40	41	90	80	64
PEAK POW MW		517	510	509	509	509	509	509	509	525	538	538	538	538	538	538	529
ENERGY GWH	784.0	19.9	13.5	19.9	68.4	82.4	78.1	94.8	93.4	73.4	42.1	13.7	6.8	7.8	67.2	59.3	43.2
-- FORT RANDALL --																	
NAT INFLOW	659	90	42	54	84	67	171	34	65	31	2				7	-7	20
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	141																
REG INFLOW	14033	435	279	405	1288	1512	1539	1679	1667	1259	657	212	105	121	1116	998	761
RELEASE	14033	161	145	388	1288	1512	1539	1679	1667	1606	1545	230	106	121	750	726	572
STOR CHANGE	0	274	134	17				0	0	-347	-887	-18	0	0	366	272	189
STORAGE	3123	3398	3532	3549	3549	3549	3549	3549	3549	3202	2315	2297	2297	2296	2662	2934	3123
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.0	1337.8	1337.5	1337.5	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	10.3	5.4	10.4	21.7	21.6	24.6	25.9	27.3	27.1	27.0	25.1	7.7	7.6	7.6	12.2	11.8	10.3
POWER																	
AVE POWER MW		45	88	183	183	207	218	230	228	223	193	57	56	56	91	92	83
PEAK POW MW		349	354	355	355	355	355	355	355	341	284	283	283	283	311	329	338
ENERGY GWH	1391.2	16.1	14.8	39.6	131.6	154.2	156.8	170.9	169.7	160.8	143.6	20.4	9.4	10.7	68.0	68.8	55.8
-- GAVINS POINT --																	
NAT INFLOW	1342	98	46	59	133	148	154	87	86	62	112	51	24	27	75	73	108
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-6	-2	-3	0	0	3	32	0	0	-8	1	
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15213	269	181	425	1416	1636	1666	1722	1735	1662	1648	303	125	143	801	798	683
RELEASE	15213	269	181	425	1416	1636	1666	1722	1722	1636	1648	303	125	143	801	798	722
STOR CHANGE								13	26								
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.1	23.8	23.8	26.6	28.0	28.0	28.0	27.5	26.8						

DATE OF STUDY 01/10/03

2002-2003 AOP EXTENSIONS, LOWER QUARTILE RUNOFF SIMULATION 99001 9901 9901 PAGE 1

TIME OF STUDY 09:49:36

CWCP, STEADY RELEASE, 24-DAY SHORTENED SEASON VALUES IN 1000 AF EXCEPT AS INDICATED

STUDY NO 16

	28FEB06	15MAR	2006	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2007	31DEC	31JAN	28FEB
	INI-SUM		22MAR											30NOV			
--FORT PECK--																	
NAT INFLOW	6720	271	126	163	588	1036	1629	709	294	282	363	188	88	100	330	237	317
DEPLETION	399	-11	-5	-6	50	312	517	182	-52	-131	-72	-34	-16	-18	-112	-122	-84
EVAPORATION	469							28	89	112	98	45	21	24	51		
MOD INFLOW	5852	282	131	169	538	724	1112	499	257	301	337	176	82	94	391	359	401
RELEASE	5384	134	62	80	357	492	565	584	584	310	261	129	60	127	553	584	500
STOR CHANGE	468	148	69	89	181	232	547	-86	-327	-10	76	47	22	-33	-163	-225	-99
STORAGE	10915	11063	11132	11221	11402	11634	12180	12095	11767	11758	11834	11881	11903	11870	11707	11482	11383
ELEV FTMSL	2212.1	2213.0	2213.4	2213.9	2215.0	2216.3	2219.4	2218.9	2217.1	2217.0	2217.4	2217.7	2217.8	2217.7	2216.7	2215.4	2214.9
DISCH KCFS	9.0	4.5	4.5	4.5	6.0	8.0	9.5	9.5	9.5	5.2	4.2	4.3	4.3	8.0	9.0	9.5	9.0
POWER																	
AVE POWER MW		56	56	57	76	101	121	122	121	67	54	56	56	102	115	120	114
PEAK POW MW		187	187	188	189	191	195	194	192	192	193	193	193	193	192	190	189
ENERGY GWH	828.8	20.3	9.5	12.2	54.4	75.3	87.4	90.9	90.4	48.0	40.4	20.0	9.4	19.6	85.3	89.5	76.3
--GARRISON--																	
NAT INFLOW	10262	484	226	290	777	1306	2752	1927	542	455	437	179	83	95	243	180	286
DEPLETION	977	-2	-1	-1	-4	214	753	519	60	-105	-6	-102	-48	-54	-104	-85	-57
CHAN STOR	0	48			-16	-21	-16			44	10	-1		-38	-10	-5	5
EVAPORATION	558							34	108	135	117	53	24	28	60		
REG INFLOW	14111	668	289	372	1122	1563	2548	1958	958	780	597	356	167	211	830	844	848
RELEASE	13537	446	194	250	1012	1168	1339	1353	1322	982	791	370	173	301	1230	1383	1222
STOR CHANGE	574	222	95	122	110	394	1210	605	-364	-202	-194	-14	-6	-91	-400	-540	-374
STORAGE	13139	13361	13456	13578	13688	14082	15292	15898	15534	15332	15137	15123	15117	15027	14627	14087	13714
ELEV FTMSL	1819.5	1820.3	1820.7	1821.2	1821.6	1823.2	1827.7	1829.9	1828.6	1827.9	1827.2	1827.1	1827.1	1826.8	1825.3	1823.2	1821.7
DISCH KCFS	22.0	15.0	14.0	14.0	17.0	19.0	22.5	22.0	21.5	16.5	12.9	12.4	12.4	19.0	20.0	22.5	22.0
POWER																	
AVE POWER MW		167	157	157	191	215	259	259	254	194	151	146	146	221	232	257	248
PEAK POW MW		327	328	330	331	336	349	355	352	349	347	347	347	346	342	336	331
ENERGY GWH	1889.0	60.2	26.4	34.0	137.7	159.8	186.6	192.9	189.1	140.0	112.6	52.5	24.5	42.5	172.3	191.2	166.9
--QAHE--																	
NAT INFLOW	1860	197	92	118	294	167	740	131	31	83	12				-45	-7	46
DEPLETION	613	23	11	14	47	66	129	151	100	25	-8	2	1	1	11	16	26
CHAN STOR	0	33	5		-14	-9	-17	2	2	24	18	2		-32	-5	-12	2
EVAPORATION	490							31	95	117	101	46	22	25	54		
REG INFLOW	14294	655	281	355	1244	1260	1933	1304	1160	947	728	325	151	244	1115	1348	1244
RELEASE	13708	340	235	348	1202	1449	1371	1678	1669	1303	714	263	114	134	1139	1008	743
STOR CHANGE	586	315	46	6	43	-189	563	-373	-508	-356	14	62	36	111	-24	341	501
STORAGE	13743	14058	14103	14110	14152	13963	14525	14152	13644	13288	13302	13364	13400	13511	13487	13827	14329
ELEV FTMSL	1588.9	1590.2	1590.4	1590.4	1590.6	1589.8	1592.1	1590.6	1588.5	1587.0	1587.1	1587.3	1587.5	1588.0	1587.9	1589.3	1591.3
DISCH KCFS	13.4	11.4	16.9	19.5	20.2	23.6	23.0	27.3	27.1	21.9	11.6	8.8	8.2	8.4	18.5	16.4	13.4
POWER																	
AVE POWER MW		134	199	230	238	277	272	322	317	254	134	103	95	98	215	191	158
PEAK POW MW		622	623	623	624	620	631	624	614	606	606	607	608	611	610	617	627
ENERGY GWH	1942.6	48.3	33.5	49.6	171.3	205.9	195.6	239.6	236.0	182.6	100.0	36.9	16.0	18.8	160.1	142.2	106.0
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	13579	340	235	348	1202	1449	1371	1670	1644	1272	687	251	108	127	1125	1008	743
RELEASE	13579	340	235	348	1202	1449	1371	1670	1644	1272	687	251	108	127	1125	1008	743
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	13.4	11.4	16.9	19.5	20.2	23.6	23.0	27.2	26.7	21.4	11.2	8.4	7.8	8.0	18.3	16.4	13.4
POWER																	
AVE POWER MW		54	79	91	95	110	108	127	125	102	56	43	40	41	90	80	64
PEAK POW MW		517	510	509	509	509	509	509	509	525	538	538	538	538	538	538	529
ENERGY GWH	782.9	19.5	13.3	19.7	68.1	82.1	77.6	94.6	93.1	73.3	42.0	15.4	6.6	7.8	67.2	59.3	43.2
--FORT RANDALL--																	
NAT INFLOW	690	94	44	56	88	70	179	36	68	32	2				7	-7	21
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	141							10	32	38	27	10	5	5	13		
REG INFLOW	14044	432	278	404	1286	1510	1538	1678	1666	1258	655	240	103	121	1116	998	761
RELEASE	14044	158	144	387	1286	1510	1538	1678	1666	1605	1543	258	103	121	750	726	572
STOR CHANGE	0	274	134	17				0	0	-347	-887	-18	0	0	366	272	189
STORAGE	3123	3398	3532	3549	3549	3549	3549	3549	3549	3202	2315	2297	2297	2296	2662	2934	3123
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1337.8	1337.5	1337.5	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	10.3	5.3	10.4	21.7	21.6	24.6	25.8	27.3	27.1	27.0	25.1	8.7	7.4	7.6	12.2	11.8	10.3
POWER																	
AVE POWER MW		44	88	183	182	207	218	230	228	223	193	63	54	56	91	92	83
PEAK POW MW		349	354	355	355	355	355	355	355	341	284	283	283	283	311	329	338
ENERGY GWH	1392.0	15.8	14.7	39.5	131.4	154.0	156.7	170.8	169.6	160.7	143.4	22.8	9.2	10.7	68.0	68.8	55.8
--GAVINS POINT--																	
NAT INFLOW	1359	100	47	60	135	150	155	88	87	63	114	51	24	27	76	74	109
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	10	-10	-22	0	-6	-2	-3	0	0	4	30	2	0	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15241	267	181	425	1416	1636	1666	1722	1735	1662	1648	330	125	143	802	799	684
RELEASE	15241	267	181	425	1416	1636	1666	1722	1722	1636	1648	330	125	143	802	799	684
STOR CHANGE								13	26								
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	26.6	28.0	28.0	28.0	27.5	26.8	11.1	9.0	9.0	13.0	13.0	13.0
POWER																	
AVE POWER MW		32	46	82	82	91	95	95	96	95	94	39	32	32	46	46	46
PEAK POW MW		114	114	114	114	114	114	114	115	117	117	117	117	117	117	117	114
ENERGY GWH	637.7	11.4	7.7	17.6	58.7	67.5	68.6	70.9	71.3	68.7	69.9	14.2	5.4	6.2	34.5	34.3	30.8
--GAVINS POINT - SIOUX CITY--																	
NAT INFLOW	1211	155	72	93	121	234	168	101	75	47	33	17	8	9	17	-3	64
DEPLETION	251	6	3	4	21	35	30	37	34	22	10	6	3	3	12	13	13
REGULATED FLOW AT SIOUX CITY																	
KAF	16201	416	250	514													

	VALUES IN 1000 AF EXCEPT AS INDICATED																
	29FEB08 INI-SUM	15MAR	2008 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2009 30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	7022	283	132	170	615	1083	1702	741	307	295	379	196	91	104	345	248	331
DEPLETION	422	-11	-5	-6	50	313	525	196	-44	-132	-75	-35	-16	-18	-113	-123	-84
EVAPORATION	494							30	94	118	104	47	22	25	54		
MOD INFLOW	6106	294	137	176	565	770	1177	515	257	309	350	183	85	97	404	371	415
RELEASE	5490	134	62	80	357	492	595	584	553	286	258	120	56	127	615	615	555
STOR CHANGE	616	160	75	96	208	278	582	-69	-297	23	92	63	29	-29	-211	-244	-140
STORAGE	11865	12025	12099	12195	12403	12681	13263	13194	12897	12921	13013	13076	13105	13076	12865	12621	12481
ELEV FTMSL	2217.6	2218.5	2218.9	2219.5	2220.6	2222.2	2225.3	2225.0	2223.4	2223.5	2224.0	2224.3	2224.5	2224.3	2223.2	2221.9	2221.1
DISCH KCFS	9.0	4.5	4.5	4.5	6.0	8.0	10.0	9.5	9.0	4.8	4.2	4.0	4.0	8.0	10.0	10.0	10.0
POWER																	
AVE POWER MW		58	58	58	78	104	131	125	118	63	55	53	53	105	131	130	130
PEAK POW MW		194	195	195	197	198	201	201	199	200	200	200	201	200	199	198	197
ENERGY GWH	868.8	20.8	9.7	12.5	55.9	77.4	94.4	93.3	88.0	45.4	41.2	19.1	8.9	20.2	97.6	97.0	87.2
--GARRISON--																	
NAT INFLOW	10598	500	233	300	803	1349	2842	1990	559	470	451	185	86	98	251	186	295
DEPLETION	1160					216	774	553	56	-134	9	-90	-42	-48	-67	-46	-22
CHAN STOR	-10	47															
EVAPORATION	589																
REG INFLOW	14329	681	296	380	1144	1604	2642	1991	948	790	583	340	158	203	849	847	872
RELEASE	13572	446	194	250	1012	1138	1339	1353	1322	952	877	370	173	286	1230	1353	1277
STOR CHANGE	757	235	101	130	133	467	1304	638	-374	-162	-294	-30	-15	-82	-381	-506	-405
STORAGE	14298	14533	14634	14765	14897	15364	16667	17305	16931	16769	16475	16445	16430	16347	15966	15460	15055
ELEV FTMSL	1824.0	1824.9	1825.3	1825.8	1826.3	1828.0	1832.6	1834.8	1833.6	1833.0	1832.0	1831.9	1831.8	1831.5	1830.2	1828.4	1826.9
DISCH KCFS	22.0	15.0	14.0	14.0	17.0	18.5	22.5	22.0	21.5	16.0	14.3	12.5	12.5	18.0	22.0	23.0	23.0
POWER																	
AVE POWER MW		171	161	161	196	215	266	266	261	194	172	150	150	215	238	258	267
PEAK POW MW		420	422	423	425	432	449	457	452	450	446	446	445	444	439	433	427
ENERGY GWH	1943.6	61.7	27.0	34.8	141.1	169.7	191.5	197.8	194.0	139.4	127.9	53.9	25.1	41.3	176.7	192.2	179.4
--OAHE--																	
NAT INFLOW	2048	217	101	130	324	183	815	144	34	92	13				-49	-8	51
DEPLETION	641	23	11	14	48	68	135	160	106	26	-9				12	17	27
CHAN STOR	-4	32	5		-14	-7	-18	2	2	25	8				-9	-9	-5
EVAPORATION	523																
REG INFLOW	14451	672	289	366	1274	1246	2001	1306	1151	918	799	328	149	233	1102	1319	1297
RELEASE	13693	459	121	339	1239	1465	1341	1670	1659	1334	710	233	116	132	1132	1009	735
STOR CHANGE	758	214	168	27	35	-219	660	-364	-508	-415	89				-30	310	561
STORAGE	14934	15147	15316	15343	15378	15158	15818	15455	14947	14532	14621	14716	14750	14850	14820	15130	15692
ELEV FTMSL	1593.7	1594.5	1595.2	1595.3	1595.4	1594.6	1597.1	1595.7	1593.8	1592.1	1592.5	1592.9	1593.0	1593.4	1593.3	1594.5	1596.6
DISCH KCFS	13.4	15.4	8.7	19.0	20.8	23.8	22.5	27.2	27.0	22.4	11.5	7.8	8.3	8.3	18.4	16.4	13.2
POWER																	
AVE POWER MW		186	106	230	252	287	273	330	325	267	138				100	197	161
PEAK POW MW		643	647	647	648	644	656	649	639	631	633	635	636	638	637	643	654
ENERGY GWH	1996.3	66.8	17.8	49.6	181.4	213.8	196.6	245.3	241.5	192.5	102.5	33.7	16.8	19.2	164.0	146.7	108.0
--BIG BEND--																	
EVAPORATION	129																
REG INFLOW	13564	459	121	339	1239	1465	1341	1662	1634	1303	683	220	110	126	1118	1009	735
RELEASE	13564	459	121	339	1239	1465	1341	1662	1634	1303	683	220	110	126	1118	1009	735
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	13.4	15.4	8.7	19.0	20.8	23.8	22.5	27.0	26.6	21.9	11.1	7.4	7.9	7.9	18.2	16.4	13.2
POWER																	
AVE POWER MW		72	41	89	98	112	105	127	124	104	56				40	80	64
PEAK POW MW		510	509	509	509	509	509	509	509	525	538	538	538	538	538	538	529
ENERGY GWH	781.7	26.0	6.9	19.2	70.2	83.0	75.9	94.1	92.6	75.1	41.8	13.5	6.7	7.7	66.8	59.4	42.7
--FORT RANDALL--																	
NAT INFLOW	779	106	49	64	100	79	203	41	76	36	2				8	-8	23
DEPLETION	80	1	1	1	4	9	12	18	15	7	1				3	3	3
EVAPORATION	141																
REG INFLOW	14118	563	170	402	1335	1535	1532	1675	1664	1293	651	210	105	120	1110	998	755
RELEASE	14118	563	170	402	1335	1535	1532	1675	1664	1293	651	210	105	120	1110	998	755
STOR CHANGE	0	409	17														
STORAGE	3123	3532	3549	3549	3549	3549	3549	3549	3549	3549	3549	3549	3549	3549	3549	3549	3549
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.0	1337.8	1337.5	1337.5	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	10.4	5.2	11.0	22.5	22.4	25.0	25.7	27.2	27.1	27.6	25.0	7.6	7.5	7.6	12.1	11.8	10.2
POWER																	
AVE POWER MW		43	94	190	189	210	217	229	228	228	192				55	91	82
PEAK POW MW		354	355	355	355	355	355	355	355	341	284				283	311	338
ENERGY GWH	1400.1	15.7	15.7	41.0	136.4	156.5	156.1	170.5	169.4	164.1	143.0	20.2	9.3	10.6	67.5	68.8	55.3
--GAVINS POINT--																	
NAT INFLOW	1401	103	48	62	139	155	160	91	89	65	117	53	25	28	78	77	113
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	10	-11	-22	0	-5	-1	-3	0	-1	5	32	0	0	-8	1	3
EVAPORATION	47																
REG INFLOW	15357	268	190	441	1470	1666	1666	1722	1735	1698	1648	303	125	143	798	802	682
RELEASE	15357	268	190	441	1470	1666	1666	1722	1722	1672	1648	303	125	143	798	802	721
STOR CHANGE																	
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0	1206.0
DISCH KCFS	13.0	9.0	13.7	24.7	24.7	27.1	28.0	28.0	28.0	28.1	26.8	10.2	9.0	9.0	13.0	13.0	13.0
POWER																	
AVE POWER MW		32	48	85	85	92	95	95	96	97	94				32	46	46
PEAK POW MW		114															

	29FEB04	15MAR	2004	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2005	31DEC	31JAN	28FEB
	INI-SUM		22MAR											30NOV			
--FORT PECK--																	
NAT INFLOW	5435	250	116	150	549	834	1061	468	270	258	341	169	79	90	289	218	293
DEPLETION	419	2	1	1	86	321	476	145	-51	-123	-55	-32	-15	-17	-106	-125	-90
EVAPORATION	407							25	78	97	85	39	18	21	44		
MOD INFLOW	4609	247	115	148	463	513	585	298	243	284	311	162	76	87	351	343	383
RELEASE	5407	119	56	71	298	430	595	584	553	327	298	140	69	111	584	615	555
STOR CHANGE	-797	128	60	77	165	83	-10	-286	-310	-44	13	22	6	-24	-233	-272	-172
STORAGE	9348	9476	9536	9613	9779	9861	9851	9565	9255	9211	9224	9247	9253	9229	8995	8723	8551
ELEV FTMSL	2202.3	2203.2	2203.6	2204.1	2205.1	2205.6	2205.6	2203.7	2201.7	2201.4	2201.5	2201.7	2201.7	2201.6	2200.0	2198.2	2197.0
DISCH KCFS	11.5	4.0	4.0	4.0	5.0	7.0	10.0	9.5	9.0	5.5	4.8	4.7	5.0	7.0	9.5	10.0	10.0
POWER																	
AVE POWER MW		48	48	48	60	84	120	114	107	65	57	56	59	83	111	116	115
PEAK POW MW		173	174	175	176	177	177	174	172	171	171	171	172	171	169	167	165
ENERGY GWH	773.8	17.2	8.0	10.3	43.2	62.7	86.6	84.6	79.4	46.8	42.6	20.1	9.9	15.9	82.9	86.4	77.2
--GARRISON--																	
NAT INFLOW	8026	297	138	178	770	993	2221	1404	397	305	429	177	83	94	119	176	245
DEPLETION	1508	38	18	23	69	166	763	527	111	-65	64	-68	-32	-36	-40	-17	-12
CHAN STOR	16	83			-11	-22	-33	5	5	38	7	1	-3	-22	-28	-6	
EVAPORATION	477							30	93	115	99	45	21	24	51		
REG INFLOW	11464	461	176	227	987	1235	2020	1437	752	620	571	342	160	196	665	802	812
RELEASE	12419	446	167	214	833	984	1220	1261	1261	911	760	356	166	270	1230	1230	1111
STOR CHANGE	-955	15	10	12	154	252	800	176	-509	-291	-190	-14	-7	-74	-565	-427	-298
STORAGE	11235	11250	11259	11272	11426	11678	12478	12655	12146	11855	11665	11651	11644	11570	11006	10578	10280
ELEV FTMSL	1811.4	1811.5	1811.5	1811.6	1812.3	1813.3	1816.7	1817.5	1815.4	1814.1	1813.3	1813.2	1813.2	1812.9	1810.4	1808.4	1807.0
DISCH KCFS	22.0	15.0	12.0	12.0	14.0	16.0	20.5	20.5	20.5	15.3	12.4	12.0	12.0	17.0	20.0	20.0	20.0
POWER																	
AVE POWER MW		157	126	126	148	170	220	223	222	165	132	128	128	180	209	206	203
PEAK POW MW		301	302	302	304	307	317	319	313	309	307	307	306	306	298	292	288
ENERGY GWH	1591.5	56.7	21.2	27.3	106.3	126.1	158.4	166.1	165.3	118.5	98.4	46.0	21.5	34.6	155.8	153.1	136.4
--OAHE--																	
NAT INFLOW	1184	223	104	134	206	113	242	92	24	72	6	-6	-3	-3	-54	-13	47
DEPLETION	585	22	10	13	46	64	123	143	93	23	-8	2	1	1	11	16	25
CHAN STOR	10	36	15		-10	-10	-24			28	16	2		-28	-16		
EVAPORATION	394							25	76	95	82	37	17	20	43		
REG INFLOW	12634	683	275	334	983	1022	1315	1185	1116	894	708	315	146	219	1105	1201	1133
RELEASE	13624	367	263	371	1250	1493	1418	1708	1527	727	1078	242	122	138	1059	832	1030
STOR CHANGE	-991	315	12	-37	-267	-471	-102	-523	-411	167	-370	73	24	81	46	369	103
STORAGE	11786	12101	12113	12077	11810	11339	11237	10714	10303	10469	10100	10172	10196	10277	10323	10692	10795
ELEV FTMSL	1580.3	1581.8	1581.9	1581.7	1580.5	1578.2	1577.7	1575.1	1573.0	1573.9	1571.9	1572.3	1572.4	1572.9	1573.1	1575.0	1575.5
DISCH KCFS	16.9	12.4	19.0	20.8	21.0	24.3	23.8	27.8	24.8	12.2	17.5	8.1	8.8	8.7	17.2	13.5	18.5
POWER																	
AVE POWER MW		138	212	233	234	267	260	300	264	130	186	86	93	92	183	145	199
PEAK POW MW		578	579	578	571	559	557	543	532	537	526	529	529	531	533	543	545
ENERGY GWH	1784.2	49.7	35.7	50.2	168.4	198.9	187.3	223.1	196.8	93.8	138.3	31.0	15.6	17.7	135.9	107.7	134.0
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	13496	367	263	371	1250	1493	1418	1700	1503	696	1051	230	116	131	1045	832	1030
RELEASE	13496	367	263	371	1250	1493	1418	1700	1503	696	1051	230	116	131	1045	832	1030
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	16.9	12.4	19.0	20.8	21.0	24.3	23.8	27.6	24.4	11.7	17.1	7.7	8.4	8.3	17.0	13.5	18.5
POWER																	
AVE POWER MW		58	89	97	98	114	112	129	116	59	86	39	42	42	85	67	89
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	529
ENERGY GWH	783.4	21.0	14.9	21.0	70.8	84.6	80.3	96.3	86.0	42.6	64.0	14.1	7.1	8.1	63.0	49.9	59.8
--FORT RANDALL--																	
NAT INFLOW	366	67	31	40	52	42	146	16	44	-12	-62	-3	-1	-2	-7	15	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	0	0	1	3	3	
EVAPORATION	130							10	31	33	23	10	5	5	13		
REG INFLOW	13645	433	294	410	1298	1526	1552	1688	1501	637	965	217	110	124	1029	822	1042
RELEASE	13646	170	149	393	1298	1526	1552	1688	1675	1612	1068	217	110	124	756	732	578
STOR CHANGE	-1	263	145	17			0	-174	-975	-103	0	0	0	0	273	90	464
STORAGE	3124	3387	3532	3549	3549	3549	3549	3549	3375	2399	2296	2296	2296	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1339.3	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	10.6	5.7	10.7	22.0	21.8	24.8	26.1	27.5	27.2	27.1	17.4	7.3	7.9	7.8	12.3	11.9	10.4
POWER																	
AVE POWER MW		47	91	186	184	209	220	231	227	211	127	53	58	57	92	91	82
PEAK POW MW		349	354	355	355	355	355	355	348	291	283	283	283	283	305	311	338
ENERGY GWH	1337.4	17.0	15.2	40.1	132.6	155.6	158.1	171.8	169.1	152.1	94.6	19.2	9.7	11.0	68.1	67.7	55.4
--GAVINS POINT--																	
NAT INFLOW	1229	89	42	53	123	134	141	78	78	56	107	46	21	25	69	67	100
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-6	-2	-3	0	0	18	19	-1	0	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	14713	269	181	425	1416	1636	1666	1722	1735	1662	1181	272	126	143	802	798	680
RELEASE	14713	269	181	425	1416	1636	1666	1722	1722	1636	1181	272	126	143	802	798	719
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0														

	VALUES IN 1000 AF EXCEPT AS INDICATED																
	28FEB05	15MAR	2005	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2006	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5615	258	120	155	567	862	1097	483	279	266	352	175	81	93	298	226	303
DEPLETION	388	2	1	1	73	304	470	152	-46	-124	-57	-33	-15	-18	-107	-126	-90
EVAPORATION	393							24	75	94	82	37	17	20	43		
MOD INFLOW	4834	256	119	153	494	558	627	307	250	296	327	170	79	91	362	352	393
RELEASE	5117	119	56	71	298	461	536	553	523	299	250	121	97	127	553	553	500
STOR CHANGE	-283	137	64	82	196	97	91	-246	-273	-3	77	49	-18	-36	-191	-201	-107
STORAGE	8551	8687	8751	8833	9029	9126	9218	8971	8699	8696	8772	8822	8804	8768	8576	8375	8268
ELEV FTMSL	2197.0	2197.9	2198.4	2198.9	2200.2	2200.9	2201.5	2199.8	2198.0	2198.5	2198.5	2198.8	2198.7	2198.5	2197.2	2195.8	2195.0
DISCH KCFS	10.0	4.0	4.0	4.0	5.0	7.5	9.0	9.0	8.5	5.0	4.1	4.1	7.0	8.0	9.0	9.0	9.0
POWER																	
AVE POWER MW		46	46	47	59	88	106	106	99	58	47	47	81	93	104	103	102
PEAK POW MW		166	167	168	170	170	171	169	166	166	167	168	167	167	165	163	162
ENERGY GWH	718.1	16.7	7.8	10.1	42.1	65.5	76.2	78.5	73.5	41.9	35.2	17.1	13.7	17.8	77.2	76.4	68.5
--GARRISON--																	
NAT INFLOW	8444	312	146	187	810	1045	2337	1477	418	320	451	187	87	99	125	185	258
DEPLETION	1085	10	5	6	20	211	714	482	63	-120	6	-84	-39	-45	-69	-49	-27
CHAN STOR	11	68			-11	-28	-17		5	38	11	0	-32	-11	-11		
EVAPORATION	462							28	90	111	96	43	20	23	50		
REG INFLOW	12026	489	196	253	1076	1267	2142	1520	793	666	610	348	170	237	687	787	785
RELEASE	12375	446	167	214	893	1045	1250	1261	1230	899	680	329	153	270	1168	1261	1111
STOR CHANGE	-349	42	30	38	184	222	892	259	-436	-232	-70	19	17	-33	-481	-473	-326
STORAGE	10280	10322	10352	10390	10574	10796	11688	11947	11511	11279	11209	11227	11244	11211	10730	10257	9931
ELEV FTMSL	1807.0	1807.2	1807.4	1807.5	1808.4	1809.4	1813.4	1814.5	1812.6	1811.6	1811.3	1811.4	1811.4	1811.3	1809.1	1806.9	1805.3
DISCH KCFS	20.0	15.0	12.0	12.0	15.0	17.0	21.0	20.5	20.0	15.1	11.1	11.1	11.1	17.0	19.0	20.5	20.0
POWER																	
AVE POWER MW		152	122	122	153	175	219	217	211	158	116	116	116	177	195	207	199
PEAK POW MW		289	289	290	292	295	307	382	375	372	371	371	371	371	363	355	349
ENERGY GWH	1546.0	54.8	20.5	26.4	110.3	129.9	158.0	161.3	157.0	113.9	86.0	41.6	19.4	34.0	145.4	153.9	133.6
--OAHE--																	
NAT INFLOW	1263	238	111	143	220	120	259	99	25	77	6	-6	-3	-3	-58	-14	50
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25
CHAN STOR	0	27	16		-16	-11	-22	3	3	28	23			-33	-11	-8	3
EVAPORATION	378							23	71	90	79	36	17	19	42		
REG INFLOW	12663	689	283	343	1051	1090	1361	1192	1090	890	637	285	133	213	1046	1222	1139
RELEASE	13031	358	259	366	1243	1486	1401	1705	1522	624	632	256	120	137	1059	833	1029
STOR CHANGE	-367	330	24	-23	-192	-397	-40	-513	-432	265	5	29	13	76	-13	389	110
STORAGE	10795	11126	11149	11127	10935	10538	10498	9985	9553	9818	9824	9853	9866	9942	9929	10318	10428
ELEV FTMSL	1575.5	1577.2	1577.3	1577.2	1576.2	1574.2	1574.0	1571.3	1569.0	1570.4	1570.5	1570.6	1570.7	1571.1	1571.0	1573.1	1573.7
DISCH KCFS	18.5	12.0	18.7	20.5	20.9	24.2	23.5	27.7	24.8	10.5	10.3	8.6	8.7	8.7	17.2	13.5	18.5
POWER																	
AVE POWER MW		131	203	223	226	259	251	292	257	109	107	90	91	91	180	143	197
PEAK POW MW		554	555	554	549	539	538	523	511	519	519	520	520	522	522	533	536
ENERGY GWH	1671.8	47.1	34.2	48.2	163.1	193.0	180.6	217.5	191.3	78.7	80.0	32.5	15.3	17.5	134.3	106.4	132.3
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	12902	358	259	366	1243	1486	1401	1697	1498	593	605	244	115	131	1045	833	1029
RELEASE	12902	358	259	366	1243	1486	1401	1697	1498	593	605	244	115	131	1045	833	1029
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	18.5	12.0	18.7	20.5	20.9	24.2	23.5	27.6	24.4	10.0	9.8	8.2	8.3	8.2	17.0	13.5	18.5
POWER																	
AVE POWER MW		57	88	96	98	113	110	129	115	50	50	42	42	42	85	67	89
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	529
ENERGY GWH	747.8	20.5	14.7	20.7	70.4	84.2	79.3	96.1	85.8	36.4	37.0	15.0	7.0	8.0	63.0	49.9	59.7
--FORT RANDALL--																	
NAT INFLOW	404	74	35	44	58	47	161	18	48	-13	-69	-4	-2	-2	-8	16	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	128						10	31	32	22	10	5	5	5	13		
REG INFLOW	13089	431	293	410	1297	1524	1550	1687	1500	533	512	230	108	123	1029	822	1042
RELEASE	13089	167	148	393	1297	1524	1550	1687	1674	1611	512	230	108	123	756	732	578
STOR CHANGE	0	264	145	17			0	-174	-1078	0	0	0	0	0	273	90	464
STORAGE	3123	3387	3532	3549	3549	3549	3549	3549	3375	2297	2296	2296	2296	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1337.5	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	10.4	5.6	10.7	22.0	21.8	24.8	26.0	27.4	27.2	27.1	8.3	7.7	7.8	7.8	12.3	11.9	10.4
POWER																	
AVE POWER MW		46	90	186	184	209	219	231	227	209	61	56	57	57	92	91	82
PEAK POW MW		349	354	355	355	355	355	355	348	282	283	283	283	283	305	311	338
ENERGY GWH	1286.7	16.7	15.2	40.1	132.5	155.4	157.9	171.7	169.0	150.8	45.3	20.3	9.5	10.9	68.1	67.7	55.4
--GAVINS POINT--																	
NAT INFLOW	1242	90	42	54	124	136	143	79	79	57	108	47	22	25	69	67	101
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-6	-2	-3	0	0	35	1	0	0	-8	1	3
EVAPORATION	47						3	9	11	10	5	2	2	5			
REG INFLOW	14169	266	181	425	1416	1636	1666	1722	1735	1662	643	268	125	143	802	798	681
RELEASE	14169	266	181	425	1416	1636	1666	1722	1722	1636	643	268	125	143	802	798	720
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	26.6	28.0	28.0	28.0	27.5	10.5	9.0	9.0	9.0	13.0	13.0	13.

	VALUES IN 1000 AF EXCEPT AS INDICATED																	
	28FEB06 INI-SUM	15MAR	2006 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2007 30NOV	31DEC	31JAN	28FEB	
--FORT PECK--																		
NAT INFLOW	5748	264	123	158	580	882	1123	495	285	273	361	179	83	95	305	231	310	
DEPLETION	399	-3	-1	-2	76	308	478	159	-42	-124	-58	-34	-16	-18	-108	-126	-91	
EVAPORATION	390							24	74	93	82	37	17	20	43			
MOD INFLOW	4959	267	125	160	504	574	645	312	253	304	337	175	82	93	370	357	401	
RELEASE	4896	119	56	71	298	400	536	553	523	282	244	118	83	127	492	523	472	
STOR CHANGE	63	148	69	89	206	174	109	-241	-270	22	93	57	-2	-34	-122	-166	-71	
STORAGE	8268	8416	8485	8574	8780	8955	9064	8823	8553	8575	8668	8725	8723	8689	8567	8402	8331	
ELEV FTMSL	2195.0	2196.1	2196.5	2197.2	2198.6	2199.7	2200.5	2198.8	2197.0	2197.2	2197.8	2198.2	2198.2	2197.9	2197.1	2196.0	2195.5	
DISCH KCFS	9.0	4.0	4.0	4.0	5.0	6.5	9.0	9.0	8.5	4.7	4.0	4.0	6.0	8.0	8.5	8.5	8.5	
POWER																		
AVE POWER MW		46	46	46	58	76	105	105	98	55	46	46	70	92	92	97	97	
PEAK POW MW		163	164	165	167	169	170	168	165	165	166	167	167	166	165	163	163	
ENERGY GWH	684.3	16.4	7.7	10.0	41.7	56.4	75.7	78.1	73.0	39.4	34.2	16.6	11.7	17.8	68.5	72.3	64.9	
--GARRISON--																		
NAT INFLOW	8762	324	151	194	840	1084	2425	1533	433	332	468	194	90	103	130	192	268	
DEPLETION	967	14	6	8	26	211	718	498	66	-124	-1	-98	-46	-52	-109	-88	-63	
CHAN STOR	6	57			-11	-17	-28		5	41	9		-22	-22		-6	0	
EVAPORATION	461							28	90	111	96	43	20	23	49			
REG INFLOW	12236	486	200	258	1100	1256	2215	1560	806	669	625	366	176	237	682	797	803	
RELEASE	12165	417	167	214	893	1045	1190	1199	1168	803	796	385	180	286	1168	1199	1055	
STOR CHANGE	71	70	34	44	208	210	1024	361	-363	-135	-171	-19	-3	-49	-487	-402	-252	
STORAGE	9931	10001	10035	10078	10286	10496	11521	11882	11519	11384	11214	11195	11191	11142	10656	10254	10002	
ELEV FTMSL	1805.3	1805.7	1805.8	1806.1	1807.0	1808.0	1812.7	1814.2	1812.7	1812.1	1811.3	1811.2	1811.2	1811.0	1808.8	1806.9	1805.7	
DISCH KCFS	20.0	14.0	12.0	12.0	15.0	17.0	20.0	19.5	19.0	13.5	12.9	12.9	12.9	18.0	19.0	19.5	19.0	
POWER																		
AVE POWER MW		139	120	120	150	171	206	206	200	142	135	135	135	187	195	197	189	
PEAK POW MW		350	351	352	355	359	376	381	376	373	371	370	370	369	361	355	350	
ENERGY GWH	1510.7	50.1	20.1	25.9	108.2	127.5	148.2	153.0	149.1	102.1	100.8	48.6	22.7	35.8	145.0	146.3	127.2	
--OAHE--																		
NAT INFLOW	1323	249	116	149	231	126	271	103	26	81	7	-7	-3	-3	-61	-15	52	
DEPLETION	613	23	11	14	47	66	129	151	100	25	-8	2	1	1	11	16	26	
CHAN STOR	7	33	11		-16	-11	-17		3	32	3	0	0	-28	-6	-3	3	
EVAPORATION	374							23	69	87	79	36	17	20	43			
REG INFLOW	12508	676	283	350	1060	1094	1316	1131	1029	804	735	341	159	234	1048	1165	1084	
RELEASE	12420	353	256	362	1238	1483	1388	1388	1518	121	564	260	121	138	1053	835	1028	
STOR CHANGE	88	323	27	-12	-177	-389	-72	-573	-490	683	170	81	38	96	-5	331	56	
STORAGE	10428	10751	10778	10766	10589	10200	10128	9555	9066	9748	9919	10000	10038	10134	10129	10459	10516	
ELEV FTMSL	1573.7	1575.3	1575.4	1575.4	1574.5	1572.5	1572.1	1569.0	1566.2	1570.0	1571.0	1571.4	1571.6	1572.1	1572.1	1573.8	1574.1	
DISCH KCFS	18.5	11.9	18.4	20.3	20.8	24.1	23.3	27.7	24.7	2.0	9.2	8.7	8.7	8.7	17.1	13.6	18.5	
POWER																		
AVE POWER MW		127	199	218	223	256	246	288	252	21	96	92	92	92	181	144	197	
PEAK POW MW		544	545	545	540	529	527	511	497	517	522	524	525	527	527	537	538	
ENERGY GWH	1583.3	45.8	33.4	47.2	160.6	190.5	176.9	214.3	187.6	15.1	71.5	33.1	15.4	17.6	134.4	107.3	132.7	
--BIG BEND--																		
EVAPORATION	129						8		24	31	27	12	6	7	14			
REG INFLOW	12292	353	256	362	1238	1483	1388	1696	1494	90	537	248	115	131	1039	835	1028	
RELEASE	12292	353	256	362	1238	1483	1388	1696	1494	90	537	248	115	131	1039	835	1028	
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	
DISCH KCFS	18.5	11.9	18.4	20.3	20.8	24.1	23.3	27.6	24.3	1.5	8.7	8.3	8.3	8.3	16.9	13.6	18.5	
POWER																		
AVE POWER MW		56	86	95	97	113	109	129	115	8	44	42	42	42	84	67	89	
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	528	
ENERGY GWH	710.6	20.2	14.5	20.5	70.1	84.0	78.6	96.0	85.5	5.5	32.9	15.2	7.1	8.1	62.6	50.0	59.6	
--FORT RANDALL--																		
NAT INFLOW	433	80	37	48	62	50	174	19	52	-15	-75	-4	-2	-2	-9	17		
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3		
EVAPORATION	128							10	31	32	22	10	5	5	13			
REG INFLOW	12502	431	293	409	1296	1524	1550	1687	1500	23	438	233	108	124	1023	823	1042	
RELEASE	12498	167	148	392	1296	1524	1550	1687	1674	1101	437	232	108	123	750	732	578	
STOR CHANGE	4	264	144	17				0	-174	-1079	1	1	0	1	273	91	464	
STORAGE	3123	3388	3532	3549	3549	3549	3549	3549	3375	2296	2298	2299	2299	2300	2573	2664	3128	
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1337.5	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0	
DISCH KCFS	10.4	5.6	10.7	22.0	21.8	24.8	26.0	27.4	27.2	18.5	7.1	7.8	7.8	7.8	12.2	11.9	10.4	
POWER																		
AVE POWER MW		46	90	185	184	209	219	231	227	144	52	57	57	57	91	91	83	
PEAK POW MW		349	354	355	355	355	355	355	348	282	284	284	284	284	305	311	338	
ENERGY GWH	1232.5	16.7	15.1	40.0	132.4	155.4	157.9	171.7	169.0	103.7	38.7	20.6	9.5	10.9	67.6	67.8	55.5	
--GAVINS POINT--																		
NAT INFLOW	1246	91	42	54	125	136	143	79	79	57	108	47	22	25	70	68	101	
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1		
CHAN STOR	-1	9	-10	-22	0	-6	-2	-3	0	17	21	-1	0	0	-8	1	3	
EVAPORATION	47							3	9	11	10	5	2	2	5			
REG INFLOW	13582	267	181	425	1416	1636	1666	1722	1735	1168	554	268	125	143	797	799	681	
RELEASE	13582	267	181	425	1416	1636	1666	1722	1722	1142	554	268	125	143	797	799	720	
STOR CHANGE								13	26								-39	
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358	
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0	
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	26.6	28.0	28.0	28.0	19.2	9.0	9.0	9.0	9.0				

	VALUES IN 1000 AF EXCEPT AS INDICATED																
	28FEB07 INI-SUM	15MAR	2007 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2008 30NOV	31DEC	31JAN	29FEB
--FORT PECK--																	
NAT INFLOW	5919	272	127	163	598	909	1156	509	294	281	371	184	86	98	314	238	319
DEPLETION	410	-3	-1	-2	76	309	482	166	-38	-124	-60	-33	-15	-18	-106	-124	-99
EVAPORATION	394							24	75	94	83	38	18	20	43		
MOD INFLOW	5115	275	128	165	522	600	674	319	257	311	348	179	84	96	377	362	418
RELEASE	5034	119	56	71	298	430	536	553	523	278	245	119	55	127	553	553	518
STOR CHANGE	82	156	73	93	224	170	138	-234	-266	33	103	61	28	-31	-177	-191	-100
STORAGE	8331	8487	8559	8653	8877	9047	9185	8951	8685	8719	8822	8883	8911	8880	8703	8512	8412
ELEV FTMSL	2195.5	2196.5	2197.0	2197.7	2199.2	2200.3	2201.3	2199.7	2197.9	2198.1	2198.8	2199.3	2199.4	2199.2	2198.0	2196.7	2196.0
DISCH KCFS	8.5	4.0	4.0	4.0	5.0	7.0	9.0	9.0	8.5	4.7	4.0	4.0	4.0	8.0	9.0	9.0	9.0
POWER																	
AVE POWER MW		46	46	46	58	82	106	105	99	54	46	47	47	93	104	103	103
PEAK POW MW		164	165	166	168	170	171	169	166	166	168	168	168	168	166	164	163
ENERGY GWH	706.9	16.5	7.7	10.0	41.9	60.9	76.0	78.4	73.4	39.0	34.5	16.8	7.8	17.9	77.6	76.9	71.5
--GARRISON--																	
NAT INFLOW	9185	340	158	204	881	1136	2542	1607	454	349	491	203	95	108	136	201	281
DEPLETION	962	-5	-2	-3	-11	211	734	514	74	-126	-4	-91	-42	-49	-100	-78	-59
CHAN STOR	-5	51			-11	-22	-22		5	42	8	0		-44	-11		
EVAPORATION	467							29	90	112	98	44	21	24	50		
REG INFLOW	12784	515	216	278	1178	1333	2321	1618	818	683	650	368	172	216	728	832	858
RELEASE	12690	417	167	214	893	1076	1309	1322	1291	768	660	320	149	286	1230	1353	1237
STOR CHANGE	94	99	50	64	286	257	1012	296	-473	-85	-11	48	22	-70	-502	-520	-379
STORAGE	10002	10100	10150	10214	10500	10757	11769	12065	11591	11507	11496	11544	11567	11497	10995	10475	10096
ELEV FTMSL	1805.7	1806.2	1806.4	1806.7	1808.1	1809.2	1813.7	1815.0	1813.0	1812.6	1812.6	1812.8	1812.9	1812.6	1810.3	1807.9	1806.1
DISCH KCFS	19.0	14.0	12.0	12.0	15.0	17.5	22.0	21.5	21.0	12.9	10.7	10.7	10.7	18.0	20.0	22.0	21.5
POWER																	
AVE POWER MW		140	120	121	151	178	228	228	222	136	113	113	113	189	208	224	215
PEAK POW MW		352	353	354	359	363	380	384	377	375	375	376	376	375	367	358	352
ENERGY GWH	1586.1	50.3	20.2	26.0	108.9	132.4	164.3	169.6	165.2	98.0	84.3	40.8	19.1	36.3	154.5	166.5	149.7
--OAH--																	
NAT INFLOW	1408	265	123	159	245	134	288	110	28	86	7	-7	-3	-3	-64	-16	56
DEPLETION	626	23	11	14	47	67	132	156	103	25	-9	2	1	1	12	17	26
CHAN STOR	-13	27	11		-16	-13	-25		3	46	12	0	0	-41	-11	-11	3
EVAPORATION	378							23	72	90	79	36	17	19	42		
REG INFLOW	13081	686	290	359	1075	1130	1441	1255	1147	784	609	276	129	221	1101	1309	1269
RELEASE	12968	342	250	357	1232	1477	1370	1702	1513	627	643	256	120	137	1053	835	1052
STOR CHANGE	113	343	40	2	-157	-348	71	-446	-366	157	-34	19	8	84	48	474	217
STORAGE	10516	10859	10899	10901	10744	10396	10467	10020	9654	9812	9777	9797	9805	9889	9937	10411	10628
ELEV FTMSL	1574.1	1575.9	1576.1	1576.1	1575.3	1573.5	1573.9	1571.5	1569.5	1570.4	1570.2	1570.3	1570.4	1570.8	1571.1	1573.6	1574.7
DISCH KCFS	18.5	11.5	18.0	20.0	20.7	24.0	23.0	27.7	24.6	10.5	10.5	8.6	8.7	8.7	17.1	13.6	18.3
POWER																	
AVE POWER MW		124	195	216	223	256	245	292	256	110	109	90	91	91	179	144	195
PEAK POW MW		547	548	548	544	535	537	524	514	518	517	518	518	521	522	535	541
ENERGY GWH	1661.2	44.6	32.7	46.7	160.6	190.8	176.2	217.1	190.6	79.2	81.4	32.4	15.2	17.4	133.4	106.9	136.0
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	12839	342	250	357	1232	1477	1370	1694	1489	596	616	244	115	131	1039	835	1052
RELEASE	12839	342	250	357	1232	1477	1370	1694	1489	596	616	244	115	131	1039	835	1052
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	18.5	11.5	18.0	20.0	20.7	24.0	23.0	27.5	24.2	10.0	10.0	8.2	8.3	8.2	16.9	13.6	18.3
POWER																	
AVE POWER MW		54	85	94	97	112	108	129	115	51	51	42	42	42	84	67	88
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	529
ENERGY GWH	744.3	19.6	14.2	20.2	69.8	83.7	77.6	95.9	85.2	36.5	37.8	15.0	7.0	8.0	62.6	50.0	61.1
--FORT RANDALL--																	
NAT INFLOW	476	88	41	53	68	55	191	21	57	-16	-82	-4	-2	-2	-10	19	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3		
EVAPORATION	128							10	31	32	22	10	5	5	13		
REG INFLOW	13099	428	291	409	1296	1523	1549	1687	1500	533	511	229	108	123	1023	822	1068
RELEASE	13103	167	148	392	1296	1523	1549	1687	1674	1611	511	229	108	123	750	732	604
STOR CHANGE	-4	262	143	17				0	-174	-1078	0	0	0	0	273	90	464
STORAGE	3128	3389	3532	3549	3549	3549	3549	3549	3375	2297	2296	2296	2296	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1337.5	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	10.4	5.6	10.7	22.0	21.8	24.8	26.0	27.4	27.2	27.1	8.3	7.7	7.7	7.7	12.2	11.9	10.5
POWER																	
AVE POWER MW		46	90	185	184	209	219	231	227	209	61	56	57	57	91	91	83
PEAK POW MW		349	354	355	355	355	355	355	348	282	283	283	283	283	305	311	338
ENERGY GWH	1288.1	16.7	15.1	40.0	132.4	155.3	157.8	171.7	169.0	150.8	45.2	20.3	9.5	10.9	67.6	67.7	57.9
--GAVINS POINT--																	
NAT INFLOW	1252	91	42	55	125	137	144	79	79	57	109	47	22	25	70	68	102
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-6	-2	-3	0	0	35	1	0	0	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	14193	267	181	425	1416	1636	1666	1722	1735	1662	643	268	125	143	797	799	709
RELEASE	14193	267	181	425	1416	1636	1666	1722	1722	1636	643	268	125	143	797	799	748
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	26.6	28.0	28.0	28.0	27.5	10.5	9					

29FEB08		2008																2009			
INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB					
-- FORT PECK --																					
NAT INFLOW	5961	274	128	164	602	915	1164	513	296	283	374	185	86	99	317	240	321				
DEPLETION	419	-3	-1	-2	76	310	486	173	-34	-125	-62	-35	-16	-19	-110	-127	-92				
EVAPORATION	396							24	75	94	83	38	18	20	43						
MOD INFLOW	5146	277	129	166	526	605	678	316	255	314	353	182	85	97	384	367	413				
RELEASE	5043	119	56	71	298	430	536	553	553	283	248	120	69	127	553	553	472				
STOR CHANGE	103	158	74	95	228	175	142	-238	-299	31	105	62	16	-30	-170	-186	-59				
STORAGE	8412	8570	8644	8738	8967	9141	9284	9046	8747	8778	8883	8945	8961	8931	8761	8575	8516				
ELEV FTMSL	2196.0	2197.1	2197.6	2198.3	2199.8	2201.0	2201.9	2200.3	2198.3	2198.5	2199.3	2199.7	2199.8	2199.6	2198.4	2197.2	2196.7				
DISCH KCFS	9.0	4.0	4.0	4.0	5.0	7.0	9.0	9.0	9.0	4.8	4.0	4.0	5.0	8.0	9.0	9.0	8.5				
POWER																					
AVE POWER MW		46	46	46	58	82	106	106	105	55	47	47	59	93	105	104	97				
PEAK POW MW		165	166	167	169	171	172	170	167	167	168	169	169	169	167	165	164				
ENERGY GWH	710.5	16.6	7.8	10.0	42.0	61.1	76.3	78.7	78.0	39.8	35.1	17.0	9.8	17.9	16.8	77.2	65.5				
-- GARRISON --																					
NAT INFLOW	9293	344	160	206	891	1150	2572	1626	460	353	496	205	96	109	137	204	284				
DEPLETION	1088	0	0	0		212	744	530	79	-128	-8	-95	-44	-50	-73	-51	-29				
CHAN STOR	6	56			-11	-22	-22			47	8	0	-11	-33	-11		6				
EVAPORATION	472							29	90	113	99	45	21	24	51						
REG INFLOW	12782	519	216	277	1177	1346	2341	1621	844	698	661	375	178	230	701	808	791				
RELEASE	12668	387	167	214	893	1138	1339	1353	1322	634	646	312	146	286	1168	1414	1250				
STOR CHANGE	115	132	49	63	285	209	1002	268	-478	63	16	62	32	-56	-467	-606	-459				
STORAGE	10096	10228	10277	10340	10624	10833	11835	12103	11625	11688	11704	11766	11798	11742	11275	10669	10210				
ELEV FTMSL	1806.1	1806.8	1807.0	1807.3	1808.6	1809.6	1814.0	1815.2	1813.1	1813.4	1813.5	1813.7	1813.9	1813.6	1811.6	1808.8	1806.7				
DISCH KCFS	21.5	13.0	12.0	12.0	15.0	18.5	22.5	22.0	21.5	10.7	10.5	10.5	10.5	18.0	19.0	23.0	22.5				
POWER																					
AVE POWER MW		130	121	121	152	189	234	234	228	113	111	112	112	190	199	236	226				
PEAK POW MW		354	355	356	361	364	381	385	377	378	378	379	380	379	372	362	354				
ENERGY GWH	1590.4	46.9	20.3	26.2	109.5	140.4	168.4	173.8	169.3	81.4	83.0	40.2	18.8	36.6	148.2	175.5	152.1				
-- OAHE --																					
NAT INFLOW	1429	269	125	161	249	136	293	112	29	87	7	-7	-3	-4	-65	-16	56				
DEPLETION	641	23	11	14	48	68	135	160	106	26	-9	2	1	1	12	17	27				
CHAN STOR	-5	46	5		-16	-19	-22		3	3	60	1	0	-42	-6	-22	3				
EVAPORATION	383							24	73	92	80	36	17	19	42						
REG INFLOW	13067	678	286	361	1078	1187	1475	1284	1174	664	583	268	125	220	1044	1359	1281				
RELEASE	12933	343	251	356	1230	1476	1366	1702	1511	627	646	256	120	137	1053	835	1025				
STOR CHANGE	134	335	36	5	-152	-290	110	-418	-337	37	-63	12	5	82	-9	524	257				
STORAGE	10628	10964	10999	11005	10853	10563	10673	10255	9918	9955	9892	9904	9908	9991	9981	10506	10762				
ELEV FTMSL	1574.7	1576.4	1576.6	1576.6	1575.8	1574.4	1574.9	1572.8	1571.0	1571.2	1570.8	1570.9	1570.9	1571.4	1571.3	1574.1	1575.4				
DISCH KCFS	18.3	11.5	18.1	19.9	20.7	24.0	22.9	27.7	24.6	10.5	10.5	8.6	8.7	8.7	17.1	13.6	18.4				
POWER																					
AVE POWER MW		125	196	216	223	257	245	294	258	111	110	90	91	91	180	144	198				
PEAK POW MW		550	551	551	547	539	542	531	521	523	521	521	521	523	523	538	545				
ENERGY GWH	1665.2	44.8	32.9	46.7	160.9	191.5	176.7	218.7	192.0	79.7	82.0	32.6	15.3	17.5	133.7	107.1	132.9				
-- BIG BEND --																					
EVAPORATION	129							8	24	31	27	12	6	7	14						
REG INFLOW	12804	343	251	356	1230	1476	1366	1694	1487	596	619	244	115	131	1039	835	1025				
RELEASE	12804	343	251	356	1230	1476	1366	1694	1487	596	619	244	115	131	1039	835	1025				
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682				
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0				
DISCH KCFS	18.3	11.5	18.1	19.9	20.7	24.0	22.9	27.5	24.2	10.0	10.1	8.2	8.3	8.2	16.9	13.6	18.4				
POWER																					
AVE POWER MW		55	85	93	97	112	107	129	114	51	51	42	42	42	84	67	88				
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	529				
ENERGY GWH	742.3	19.6	14.2	20.2	69.7	83.6	77.4	95.9	85.1	36.5	37.9	15.0	7.0	8.0	62.6	50.0	59.5				
-- FORT RANDALL --																					
NAT INFLOW	489	90	42	54	70	56	195	21	59	-16	-84	-4	-2	-2	-10	20					
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3					
EVAPORATION	128							10	31	32	22	10	5	5	13						
REG INFLOW	13077	431	292	409	1296	1523	1549	1687	1500	533	511	229	108	123	1023	822	1042				
RELEASE	13077	167	148	392	1296	1523	1549	1687	1674	1611	511	229	108	123	750	732	578				
STOR CHANGE	0	265	144	17				0	-174	-1078	0	0	0	0	273	90	464				
STORAGE	3123	3388	3532	3549	3549	3549	3549	3549	3375	2297	2296	2296	2296	2296	2569	2659	3123				
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1337.5	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0				
DISCH KCFS	10.5	5.6	10.7	22.0	21.8	24.8	26.0	27.4	27.2	27.1	8.3	7.7	7.7	7.7	12.2	11.9	10.4				
POWER																					
AVE POWER MW		46	90	185	184	209	219	231	227	209	61	56	57	57	91	91	82				
PEAK POW MW		349	354	355	355	355	355	355	348	282	283	283	283	283	305	311	338				
ENERGY GWH	1285.5	16.7	15.1	40.0	132.4	155.3	157.8	171.7	169.0	150.8	45.2	20.3	9.5	10.9	67.6	67.7	55.4				
-- GAVINS POINT --																					
NAT INFLOW	1252	91	42	55	125	137	144	79	57	109	47	22	25	70	68	102					
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1					
CHAN STOR	-1	9	-10	-22	0	-6	-2	-3	0	35	1	0	0	-8	1	3					
EVAPORATION	47							3	9	11	10	5	2	2	5						
REG INFLOW	14167	267	181	425	1416	1															

	28FEB03	15MAR	2003	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2004	31DEC	31JAN	29FEB
	INI-SUM		22MAR											30NOV			
-- FORT PECK--																	
NAT INFLOW	8901	296	138	178	739	1487	2309	1130	423	351	492	195	91	104	321	276	371
DEPLETION	215	-31	-15	-19	69	291	489	139	-95	-105	-73	-27	-12	-14	-125	-150	-107
EVAPORATION	331							19	62	79	70	32	15	17	37		
MOD INFLOW	8355	328	153	196	670	1196	1820	972	456	377	495	190	88	101	409	426	478
RELEASE	4784	149	56	71	238	369	536	523	293	251	121	57	95	492	523	489	
STOR CHANGE	3570	179	97	125	432	827	1284	449	-67	84	244	68	32	6	-83	97	-11
STORAGE	11113	11292	11389	11514	11946	12773	14058	14507	14439	14523	14768	14836	14868	14874	14791	14694	14683
ELEV FTMSL	2213.3	2214.3	2214.9	2215.6	2218.1	2222.7	2229.4	2231.7	2231.3	2231.7	2232.9	2233.2	2233.4	2233.4	2233.0	2232.6	2232.5
DISCH KCFS	13.0	5.0	4.0	4.0	4.0	6.0	9.0	8.5	8.5	4.9	4.1	4.1	4.1	6.0	8.0	8.5	8.5
POWER																	
AVE POWER MW		63	51	51	51	78	120	115	115	67	55	56	56	82	109	115	115
PEAK POW MW		144	145	145	148	153	159	160	160	161	161	162	162	162	162	161	161
ENERGY GWH	775.5	22.7	8.5	11.0	36.9	58.1	86.1	85.3	85.5	48.1	41.2	20.0	9.3	15.7	80.9	85.9	80.3
-- GARRISON--																	
NAT INFLOW	12901	482	225	289	1250	1723	3207	2405	764	522	593	236	110	126	260	316	394
DEPLETION	1206	34	16	20	9	310	907	514	51	-121	-2	-94	-44	-50	-138	-120	-87
CHAN STOR	49	85	11			-21	-31	5		36	9			-19	-20	-5	0
EVAPORATION	354							21	68	85	74	34	16	18	39		
REG INFLOW	16174	682	275	340	1479	1761	2804	2398	1168	887	780	417	195	234	831	954	970
RELEASE	13701	476	208	268	1071	1261	1339	1353	1322	961	782	379	177	286	1230	1353	1237
STOR CHANGE	2473	206	67	72	408	500	1465	1045	-154	-74	-2	39	18	-52	-399	-399	-267
STORAGE	13366	13572	13639	13711	14119	14619	16085	17130	16976	16902	16899	16938	16956	16904	16505	16106	15839
ELEV FTMSL	1820.4	1821.2	1821.4	1821.7	1823.3	1825.2	1830.6	1834.2	1833.7	1833.4	1833.4	1833.6	1833.6	1833.5	1832.1	1830.7	1829.7
DISCH KCFS	24.0	16.0	15.0	15.0	18.0	20.5	22.5	22.0	21.5	16.1	12.7	12.7	12.7	18.0	20.0	22.0	21.5
POWER																	
AVE POWER MW		179	169	169	204	235	263	265	262	197	155	155	156	219	242	264	256
PEAK POW MW		330	331	331	336	342	357	368	366	366	366	366	366	366	362	358	355
ENERGY GWH	1968.2	64.5	28.4	36.5	146.8	174.5	189.7	197.4	194.9	141.8	115.6	56.0	26.1	42.1	180.0	196.1	177.9
-- OAHE--																	
NAT INFLOW	3200	460	214	276	394	285	749	246	103	135	85	91	42	48	18	5	49
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2	1	1	11	15	25
CHAN STOR	13	38	5	0	-14	-11	-9	2	2	23	15	0		-23	-9	-9	2
EVAPORATION	345							21	67	83	72	32	15	17	38		
REG INFLOW	15999	952	417	530	1406	1472	1959	1441	1270	1013	818	435	203	293	1191	1334	1263
RELEASE	12622	434	70	249	792	975	907	1501	1654	1444	951	460	213	194	1093	948	734
STOR CHANGE	3377	518	347	282	614	497	1052	-59	-384	-432	-134	-25	-10	99	98	386	528
STORAGE	14003	14521	14868	15150	15764	16261	17313	17254	16869	16438	16304	16279	16270	16368	16466	16852	17380
ELEV FTMSL	1590.0	1592.1	1593.5	1594.5	1596.9	1598.7	1602.4	1602.2	1600.9	1599.3	1598.9	1598.8	1598.7	1599.1	1599.4	1600.8	1602.7
DISCH KCFS	15.2	14.6	5.1	13.9	13.3	15.9	15.3	24.4	26.9	24.3	15.5	15.5	15.3	12.2	17.8	15.4	12.8
POWER																	
AVE POWER MW		173	61	168	162	195	190	306	336	301	191	191	189	152	220	192	160
PEAK POW MW		631	638	643	655	664	684	682	675	667	665	664	664	666	668	675	685
ENERGY GWH	1892.4	62.2	10.2	36.2	116.5	145.0	137.0	228.0	250.1	216.8	142.4	68.8	31.8	29.1	163.7	142.8	111.7
-- BIG BEND--																	
EVAPORATION	78							5	15	19	16	7	3	4	9		
REG INFLOW	12544	434	70	249	792	975	907	1496	1640	1426	935	453	209	190	1084	948	734
RELEASE	12544	434	70	249	792	975	907	1496	1640	1426	935	453	209	190	1084	948	734
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	15.2	14.6	5.1	13.9	13.3	15.9	15.3	24.3	26.7	24.0	15.2	15.2	15.1	12.0	17.6	15.4	12.8
POWER																	
AVE POWER MW		68	24	65	62	74	71	114	125	114	75	77	76	61	87	75	61
PEAK POW MW		510	509	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	724.6	24.6	4.0	14.1	44.9	55.3	51.4	84.7	92.9	81.8	55.6	27.6	12.8	11.6	64.8	56.0	42.7
-- FORT RANDALL--																	
NAT INFLOW	1200	142	66	85	239	150	195	89	65	64	38	3	1	1	18	5	39
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	88							6	19	24	19	7	3	3	8		
REG INFLOW	13576	575	136	333	1027	1116	1090	1561	1671	1459	953	447	207	188	1092	950	770
RELEASE	13576	167	119	333	1027	1116	1090	1561	1671	1603	1583	757	354	210	726	713	546
STOR CHANGE	0	408	17					0	0	-144	-630	-310	-146	-22	366	237	224
STORAGE	3124	3532	3549	3549	3549	3549	3549	3549	3549	3405	2775	2465	2319	2297	2663	2900	3124
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.2	1340.4	1337.9	1337.5	1343.5	1347.0	1350.0
DISCH KCFS	9.5	5.6	8.5	18.6	17.3	18.2	18.3	25.4	27.2	26.9	25.7	25.4	25.5	13.2	11.8	11.6	9.5
POWER																	
AVE POWER MW		47	73	158	146	154	155	214	229	225	207	193	187	97	88	91	77
PEAK POW MW		354	355	355	355	355	355	355	355	349	318	297	285	284	311	327	338
ENERGY GWH	1345.3	16.9	12.2	34.1	105.3	114.3	111.7	159.1	170.1	162.1	153.6	69.4	31.4	18.5	65.8	67.5	53.3
-- GAVINS POINT--																	
NAT INFLOW	1899	93	44	56	207	257	237	178	144	114	132	51	24	27	86	89	161
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	7	-6	-19	3	-2	0	-14	-3	0	2	1	0	23	3	0	4
EVAPORATION	28							2	5	7	6	3	1	1	3		
REG INFLOW	15332	268	157	370	1232	1353	1303	1685	1796	1716	1709	800	373	256	801	802	711
RELEASE	15332	268	157	370	1232	1353	1303	1685	1783	1690	1709	800	373	256	801	802	750
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	11.3	20.7	20.7												

DATE OF STUDY	01/10/03	2002-2003 AOP MEDIAN RUNOFF SIMULATION													99001	9901	4	PAGE	1
TIME OF STUDY	09:48:18	CWCP, FLOW TO TARGET, 5-DAY SHORTENED SEASON													STUDY NO				26
	28FEB03	2003											2004						
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB		
-- FORT PECK--																			
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349		
DEPLETION	122	-3	-1	-2	70	304	316	138	-87	-99	-64	-33	-15	-17	-122	-149	-114		
EVAPORATION	391							24	74	93	82	37	17	20	43				
MOD INFLOW	6887	267	125	160	558	906	1535	667	337	325	380	183	85	97	389	410	463		
RELEASE	5575	179	69	89	357	430	536	553	348	270	131	97	127	615	646	575			
STOR CHANGE	1312	89	55	71	201	476	999	114	-217	-23	110	52	-12	-29	-226	-236	-112		
STORAGE	10937	11026	11081	11152	11353	11829	12828	12942	12725	12702	12812	12864	12852	12822	12597	12361	12249		
ELEV FTMSL	2212.2	2212.8	2213.1	2213.5	2214.7	2217.4	2223.0	2223.6	2222.4	2222.3	2222.9	2223.2	2223.1	2223.0	2221.7	2220.4	2219.8		
DISCH KCFS	11.0	6.0	5.0	5.0	6.0	7.0	9.0	9.0	9.0	5.8	4.4	4.4	7.0	8.0	10.0	10.5	10.0		
POWER																			
AVE POWER MW		75	63	63	76	89	117	118	118	77	58	58	92	105	130	135	129		
PEAK POW MW		142	143	143	144	148	153	154	153	153	154	154	154	153	152	151	150		
ENERGY GWH	873.7	27.1	10.6	13.6	54.6	66.3	84.0	88.0	87.9	55.2	42.9	20.9	15.5	20.2	97.0	100.2	89.8		
-- GARRISON--																			
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326		
DEPLETION	1503	50	23	30	129	277	828	556	81	-89	34	-92	-43	-49	-102	-80	-51		
CHAN STOR	11	54	11		-11	-11	-21			32	15	0	-27	-10	-21	-5	5		
EVAPORATION	452							27	87	109	95	43	20	23	49				
REG INFLOW	14633	651	276	341	1070	1566	2644	2036	967	857	610	371	183	245	900	957	957		
RELEASE	13019	476	208	268	1012	1107	1250	1261	1230	948	740	358	236	286	1230	1261	1150		
STOR CHANGE	1614	175	67	73	59	459	1395	776	-263	-91	-130	13	-53	-41	-329	-303	-193		
STORAGE	13151	13326	13394	13467	13525	13984	15379	16155	15892	15801	15671	15684	15631	15590	15261	14958	14765		
ELEV FTMSL	1819.5	1820.2	1820.5	1820.8	1821.0	1822.8	1828.1	1830.8	1829.9	1829.6	1829.1	1829.2	1829.0	1828.8	1827.6	1826.5	1825.8		
DISCH KCFS	23.0	16.0	15.0	15.0	17.0	18.0	21.0	20.5	20.0	15.9	12.0	12.0	17.0	18.0	20.0	20.5	20.0		
POWER																			
AVE POWER MW		178	168	168	191	203	242	243	238	190	143	143	201	213	235	239	232		
PEAK POW MW		327	328	329	329	335	350	358	355	354	353	353	353	352	349	345	343		
ENERGY GWH	1832.0	64.1	28.2	36.3	137.2	151.0	174.3	180.6	177.3	136.5	106.6	51.5	33.8	40.8	174.8	177.8	161.3		
-- OAHE--																			
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20		40		
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2	1	1	11	15	25		
CHAN STOR	15	33	5	0	-9	-5	-14	2	2	18	18	0	-23	-5	-9	-2	2		
EVAPORATION	418							26	81	100	87	39	18	21	46				
REG INFLOW	14345	804	350	445	1321	1276	1805	1260	1094	961	692	323	196	262	1144	1243	1168		
RELEASE	12707	337	196	261	977	1069	988	1498	1604	1393	912	275	214	111	961	972	939		
STOR CHANGE	1638	468	154	184	344	207	817	-238	-511	-431	-220	47	-17	151	183	271	229		
STORAGE	13767	14234	14388	14572	14916	15124	15940	15703	15192	14761	14541	14589	14572	14723	14905	15176	15405		
ELEV FTMSL	1589.0	1590.9	1591.6	1592.3	1593.6	1594.4	1597.5	1596.7	1594.7	1593.0	1592.2	1592.4	1592.3	1592.9	1593.6	1594.6	1595.5		
DISCH KCFS	15.7	11.3	14.2	14.6	16.4	17.4	16.6	24.4	26.1	23.4	14.8	9.3	15.4	7.0	15.6	15.8	16.3		
POWER																			
AVE POWER MW		133	168	174	196	209	202	297	316	281	177	110	183	84	187	190	197		
PEAK POW MW		626	629	632	639	643	658	654	644	636	632	633	632	635	639	644	648		
ENERGY GWH	1850.6	48.0	28.2	37.5	141.3	155.6	145.4	221.1	234.8	202.0	131.8	39.8	30.8	16.0	139.3	141.6	137.5		
-- BIG BEND--																			
EVAPORATION	103							6	20	25	22	10	5	5	11				
REG INFLOW	12604	337	196	261	977	1069	988	1492	1584	1368	890	265	209	106	950	972	939		
RELEASE	12604	337	196	261	977	1069	988	1492	1584	1368	890	265	209	106	950	972	939		
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682		
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0		
DISCH KCFS	15.7	11.3	14.2	14.6	16.4	17.4	16.6	24.3	25.8	23.0	14.5	8.9	15.1	6.7	15.4	15.8	16.3		
POWER																			
AVE POWER MW		54	66	68	77	81	78	114	121	109	71	45	76	34	77	78	78		
PEAK POW MW		517	509	509	509	509	509	509	509	518	538	538	538	538	538	538	529		
ENERGY GWH	728.2	19.3	11.1	14.8	55.3	60.6	56.0	84.5	89.7	78.3	53.0	16.3	12.8	6.5	57.6	57.9	54.5		
-- FORT RANDALL--																			
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19		
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3		
EVAPORATION	116							8	25	31	25	9	4	4	10				
REG INFLOW	13306	458	253	333	1088	1200	1161	1540	1601	1371	867	256	205	102	947	969	955		
RELEASE	13307	167	119	333	1088	1200	1161	1540	1601	1535	1484	705	227	102	744	719	581		
STOR CHANGE	0	291	134					0	0	-164	-617	-449	-22	0	203	250	374		
STORAGE	3124	3415	3549	3549	3549	3549	3549	3549	3549	3385	2768	2319	2297	2297	2500	2750	3124		
ELEV FTMSL	1350.0	1353.6	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.2	1345.1	1337.9	1337.5	1337.5	1341.0	1344.8	1350.0		
DISCH KCFS	10.0	5.6	8.6	18.7	18.3	19.5	19.5	25.0	26.0	25.8	24.1	23.7	16.3	6.5	12.1	11.7	10.1		
POWER																			
AVE POWER MW		47	73	158	155	165	165	211	219	216	193	178	119	47	90	90	81		
PEAK POW MW		350	355	355	355	355	355	355	355	349	318	285	284	283	300	317	338		
ENERGY GWH	1317.8	16.8	12.2	34.1	111.4	122.8	118.8	157.0	163.1	155.2	143.9	63.9	20.0	9.1	66.7	66.7	56.1		
-- GAVINS POINT--																			
NAT INFLOW	1450	92	43	55	148	174	166	86	103	77	122	50	23	27	77	79	127		
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1			
CHAN STOR	-1	8	-6	-19	1	-2	0	-11	-2	0	3	1	14	18	-10	1	3		
EVAPORATION	38							2	7	9	8	2	2	4					
REG INFLOW	14604	268	157	370	1232	1353	1303	1574	1685	1609	1599	747	260	143	796	798	711		
RELEASE	14604	268	157	370	1232	1353	1303	1574	1672	1583	1599	747	260	143	796	798	750		
STOR CHANGE								13	26								-39		
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358		
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0		
DISCH KCFS	13.0	9.0	11.3	20.7	20.7	22.0	21.9	25.6	27.2	26.6	26.0	25.1	18.7	9.					

	28FEB05	15MAR	2005	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2006	31DEC	31JAN	28FEB
	INI-SUM		22MAR											30NOV			
--FORT PECK--																	
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349
DEPLETION	389	-2	-1	-1	56	331	556	190	-75	-143	-78	-40	-18	-21	-133	-139	-93
EVAPORATION	440							27	84	105	92	42	20	22	48		
MOD INFLOW	6571	266	124	160	572	879	1295	612	315	357	384	185	86	99	395	400	442
RELEASE	5953	149	62	80	298	492	762	553	523	413	332	161	111	143	615	676	583
STOR CHANGE	618	117	62	79	274	387	533	59	-208	-56	51	24	-25	-44	-220	-276	-141
STORAGE	13236	13354	13416	13495	13769	14156	14690	14749	14541	14485	14536	14561	14536	14492	14272	13996	13855
ELEV FTMSL	2225.2	2225.8	2226.1	2226.5	2228.0	2229.9	2232.5	2232.8	2231.8	2231.5	2231.8	2231.9	2231.8	2231.6	2230.5	2229.1	2228.4
DISCH KCFS	9.5	5.0	4.5	4.5	5.0	8.0	12.8	9.0	8.5	6.9	5.4	5.4	8.0	9.0	10.0	11.0	10.5
POWER																	
AVE POWER MW		66		60	67	107	96	122	115	94	73	73	108	121	135	147	140
PEAK POW MW		202	202	203	204	205	207	207	207	206	207	207	207	207	206	205	204
ENERGY GWH	913.5	23.9	10.0	12.9	48.0	79.7	69.0	90.6	85.5	67.5	54.4	26.3	18.2	23.3	100.2	109.7	94.3
--GARRISON--																	
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326
DEPLETION	894	1	0	1	7	184	786	512	29	-132	-3	-103	-48	-55	-117	-101	-67
CHAN STOR	-10	46	5		-5	-31	-49	38	5	15	15		-26	-10	-10	-10	5
EVAPORATION	513							31	99	124	108	49	23	26	55		
REG INFLOW	15536	663	286	361	1138	1700	2885	2114	981	934	697	407	200	264	920	1004	981
RELEASE	13878	476	222	286	1101	1261	1339	1353	1322	979	828	401	236	301	1230	1322	1222
STOR CHANGE	1658	187	64	76	38	440	1546	761	-341	-46	-131	6	-36	-37	-310	-318	-241
STORAGE	15969	16157	16221	16296	16334	16774	18320	19081	18740	18694	18563	18569	18533	18496	18186	17868	17628
ELEV FTMSL	1830.2	1830.8	1831.1	1831.3	1831.5	1833.0	1838.2	1840.6	1839.5	1839.4	1839.0	1839.0	1838.9	1838.7	1837.7	1836.7	1835.9
DISCH KCFS	22.5	16.0	16.0	16.0	18.5	20.5	22.5	22.0	21.5	16.5	13.5	13.5	17.0	19.0	20.0	21.5	22.0
POWER																	
AVE POWER MW		191	192	192	222	247	277	275	270	207	169	169	213	237	249	266	270
PEAK POW MW		358	359	360	360	364	380	478	474	473	472	472	471	471	467	463	461
ENERGY GWH	2073.4	68.9	32.2	41.5	159.9	183.9	199.3	204.9	201.1	148.9	126.0	60.9	35.8	45.6	185.2	197.7	181.6
--OAHE--																	
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20		40
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25
CHAN STOR	1	28			-11	-8	-8	2	2	21	13	0	-16	-9	-4	-7	-2
EVAPORATION	453							29	90	110	93	42	19	22	48		
REG INFLOW	15129	798	359	462	1408	1423	1894	1341	1171	985	770	363	203	272	1146	1299	1235
RELEASE	15191	582	138	336	1227	1327	1238	1769	1875	1674	1163	550	254	223	1112	909	813
STOR CHANGE	-62	216	221	126	181	96	655	-428	-704	-689	-393	-188	-51	49	34	390	421
STORAGE	16639	16856	17077	17203	17385	17481	18136	17708	17004	16315	15922	15734	15683	15732	15766	16156	16578
ELEV FTMSL	1600.1	1600.8	1601.6	1602.1	1602.7	1603.0	1605.2	1603.8	1601.4	1598.9	1597.5	1596.8	1596.6	1596.8	1596.9	1598.3	1599.9
DISCH KCFS	15.9	19.6	10.0	18.8	20.6	21.6	20.8	28.8	30.5	28.1	18.9	18.5	18.3	14.1	18.1	14.8	14.6
POWER																	
AVE POWER MW		243	125	236	259	272	264	365	383	349	233	226	223	172	221	182	181
PEAK POW MW		675	679	682	685	687	698	691	678	665	658	654	653	654	655	662	670
ENERGY GWH	2292.4	87.6	21.0	51.0	186.7	202.5	190.2	271.6	284.7	251.1	173.0	81.4	37.4	33.0	164.3	135.1	121.8
--BIG BEND--																	
EVAPORATION	103							6	20	25	22	10	5	5	11		
REG INFLOW	15088	582	138	336	1227	1327	1238	1763	1855	1650	1141	541	249	218	1101	909	813
RELEASE	15088	582	138	336	1227	1327	1238	1763	1855	1650	1141	541	249	218	1101	909	813
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	15.9	19.6	10.0	18.8	20.6	21.6	20.8	28.7	30.2	27.7	18.6	18.2	17.9	13.7	17.9	14.8	14.6
POWER																	
AVE POWER MW		92	47	88	97	101	97	134	141	131	91	91	90	69	88	72	70
PEAK POW MW		510	509	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	870.1	33.0	7.8	19.0	69.5	75.2	70.1	99.8	105.0	94.6	67.7	32.8	15.2	13.3	65.8	53.8	47.2
--FORT RANDALL--																	
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	118							8	25	31	25	10	4	4	10		
REG INFLOW	15791	703	195	408	1338	1458	1411	1811	1872	1653	1117	532	245	214	1098	906	829
RELEASE	15790	295	178	408	1338	1458	1411	1811	1872	1797	1754	836	390	236	732	719	555
STOR CHANGE	0	408	17					0	-144	-637	-304	-145	-22	366	187	274	
STORAGE	3124	3532	3549	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2850	3124
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1346.3	1350.0
DISCH KCFS	10.0	9.9	12.8	22.9	22.5	23.7	23.7	29.4	30.4	30.2	28.5	28.1	28.1	14.9	11.9	11.7	10.0
POWER																	
AVE POWER MW		82	109	193	190	200	200	247	256	252	228	212	206	108	89	91	80
PEAK POW MW		354	355	355	355	355	355	355	355	349	318	297	285	284	311	324	338
ENERGY GWH	1564.4	29.7	18.3	41.7	136.6	148.8	144.0	184.1	190.2	181.4	169.8	76.4	34.5	20.8	66.4	67.9	54.0
--GAVINS POINT--																	
NAT INFLOW	1450	92	43	55	148	174	166	86	103	77	122	50	23	27	77	79	127
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	0	-6	-19	1	-2	0	-11	-2	0	3	1	0	25	5	0	
EVAPORATION	38							2	7	9	8	4	2	2	4		
REG INFLOW	17087	388	216	445	1482	1611	1553	1845	1956	1871	1869	878	410	282	800	798	686
RELEASE	17087	388	216	445	1482	1611	1553	1845	1943	1845	1869	878	410	282	800	798	725
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0																

	VALUES IN 1000 AF EXCEPT AS INDICATED																
	28FEB06 INI-SUM	15MAR	2006			30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2007		28FEB
			22MAR	31MAR										30NOV	31DEC	31JAN	
--FORT PECK--																	
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349
DEPLETION	389	-2	-1	-1	56	331	556	190	-75	-143	-78	-40	-18	-21	-133	-139	-93
EVAPORATION	436							27	84	105	91	41	19	22	47		
MOD INFLOW	6575	266	124	160	572	879	1295	612	315	357	385	186	87	99	396	400	442
RELEASE	6853	179	69	89	417	492	1083	646	615	498	401	194	111	159	615	676	611
STOR CHANGE	-278	88	55	70	155	387	212	-33	-300	-140	-16	-8	-24	-59	-219	-276	-169
STORAGE	13855	13942	13997	14068	14223	14610	14822	14789	14489	14349	14333	14325	14301	14241	14022	13746	13577
ELEV FTMSL	2228.4	2228.8	2229.3	2229.5	2230.3	2232.2	2233.2	2233.0	2231.6	2230.9	2230.8	2230.8	2230.6	2230.3	2229.3	2227.8	2227.0
DISCH KCFS	10.5	6.0	5.0	5.0	7.0	8.0	18.2	10.5	10.0	8.4	6.5	6.5	8.0	10.0	10.0	11.0	11.0
POWER																	
AVE POWER MW		80	67	67	94	108	56	142	135	113	88	88	108	134	134	147	146
PEAK POW MW		204	205	205	206	207	207	208	207	206	206	206	206	206	205	204	203
ENERGY GWH	978.8	28.9	11.3	14.5	67.7	80.2	40.6	105.8	100.6	81.1	65.3	31.6	18.1	25.8	99.8	109.2	98.3
--GARRISON--																	
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326
DEPLETION	968	-7	-3	-4	-8	214	816	569	35	-135	-8	-107	-50	-57	-119	-102	-67
CHAN STOR	7	45	10		-20	-10	-101	75	5	16	18		-15	-20	0	-10	0
EVAPORATION	518							32	102	126	108	48	22	25	55		
REG INFLOW	16361	700	302	375	1258	1691	3124	2185	1064	1020	773	444	213	272	932	1005	1004
RELEASE	16992	536	250	214	1369	1660	1666	1691	1660	1470	1139	551	257	317	1230	1537	1444
STOR CHANGE	-632	164	52	161	-111	31	1457	494	-596	-450	-366	-108	-44	-45	-298	-532	-440
STORAGE	17628	17792	17843	18004	17893	17924	19381	19876	19279	18829	18462	18355	18311	18266	17968	17436	16996
ELEV FTMSL	1835.9	1836.5	1836.6	1837.2	1836.8	1836.9	1841.5	1843.0	1841.2	1839.8	1838.6	1838.3	1838.2	1838.0	1837.0	1835.3	1833.8
DISCH KCFS	22.0	18.0	18.0	12.0	23.0	27.0	28.0	27.5	27.0	24.7	18.5	18.5	18.5	20.0	20.0	25.0	26.0
POWER																	
AVE POWER MW		222	222	149	284	332	349	348	342	311	232	231	231	249	248	306	315
PEAK POW MW		463	463	465	464	464	481	491	479	475	470	469	469	468	465	458	453
ENERGY GWH	2555.2	79.7	37.3	32.1	204.2	247.0	251.4	258.9	254.1	223.9	172.8	83.2	38.8	47.8	184.4	227.9	211.8
--OAHE--																	
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20		40
DEPLETION	613	23	11	14	47	66	129	151	100	25	-8	2	1	1	11	16	26
CHAN STOR	-17	17		25	-46	-17	-4	2	2	9	25	0	0	-6	0	-21	-4
EVAPORATION	486							30	94	117	101	45	21	24	53		
REG INFLOW	18177	847	387	416	1639	1814	2222	1674	1501	1456	1086	509	238	289	1146	1500	1454
RELEASE	15918	582	153	366	1322	1426	1333	1848	1955	1752	1243	589	272	244	1112	939	783
STOR CHANGE	2259	265	234	50	317	388	889	-175	-454	-296	-157	-80	-34	45	34	561	671
STORAGE	16578	16843	17077	17127	17444	17832	18721	18546	18093	17797	17640	17560	17526	17572	17605	18167	18837
ELEV FTMSL	1599.9	1600.8	1601.6	1601.8	1602.9	1604.2	1607.1	1606.6	1605.1	1604.1	1603.6	1603.3	1603.2	1603.3	1603.4	1605.3	1607.5
DISCH KCFS	14.6	19.5	11.0	20.5	22.2	23.2	22.4	30.1	31.8	29.4	20.2	19.8	19.6	15.4	18.1	15.3	14.1
POWER																	
AVE POWER MW		243	138	257	279	293	287	386	406	374	256	251	247	194	229	195	182
PEAK POW MW		675	679	680	686	693	709	705	698	692	689	688	687	688	689	699	710
ENERGY GWH	2447.4	87.6	23.2	55.4	201.0	218.2	206.5	287.3	302.0	269.0	190.6	90.2	41.6	37.3	170.4	144.8	122.2
--BIG BEND--																	
EVAPORATION	103							6	20	25	22	10	5	5	11		
REG INFLOW	15814	582	153	366	1322	1426	1333	1842	1935	1727	1221	579	267	238	1101	939	783
RELEASE	15814	582	153	366	1322	1426	1333	1842	1935	1727	1221	579	267	238	1101	939	783
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	14.6	19.5	11.0	20.5	22.2	23.2	22.4	30.0	31.5	29.0	19.9	19.5	19.2	15.0	17.9	15.3	14.1
POWER																	
AVE POWER MW		92	52	96	104	109	105	140	147	138	97	98	97	76	88	75	68
PEAK POW MW		510	509	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	911.6	33.0	8.7	20.7	74.9	80.8	75.5	104.3	109.6	99.0	72.4	35.1	16.2	14.5	65.8	55.5	45.5
--FORT RANDALL--																	
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	118						8	25	31	25	10	4	4	10			
REG INFLOW	16517	703	209	438	1433	1557	1506	1890	1952	1731	1197	570	263	235	1098	936	799
RELEASE	16517	295	192	438	1433	1557	1506	1890	1952	1875	1834	874	408	257	732	719	555
STOR CHANGE		408	17	0	0	0	0	0	-144	-637	-304	-145	-22	366	217	244	
STORAGE	3124	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2880	3124	
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1345.1	1340.4	1337.9	1337.5	1343.5	1346.7	1350.0	
DISCH KCFS	10.0	9.9	13.9	24.5	24.1	25.3	25.3	30.7	31.7	31.5	29.8	29.4	16.2	11.9	11.7	10.0	
POWER																	
AVE POWER MW		82	118	207	203	213	213	258	266	263	238	222	215	118	89	91	80
PEAK POW MW		354	355	355	355	355	355	355	355	349	318	297	285	284	311	326	338
ENERGY GWH	1636.1	29.7	19.7	44.7	146.2	158.7	153.5	192.0	198.1	189.0	177.4	79.9	36.1	22.6	66.4	68.0	54.0
--GAVINS POINT--																	
NAT INFLOW	1450	92	43	55	148	174	166	86	77	77	122	50	23	27	77	79	127
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	0	-8	-20	1	-2	0	-10	-2	0	3	1	0	25	8	0	3
EVAPORATION	38						2	7	9	8	4	2	2	4			
REG INFLOW	17814	388	228	473	1577	1709	1648	1925	2036	1948	1949	916	428	303	802	798	686
RELEASE	17814	388	228	473	1577	1709	1648	1925	2023	1922	1949	916	428	303	802	798	725
STOR CHANGE									13	26							

	VALUES IN 1000 AF EXCEPT AS INDICATED																
	29FEB04 INI-SUM	15MAR	2004 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2005 30NOV	31DEC	31JAN	28FEB
-- FORT PECK--																	
NAT INFLOW	6556	264	123	158	574	1011	1589	692	287	275	354	183	85	98	322	231	309
DEPLETION	345	3	2	2	74	295	438	167	-60	-130	-68	-32	-15	-17	-110	-121	-83
EVAPORATION	456							28	87	109	96	43	20	23	50		
MOD INFLOW	5755	261	122	156	500	716	1151	497	260	296	326	172	80	92	382	352	392
RELEASE	5523	134	62	80	417	492	536	553	553	338	284	137	67	143	584	615	528
STOR CHANGE	231	127	59	76	83	224	615	-56	-294	-42	42	34	13	-51	-202	-263	-136
STORAGE	10505	10632	10691	10767	10851	11075	11690	11634	11340	11298	11340	11375	11388	11337	11135	10872	10736
ELEV FTMSL	2209.6	2210.4	2210.8	2211.2	2211.7	2213.0	2216.6	2216.3	2214.6	2214.4	2214.6	2214.8	2214.9	2214.6	2213.4	2211.8	2211.0
DISCH KCFS	10.5	4.5	4.5	4.5	7.0	8.0	9.0	9.0	9.0	5.7	4.6	4.6	4.8	9.0	9.5	10.0	9.5
POWER																	
AVE POWER MW		56	56	56	87	100	113	114	114	72	58	58	61	113	119	125	118
PEAK POW MW		183	184	184	185	187	191	191	189	188	189	189	189	189	187	185	184
ENERGY GWH	837.6	20.0	9.4	12.1	62.5	74.1	81.6	85.0	84.6	51.6	43.4	21.0	10.2	21.8	88.6	92.6	79.1
-- GARRISON--																	
NAT INFLOW	10069	475	221	285	763	1282	2701	1891	532	446	428	175	82	93	238	177	280
DEPLETION	1463	45	21	27	84	234	815	571	57	-105	25	-81	-38	-43	-69	-52	-28
CHAN STOR	11	65			-27	-11	-11			35	11		-2	-44	-5	-5	5
EVAPORATION	536							33	104	130	112	50	23	27	58		
REG INFLOW	13604	629	263	338	1069	1529	2411	1841	924	794	586	343	161	208	828	839	841
RELEASE	13336	476	208	268	1012	1168	1250	1261	1230	1041	836	405	194	270	1230	1322	1166
STOR CHANGE	268	153	55	71	57	361	1161	580	-305	-246	-250	-62	-34	-62	-401	-483	-325
STORAGE	12642	12795	12850	12921	12978	13338	14500	15080	14775	14528	14278	14216	14182	14121	13719	13236	12910
ELEV FTMSL	1817.4	1818.1	1818.3	1818.6	1818.8	1820.3	1824.8	1827.0	1825.8	1824.9	1823.9	1823.7	1823.6	1823.3	1821.8	1819.8	1818.5
DISCH KCFS	21.5	16.0	15.0	15.0	17.0	19.0	21.0	20.5	20.0	17.5	13.6	13.6	14.0	17.0	20.0	21.5	21.0
POWER																	
AVE POWER MW		176	165	166	188	211	237	237	232	202	157	156	160	194	226	240	232
PEAK POW MW		321	321	322	323	327	340	347	343	341	338	337	337	336	331	326	322
ENERGY GWH	1823.3	63.2	27.8	35.7	135.1	156.7	170.9	176.4	172.7	145.4	116.4	56.1	26.9	37.2	168.3	178.6	155.9
-- OAHE--																	
NAT INFLOW	1761	187	87	112	278	158	701	124	29	79	11				-42	-7	44
DEPLETION	585	22	10	13	46	64	123	143	93	23	-8	2	1	1	11	16	25
CHAN STOR	2	27	5	0	-10	-10	-10		2	12	19	0	-2	-15	-15	-7	2
EVAPORATION	473							30	92	113	98	44	21	24	52		
REG INFLOW	14041	667	290	366	1234	1253	1818	1214	1076	996	777	359	171	230	1110	1292	1188
RELEASE	13769	348	239	353	1211	1374	1215	1706	1675	1306	745	470	98	136	1140	852	900
STOR CHANGE	272	319	51	13	23	-121	603	-493	-599	-310	32	-112	73	94	-30	440	288
STORAGE	13229	13548	13599	13612	13636	13514	14117	13625	13026	12716	12748	12637	12710	12804	12774	13214	13502
ELEV FTMSL	1586.8	1588.1	1588.3	1588.4	1588.5	1588.0	1590.5	1588.4	1585.9	1584.6	1584.7	1584.2	1584.5	1584.9	1584.8	1586.7	1587.9
DISCH KCFS	13.6	11.7	17.2	19.8	20.3	22.3	20.4	27.8	27.2	21.9	12.1	15.8	7.1	8.6	18.5	13.8	16.2
POWER																	
AVE POWER MW		136	200	230	237	260	239	324	314	251	138	180	81	98	212	159	188
PEAK POW MW		612	613	613	613	611	623	613	600	593	594	591	593	595	594	604	611
ENERGY GWH	1924.9	48.9	33.6	49.7	170.5	193.1	171.9	241.1	233.6	180.4	102.9	64.8	13.6	18.9	157.4	118.4	126.1
-- BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	13640	348	239	353	1211	1374	1215	1699	1651	1275	718	458	93	130	1126	852	900
RELEASE	13640	348	239	353	1211	1374	1215	1699	1651	1275	718	458	93	130	1126	852	900
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	13.6	11.7	17.2	19.8	20.3	22.3	20.4	27.6	26.8	21.4	11.7	15.4	6.7	8.2	18.3	13.8	16.2
POWER																	
AVE POWER MW		55	81	93	95	105	96	129	126	102	59	78	34	41	90	68	78
PEAK POW MW		517	510	509	509	509	509	509	509	525	538	538	538	538	538	538	529
ENERGY GWH	787.6	20.0	13.6	20.0	68.6	77.8	68.8	96.2	93.5	73.5	43.9	27.9	5.7	8.0	67.3	50.7	52.3
-- FORT RANDALL--																	
NAT INFLOW	643	88	41	53	82	66	167	33	63	30	2				6	-6	19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	141							10	32	38	27	10	5	5	13		
REG INFLOW	14058	434	279	405	1289	1431	1370	1704	1667	1259	686	447	88	124	1116	843	916
RELEASE	14059	161	145	388	1289	1431	1370	1704	1667	1606	1564	475	88	124	750	726	572
STOR CHANGE	-1	274	134	17				0	0	-347	-877	-28	0	0	366	117	344
STORAGE	3124	3398	3532	3549	3549	3549	3549	3549	3549	3202	2324	2297	2296	2296	2662	2779	3123
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.0	1338.0	1337.5	1337.5	1337.5	1343.5	1345.2	1350.0
DISCH KCFS	10.5	5.4	10.4	21.7	21.7	23.3	23.0	27.7	27.1	27.0	25.4	16.0	6.4	7.8	12.2	11.8	10.3
POWER																	
AVE POWER MW		45	88	183	183	196	194	233	228	223	196	116	47	57	91	92	82
PEAK POW MW		349	354	355	355	355	355	355	355	341	285	284	283	283	311	319	338
ENERGY GWH	1389.6	16.1	14.8	39.6	131.7	146.0	139.9	173.4	169.7	160.8	145.5	41.8	7.8	11.0	68.0	68.1	55.3
-- GAVINS POINT--																	
NAT INFLOW	1335	98	46	59	132	147	153	87	85	62	112	50	23	27	75	73	107
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	10	-10	-22	0	-3	0	-9	1	0	3	18	18	-3	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15232	269	181	425	1416	1556	1500	1740	1735	1662	1666	533	125	143	802	798	682
RELEASE	15232	269	181	425	1416	1556	1500	1740	1722	1636	1666	533	125	143	802	798	721
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	25.3	25.2	28.3	28.0	27.5	27.1	17.9	9.0	9.0	13.0	13.0	13.0

	VALUES IN 1000 AF EXCEPT AS INDICATED																
	28FEB05 INI-SUM	15MAR	2005 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2006 30NOV	31DEC	31JAN	28FEB
-- FORT PECK--																	
NAT INFLOW	6613	267	124	160	579	1019	1603	698	289	278	357	185	86	98	325	233	312
DEPLETION	387	-11	-5	-6	50	311	513	174	-57	-131	-72	-33	-15	-17	-110	-121	-83
EVAPORATION	464							28	89	111	97	44	21	24	51		
MOD INFLOW	5762	277	129	166	529	708	1090	496	257	298	332	173	81	92	384	354	395
RELEASE	5389	134	62	80	357	461	565	584	553	351	262	127	60	127	553	584	528
STOR CHANGE	373	143	67	86	172	247	525	-88	-296	-53	70	46	21	-35	-169	-230	-133
STORAGE	10736	10880	10947	11033	11205	11451	11976	11888	11592	11539	11609	11655	11676	11642	11472	11242	11110
ELEV FTMSL	2211.0	2211.9	2212.3	2212.8	2213.8	2215.3	2218.3	2217.8	2216.1	2215.8	2216.2	2216.4	2216.5	2216.4	2215.4	2214.0	2213.3
DISCH KCFS	9.5	4.5	4.5	4.5	6.0	7.5	9.5	9.5	9.0	5.9	4.3	4.3	4.3	8.0	9.0	9.5	9.5
POWER																	
AVE POWER MW		56	56	56	75	94	121	121	114	75	54	54	55	102	114	120	119
PEAK POW MW		185	186	186	188	190	194	193	191	190	191	191	191	191	190	188	187
ENERGY GWH	824.6	20.2	9.4	12.2	54.1	70.3	86.9	90.4	85.2	53.9	40.3	19.5	9.2	19.5	84.8	88.9	79.9
-- GARRISON--																	
NAT INFLOW	10134	478	223	287	768	1290	2718	1903	535	449	431	176	82	94	240	178	282
DEPLETION	983	14	7	8	28	202	732	491	55	-103	-1	-100	-46	-53	-105	-87	-59
CHAN STOR	0	54			-16	-16	-21		5	32	17		0	-39	-10	-5	
EVAPORATION	547							33	106	132	114	51	24	27	59		
REG INFLOW	13993	652	279	359	1081	1533	2530	1963	933	803	596	351	164	208	829	844	869
RELEASE	13524	476	194	250	982	1230	1339	1353	1322	955	797	386	194	270	1230	1353	1194
STOR CHANGE	469	176	85	109	99	303	1191	610	-389	-152	-201	-35	-31	-62	-401	-509	-325
STORAGE	12910	13086	13171	13279	13379	13682	14873	15483	15094	14942	14742	14707	14676	14614	14214	13705	13380
ELEV FTMSL	1818.5	1819.2	1819.6	1820.0	1820.4	1821.6	1826.2	1828.4	1827.0	1826.4	1825.7	1825.6	1825.4	1825.2	1823.7	1821.7	1820.4
DISCH KCFS	21.0	16.0	14.0	14.0	16.5	20.0	22.5	22.0	21.5	16.0	13.0	13.0	14.0	17.0	20.0	22.0	21.5
POWER																	
AVE POWER MW		177	156	156	184	224	256	255	250	186	150	149	161	195	228	247	239
PEAK POW MW		324	325	326	328	331	345	433	428	426	423	423	422	421	416	408	404
ENERGY GWH	1860.6	63.7	26.1	33.7	132.6	166.5	184.6	189.7	186.0	133.9	111.5	53.8	27.1	37.5	169.4	183.9	160.6
-- OAH--																	
NAT INFLOW	1794	190	89	114	283	161	714	127	30	80	11				-43	-7	45
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25
CHAN STOR	-3	24	10		-12	-17	-12		2	26	15	0	-5	-15	-15	-10	2
EVAPORATION	487							31	95	117	101	45	21	24	53		
REG INFLOW	14231	668	282	351	1207	1309	1915	1304	1164	920	730	339	167	230	1108	1320	1216
RELEASE	13748	347	238	352	1208	1372	1210	1705	1672	1305	745	470	98	136	1139	1008	744
STOR CHANGE	483	321	44	-1	-1	-63	705	-401	-508	-384	-15	-131	69	94	-31	312	472
STORAGE	13502	13823	13867	13866	13865	13802	14507	14106	13598	13213	13199	13067	13137	13231	13200	13512	13985
ELEV FTMSL	1587.9	1589.3	1589.4	1589.4	1589.4	1589.2	1592.0	1590.4	1588.3	1586.7	1586.6	1586.6	1586.4	1586.8	1586.6	1588.0	1589.9
DISCH KCFS	16.2	11.7	17.1	19.7	20.3	22.3	20.3	27.7	27.2	21.9	12.1	15.8	7.1	8.6	18.5	16.4	13.4
POWER																	
AVE POWER MW		136	201	231	238	261	240	327	317	254	140	182	82	99	214	190	157
PEAK POW MW		617	618	618	618	617	631	623	613	604	604	602	602	604	604	611	621
ENERGY GWH	1940.3	49.1	33.7	49.8	171.1	194.0	172.5	243.4	236.2	182.7	104.1	65.5	13.7	19.0	159.0	141.2	105.4
-- BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	13619	347	238	352	1208	1372	1210	1698	1648	1274	718	458	92	130	1125	1008	744
RELEASE	13619	347	238	352	1208	1372	1210	1698	1648	1274	718	458	92	130	1125	1008	744
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	16.2	11.7	17.1	19.7	20.3	22.3	20.3	27.6	26.8	21.4	11.7	15.4	6.7	8.2	18.3	16.4	13.4
POWER																	
AVE POWER MW		55	80	92	95	104	95	129	125	102	59	78	34	41	90	80	64
PEAK POW MW		517	510	509	509	509	509	509	509	525	538	538	538	538	538	538	529
ENERGY GWH	786.1	19.9	13.5	19.9	68.4	77.7	68.6	96.1	93.3	73.4	43.9	27.9	5.7	7.9	67.2	59.3	43.2
-- FORT RANDALL--																	
NAT INFLOW	659	90	42	54	84	67	171	34	65	31	2				7	-7	20
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	141							10	32	38	27	10	5	5	13		
REG INFLOW	14053	435	279	405	1288	1430	1369	1704	1666	1259	686	446	88	123	1116	998	761
RELEASE	14053	161	145	388	1288	1430	1369	1704	1666	1606	1564	474	88	124	750	726	572
STOR CHANGE	0	274	134	17	0	0	0	0	-347	-877	-28	0	0	366	272	189	
STORAGE	3123	3398	3532	3549	3549	3549	3549	3549	3202	2325	2297	2297	2297	2296	2662	2934	3123
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.0	1338.0	1337.5	1337.5	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	10.3	5.4	10.4	21.7	21.6	23.3	23.0	27.7	27.1	27.0	25.4	15.9	6.3	7.8	12.2	11.8	10.3
POWER																	
AVE POWER MW		45	88	183	183	196	194	233	228	223	196	116	47	57	91	92	83
PEAK POW MW		349	354	355	355	355	355	355	355	341	285	284	283	283	311	329	338
ENERGY GWH	1390.3	16.1	14.8	39.6	131.6	145.9	139.8	173.4	169.6	160.8	145.5	41.8	7.8	10.9	68.0	68.8	55.8
-- GAVINS POINT--																	
NAT INFLOW	1342	98	46	59	133	148	154	87	86	62	112	51	24	27	75	73	108
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-3	0	-9	1	0	3	18	18	-3	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15233	269	181	425	1416	1556	1500	1740	1735	1662	1666	533	125	143	802	798	683
RELEASE	15233	269	181	425	1416	1556	1500	1740	1722	1636	1666	533	125	143	802	798	722
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.1	23.8	23.8	25.3	25.2	28.3	28.0	27.5	27.1	17.9	9.0	9.			

	VALUES IN 1000 AF EXCEPT AS INDICATED																
	28FEB06 INI-SUM	15MAR	2006 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2007 30NOV	31DEC	31JAN	28FEB
-- FORT PECK--																	
NAT INFLOW	6720	271	126	163	588	1036	1629	709	294	282	363	188	88	100	330	237	317
DEPLETION	399	-11	-5	-6	50	312	517	182	-52	-131	-72	-34	-16	-18	-112	-122	-84
EVAPORATION	473							29	90	113	99	45	21	24	52		
MOD INFLOW	5848	282	131	169	538	724	1112	498	256	300	336	176	82	94	390	359	401
RELEASE	5379	134	62	80	357	461	565	584	553	333	249	120	56	127	584	584	528
STOR CHANGE	469	148	69	89	181	263	547	-86	-298	-34	87	56	27	-33	-194	-225	-127
STORAGE	11110	11257	11326	11415	11596	11859	12405	12320	12022	11988	12075	12131	12157	12124	11930	11705	11578
ELEV FTMSL	2213.3	2214.1	2214.5	2215.0	2216.1	2217.6	2220.7	2220.2	2218.5	2218.3	2218.8	2219.1	2219.3	2219.1	2218.0	2216.7	2216.0
DISCH KCFS	9.5	4.5	4.5	4.5	6.0	7.5	9.5	9.5	9.0	5.6	4.0	4.0	4.0	8.0	9.5	9.5	9.5
POWER																	
AVE POWER MW		57	57	57	76	95	122	123	116	72	52	52	52	103	122	121	120
PEAK POW MW		188	189	189	191	193	197	196	194	194	195	195	195	195	193	192	191
ENERGY GWH	832.9	20.4	9.5	12.3	54.7	71.0	87.9	91.4	86.2	51.8	38.8	18.8	8.7	19.8	90.6	90.1	81.0
-- GARRISON--																	
NAT INFLOW	10262	484	226	290	777	1306	2752	1927	542	455	437	179	83	95	243	180	286
DEPLETION	977	-2	-1	-1	-4	214	753	519	60	-105	-6	-102	-48	-54	-104	-85	-57
CHAN STOR	0	53			-16	-16	-21		5	35	16	0	-41	-16			
EVAPORATION	562							34	109	136	117	53	25	28	60		
REG INFLOW	14102	673	289	372	1122	1537	2543	1958	932	793	590	348	162	207	855	849	871
RELEASE	13533	446	194	250	982	1230	1339	1353	1322	995	805	389	182	270	1230	1353	1194
STOR CHANGE	569	227	95	122	140	308	1204	605	-390	-202	-214	-41	-20	-63	-375	-504	-323
STORAGE	13380	13606	13701	13823	13963	14271	15475	16081	15690	15488	15274	15232	15213	15150	14776	14272	13948
ELEV FTMSL	1820.4	1821.3	1821.7	1822.2	1822.7	1823.9	1828.4	1830.6	1829.2	1828.5	1827.7	1827.5	1827.4	1827.2	1825.8	1823.9	1822.7
DISCH KCFS	21.5	15.0	14.0	14.0	16.5	20.0	22.5	22.0	21.5	16.7	13.1	13.1	13.1	17.0	20.0	22.0	21.5
POWER																	
AVE POWER MW		167	157	157	186	226	259	259	254	196	153	153	153	198	231	251	243
PEAK POW MW		407	408	410	412	417	433	441	436	433	430	430	429	429	424	417	412
ENERGY GWH	1885.5	60.2	26.4	34.0	133.7	168.1	186.3	192.5	188.6	141.5	114.1	55.0	25.7	38.0	171.8	186.6	163.0
-- OAH--																	
NAT INFLOW	1860	197	92	118	294	167	740	131	31	83	12				-45	-7	46
DEPLETION	613	23	11	14	47	66	129	151	100	25	-8				11	16	26
CHAN STOR	0	31	5		-12	-16	-12		2	23	17			-19	-14	-10	2
EVAPORATION	502							31	97	120	104	47	22	25	55		
REG INFLOW	14278	652	281	355	1217	1314	1938	1304	1158	955	738	341	159	225	1105	1320	1216
RELEASE	13695	340	235	348	1202	1367	1201	1702	1668	1303	743	469	98	136	1133	1008	743
STOR CHANGE	583	312	46	6	15	-52	737	-399	-510	-347	-5	-129	61	89	-28	313	473
STORAGE	13985	14297	14342	14349	14364	14312	15049	14650	14140	13792	13788	13659	13720	13810	13781	14094	14568
ELEV FTMSL	1589.9	1591.2	1591.4	1591.4	1591.5	1591.2	1594.2	1592.6	1590.6	1589.1	1589.1	1588.6	1588.8	1589.2	1589.1	1590.4	1592.3
DISCH KCFS	13.4	11.4	16.9	19.5	20.2	22.2	20.2	27.7	27.1	21.9	12.1	15.8	7.0	8.6	18.4	16.4	13.4
POWER																	
AVE POWER MW		135	200	231	239	263	241	331	321	257	142	184	83	100	215	192	159
PEAK POW MW		627	628	628	628	627	642	634	624	617	617	614	615	617	616	623	632
ENERGY GWH	1957.4	48.6	33.7	49.9	172.2	195.6	173.3	245.9	238.6	184.8	105.3	66.4	13.9	19.3	160.3	143.1	106.6
-- BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	13567	340	235	348	1202	1367	1201	1695	1644	1272	716	457	92	129	1119	1008	743
RELEASE	13567	340	235	348	1202	1367	1201	1695	1644	1272	716	457	92	129	1119	1008	743
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	13.4	11.4	16.9	19.5	20.2	22.2	20.2	27.6	26.7	21.4	11.6	15.4	6.6	8.1	18.2	16.4	13.4
POWER																	
AVE POWER MW		54	79	91	95	104	95	129	125	102	59	77	34	41	90	80	64
PEAK POW MW		517	510	509	509	509	509	509	509	525	538	538	538	538	538	538	529
ENERGY GWH	783.1	19.5	13.3	19.7	68.1	77.4	68.0	96.0	93.1	73.3	43.8	27.9	5.7	7.9	66.9	59.3	43.2
-- FORT RANDALL--																	
NAT INFLOW	690	94	44	56	88	70	179	36	68	32	2				7	-7	21
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	141							10	32	38	27	10	5	5	13		
REG INFLOW	14032	432	278	404	1286	1428	1368	1703	1665	1258	684	446	88	123	1110	998	761
RELEASE	14032	158	144	387	1286	1428	1368	1703	1665	1562	474	88	123	744	726	572	
STOR CHANGE	0	274	134	17			0	0	-347	-877	-28	0	0	366	272	189	
STORAGE	3123	3398	3532	3549	3549	3549	3549	3549	3549	3202	2325	2297	2297	2296	2662	2934	3123
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.0	1338.0	1337.5	1337.5	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	10.3	5.3	10.4	21.7	21.6	23.2	23.0	27.7	27.1	27.0	25.4	15.9	6.3	7.8	12.1	11.8	10.3
POWER																	
AVE POWER MW		44	88	183	182	196	194	233	228	223	195	116	46	57	91	92	83
PEAK POW MW		349	354	355	355	355	355	355	355	341	285	284	283	283	311	329	338
ENERGY GWH	1388.2	15.8	14.7	39.5	131.4	145.7	139.7	173.3	169.5	160.7	145.3	41.8	7.8	10.9	67.5	68.8	55.8
-- GAVINS POINT--																	
NAT INFLOW	1359	100	47	60	135	150	155	88	87	63	114	51	24	27	76	74	109
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	10	-10	-22	0	-3	0	-9	1	0	3	18	18	-3	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15228	267	181	425	1416	1556	1500	1740	1735	1662	1666	533	125	143	797	799	684
RELEASE	15228	267	181	425	1416	1556	1500	1740	1722	1636	1666	533	125	143	797	799	723
STOR CHANGE									13	26							-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	25.3	25.2	28.3	28.0	27.5	27.1	17.9	9.0	9.0	13.0	13.0	13.0
POWER																	
AVE POWER MW</																	

	29FEB08	15MAR	2008	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2009	31DEC	31JAN	28FEB
	INI-SUM		22MAR											30NOV			
--FORT PECK--																	
NAT INFLOW	7022	283	132	170	615	1083	1702	741	307	295	379	196	91	104	345	248	331
DEPLETION	422	-11	-5	-6	50	313	525	196	-44	-132	-75	-35	-16	-18	-113	-123	-84
EVAPORATION	496							30	95	119	104	47	22	25	54		
MOD INFLOW	6104	294	137	176	565	770	1177	515	256	308	350	183	85	97	404	371	415
RELEASE	5628	134	62	80	357	461	595	615	615	352	278	134	62	127	584	615	555
STOR CHANGE	476	160	75	96	208	309	582	-100	-359	-43	72	48	23	-29	-180	-244	-140
STORAGE	12037	12196	12271	12367	12575	12884	13466	13365	13007	12963	13036	13084	13107	13077	12897	12653	12513
ELEV FTMSL	2218.6	2219.5	2219.9	2220.4	2221.6	2223.3	2226.4	2225.9	2224.0	2223.7	2224.1	2224.4	2224.5	2224.3	2223.4	2222.0	2221.3
DISCH KCFS	9.5	4.5	4.5	4.5	6.0	7.5	10.0	10.0	10.0	5.9	4.5	4.5	4.5	8.0	9.5	10.0	10.0
POWER																	
AVE POWER MW		58	58	58	78	98	132	132	132	78	60	60	59	105	125	131	130
PEAK POW MW		195	196	196	198	199	203	202	200	200	200	200	201	200	199	198	197
ENERGY GWH	893.0	20.9	9.8	12.6	56.1	72.9	94.9	98.6	98.1	56.0	44.3	21.5	10.0	20.2	92.8	97.1	87.3
--GARRISON--																	
NAT INFLOW	10598	500	233	300	803	1349	2842	1990	559	470	451	185	86	98	251	186	295
DEPLETION	1160					216	774	553	56	-134	9	-90	-42	-48	-67	-46	-22
CHAN STOR	-5	52			-16	-16	-26			41	14	0	0	-36	-15	-5	
EVAPORATION	589							36	113	142	123	56	26	30	64		
REG INFLOW	14472	686	296	380	1144	1579	2637	2016	1005	855	611	353	165	208	823	842	872
RELEASE	13891	446	194	250	1041	1261	1398	1414	1383	952	801	388	182	286	1230	1414	1250
STOR CHANGE	581	240	101	130	103	318	1239	602	-379	-97	-191	-35	-17	-78	-407	-572	-377
STORAGE	14507	14747	14848	14978	15081	15399	16638	17240	16861	16764	16574	16539	16522	16444	16037	15465	15088
ELEV FTMSL	1824.8	1825.7	1826.1	1826.6	1827.0	1828.1	1832.5	1834.6	1833.3	1833.0	1832.3	1832.1	1832.1	1831.9	1830.4	1828.4	1827.0
DISCH KCFS	22.0	15.0	14.0	14.0	17.5	20.5	23.5	23.0	22.5	16.0	13.0	13.0	13.1	18.0	20.0	23.0	22.5
POWER																	
AVE POWER MW		172	162	162	203	238	278	278	272	193	157	157	158	216	238	270	261
PEAK POW MW		423	425	426	428	432	448	456	451	450	447	447	447	446	440	433	428
ENERGY GWH	1990.7	62.0	27.2	35.0	145.9	177.2	199.9	206.5	202.6	139.2	117.1	56.5	26.5	41.4	177.1	201.0	175.6
--OAH--																	
NAT INFLOW	2048	217	101	130	324	183	815	144	34	92	13				-49	-8	51
DEPLETION	641	23	11	14	48	68	135	160	106	26	-9	2	1	1	12	17	27
CHAN STOR	-3	32	5		-16	-13	-13		2	29	14	0	0	-23	-9	-14	2
EVAPORATION	532							34	104	128	110	50	23	26	58		
REG INFLOW	14763	672	289	366	1302	1362	2065	1367	1210	920	727	337	158	236	1102	1375	1276
RELEASE	14168	459	126	346	1263	1433	1249	1762	1726	1362	807	529	95	135	1132	1009	735
STOR CHANGE	595	213	164	20	38	-71	815	-395	-516	-442	-81	-193	63	101	-30	367	540
STORAGE	15140	15353	15517	15537	15575	15505	16320	15925	15410	14967	14887	14694	14757	14857	14827	15194	15735
ELEV FTMSL	1594.5	1595.3	1596.0	1596.0	1596.2	1595.9	1598.9	1597.5	1595.5	1593.8	1593.5	1592.8	1593.0	1593.4	1593.3	1594.7	1596.8
DISCH KCFS	13.4	15.4	9.1	19.4	21.2	23.3	21.0	28.7	28.1	22.9	13.1	17.8	6.8	8.5	18.4	16.4	13.2
POWER																	
AVE POWER MW		186	110	235	258	283	257	351	341	276	158	213	82	102	220	197	161
PEAK POW MW		647	650	651	651	650	665	658	648	640	638	635	636	638	637	644	654
ENERGY GWH	2077.2	67.1	18.5	50.9	185.6	210.3	185.0	261.3	253.6	198.5	117.4	76.6	13.8	19.7	164.0	146.8	108.2
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	14040	459	126	346	1263	1433	1249	1754	1701	1331	780	517	89	129	1118	1009	735
RELEASE	14040	459	126	346	1263	1433	1249	1754	1701	1331	780	517	89	129	1118	1009	735
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	13.4	15.4	9.1	19.4	21.2	23.3	21.0	28.5	27.7	22.4	12.7	17.4	6.4	8.1	18.2	16.4	13.2
POWER																	
AVE POWER MW		72	42	91	99	109	98	134	130	107	64	87	33	41	90	80	64
PEAK POW MW		510	509	509	509	509	509	509	509	525	538	538	538	538	538	538	529
ENERGY GWH	810.1	26.0	7.1	19.6	71.6	81.2	70.8	99.3	96.3	76.7	47.7	31.5	5.5	7.9	66.8	59.4	42.7
--FORT RANDALL--																	
NAT INFLOW	779	106	49	64	100	79	203	41	76	36	2				8	-8	23
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	141							10	32	38	27	10	5	5	13		
REG INFLOW	14594	563	175	409	1359	1503	1440	1767	1731	1322	749	505	85	123	1110	998	755
RELEASE	14594	155	158	409	1359	1503	1440	1767	1731	1669	1626	533	85	123	744	726	566
STOR CHANGE	0	409	17					0	0	-347	-877	-28	0	0	366	272	189
STORAGE	3123	3532	3549	3549	3549	3549	3549	3549	3549	3202	2325	2297	2297	2296	2662	2934	3123
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.0	1338.0	1337.5	1337.5	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	10.4	5.2	11.3	22.9	22.8	24.4	24.2	28.7	28.1	28.0	26.4	17.9	6.1	7.7	12.1	11.8	10.2
POWER																	
AVE POWER MW		43	96	193	193	206	204	242	237	232	203	130	45	57	91	92	82
PEAK POW MW		354	355	355	355	355	355	355	355	341	285	284	283	283	311	329	338
ENERGY GWH	1443.4	15.7	16.2	41.7	138.8	153.3	146.9	179.7	176.1	166.9	151.2	46.9	7.5	10.9	67.5	68.8	55.3
--GAVINS POINT--																	
NAT INFLOW	1401	103	48	62	139	155	160	91	89	65	117	53	25	28	78	77	113
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	10	-12	-22	0	-3	0	-9	1	0	3	16	22	-3	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15833	268	194	448	1493	1636	1577	1808	1802	1728	1734	592	127	143	799	802	682
RELEASE	15833	268	194	448	1493	1636	1577	1808	1789	1702	1734	592	127	143	799	802	721
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	14.0	25.1	25.1	26											

	28FEB05	15MAR	2005	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2006	31DEC	31JAN	28FEB
	INI-SUM		22MAR											30NOV			
-- FORT PECK--																	
NAT INFLOW	5615	258	120	155	567	862	1097	483	279	266	352	175	81	93	298	226	303
DEPLETION	388	2	1	1	73	304	470	152	-46	-124	-57	-33	-15	-18	-107	-126	-90
EVAPORATION	394							24	75	94	82	37	18	20	43		
MOD INFLOW	4833	256	119	153	494	558	627	307	250	296	327	170	79	91	362	352	393
RELEASE	5224	119	56	71	298	461	536	553	553	346	258	125	83	127	553	584	500
STOR CHANGE	-392	137	64	82	196	97	91	-247	-304	-51	68	45	-4	-36	-191	-232	-107
STORAGE	8662	8799	8863	8945	9141	9238	9329	9083	8779	8728	8796	8841	8837	8801	8610	8377	8271
ELEV FTMSL	2197.8	2198.7	2199.1	2199.7	2201.0	2201.6	2202.2	2200.6	2198.6	2198.2	2198.7	2199.0	2198.9	2198.7	2197.4	2195.8	2195.0
DISCH KCFS	9.5	4.0	4.0	4.0	5.0	7.5	9.0	9.0	9.0	5.8	4.2	4.2	6.0	8.0	9.0	9.5	9.0
POWER																	
AVE POWER MW		47	47	47	59	88	106	106	105	68	49	49	70	93	104	108	102
PEAK POW MW		167	168	169	171	171	172	170	167	167	167	168	168	167	165	163	162
ENERGY GWH	734.9	16.7	7.8	10.1	42.3	65.7	76.5	78.8	78.1	48.7	36.4	17.6	11.7	17.8	77.3	80.7	68.5
-- GARRISON--																	
NAT INFLOW	8444	312	146	187	810	1045	2337	1477	418	320	451	187	87	99	125	185	258
DEPLETION	1085	10	5	6	20	211	714	482	63	-120	6	-84	-39	-45	-69	-49	-27
CHAN STOR	6	62			-11	-28	-17	29	35	18	18	-20	-22	-11	-6	6	
EVAPORATION	465							90	112	97	44	20	23	50			
REG INFLOW	12124	483	196	253	1076	1267	2142	1520	818	709	624	351	169	226	687	813	790
RELEASE	12602	446	167	214	893	1138	1220	1230	1199	911	743	360	168	286	1199	1291	1139
STOR CHANGE	-478	37	30	38	184	130	922	290	-381	-202	-119	-8	1	-60	-512	-479	-348
STORAGE	10398	10435	10465	10503	10687	10817	11738	12029	11648	11446	11327	11319	11320	11260	10747	10269	9921
ELEV FTMSL	1807.6	1807.7	1807.9	1808.1	1808.9	1809.5	1813.6	1814.9	1813.2	1812.3	1811.8	1811.8	1811.8	1811.5	1809.2	1807.0	1805.3
DISCH KCFS	20.0	15.0	12.0	12.0	15.0	18.5	20.5	20.0	19.5	15.3	12.1	12.1	12.1	18.0	19.5	21.0	20.5
POWER																	
AVE POWER MW		153	123	123	154	190	214	212	206	161	127	127	127	187	201	212	204
PEAK POW MW		291	291	291	294	296	308	384	378	374	372	372	372	371	363	355	349
ENERGY GWH	1577.5	55.0	20.6	26.5	110.8	141.6	154.4	157.7	153.6	116.0	94.4	45.6	21.3	36.0	149.4	157.7	136.9
-- OAHE--																	
NAT INFLOW	1263	238	111	143	220	120	259	99	25	77	6	-6	-3	-3	-58	-14	50
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25
CHAN STOR	-3	27	16		-16	-19	-11	3	3	23	18	0	0	-33	-8	-8	3
EVAPORATION	380							24	74	91	78	36	17	19	42		
REG INFLOW	12886	688	283	343	1051	1174	1342	1160	1057	897	697	317	148	229	1080	1253	1166
RELEASE	13376	358	259	366	1243	1404	1231	1729	1521	1123	726	237	122	137	1059	833	1029
STOR CHANGE	-491	330	24	-23	-192	-230	111	-569	-464	-226	-28	79	26	92	21	420	138
STORAGE	10928	11259	11282	11260	11068	10838	10949	10380	9916	9690	9661	9741	9767	9859	9880	10300	10438
ELEV FTMSL	1576.2	1577.8	1577.9	1577.8	1576.9	1575.7	1576.3	1573.4	1571.0	1569.7	1569.6	1570.0	1570.1	1570.7	1570.8	1573.0	1573.7
DISCH KCFS	18.5	12.0	18.7	20.5	20.9	22.8	20.7	28.1	24.7	18.9	11.8	8.0	8.8	8.7	17.2	13.5	18.5
POWER																	
AVE POWER MW		131	204	224	227	247	223	301	260	197	123	83	92	91	180	143	197
PEAK POW MW		557	558	557	553	546	550	534	521	515	514	516	517	520	520	532	536
ENERGY GWH	1723.7	47.3	34.3	48.4	163.7	183.6	160.9	223.7	193.7	141.6	91.3	29.9	15.4	17.4	134.0	106.3	132.3
-- BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	13248	358	259	366	1243	1404	1231	1722	1497	1092	698	225	116	131	1045	833	1029
RELEASE	13248	358	259	366	1243	1404	1231	1722	1497	1092	698	225	116	131	1045	833	1029
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	18.5	12.0	18.7	20.5	20.9	22.8	20.7	28.0	24.3	18.3	11.4	7.6	8.4	8.2	17.0	13.5	18.5
POWER																	
AVE POWER MW		57	88	96	98	107	97	131	115	90	57	38	42	42	85	67	89
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	529
ENERGY GWH	767.8	20.5	14.7	20.7	70.4	79.5	69.7	97.5	85.7	64.7	42.7	13.8	7.1	8.0	63.0	49.9	59.7
-- FORT RANDALL--																	
NAT INFLOW	404	74	35	44	58	47	161	18	48	-13	-69	-4	-2	-2	-8	16	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	0	1	3	3	3	
EVAPORATION	135							10	31	35	25	10	5	5	13		
REG INFLOW	13436	431	293	410	1297	1442	1380	1712	1499	1036	601	211	109	123	1029	822	1042
RELEASE	13435	167	148	393	1297	1442	1380	1712	1673	1611	1105	211	109	123	756	732	578
STOR CHANGE	0	264	145	17				0	-174	-575	-503	0	0	0	273	90	464
STORAGE	3123	3387	3532	3549	3549	3549	3549	3549	3375	2800	2296	2296	2296	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1345.5	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	10.4	5.6	10.7	22.0	21.8	23.4	23.2	27.8	27.2	27.1	18.0	7.1	7.9	7.7	12.3	11.9	10.4
POWER																	
AVE POWER MW		46	90	186	184	198	196	234	227	217	135	52	58	57	92	91	82
PEAK POW MW		349	354	355	355	355	355	355	348	320	283	283	283	283	305	311	338
ENERGY GWH	1322.9	16.7	15.2	40.1	132.5	147.1	140.9	174.2	168.9	156.2	100.6	18.7	9.7	10.9	68.1	67.7	55.4
-- GAVINS POINT--																	
NAT INFLOW	1242	90	42	54	124	136	143	79	79	57	108	47	22	25	69	67	101
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-3	0	-9	1	0	17	20	-1	0	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	14515	266	181	425	1416	1556	1500	1740	1735	1662	1217	268	125	143	802	798	681
RELEASE	14515	266	181	425	1416	1556	1500	1740	1722	1636	1217	268	125	143	802	798	720
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0															

	28FEB06	15MAR	2006	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2007	31DEC	31JAN	28FEB
	INI-SUM		22MAR											30NOV			
--FORT PECK--																	
NAT INFLOW	5748	264	123	158	580	882	1123	495	285	273	361	179	83	95	305	231	310
DEPLETION	399	-3	-1	-2	76	308	478	159	-42	-124	-58	-34	-16	-18	-108	-126	-91
EVAPORATION	387							24	74	92	81	37	17	20	42		
MOD INFLOW	4962	267	125	160	504	574	645	312	253	305	338	175	82	93	371	357	401
RELEASE	5088	119	56	71	298	430	536	553	553	338	252	122	57	127	523	553	500
STOR CHANGE	-127	148	69	89	206	144	109	-241	-300	-33	86	53	25	-34	-152	-196	-99
STORAGE	8271	8419	8488	8577	8783	8927	9036	8795	8495	8461	8547	8600	8625	8591	8439	8243	8144
ELEV FTMSL	2195.0	2196.1	2196.6	2197.2	2198.6	2199.5	2200.3	2198.7	2196.6	2196.4	2197.0	2197.3	2197.5	2197.3	2196.2	2194.8	2194.1
DISCH KCFS	9.0	4.0	4.0	4.0	5.0	7.0	9.0	9.0	9.0	5.7	4.1	4.1	4.1	8.0	8.5	9.0	9.0
POWER																	
AVE POWER MW		46	46	46	58	82	105	105	104	65	47	47	47	92	97	102	101
PEAK POW MW		163	164	165	167	169	170	167	164	164	165	165	166	165	164	162	161
ENERGY GWH	708.3	16.4	7.7	10.0	41.7	60.7	75.7	78.0	77.1	46.9	35.1	17.0	8.0	17.7	72.4	75.9	68.1
--GARRISON--																	
NAT INFLOW	8762	324	151	194	840	1084	2425	1533	433	332	468	194	90	103	130	192	268
DEPLETION	967	14	6	8	26	211	718	498	66	-124	-1	-98	-46	-52	-109	-88	-63
CHAN STOR	0	57			-11	-23	-22			37	17		0	-43	6	-6	
EVAPORATION	457							28	89	110	95	43	20	23	49		
REG INFLOW	12426	486	200	258	1100	1281	2220	1560	832	721	643	370	173	216	707	828	831
RELEASE	12555	417	167	214	893	1076	1250	1261	1230	914	714	345	161	286	1199	1291	1139
STOR CHANGE	-129	70	34	44	208	205	971	300	-398	-193	-70	25	12	-70	-492	-463	-308
STORAGE	9921	9991	10024	10068	10276	10480	11451	11751	11353	11159	11089	11113	11125	11055	10563	10100	9792
ELEV FTMSL	1805.3	1805.6	1805.8	1806.0	1807.0	1808.0	1812.4	1813.7	1811.9	1811.1	1810.7	1810.9	1810.9	1810.6	1808.3	1806.2	1804.7
DISCH KCFS	20.5	14.0	12.0	12.0	15.0	17.5	21.0	20.5	20.0	15.4	11.6	11.6	11.6	18.0	19.5	21.0	20.5
POWER																	
AVE POWER MW		139	120	120	150	176	216	215	210	160	121	121	121	186	199	211	202
PEAK POW MW		350	351	351	355	359	375	379	373	370	369	369	369	368	360	352	346
ENERGY GWH	1552.7	50.1	20.1	25.9	108.2	131.2	155.2	160.2	156.1	115.3	89.9	43.5	20.3	35.7	148.3	156.6	136.1
--OAHE--																	
NAT INFLOW	1323	249	116	149	231	126	271	103	26	81	7	-7	-3	-3	-61	-15	52
DEPLETION	613	23	11	14	47	66	129	151	100	25	-8	2	1	1	11	16	26
CHAN STOR	0	35	11		-16	-14	-19	3	3	26	21	0	0	-36	-8	-8	3
EVAPORATION	373							23	71	89	78	35	16	19	41		
REG INFLOW	12891	679	283	350	1060	1123	1372	1192	1087	907	672	302	141	226	1077	1252	1167
RELEASE	13020	353	256	362	1238	1401	1218	1728	1517	699	828	247	121	137	1052	835	1028
STOR CHANGE	-129	326	27	-12	-177	-278	154	-536	-430	208	-156	55	20	89	25	417	140
STORAGE	10438	10764	10791	10778	10601	10323	10477	9941	9511	9719	9563	9618	9638	9727	9752	10169	10309
ELEV FTMSL	1573.7	1575.4	1575.5	1575.4	1574.6	1573.1	1573.9	1571.1	1568.7	1569.9	1569.0	1569.3	1569.4	1569.9	1570.1	1572.3	1573.0
DISCH KCFS	18.5	11.8	18.4	20.3	20.8	22.8	20.5	28.1	24.7	11.7	13.5	8.3	8.7	8.7	17.1	13.6	18.5
POWER																	
AVE POWER MW		127	199	218	223	242	218	296	256	122	140	86	91	90	178	143	196
PEAK POW MW		545	545	545	540	533	537	522	510	516	511	513	513	516	517	529	532
ENERGY GWH	1660.2	45.8	33.4	47.2	160.7	180.4	156.7	220.2	190.4	87.8	104.0	31.1	15.2	17.3	132.4	106.1	131.6
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	12891	353	256	362	1238	1401	1218	1721	1493	668	801	235	115	131	1038	835	1028
RELEASE	12891	353	256	362	1238	1401	1218	1721	1493	668	801	235	115	131	1038	835	1028
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	18.5	11.8	18.4	20.3	20.8	22.8	20.5	28.0	24.3	11.2	13.0	7.9	8.3	8.2	16.9	13.6	18.5
POWER																	
AVE POWER MW		56	86	95	97	107	96	131	115	57	66	40	42	42	84	67	89
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	529
ENERGY GWH	748.2	20.2	14.5	20.5	70.1	79.4	69.0	97.4	85.5	40.9	48.9	14.4	7.1	8.0	62.5	50.0	59.6
--FORT RANDALL--																	
NAT INFLOW	433	80	37	48	62	50	174	19	52	-15	-75	-4	-2	-2	-9	17	
DEPLETION	80	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3	
EVAPORATION	129						10	31	33	23	10	5	5	13			
REG INFLOW	13108	431	293	409	1296	1442	1380	1712	1499	606	702	221	108	123	1022	823	1042
RELEASE	13108	167	148	392	1296	1442	1380	1712	1673	1611	775	221	108	123	750	732	578
STOR CHANGE	0	264	144	17	0	0	0	0	-174	-1005	-73	0	0	0	272	91	464
STORAGE	3123	3388	3532	3549	3549	3549	3549	3549	3375	2369	2296	2296	2296	2296	2568	2659	3123
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1338.8	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	10.4	5.6	10.7	22.0	21.8	23.4	23.2	27.8	27.2	27.1	12.6	7.4	7.8	7.8	12.2	11.9	10.4
POWER																	
AVE POWER MW		46	90	185	184	198	196	234	227	211	92	54	57	57	91	91	82
PEAK POW MW		349	354	355	355	355	355	355	348	288	283	283	283	283	305	311	338
ENERGY GWH	1286.6	16.7	15.1	40.0	132.4	147.2	140.9	174.2	168.9	151.7	68.7	19.6	9.6	10.9	67.6	67.7	55.4
--GAVINS POINT--																	
NAT INFLOW	1246	91	42	54	125	136	143	79	79	57	108	47	22	25	70	68	101
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-3	0	-9	1	0	27	10	-1	0	-8	1	3
EVAPORATION	47						3	9	11	10	5	2	2	5			
REG INFLOW	14192	267	181	425	1416	1556	1500	1740	1735	1662	898	268	125	143	797	799	681
RELEASE	14192	267	181	425	1416	1556	1500	1740	1722	1636	898	268	125	143	797	799	720
STOR CHANGE									13	26							-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8													

	28FEB07	2007										2008					
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB
-- FORT PECK --																	
NAT INFLOW	5919	272	127	163	598	909	1156	509	294	281	371	184	86	98	314	238	319
DEPLETION	410	-3	-1	-2	76	309	482	166	-38	-124	-60	-33	-15	-18	-106	-124	-99
EVAPORATION	388							24	74	92	81	37	17	20	43		
MOD INFLOW	5121	275	128	165	522	600	674	319	258	313	350	180	84	96	377	362	418
RELEASE	5023	119	56	71	298	430	536	553	523	342	255	122	57	127	523	523	489
STOR CHANGE	99	156	73	93	224	170	138	-234	-265	-30	95	58	27	-31	-145	-161	-71
STORAGE	8144	8300	8373	8466	8691	8860	8999	8764	8500	8470	8566	8623	8650	8619	8474	8314	8243
ELEV FTMSL	2194.1	2195.2	2195.8	2196.4	2198.0	2199.1	2200.0	2198.5	2196.6	2196.4	2197.1	2197.5	2197.7	2197.5	2196.5	2195.3	2194.8
DISCH KCFS	9.0	4.0	4.0	4.0	5.0	7.0	9.0	9.0	8.5	5.7	4.1	4.1	4.1	8.0	8.5	8.5	8.5
POWER																	
AVE POWER MW		45	46	46	58	81	105	105	98	66	48	47	48	92	97	97	96
PEAK POW MW		162	163	164	166	168	169	167	164	164	165	166	166	165	164	162	162
ENERGY GWH	699.2	16.3	7.7	9.9	41.5	60.5	75.5	77.9	72.8	47.5	35.5	17.1	8.0	17.7	72.5	71.9	66.9
-- GARRISON --																	
NAT INFLOW	9185	340	158	204	881	1136	2542	1607	454	349	491	203	95	108	136	201	281
DEPLETION	962	-5	-2	-3	-11	211	734	514	74	-126	-4	-91	-42	-49	-100	-78	-59
CHAN STOR	6	57			-11	-23	-22		5	30	18	0		-43	-6		0
EVAPORATION	462							28	90	111	96	44	20	23	50		
REG INFLOW	12790	521	216	278	1178	1333	2321	1618	819	736	671	373	174	217	704	802	829
RELEASE	12696	417	167	214	893	1076	1279	1291	1261	882	714	352	164	286	1230	1291	1179
STOR CHANGE	94	104	50	64	286	257	1042	327	-442	-146	-43	20	9	-68	-526	-490	-350
STORAGE	9792	9896	9946	10011	10296	10553	11595	11922	11480	11334	11291	11311	11321	11252	10726	10236	9886
ELEV FTMSL	1804.7	1805.2	1805.4	1805.7	1807.1	1808.3	1813.0	1814.4	1812.5	1811.8	1811.7	1811.7	1811.8	1811.5	1809.1	1806.8	1805.1
DISCH KCFS	20.5	14.0	12.0	12.0	15.0	17.5	21.5	21.0	20.5	14.8	11.6	11.8	11.8	18.0	20.0	21.0	20.5
POWER																	
AVE POWER MW		139	119	120	150	177	222	222	216	155	122	124	124	187	206	212	203
PEAK POW MW		348	349	350	355	360	377	382	375	373	372	372	372	371	363	354	348
ENERGY GWH	1576.3	49.9	20.0	25.8	108.1	131.4	159.5	164.9	160.7	111.9	90.5	44.6	20.8	36.0	153.0	157.6	141.6
-- OAHE --																	
NAT INFLOW	1408	265	123	159	245	134	288	110	28	86	7	-7	-3	-3	-64	-16	56
DEPLETION	626	23	11	14	47	67	132	156	103	25	-9	2	1	1	12	17	26
CHAN STOR	0	36	11		-16	-14	-22	3	3	32	18	-1		-35	-11	-6	3
EVAPORATION	375							23	72	90	78	35	17	19	42		
REG INFLOW	13102	694	290	359	1074	1129	1413	1225	1117	886	669	308	144	228	1101	1253	1212
RELEASE	13004	345	252	357	1232	1395	1200	1726	1512	699	835	253	121	137	1053	835	1052
STOR CHANGE	98	349	38	2	-157	-265	213	-502	-396	187	-166	55	24	90	48	418	160
STORAGE	10309	10658	10696	10698	10541	10275	10488	9987	9591	9778	9612	9667	9690	9781	9829	10247	10407
ELEV FTMSL	1573.0	1574.8	1575.0	1575.0	1574.2	1572.9	1574.0	1571.3	1569.2	1570.2	1569.3	1569.6	1569.7	1570.2	1570.5	1572.7	1573.6
DISCH KCFS	18.5	11.6	18.2	20.0	20.7	22.7	20.2	28.1	24.6	11.8	13.6	8.5	8.7	8.7	17.1	13.6	18.3
POWER																	
AVE POWER MW		124	195	215	222	241	214	296	256	122	141	88	90	90	179	143	194
PEAK POW MW		542	543	543	539	531	537	523	512	517	513	514	515	518	519	531	535
ENERGY GWH	1659.2	44.7	32.7	46.4	159.6	179.3	154.3	220.2	190.2	88.1	105.1	31.8	15.2	17.4	132.9	106.4	135.1
-- BIG BEND --																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	12876	345	252	357	1232	1395	1200	1719	1488	668	808	240	115	131	1039	835	1052
RELEASE	12876	345	252	357	1232	1395	1200	1719	1488	668	808	240	115	131	1039	835	1052
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	18.5	11.6	18.2	20.0	20.7	22.7	20.2	28.0	24.2	11.2	13.1	8.1	8.3	8.2	16.9	13.6	18.3
POWER																	
AVE POWER MW		55	85	94	97	106	94	131	115	57	66	41	42	42	84	67	88
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	529
ENERGY GWH	747.4	19.8	14.3	20.2	69.8	79.0	68.0	97.3	85.2	40.9	49.4	14.7	7.0	8.0	62.6	50.0	61.1
-- FORT RANDALL --																	
NAT INFLOW	476	88	41	53	68	55	191	21	57	-16	-82	-4	-2	-2	-10	19	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	0	0	1	3	3	
EVAPORATION	129						10	31	33	23	10	5	5	13			
REG INFLOW	13135	432	292	409	1296	1441	1379	1712	1499	605	702	226	108	123	1023	822	1068
RELEASE	13135	167	148	392	1296	1441	1379	1712	1673	1611	774	226	108	123	750	732	604
STOR CHANGE	0	265	144	17	0	0	0	0	-174	-1006	-72	0	0	0	273	90	464
STORAGE	3123	3388	3532	3549	3549	3549	3549	3549	3375	2369	2296	2296	2296	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1338.8	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	10.4	5.6	10.7	22.0	21.8	23.4	23.2	27.8	27.2	27.1	12.6	7.6	7.8	7.7	12.2	11.9	10.5
POWER																	
AVE POWER MW		46	90	185	184	198	196	234	227	211	92	56	57	57	91	91	83
PEAK POW MW		349	354	355	355	355	355	355	348	288	283	283	283	283	305	311	338
ENERGY GWH	1289.1	16.7	15.1	40.0	132.4	147.0	140.8	174.2	168.9	151.7	68.7	20.0	9.5	10.9	67.6	67.7	57.9
-- GAVINS POINT --																	
NAT INFLOW	1252	91	42	55	125	137	144	79	79	57	109	47	22	25	70	68	102
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-3	0	-9	1	0	27	9	0	0	-8	1	3
EVAPORATION	47						3	9	11	10	5	2	2	5			
REG INFLOW	14224	267	181	425	1416	1556	1500	1740	1735	1662	898	272	125	143	797	799	709
RELEASE	14224	267	181	425	1416	1556	1500	1740	1722	1636	898	272	125	143	797	799	748
STOR CHANGE									13	26							-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	25.3	25.2	28.3	28.0	27.							

		VALUES IN 1000 AF EXCEPT AS INDICATED															
29FEB08		2008										2009					
INI-SUM		15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5961	274	128	164	602	915	1164	513	296	283	374	185	86	99	317	240	321
DEPLETION	419	-3	-1	-2	76	310	486	173	-34	-125	-62	-35	-16	-19	-110	-127	-92
EVAPORATION	391							24	75	93	82	37	17	20	43		
MOD INFLOW	5151	277	129	166	526	605	678	316	255	315	354	183	85	97	384	367	413
RELEASE	5055	119	56	71	298	430	536	553	523	326	258	125	58	127	523	553	500
STOR CHANGE	96	158	74	95	228	175	142	-237	-267	-11	97	58	27	-30	-139	-186	-87
STORAGE	8243	8400	8474	8569	8797	8972	9114	8877	8610	8598	8695	8753	8780	8750	8612	8425	8339
ELEV FTMSL	2194.8	2196.0	2196.5	2197.1	2198.7	2199.8	2200.8	2199.2	2197.4	2197.3	2198.0	2198.4	2198.6	2198.4	2197.4	2196.1	2195.5
DISCH KCFS	8.5	4.0	4.0	4.0	5.0	7.0	9.0	9.0	8.5	5.5	4.2	4.2	4.2	8.0	8.5	9.0	9.0
POWER																	
AVE POWER MW		46	46	46	58	82	105	105	98	63	49	49	49	93	98	103	102
PEAK POW MW		163	164	165	167	169	170	168	165	165	166	167	167	167	165	164	163
ENERGY GWH	707.2	16.4	7.7	9.9	41.7	60.7	75.8	78.2	73.2	45.5	36.1	17.5	8.2	17.8	16.0	76.6	68.7
--GARRISON--																	
NAT INFLOW	9293	344	160	206	891	1150	2572	1626	460	353	496	205	96	109	137	204	284
DEPLETION	1088	0	0	0		212	744	530	79	-128	-8	-95	-44	-50	-73	-51	-29
CHAN STOR	-5	51			-11	-22	-22		5	33	14	0	0	-42	-6	-6	
EVAPORATION	465							29	90	112	97	44	21	23	50		
REG INFLOW	12790	513	216	277	1177	1346	2341	1621	819	729	679	380	177	221	677	803	813
RELEASE	12670	387	167	214	893	1107	1279	1291	1261	922	704	341	160	286	1230	1291	1139
STOR CHANGE	119	126	49	63	285	239	1062	330	-442	-194	-25	39	18	-64	-553	-488	-326
STORAGE	9886	10013	10062	10125	10409	10648	11710	12040	11598	11405	11379	11419	11436	11372	10820	10331	10006
ELEV FTMSL	1805.1	1805.7	1806.0	1806.3	1807.6	1808.7	1813.5	1814.9	1813.0	1812.2	1812.0	1812.2	1812.3	1812.0	1809.5	1807.3	1805.7
DISCH KCFS	20.5	13.0	12.0	12.0	15.0	18.0	21.5	21.0	20.5	15.5	11.5	11.5	11.5	18.0	20.0	21.0	20.5
POWER																	
AVE POWER MW		129	120	120	151	182	222	222	217	163	120	120	121	188	207	213	204
PEAK POW MW		350	351	352	357	361	379	384	377	374	373	374	374	373	364	356	350
ENERGY GWH	1579.4	46.5	20.1	25.9	108.6	135.6	160.1	165.5	161.3	117.3	89.5	43.3	20.3	36.1	153.6	158.1	137.3
--OAHE--																	
NAT INFLOW	1429	269	125	161	249	136	293	112	29	87	7	-7	-3	-4	-65	-16	56
DEPLETION	641	23	11	14	48	68	135	160	106	26	-9	2	1	1	12	17	27
CHAN STOR	0	41	5		-16	-16	-19	3	3	28	23	0	0	-36	-11	-6	3
EVAPORATION	380							24	72	91	80	36	17	19	42		
REG INFLOW	13079	673	286	361	1077	1159	1418	1222	1114	921	663	297	139	225	1100	1253	1170
RELEASE	12960	343	251	356	1230	1394	1196	1726	1510	700	836	247	121	137	1053	835	1025
STOR CHANGE	119	330	36	5	-152	-235	222	-104	-396	220	-173	49	18	88	47	418	146
STORAGE	10407	10737	10773	10778	10626	10391	10613	10109	9712	9933	9760	9809	9827	9915	9962	10380	10526
ELEV FTMSL	1573.6	1575.2	1575.4	1575.4	1574.7	1573.5	1574.6	1572.0	1569.8	1571.1	1570.1	1570.4	1570.5	1571.0	1571.2	1573.4	1574.2
DISCH KCFS	18.3	11.5	18.1	19.9	20.7	22.7	20.1	28.1	24.6	11.8	13.6	8.3	8.7	8.7	17.1	13.6	18.4
POWER																	
AVE POWER MW		124	194	215	222	242	214	297	256	123	142	87	91	91	179	144	197
PEAK POW MW		544	545	545	541	535	541	527	515	522	517	518	519	521	523	534	538
ENERGY GWH	1660.2	44.5	32.7	46.3	159.7	179.8	154.4	221.1	190.7	88.6	105.8	31.3	15.3	17.4	133.5	106.8	132.1
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	12831	343	251	356	1230	1394	1196	1719	1486	669	809	235	115	131	1039	835	1025
RELEASE	12831	343	251	356	1230	1394	1196	1719	1486	669	809	235	115	131	1039	835	1025
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	18.3	11.5	18.1	19.9	20.7	22.7	20.1	28.0	24.2	11.2	13.2	7.9	8.3	8.2	16.9	13.6	18.4
POWER																	
AVE POWER MW		55	85	93	97	106	94	131	114	57	66	40	42	42	84	67	88
PEAK POW MW		518	510	509	509	509	509	509	518	538	538	538	538	538	538	538	529
ENERGY GWH	744.8	19.6	14.2	20.2	69.7	79.0	67.8	97.3	85.1	41.0	49.4	14.4	7.1	8.0	62.6	50.0	59.5
--FORT RANDALL--																	
NAT INFLOW	489	90	42	54	70	56	195	21	59	-16	-84	-4	-2	-2	-10	20	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	
EVAPORATION	129							10	31	33	23	10	5	5	13		
REG INFLOW	13104	431	292	409	1296	1441	1379	1712	1499	606	701	221	108	123	1023	822	1042
RELEASE	13104	167	148	392	1296	1441	1379	1712	1673	1611	774	221	108	123	750	732	578
STOR CHANGE	0	265	144	17				0	-174	-1005	-73	0	0	0	273	90	464
STORAGE	3123	3388	3532	3549	3549	3549	3549	3549	3375	2370	2296	2296	2296	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.3	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1353.1	1338.8	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	10.5	5.6	10.7	22.0	21.8	23.4	23.2	27.8	27.2	27.1	12.6	7.4	7.8	7.7	12.2	11.9	10.4
POWER																	
AVE POWER MW		46	90	185	184	198	196	234	227	211	92	54	57	57	91	91	82
PEAK POW MW		349	354	355	355	355	355	355	348	288	283	283	283	283	305	311	338
ENERGY GWH	1286.2	16.7	15.1	40.0	132.4	147.0	140.8	174.2	168.9	151.7	68.7	19.6	9.6	10.9	67.6	67.7	55.4
--GAVINS POINT--																	
NAT INFLOW	1252	91	42	55	125	137	144	79	79	57	109	47	22	25	70	68	102
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	9	-10	-22	0	-3	0	-9	1	0	27	10	-1	0	-8	1	3
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	14194	267	181	425	1416	1556	1500	1740	1735	1662	898	268	125	143	797	799	682
RELEASE	14194	267	181	425	1416	1556	1500	1740	1722	1636	898	268	125	143	797	799	721
STOR CHANGE								13	26								-39
STORAGE	358	358	358	358	358	358	358	358	371	397	397	397	397	397	397	397	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	13.0	9.0	13.0	23.8	23.8	25.3	25.2	28.3	28.0	27.5	14.6	9.0	9.0	9.0	13.0	13.0	13.0
POWER																	