

US Army Corps
of Engineers



2000-2001

Northwestern Division
Missouri River Basin
Water Management Division

Missouri River Main Stem Reservoirs 2000-2001 Annual Operating Plan



January 2001



REPLY TO
ATTENTION OF

DEPARTMENT OF THE ARMY
NORTHWESTERN DIVISION, CORPS OF ENGINEERS
12565 WEST CENTER ROAD
OMAHA, NEBRASKA 68144-3869

This Annual Operating Plan (AOP) for the Missouri River System was prepared by the Corps of Engineers' Missouri River Basin Water Management Division, Northwestern Division. The plan outlines the operating objectives of the Missouri River main stem reservoirs for the coming year (December 2000 through July 2001). In addition, two sets of 5-year extensions to the AOP, through March 2007, are presented to serve as guides for longer range planning.

Previous AOP's have included a System description and discussion of the typical operation to meet authorized purposes and a historic summary of the previous year's operation. Although not included in this AOP, they are available as separate reports upon request. To receive a copy of either the "System Description and Operation" or the "Summary of Actual 1999-00 Operations," contact the Water Management Division at 12565 West Center Road, Omaha, Nebraska 68144-3869, phone (402) 697-2676. Both reports are also available at the "Reports and Publications" link on our web site at: www.nwd.usace.army.mil/rcc.

The development of this year's Draft AOP was coordinated with the Missouri River Natural Resources Committee (MRNRC) and the general public. The MRNRC recommendations for the 2000-2001 AOP are shown as Exhibits 1 and 2.

The Draft AOP also received review at three fall public meetings held at Bismarck, North Dakota, on October 17, 2000, at Fort Peck, Montana, on October 18, 2000, and at Kansas City, Missouri, on October 19, 2000. The primary purpose of these meetings was to present the Draft AOP and receive comments from all concerned. Private citizens and representatives of public and industry interest groups and Missouri River basin states attended the meetings.

The final plan presented in this report is approved as the framework within which the Missouri River Region will schedule detailed daily, weekly, and monthly regulation of the individual main stem reservoirs for the period December 2000 through 2001. The final plan differs slightly from the draft plan presented at the October public meetings. First, the AOP studies were updated to reflect current basin conditions as of December 1, 2000. The final plan also differs from the draft in that lower winter System releases are used when System storage is below normal as an additional water conservation measure and to offset excess releases made for threatened and endangered species operation during the previous summer. Although a winter release rate of 12,000 cubic feet per second was used in the studies, releases will be adjusted as needed to assure adequate downstream water supply. This change was the result of suggestions from various interests made during the public comment period. A number of clarifications and word changes were also made to the draft to improve readability. The press release announcing the adopted plan for next year is shown on Exhibit 3.

A handwritten signature in black ink that reads "Duane R. Sims".

Duane R. Sims
Lieutenant Colonel, Military Police
Assistant Division Engineer

MISSOURI RIVER MAIN STEM RESERVOIRS

Annual Operating Plan 2000-2001

List of Tables	ii
List of Plates	ii
List of Exhibits	iii
List of Abbreviations	iv
Definition of Terms	v
I. FOREWORD	1
II. PURPOSE AND SCOPE	2
III. FUTURE WATER SUPPLY – AUGUST 2000 – DECEMBER 2001	3
IV. ANNUAL OPERATING PLAN FOR 2000-2001	4
A. General	4
B. Operating Plans for the Balance of the 2000 Navigation Season.....	7
C. Operating Plan for the Winter of 2000-2001	8
D. Operations During the 2001 Navigation Season.....	10
V. SUMMARY OF RESULTS EXPECTED IN 2000-2001.....	15
A. Flood Control	15
B. Water Supply and Water Quality Control.....	16
C. Irrigation	16
D. Navigation.....	16
E. Power	16
F. Recreation, Fish and Wildlife.....	16
G. System Storage.....	18
H. Summary of Water Use by Functions.....	19
VI. TENTATIVE PROJECTION OF OPERATIONS THROUGH MARCH 2007	19
A. Median Runoff	21
B. Lower Quartile Runoff – Navigation Season Shortened at 52 MAF on July 1	21

C.	Lower Quartile Runoff – Navigation Season Shortened at 40 MAF on July 1	21
D.	Lower Decile Runoff – Navigation Season Shortened at 52 MAF on July 1	21
E.	Lower Decile Runoff – Navigation Season Shortened at 40 MAF on July 1	22

TABLES

I	Natural and Gross Water Supply at Sioux City	4
II	Gavins Point Releases Needed to Meet Navigation Requirements.....	6
III	Navigation Service Support for the 2001 Season	11
IV	Reservoir Unbalancing Schedule	13
V	MRNRC Recommended Reservoir Elevation Guidelines for Unbalancing.....	13
VI	Peaking Capability and Sales	17
VII	Energy Generation and Sales	17
VIII	Anticipated December 31, 2001 Storage in Main Stem System	18
IX	Missouri River Main Stem Water Use for Calendar Years 1999, 2000, and 2001 Above Sioux City, Iowa	20
X	March 1 Reservoir Unbalancing, AOP Extensions.....	21

PLATES

1	Missouri River Basin Map
2	Summary of Engineering Data – Missouri River Main Stem Reservoirs
3	System Storage
4	Gavins Point Releases
5	Fort Peck Elevations and Releases
6	Garrison Elevations and Releases
7	Oahe Elevations and Releases
8	Fort Randall Elevations and Releases
9	Reservoir Release and Unregulated Flow
10	System Gross Capability and Average Monthly Generation
11	Tentative Five Year Extensions of 2000-2001 AOP – System Storage, Gavins Point Regulated Flows, and Peaking Capability (To be provided in Final AOP)
12	Tentative Five Year Extensions of 2000-2001 AOP – Reservoir Elevations

EXHIBITS

Exhibit 1 – MRNRC 2000-2001 AOP Recommendations, September 1, 2000

Exhibit 2 – MRNRC 2000-2001 AOP Recommendations Follow-up, September 21, 2000

Exhibit 3 – News Release Announcing 2001 AOP, January 12, 2001

ABBREVIATIONS

AOP	-	annual operating plan
ac.ft.	-	acre-feet
AF	-	acre-feet
B	-	Billion
cfs	-	cubic feet per second
Corps	-	Corps of Engineers
CY	-	calendar year (January 1 to December 31)
elev	-	elevation
ft	-	feet
FY	-	fiscal year (October 1 to September 30)
GIS	-	Geographic Information System
GWh	-	gigawatt hour
KAF	-	1,000 acre-feet
Kcfs	-	1,000 cubic feet per second
kW	-	kilowatt
kWh	-	kilowatt hour
M	-	million
MAF	-	million acre-feet
MRBA	-	Missouri River Basin Association
MRNRC	-	Missouri River Natural Resources Committee
msl	-	mean sea level
MW	-	megawatt
MWh	-	megawatt hour
PI	-	Preliminary Injunction
plover	-	piping plover
pp	-	powerplant
P-S MBP	-	Pick-Sloan Missouri Basin Program
RCC	-	Reservoir Control Center
RM	-	river mile
tern	-	interior least tern
TRO	-	Temporary Restraining Order
tw	-	tailwater
USGS	-	United States Geological Survey
yr	-	year

DEFINITION OF TERMS

Acre-foot (AF, ac-ft) is the quantity of water required to cover 1 acre to a depth of 1 foot and is equivalent to 43,560 cubic feet or 325,850 gallons.

Cubic foot per second (cfs) is the rate of discharge representing a volume of 1 cubic foot passing a given point during 1 second and is equivalent to approximately 7.48 gallons per second or 448.8 gallons per minute. The volume of water represented by a flow of 1 cubic foot per second for 24 hours is equivalent to 86,400 cubic feet, approximately 1.983 acre-feet, or 646,272 gallons.

Discharge is the volume of water (or more broadly, volume of fluid plus suspended sediment) that passes a given point within a given period of time.

Drainage area of a stream at a specific location is that area, measured in a horizontal plane, enclosed by a topographic divide from which direct surface runoff from precipitation normally drains by gravity into the river above the specified point. Figures of drainage area given herein include all closed basins, or noncontributing areas, within the area unless otherwise noted.

Drainage basin is a part of the surface of the earth that is occupied by drainage system, which consists of a surface stream or body of impounded surface water together with all tributary surface streams and bodies of impounded water.

Gaging station is a particular site on a stream, canal, lake, or reservoir where systematic observations of hydrologic data are obtained.

Runoff in inches shows the depth to which the drainage area would be covered if all the runoff for a given time period were uniformly distributed on it.

Streamflow is the discharge that occurs in a natural channel. Although the term "discharge" can be applied to the flow of a canal, the word "streamflow" uniquely describes the discharge in a surface stream course. The term "streamflow" is more general than "runoff" as streamflow may be applied to discharge whether or not it is affected by diversion or regulation.

MISSOURI RIVER MAIN STEM RESERVOIRS

Annual Operating Plan 2000 - 2001

I. FOREWORD

This Annual Operating Plan (AOP) presents pertinent information and tentative plans for operating the Missouri River Main Stem Reservoir System (System) for the remainder of 2000 through December 2001 under widely varying water supply conditions. It provides a framework for the development of detailed monthly, weekly, and daily regulation schedules for the System's six individual dams during the upcoming year to serve the Congressionally authorized project purposes. Regulation is directed by the Missouri River Basin Water Management Division (formerly the Reservoir Control Center), Northwestern Division, U.S. Army Corps of Engineers (Corps). A map of the Missouri River basin is shown on *Plate 1* and the summary of engineering data for the six main stem reservoirs is shown on *Plate 2*.

This plan may require adjustments when substantial departures from expected runoff occur. Results of a 5-year extension to the AOP studies (March 2002 to March 2007) are presented to serve as a guide for Western Area Power Administration's power marketing activities and those other interests that require information on reservoir conditions for long term planning.

The AOP studies described in the following paragraphs and shown at the end of this document have been updated from the Draft AOP studies to reflect actual conditions through late November and forecasted December 1, 2000 initial conditions. These updated studies serve as the basis for 2001 forecasts and for extensions through March 1, 2007.

Previous AOP's have used August 1 of the current year as the initial condition, but much lower runoff forecasts, low System storage, and two lawsuits pertaining to System operation rendered the Draft AOP regulation forecasts obsolete.

The first lawsuit, State of Kansas *v.* United States, filed in the United States District Court for the District of Kansas in Topeka, Kansas on September 25, 2000 resulted in a Temporary Restraining Order (TRO) and Preliminary Injunction (PI) that prevented the use of water stored in the Kansas River tributary dams for support of navigation on the lower Missouri River. Prior to the TRO, the Missouri River Basin Water Management Division had requested the Kansas City District to use water stored in Tuttle Creek, Milford, and Perry reservoirs to meet a 2,000 cubic feet per second (cfs) target on the Kansas River at Desoto, Kansas. This was 1,000 cfs above the minimum summertime water quality target. As a result of the TRO, the target flow on the Kansas River was reduced to 1,000 cfs, and additional releases were made from the main stem System to maintain the navigation flow targets. On a motion of the Plaintiff, the case has been dismissed and the PI vacated.

The second lawsuit, Standing Rock Sioux Tribe, et al v. U.S. Army Corps of Engineers, et al, pertained to the Lake Oahe elevation. The U.S. District Court in Aberdeen, South Dakota issued a Temporary Restraining Order (TRO) effective at 1800 hours on November 6, 2000 to maintain Lake Oahe at an elevation of 1597 feet above mean sea level (msl) with a variance not to exceed 6 inches downward to minimize impacts to exposed cultural and historical sites important to the Standing Rock Tribe. As a result, Oahe and Big Bend releases were immediately reduced and Garrison releases were increased to comply with the order. The effect on the main stem System was that releases from Oahe were drastically reduced and much higher flows were initiated from Garrison. The TRO was voluntarily modified and extended while settlement opportunities were pursued. A Joint Motion to Stay the Proceedings until January 22, 2001 was granted (later amended to January 23) by order dated November 28, 2000. That order provides that "Lake Oahe shall not be reduced below 1597 msl with not more than an eighteen (18) inch total variance downward."

This AOP includes only the plan for future operation. Previous AOP's have included a System description and discussion of the typical operation to meet authorized purposes and a historic summary of the previous year's operation. Although not included in this AOP, they are available as separate reports upon request. To receive a copy of either the updated version of the "System Description and Operation" dated January 2000, or the "Summary of Actual 1999-2000 Operations," contact the Missouri River Basin Water Management Division at 12565 West Center Road, Omaha, Nebraska 68144-3869, phone (402) 697-2676. Both reports will be available at the "Reports and Publications" link on our web site at: www.nwd-mr.usace.army.mil/rcc in early 2001.

II. PURPOSE AND SCOPE

Beginning in 1953, projected System operation for the year ahead was developed annually as a basis for advance coordination with the various interested Federal, state, and local agencies and private citizens. Also beginning in 1953, a coordinating committee was organized to make recommendations on each upcoming year's System operation. The Coordinating Committee on Missouri River Main Stem Reservoir Operations held meetings semiannually until 1981 and provided recommendations to the Corps. In 1982 the committee was dissolved because it did not conform to the provisions of the Federal Advisory Committee Act. Since 1982, to continue providing a forum for public participation, one or more open public meetings are held semiannually in the spring and fall. The fall public meeting is conducted to take public input on a draft of the Annual Operating Plan, which is typically published in early October each year. The spring meetings are conducted to update the public on the current hydrologic conditions and projected System operation for the remainder of the year.

The spring public meetings were held in Jefferson City, Missouri, on April 12, 2000 and in South Sioux City, Nebraska, on April 13, 2000. The attendees were given an update regarding the outlook for 2000 runoff and projected operation for the remainder of 2000. Three fall public meetings on the Draft AOP were held on October 17, 2000 at Bismarck, North Dakota, October 18, 2000 at Fort Peck, Montana, and on October 19, 2000 at Kansas City, Missouri.

Pre-draft AOP coordination was conducted with the Missouri River Natural Resources Committee (MRNRC). Its recommendations for the 2000-2001 AOP are shown as Exhibits 1 and 2.

III. FUTURE WATER SUPPLY - AUGUST 2000 - DECEMBER 2001

The AOP forecast studies described in this document underwent a major revision between the draft and the final AOP. The Draft 2000-2001 AOP studies used August 1, 2000 as the initial condition and the appropriate water supplies to the reservoirs for the period August 2000 to December 2001 were estimated. The period August through February is normally one of relatively low and stable inflows and can be forecast with reasonable reliability. Therefore, a Basic Forecast (most likely for current runoff conditions) of monthly inflows to the river reaches above the six reservoirs and the river reach from Gavins Point to Sioux City was prepared for the period August 2000 to February 2001.

However, due to changed basin and reservoir conditions, and the previously described lawsuits pertaining to the use of Kansas River basin reservoirs for navigation support and the Lake Oahe pool elevation, forecast studies for the final AOP used a forecasted December 1, 2000 starting condition and the Basic Forecast was revised for the period December through February.

Forecasts of the Lower Quartile and Lower Decile using 80 percent and Upper Quartile and Upper Decile using 120 percent of the Basic Forecast are also used to give a range of monthly inflows leading up to March 1, 2001, the beginning of next year's runoff season. Inflows to the System after March 1, 2001, are dependent upon many hydrologic factors which are impossible to forecast at the time the AOP is prepared. Therefore, in lieu of utilizing forecasted inflows to the Missouri River above Sioux City for the period March 2001 to December 2001, inflows were based on analyses of the past water supply records extending from 1898 through 1997. Runoff conditions selected for use in the AOP were the Upper Decile with a runoff of 34.5 million acre-feet (MAF) having 1 chance in 10 of being exceeded, the Upper Quartile with a runoff of 30.6 MAF having 1 chance in 4 of being exceeded, and the Median (most likely) with a runoff of 24.6 MAF having 1 chance in 2 of being exceeded. The lower range of System inflows used for the analyses in the AOP, the Lower Quartile with a runoff of 19.5 MAF having 1 chance in 4 of occurrence of less runoff and the Lower Decile with a runoff of 15.5 MAF having 1 chance in 10 of occurrence of less runoff, completes the range of inflows into the System.

The range between the AOP forecasts for Lower Decile (15.5 MAF with a 90 percent exceedence) and the Upper Decile (34.5 MAF with a 10 percent exceedence) simulates 80 percent of the historic runoffs. There is still a 20 percent chance that a runoff condition may occur that has not been simulated; i.e., 10 percent chance a runoff event could be lower than the 15.5 MAF (Lower Decile) and a 10 percent chance a runoff event could be greater than the 34.5 MAF (Upper Decile).

The estimated natural flow 1/ at Sioux City, the corresponding post-1949 water use effects, and the net flow 2/ available above Sioux City are shown in **Table I**, where several water supply conditions are quantified for the periods December 2000, Calendar Year (CY) 2000, and CY 2001. The natural water supply for CY 2000 (actual January 2000 to November 2000 runoff plus Basic Forecast for December 2000) is estimated to total about 16.6 MAF.

**TABLE I
NATURAL AND GROSS WATER SUPPLY AT SIOUX CITY**

	<u>Natural 1/</u>	<u>Post-1949 Depletions</u>	<u>Net 2/</u>
	(Volumes in 1,000 Acre-Feet)		
<u>December 2000</u> (Basic Forecast)			
Basic	700	+100	800
120% Basic	800	+200	1,000
80% Basic	600	+100	700
<u>Calendar Year 2000</u> (January-November Actual; December Basic Forecast)			
Basic	16,600	-1,700	14,900
120% Basic	16,700	-1,800	14,900
80% Basic	16,500	-1,400	15,100
<u>Calendar Year 2001</u> (Extended Forecast - Statistical Analysis of Past Records)			
Upper Decile	34,500	-2,400	32,100
Upper Quartile	30,600	-2,400	28,200
Median	24,600	-2,600	22,000
Lower Quartile	19,500	-2,600	16,900
Lower Decile	15,500	-2,200	13,300

1/ The word “natural” is used to designate flows adjusted to the 1949 level of basin development, except that regulation and evaporation effects of the Fort Peck Reservoir have also been eliminated during its period of operation prior to 1949. 2/ The word “net” represents the total streamflow after deduction of the post-1949 irrigation, upstream storage, and other use effects.

IV. ANNUAL OPERATING PLAN FOR 2000-2001

A. General. The anticipated operation described in this AOP is designed to meet the operational objectives documented in the current Missouri River Master Water Control Manual (Master Manual). Consideration has been given to all of the authorized project purposes including the needs of endangered species. It incorporates the lessons learned during the 6 consecutive years of drought of the late-1980’s through 1992 as well as the high runoff period that followed. Runoff during the period 1993 to 1999 was greater than upper quartile level during 5 of those 7 years, including the record 49.0 MAF of runoff in 1997.

This 2000-2001 AOP, developed for all five runoff scenarios, follows the March 15 and July 1 water-in-storage (storage) checks contained in the current Master Manual used to determine navigation flow service level and navigation season length. The September 1 storage check that previously was used to determine winter multipurpose System releases was not used in the AOP studies. Rather, when forecasted System storage was below 57.1 MAF on March 1, winter releases were set at 12,000 cfs as an additional water conservation measure and to offset excess releases made for threatened and endangered species operation during the previous summer. Although a winter release rate of 12,000 cfs was used in the studies, releases will be adjusted as needed to assure adequate downstream water supply, including powerplants. An additional Lower Decile study that shortens the navigation season by 2 weeks is included. Adjusted regulations for fish spawning and endangered species nesting habitat have been adopted for the three scenarios of Median, Lower Quartile, and Lower Decile runoffs with no peaking cycle at Gavins Point Dam as was implemented to conserve water during the recent drought years. Intrasystem releases are adjusted to best serve the multiple-purpose functions of the projects with special emphasis placed on regulation for fisheries starting in early April and for endangered species beginning in early May and continuing through August.

A reanalysis of the average monthly Gavins Point releases needed to meet navigation service requirements was completed in 1999. The study used the Daily Long Range Study (DLRS) model for the period 1950 to 1996. As part of this study, the relationship between annual runoff upstream of Sioux City and the average Gavins Point release required for the navigation season was analyzed. The study concluded that generally more water was needed downstream to support navigation during years with below normal upper basin runoff than during years with higher upper basin runoff. Therefore, regulation studies since 1999 use two levels of System release requirements: one for Median, Upper Quartile, and Upper Decile runoff scenarios, and another for Lower Quartile and Lower Decile scenarios.

The updated release requirements for full service navigation used in the development of the 2000-2001 AOP are given in **Table II**. Releases required for minimum service navigation support are 6,000 cfs less than the numbers provided in **Table II**. A final report detailing the procedures used in this study is available on our web site.

In summary, the Upper Decile runoff scenario follows the Master Manual with much above normal runoff prompting release increases early in the year to evacuate floodwater from the reservoirs. Releases for Upper Decile and Upper Quartile runoff for 2001 are considerably lower than was shown in recent Annual Operating Plans since March 1 System storage based on the 120 Percent Forecast is expected to be 6.1 MAF less than the desired 57.1 MAF. The Median, Lower Quartile, and Lower Decile runoffs follow the March 15 and July 1 System storage checks contained in the Master Manual. Since System storage is less than 52 MAF on July 1, 2001 for Lower Decile runoff, an additional study shortens the navigation season by 2 weeks. The Median and above runoff forecasts also include releases that provide a steady to rising lake level in the upper three large reservoirs during the spring fish spawn period. Similar regulations have resulted in a higher fish reproduction success. Gavins Point releases will not be cycled to conserve water under any of the five studied runoff levels but may be necessary for flood control operations during the endangered species nesting period or should significant drought conditions return.

TABLE II
GAVINS POINT RELEASES NEEDED TO MEET
NAVIGATION REQUIREMENTS
1950 - 1996
(Discharges in 1,000 cfs)

Runoff Scenario	<u>Month</u>								<u>Average</u>
	<u>Apr</u>	<u>May</u>	<u>Jun</u>	<u>Jul</u>	<u>Aug</u>	<u>Sep</u>	<u>Oct</u>	<u>Nov</u>	
Median, Upper Quartile, Upper Decile	26.7	28.0	27.9	31.6	33.2	32.6	32.0	31.1	30.4
Lower Quartile, Lower Decile	29.8	31.3	31.2	34.3	34.0	33.5	33.1	31.2	32.3

The lowest runoff scenario presented is Lower Decile. Runoff less than Lower Decile is possible, as was experienced in 1988 (12.4 MAF). One of the operational objectives of the current Master Manual is to provide for water supply requirements in the open Missouri River reaches between the reservoirs and below the System. Recent experience has shown that these water supply requirements are greater than was anticipated during the development of the guidelines documented in the current Master Manual. Also, operation to limit impacts to threatened and endangered species has resulted in higher releases during low runoff periods. Therefore, in order to meet the operational objectives of the current Master Manual, we would need to adjust the water conservation guidelines published in the Master Manual. These water conservation guidelines apply during drought periods and present criteria for season length, service level, minimum navigation season length, and nonnavigation season minimum releases. In order to meet the operational objectives of the current Master Manual, adjustments to drought water conservation guidelines would need to occur when total System storage is at or below 52 MAF on July 1. It is important to note that there are many possible combinations of potential adjustments that would result in attainment of the current Master Manual operational objectives.

This year's Lower Decile studies show a decline of total System storage below the 52 MAF level by July 1, 2001. Should significant drought conditions persist, (i.e., 52 MAF - July 1 level or less) the Missouri River Basin Association (MRBA), the MRNRC, and other interested parties would be consulted for adjustment recommendations that would best meet the operational objectives of the current Master Manual. We would facilitate discussion by providing studies that outline the effects of the various adjustment options to the aforementioned groups. If a general agreement on reasonable adjustments cannot be attained, we will determine which adjustments best meet the current Master Manual operational objectives.

Background information available for preparation of the 2000-2001 AOP includes 13 years of operation at Fort Peck Reservoir (1940) by itself plus 47 years of System experience as Fort Randall (1953), Garrison (1955), Gavins Point (1955), Oahe (1962), and Big Bend (1964)

have been brought progressively into operation. In addition to the long period of actual regulation experience, many background operational studies for the completed System are available for guidance.

Actual System operation from January through November 2000 and the operating plans for each project for the remainder of 2000 with the Basic Forecast and for CY 2001 using the five alternate levels of estimated runoff described on page 2 are presented on **Plates 3 through 8**, inclusive. An exception is the omission of Big Bend, since storage at that project is relatively constant and average monthly releases are essentially the same as those at Oahe. These plates also show, on a condensed scale, actual operations during the period 1953 through 1999.

Plate 9 illustrates for Fort Peck, Garrison, Oahe, and Gavins Point Dams the actual reservoir releases (Regulated Flow) as well as the Missouri River flows (Unregulated Flow) that would have resulted if the reservoirs were not in place during the period January 1999 through July 2000. **Plate 10** presents past and forecasted gross monthly, average power generation, and gross peaking capability for the System.

B. Operation for the Balance of the 2000 Navigation Season. Gavins Point releases continued at 31,500 cubic feet per second (cfs) range until the endangered and threatened species left in late August. Releases were then adjusted as needed to provide 1,500 cfs less than full service support to navigation flows as computed by the July 1 System storage check. System storage was 57.0 MAF on July 1, 2000, substantially less than the 59.0 MAF minimum storage required to provide full service flows the remainder of the navigation season. A full 8-month navigation season was provided in 2000, but unlike the past 5 years, the navigation season was not extended since there was no excess storage to evacuate from the System.

The decline in System storage over the past year began with lack of significant runoff from a plains snowpack and continued with dismal runoff from the much below normal mountain snowpack (82 percent of normal) in combination with below normal rainfall. The total runoff for 2000 is expected to be below Lower Quartile, but there has been a great deal of variability in the way the runoff has occurred. January and February were 99 and 106 percent of normal, respectively. March dropped to 63 percent, and April was 59 percent of normal. The reduction during March and April was due to the lack of a significant plains snow cover, most of which melted during February and did not produce any significant runoff. The months of May, June, and July were well below average at 65, 60, and 65 percent of normal, respectively. Low runoff continued in the August through November period. The December 1 runoff forecast of 16.6 MAF is just 66 percent of normal. The closing dates for ending the 2000 navigation season were November 22 at Sioux City, November 24 at Omaha, November 25 at Nebraska City, November 27 at Kansas City, and December 1 at the mouth of the Missouri River near St. Louis.

Energy generation by the System powerplants for the period August 1 to December 1 was 3.2 billion kilowatt hours (kWh), 0.6 billion kWh below normal.

Fort Peck releases ranged from 4,500 to 9,000 cfs, for the remainder of the 2000 navigation season. Fort Peck Lake declined 4.0 feet from elevation 2232.0 feet msl to 2228.0

feet msl by the end of the navigation season, 6.9 feet lower than the 1967-1999 long term average.

Garrison releases ranged from 13,000 to 27,000 cfs through the remainder of the 2000 navigation season. Releases as high as 27,000 cfs were scheduled November 9-17 to prevent the lowering of Lake Oahe. The level of Lake Sakakawea declined steadily by 6.9 feet from elevation 1837.4 feet msl to 1830.5 feet msl by the end of the navigation season, 8.1 feet below the long term average.

Oahe releases were reduced from 34,000 cfs in August to 8,000 cfs in November to achieve the scheduled Fort Randall drawdown to elevation 1335.0 feet msl prior to the end of the navigation season. A low 8,000 cfs release was scheduled November 7-9 to meet the requirements of the TRO that prohibited the lowering of Lake Oahe below elevation 1597.7 feet msl, plus or minus 6 inches. Releases were adjusted to serve the variable power loads. Lake Oahe fell 7.1 feet from August through early November, from elevation 1604.8 to elevation 1597.7 feet msl. The lake level was maintained near 1597.7 feet msl during the remainder of November as required by the TRO and, at the close of the navigation season, was at 1597.3 feet msl, 4.7 feet lower than the long term average.

Big Bend releases paralleled those from Oahe. Lake Sharpe generally fluctuated between 1420.0 and 1421.0 feet msl for weekly cycling during high power load periods. Actual elevations ranged from 1418.4 feet msl to 1421.0 feet msl during the period August through November. The lake was lowered to near elevation 1418.5 feet msl September 8-13 to facilitate protection of a cultural resources site along the shores of Lake Sharpe. Reservoir fluctuations of a foot are scheduled during the course of most weeks in order to follow peaking power demands. Storage lost during the week is regained during the succeeding weekend period of lower power demands.

Fort Randall releases generally paralleled those from Gavins Point. Lake Francis Case lowered 4.2 feet in September, from elevation 1355.7 feet msl to elevation 1351.5 feet msl. The fall drawdown of Lake Francis Case, originally planned to reach 1337.5 feet msl at the end of November, was accelerated to lower the pool to near 1335 feet msl by October 25. This allowed the Omaha District to attempt to locate remains at St. Phillips Cemetery in the White Swan area. Lake Francis Case was further lowered to elevation 1332.6 feet msl to supply navigation flows as Oahe releases were reduced in November to comply with the TRO. The drawdown will provide sufficient capacity to store a reasonable level of power releases from Oahe and Big Bend during the coming winter season.

Gavins Point releases ranged from 29,000 to 34,500 cfs during the remainder of the navigation season. Lewis and Clark Lake rose about 1 foot from elevation 1205.8 to near elevation 1207.0 feet msl during the remainder of the 2000 navigation season that ended December 1. The lake level will be maintained near 1207.0 feet msl through the winter.

C. Operating Plan for the Winter of 2000-2001. Winter releases from the System are normally based on the amount of water in storage on September 1 in accordance with guidelines

presented in the Master Manual. A System storage level of 58.0 MAF or above on September 1 indicates a full service release rate for the following winter. A System storage of 43.0 MAF indicates minimum service releases. Full and minimum service releases call for an average winter Fort Randall release of 15,000 and 5,000 cfs, respectively. Following the criteria in the current Master Manual, the Fort Randall 2000-2001 winter release rate would be near 12,500 cfs based on the September 1, 2000 System storage of 54.3 MAF. However, due to the low System storage, Gavins Point releases were set at 12,000 cfs as a water conservation measure and to offset the increased releases required for the endangered species nesting requirements. Sustained winter release rates above this amount are not anticipated since System storage is forecast to be 6.8 MAF below the desired 57.1 MAF on March 1, 2001. However, it may be necessary at times to increase System releases to provide adequate downstream flows if ice jams or blockages form which temporarily restrict flows. These events are expected to occur infrequently and be of short duration based on past experiences.

For the winter period from the close of the 2000 navigation season on December 1, 2000 until the opening of the 2001 navigation season on April 1, 2001 operations are expected to be as follows:

Fort Peck releases are expected to be near 10,000 cfs before the beginning of the winter period to prevent ice-jam flooding during the winter freeze-in period on the reach of the Missouri River from the dam to the Williston, North Dakota area. Releases will then be increased only slightly to 11,000 cfs for the remainder of the winter period to meet critical winter hydropower demands. Fort Peck Lake with the Basic Forecast is expected to fall steadily by 4.0 feet to elevation 2224.0 by March 1, the beginning of next year's runoff season. The lake would then rise to near elevation 2225.1 feet msl by March 31, which would be nearly 8.0 feet below normal.

Garrison winter releases are lower than the draft AOP forecasts as a result of the Temporary Restraining Order at Lake Oahe. Water stored in Lake Sakakawea that normally would have been transferred to Lake Oahe during the winter was moved to Lake Oahe in November to meet the requirements of the TRO. Releases will average only 17,500 cfs from December through February to balance the upper three reservoirs by March 1. Releases are normally scheduled near 20,000 cfs in December with reductions to 18,000 cfs during the freeze-in in the Bismarck area in an attempt to remain below a 13-foot stage at the Bismarck gage. Flood stage is 16 feet. Lake Sakakawea is expected to lower from near elevation 1830.9 feet msl to elevation 1829.3 feet msl by March 1, 8.2 feet below the base of the annual flood control storage zone. The Median forecast indicates the lake will rise to elevation 1830.0 by March 31, which would be 5.8 feet below normal.

Oahe releases for the winter season will provide backup for the Fort Randall and Gavins Point releases plus fill the recapture space available at Fort Randall consistent with anticipated winter power loads. Monthly average releases may vary substantially with fluctuations in power loads occasioned by weather conditions but, in general, are expected to average between 11,000 and 17,000 cfs. Daily releases will vary widely to best meet power loads. Peak hourly releases as well as daily energy generation will be constrained to prevent urban flooding in the Pierre and

Fort Pierre areas if severe ice problems develop downstream of Oahe Dam. This potential reduction has been coordinated with the Western Area Power Administration.

The Lake Oahe level is expected to gradually rise from elevation 1597.3 feet msl at the end of the 2000 navigation season to elevation 1599.1 by March 1, with a further rise to elevation 1601.7 feet msl by the end of March, 5.0 feet below normal.

Lake Sharpe at Big Bend will be maintained in the normal 1420.0 to 1421.0 feet msl range during the winter.

Fort Randall releases will average 9,000 to 10,000 cfs. Lake Francis Case is expected to rise from a low of about 1335.0 feet msl at the end of the 2000 navigation season to near elevation 1350.0, the seasonal base of flood control, by March 1. However, if the plains snowpack flood potential downstream of Oahe is quite low at that time, measures will be taken to raise Lake Francis Case to near elevation 1353.0 by March 1. It is likely that a Lake Francis Case level above elevation 1353 feet msl, to as high as 1355.2, will be reached by the end of the winter period on March 31 if runoff conditions permit. The level of Lake Francis Case above the White River delta near Chamberlain, South Dakota will likely remain at a higher elevation than the lake below the delta from late October through December, due to the damming effect of this delta area.

Gavins Point releases were gradually reduced beginning the last week of November to near a winter level of 12,000 cfs. It is anticipated, although not modeled, that releases may have to be increased during periods of freeze-in to maintain water levels necessary for downstream water intakes. Lewis and Clark Lake will generally be near elevation 1207 feet msl until late February when it will be lowered to elevation 1206 feet msl for controlling spring floods, primarily from the Niobrara River and Ponca Creek along the Fort Randall to Gavins Point reach.

System storage for all five runoff conditions will be substantially below the base of the annual flood control zone by March 1, 2001, the beginning of next year's runoff season.

D. Operations During the 2001 Navigation Season. The Upper Decile, Upper Quartile, Median, and Lower Quartile runoff scenarios studied for this year's AOP follow the guidelines presented in the Master Manual for navigation service flow support and season length. Two Lower Decile studies are included, one with an 8-month navigation season as called for in the Master Manual and an additional study that has a 2-week shortening since the July 1 System storage is less than 52.0 MAF. Steady System releases or repetitive daily project patterns will be held from early May, at the beginning of the endangered species nesting season, to the end of the nesting in late August. All runoff scenarios except Lower Quartile and Lower Decile would provide rising pool levels in the spring fish spawn period.

All five runoff scenarios studied for this year's AOP are based on gradually increasing System releases to provide navigation season flow rates at the mouth of the Missouri near St. Louis by April 1, 2001, the normal navigation season opening date. The corresponding dates at upstream locations are: Sioux City, Iowa, March 23; Omaha, Nebraska, March 25; Nebraska

City, Nebraska, March 26; and Kansas City, Missouri, March 28. The studies illustrated on *Plates 3 through 8* and summarized in *Table III* are based on providing greater than full service flows and a full 8-month season extended by 10 days as a reservoir flood storage evacuation measure for the Upper Decile runoff scenario. Releases for Upper Quartile runoff are 1,600 cfs below full service in the spring, increasing to near full service during the summer and fall with an 8-month navigation season. The normal runoff scenario characterized by the Median study indicates 2,300 cfs less than full service flows for a full 8-month navigation season. Lower Quartile has a 3,000 cfs spring and 4,500 cfs summer and fall reduction below full service flows with an 8-month season. Both Lower Decile studies have releases 3,100 cfs below full service in the spring and 5,900 cfs below full service in the summer and fall.

**TABLE III
NAVIGATION SERVICE SUPPORT
FOR THE 2001 SEASON**

	Runoff Scenario (MAF)	2001 System Storage		Flow Level Above or Below Full Service (in cfs)		Length of Season (Months)
		March 15 (MAF)	July 1 (MAF)	Spring	Summer/Fall	
U.D.	34.5	52.4	60.0	+4,300	+ 3,500	8 + 10 days
U.Q.	30.6	52.2	58.8	-1,600	-100	8
Med	24.6	51.2	55.7	-2,300	-2,300	8
L.Q.	19.5	50.3	52.6	-3,000	-4,500	8
L.D.	15.5	50.2	50.7	-3,100	-5,900	8 or 7.5

Navigation flow support for the 2001 season will be determined by actual reservoir System storage on March 15 and July 1 following the Master Manual guidelines. Gavins Point releases may be quite variable during the 2001 navigation season but, for Median, Lower Quartile, and Lower Decile, are expected to range from 24,400 to 30,900 cfs. For Upper Quartile, releases range from 25,100 to 33,100 cfs; for the Upper Decile, Gavins Point releases would range from a minimum 31,000 cfs to a maximum 35,000 cfs. Release reductions necessary to minimize downstream flooding are not reflected in these monthly averages but will be instituted as conditions warrant.

Planned storages and releases for the System and individual reservoirs within the System are shown on *Plates 3 through 8*. Ample regulatory storage space exists in the System to control flood inflows under all conditions studied. *Table III* summarizes the navigation service support projected for the 2001 navigation season.

Two reservoir operations that have not been a part of previous Annual Operating Plans are included for 2001 in the Upper Decile, Upper Quartile, and Median forecasts. An endangered species flow modification “mini-test” will be conducted at Fort Peck beginning in early June to monitor effects of higher spring releases and warmer water released from the spillway. It will also allow for an evaluation of the integrity of the spillway structure given the potential for increased frequency of use. Streambank erosion and fishing impacts will also be monitored.

During the Fort Peck “mini-test,” which will last about 4 weeks, flows will vary from 8,000 to 15,000 cfs as various combinations of spillway and powerplant releases are monitored. The maximum spillway release of 11,000 cfs will combine with a minimum powerplant release of 4,000 cfs for 6 days. This operation is reflected in the June releases shown for Fort Peck for Upper Decile, Upper Quartile, and Median runoff, but will be timed to avoid lowering the lake during the forage fish spawn. The “mini-test” will not be conducted if sufficient flows will not pass over the spillway crest (elevation 2225 feet msl). A minimum lake elevation of about 2229 feet msl is needed during the test to avoid unstable flows over the spillway. This elevation cannot be achieved in 2001 for Lower Quartile and Lower Decile flows. A more extensive test with a combined 20,000 to 30,000 cfs release from Fort Peck is scheduled to be conducted beginning in early June 2002 to determine if warm water releases will benefit the native river fishery. Peak outflows during the 2002 test would be maintained for 2 weeks within the 4-week test period. Any permanent change to the Fort Peck operation to enhance flows for endangered species will be considered as part of the Master Manual Review and Update.

The other reservoir operation involves unbalancing the three large upper reservoirs to benefit reservoir fishery and the endangered interior least tern and threatened piping plover. **Table IV** indicates the reservoirs will be balanced on March 1, 2001, but 1 year later, on March 1, 2002, Fort Peck will be high, Garrison low, and Oahe allowed to float (normal operation) should Median or greater runoff occur. This unbalancing is computed based on the percent of the carryover multiple purpose pool that remains in Fort Peck Lake, Lake Sakakawea, and Lake Oahe. In terms of elevations, Fort Peck would be 4.0 feet high, Garrison would be 3.0 feet low, and Oahe would be balanced on March 1, 2002, for Upper Decile and Upper Quartile. Since Median runoff does not refill the reservoirs in 2001, Fort Peck would be only 1.5 feet high and Garrison would be 1.0 foot low. This would permit the Fort Peck “spring rise” test of 20,000 to 30,000 cfs in the spring of 2002, as described in the previous paragraph. The unbalancing would alternate at each project; high one year, float (normal operation) the next year, and low the third year as shown on **Table IV**. **Table V** shows the lake elevations proposed by the MRNRC at which the unbalancing would be terminated. **Table V** indicates that no reservoir unbalancing should occur for any of the five runoff conditions in 2001 since Fort Peck Lake is below elevation 2227 feet msl on March 1, 2001. However, it is important to implement unbalancing to benefit endangered species should Median or greater runoff occur. No reservoir unbalancing is shown for the Lower Quartile and Lower Decile studies.

**TABLE IV
RESERVOIR UNBALANCING SCHEDULE**

	Fort Peck		Garrison		Oahe	
<i>Year</i>	<i>March 1</i>	<i>Rest of Year</i>	<i>March 1</i>	<i>Rest of Year</i>	<i>March 1</i>	<i>Rest of year</i>
2001	Balance	High	Balance	Low	Balance	Float
2002	High	Float	Low	Hold peak	Raise & hold during spawn	Float
2003	Raise & hold during spawn	Float	High	Float	Low	Hold peak
2004	Low	Hold peak	Raise & hold during spawn	Float	High	Float

Notes:

Float year: Normal operation, then unbalance 1 foot during low pool years or 3 feet when System storage is near 57.1 MAF on March 1.

Low year: Begin low, then hold peak the remainder of the year.

High year: Begin high, raise and hold pool during spawn, then float.

**TABLE V
MRNRC RECOMMENDED
RESERVOIR ELEVATION GUIDELINES
FOR UNBALANCING**

	Fort Peck	Garrison	Oahe
Implement unbalancing if March 1 reservoir elevation is above this level.	2234 feet msl	1837.5 feet msl	1607.5 feet msl
Implement unbalancing if March 1 reservoir elevation is in this range and the pool is expected to raise more than 3 feet after March 1.	2227-2234 feet msl	1827-1837.5 feet msl	1600-1607.5 feet msl
Scheduling Criteria	Avoid lake level decline during spawn period which ranges from April 15 – May 30.	Schedule after spawn period of April 20 – May 20.	Schedule after spawn period of April 8 – May 15.

Summary of Reservoir Regulation Activities for Endangered Species and Fish Propagation Enhancement

As discussed in the section above, the 2000-2001 AOP includes provisions for unbalancing the Fort Peck, Garrison, and Oahe reservoirs for Median and greater runoff scenarios. The unbalancing is intended to benefit the reservoir fisheries in the long term by ensuring a periodic rise in reservoir elevation sufficient to provide good spawning conditions and inundating vegetation, thereby increasing young-of-the-year fish survival. Unbalancing is also intended to benefit interior least tern and piping plover production in the long term by maintaining and exposing sandbar and shoreline habitat.

Fort Peck will have a 2,500 cfs reduction in flows during the tern and plover nesting season for Upper Decile runoff and a 4,000 cfs reduction for Upper Quartile and Median runoff conditions. The resulting stage difference will provide excellent nesting habitat. For Lower Quartile and Lower Decile runoff scenarios, no difference in flows is anticipated during the nesting season, but the releases are low enough that good habitat should be available.

If flood flows enter the Missouri River below the project during the nesting season, hourly releases will be lowered to no less than 3,000 cfs in order to keep traditional riverine fish rearing areas continuously inundated while helping to lower river stages at downstream nesting sites. April releases should be adequate for trout spawning below the project. A rising pool in the April-to-May sport fish spawning season will be dependent upon the ever changing daily inflow pattern to the reservoir but appears possible with all AOP plans.

Garrison will have a reduction in flows during the tern and plover nesting season under all runoff scenarios. For Median and above runoff, the reductions will be approximately 2,000 cfs. For Lower Quartile and Lower Decile, the reductions will be in the 500-1,000 cfs range. Hourly peaking will be limited to no more than 30,000 cfs for 6 hours if the daily average release is lower than 28,000 cfs. This will limit peak stages below the project for nesting birds.

Except for the Upper Quartile and Upper Decile runoff conditions, Lake Sakakawea elevations will not reach levels considered necessary for optimum fish spawning during the month of May. In addition to the runoff conditions, the actual timing of the rise in lake elevation will be dependent upon the pattern of inflow at that time.

Oahe releases in the spring and summer will back up those from Gavins Point. If flows into the System are Median or greater, Oahe's elevation in the spring will likely be steady or rising. Under all AOP plans, the Oahe pool will fall during the summer.

Fort Randall will be operated to provide for a pool elevation near 1355 during the fish spawn period and the lake will not be drawn down below elevation 1337.5 feet msl in the fall for water intakes. Hourly releases from Fort Randall, during the 2001 nesting season will be limited to 37,000 cfs. Daily average flows may be increased every third day to preserve the capability of increasing releases later in the summer if conditions turn dry.

Gavins Point releases will be set in May when terns and plovers begin to initiate nesting. The release rate will be based on an assessment of flows needed to support navigation in July and August. The resulting steady release prevents inundation of nests and chicks due to navigation support flows. Flows during the nesting season will be near or below what they were this past nesting season for all runoff conditions. The excellent habitat conditions should result in very good tern and plover production. Cycling releases every third day is not planned during the 2001 nesting season except during downstream flood control operations.

The Gavins Point pool will be operated near 1206 feet msl in the spring and early summer with variations day to day due to rainfall runoff. Greater fluctuations occur in the river, increasing the risk of nest inundation in the upper end of the Gavins Point pool. Several factors contribute to the increased risk of nest inundation in the upper end of the Gavins Point pool. First, because there are greater numbers of endangered species nesting below the Gavins Point project which must be preserved, Gavins Point releases are restricted during the nesting season. Second, unexpected rainfall runoff between Fort Randall and Gavins Point can result in sudden pool rises because the Gavins Point project has a smaller storage capacity than the other System reservoirs. Third, the operation of Gavins Point for downstream flood control may necessitate sudden release reductions to prevent downstream bird losses. And finally, high releases required in wet years make nest inundation more likely. When combined, all these factors make it difficult and sometimes impossible to prevent inundation of nests in the upper end of Lewis and Clark Lake. The pool will be increased to elevation 1207.0 feet msl following the nesting season.

Summary of Habitat Activities

The Biological Opinion on the ongoing operations of the System was completed on November 30, 2000. A draft implementation plan, which includes actions to meet endangered species needs, is located on Missouri River Region web page.

V. SUMMARY OF RESULTS EXPECTED IN 2000-2001

With System operations in accordance with the 2000-2001 AOP outlined in the preceding pages, the following results can be expected.

A. Flood Control. All runoff scenarios studied will begin next year's runoff season on March 1, 2001 substantially below the desired 57.1 MAF base of annual flood control and multiple use zone. Therefore, the entire System flood control zone plus an additional 6.1 to 7.4 MAF of the carryover multiple use zone will be available to store runoff. The System will be available to significantly reduce peak discharges for all floods that may originate above the System.

Remaining storage in the carryover multiple use zone will be adequate to provide support for all of the other multiple purposes of the System, although recreation access may be difficult at some locations for the lower runoff scenarios.

B. Water Supply and Water Quality Control. Although below normal winter releases are being provided for all five runoff scenarios, all water supply and water quality requirements on the Missouri River both below Gavins Point Dam and between main stem reservoirs should be met for all flow conditions studied. It is possible with the low winter releases that ice formation or ice jams may temporarily reduce river stages to levels below which some intakes can draw water. Therefore, during severe cold spells it may be necessary to increase Gavins Point releases as was required during the recent drought years to help alleviate water supply problems.

C. Irrigation. Scheduled releases from the System reservoirs will be ample to meet the volumes of flow required for irrigation diversions from the Missouri River. Some access problems may be experienced, however, if drought conditions persist. Tributary irrigation water usage is fully accounted for in the estimates of water supply.

D. Navigation. Service to navigation in 2001 would be scheduled above full service flow support for the Upper Decile runoff scenario. Navigation support for Upper Quartile runoff will be 1,600 cfs under full service in the spring and near full service the remainder of the season. The three studies of Median, Lower Quartile, and Lower Decile have reductions below full service as shown in *Table III*. Although these studies provide a comparison of typical flow support under varying runoff conditions that cover 80 percent of the historic runoff conditions, the actual rate of flow support for the 2001 navigation season will be based on actual System storage on March 15 and July 1, 2001.

In addition to greater than full service flow, the Upper Decile condition has an 8-month navigation season with a 10-day extension. Upper Quartile, Median and Lower Quartile runoffs have an 8-month navigation season. Should Lower Decile runoff occur with System storage forecast to be less than 52 MAF on July 1, 2001, meetings will be conducted with navigators, MRBA, the MRNRC, and other interested parties to determine if the navigation season will be shortened. The anticipated service level and season length for all runoff conditions studied are shown in *Table III*.

E. Power. *Tables VI* and *VII* give the estimated monthly System load requirements and hydropower supply of the Eastern Division, Pick-Sloan Missouri Basin Program (P-S MBP), from December 2000 through December 2001. Estimates of monthly peak demands and energy include customer requirements for firm, short-term firm, summer firm, peaking, and various other types of power sales, System losses, and the effects of diversity. Also included in the estimated requirements are deliveries of power to the Western Division, P-S MBP, to help meet its firm power commitments.

F. Recreation, Fish and Wildlife. The basic operations of the System will continue to provide recreation and fish and wildlife opportunities in the project areas and along the Missouri River as well as other benefits of a controlled river. Special operational adjustments incorporating specific objectives for these purposes will be accomplished whenever possible. Conditions should be favorable for the many visitors who enjoy the camping, boating, fishing, hunting, swimming, picnicking, and other recreational activities associated with the System reservoirs and for increasing usage of the regulated reaches of the Missouri River downstream of the reservoirs.

TABLE VI
PEAKING CAPABILITY AND SALES
 (1,000 kW at plant)

2000	Estimated Committed Sales*	Expected C of E Capability					Expected Bureau Capability**					Expected Total System Capability				
		120%			Basic		80%			120%			Basic		80%	
		U.D.	U.Q.	Med.	L.Q.	L.D.	***	U.D.	U.Q.	Med.	L.Q.	L.D.	U.D.	U.Q.	Med.	L.Q.
Aug																
Sep																
Oct																
Nov																
Dec	1819		2127	2125	2122			196	195	190			2323	2320	2312	
<u>2001</u>																
Jan	2228		2151	2145	2141			191	194	187			2342	2339	2328	
Feb	1925		2159	2150	2144			187	194	185			2346	2344	2329	
Mar	1725	2228	2223	2206	2188	2185	188	188	194	185	185	2416	2411	2400	2373	2370
Apr	1494	2243	2239	2212	2186	2180	190	190	192	187	187	2433	2429	2404	2373	2367
May	1384	2260	2252	2219	2185	2174	189	189	195	193	193	2449	2441	2414	2378	2367
Jun	1706	2286	2280	2244	2204	2181	204	204	203	198	198	2490	2484	2447	2402	2379
Jul	2283	2305	2288	2245	2200	2171	204	204	204	198	197	2509	2492	2449	2398	2368
Aug	2124	2299	2279	2230	2183	2152	202	203	202	197	196	2501	2482	2432	2380	2348
Sep	1525	2293	2270	2219	2168	2136	203	202	202	198	196	2496	2472	2421	2366	2332
Oct	1452	2276	2251	2197	2144	2087	202	202	202	199	197	2478	2453	2399	2343	2284
Nov	1763	2235	2215	2160	2106	2082	200	201	201	198	196	2435	2416	2361	2304	2278
Dec	1943	2211	2199	2147	2090	2060	195	196	198	196	193	2406	2395	2345	2286	2253

* Estimated sales, including system reserves. Power in addition to hydro production needed for these load requirements will be obtained from other power systems by interchange or purchase.

** Total output of Canyon Ferry and 1/2 of the output of Yellowtail powerplant.

*** Lower decile values based on navigation season shortened at 40 MAF on July 1.

TABLE VII
ENERGY GENERATION AND SALES
 (Million kWh at plant)

2000	Estimated Committed Sales*	Expected C of E Generation					Expected Bureau Generation **					Expected Total System Generation				
		120%			Basic		80%			120%			Basic		80%	
		U.D.	U.Q.	Med.	L.Q.	L.D.	***	U.D.	U.Q.	Med.	L.Q.	L.D.	U.D.	U.Q.	Med.	L.Q.
Aug																
Sep																
Oct																
Nov																
Dec	906		555	556	552			76	53	45			631	609	597	
<u>2001</u>																
Jan	903		559	556	552			74	53	45			633	609	597	
Feb	847		442	442	439			65	47	40			507	489	479	
Mar	791	620	589	552	582	588	73	73	67	44	44	693	662	619	626	632
Apr	737	792	680	667	737	706	70	70	60	36	36	862	750	727	773	742
May	682	942	852	816	840	814	104	104	85	41	41	1046	956	901	881	855
Jun	738	1029	950	897	828	785	133	133	96	43	43	1162	1083	993	871	828
Jul	812	1046	1000	941	907	860	151	130	88	51	50	1197	1130	1029	958	910
Aug	831	1075	1011	934	897	854	100	92	78	51	50	1175	1103	1012	948	904
Sep	714	947	833	789	754	716	93	88	75	49	48	1040	921	864	803	764
Oct	716	810	702	649	628	586	93	88	78	56	55	903	790	727	684	641
Nov	778	798	647	602	571	532	90	89	79	58	52	888	736	681	629	584
Dec	<u>911</u>	<u>854</u>	<u>684</u>	<u>592</u>	<u>582</u>	<u>557</u>	<u>91</u>	<u>91</u>	<u>56</u>	<u>59</u>	<u>53</u>	<u>945</u>	<u>775</u>	<u>648</u>	<u>641</u>	<u>610</u>
CY TOT	9460	9914	8949	8437	8317	7989	1137	1097	862	573	557	11051	10046	9299	8890	8546

* Estimated sales including system reserves and losses. Power in addition to hydro production needed for these load requirements will be obtained from other systems by interchange or purchase.

** Total output Canyon Ferry and 1/2 output of Yellowtail powerplant.

*** Lower decile values based on navigation season shortened at 40 MAF on July 1.

Boat ramps that were lowered and low water ramps that were constructed during the drought of the late 1980's to early 1990's should be adequate to provide lake access next year even under the Lower Decile runoff scenario. However, boat ramps in a few areas where the ramps could not be extended may become unusable. This will affect the normal use patterns as visitors will have to seek out areas with usable boat ramps.

The effects of the planned System operation during 2000-2001 on fish and wildlife are included in the section entitled, "Summary of Reservoir Regulation Activities for Endangered Species and Fish Propagation Enhancement."

G. System Storage. If presently anticipated runoff estimates based upon normal precipitation materialize, System storage will total about 49.9 MAF by the close of CY 2000. This year-end storage would be 7.6 MAF less than the 57.5 MAF experienced on December 31, 1999, and 5.8 MAF less than the 1967 to 1999 average. Since the System first filled to normal operating levels in 1967, the lowest end-of-December storage was 40.9 MAF in 1990. The previous lowest storage prior to the recent 6 consecutive years of drought was 50.9 MAF in 1981. The end-of-year storages have ranged from a maximum of 60.9 MAF, which occurred in 1975, to the 1990 minimum of 40.9 MAF. Under the five runoff conditions of inflow analyzed for this AOP, the total System storage at the end of next year on December 31, 2001, would be approximately as shown on *Table VIII*.

**TABLE VIII
ANTICIPATED DECEMBER 31, 2001 STORAGE IN MAIN STEM SYSTEM**

Water Supply Condition	Total (12/31/01)	Above Minimum Pools 1/ (Volumes in 1,000 Acre-Feet)	Unfilled Carryover Storage 2/	Total Change CY 2001
Upper Decile	57,600	39,500	0	7,400
Upper Quartile	56,800	38,700	300	6,600
Median	52,100	34,000	5,000	2,200
Lower Quartile	47,300	29,200	9,800	- 2,400
Lower Decile <u>3/</u>	44,800	26,700	12,300	-4,900
Lower Decile <u>4/</u>	45,300	27,200	11,800	-4,400

- 1/ Net usable storage above 18.1 million-acre-foot System minimum pool level established for power, recreation, irrigation diversions, and other purposes.
- 2/ System base of flood control zone containing 57.1 million acre-feet.
- 3/ No shortening.
- 4/ With 2-week shortening

H. Summary of Water Use by Functions. Anticipated water use in CY 2000, under the plan of operation with the Basic Forecast of water supply, is shown in *Table IX*. Actual water use data for CY 1999 are included for information and comparison.

Under the planned operations, estimated water use in CY 2001, which will be subject to reappraisal next year, also is shown in *Table IX* for the various levels of water supply.

VI. TENTATIVE PROJECTION OF OPERATIONS THROUGH MARCH 2007

The 5-year extension to the Annual Operating Plan (March 2002 to March 2007) has been prepared to serve as a guide for Western Area Power Administration's power marketing activities. As discussed in Section IV, Chapter A, adjustments to the drought water conservation guidelines are necessary to continue to meet the operational objectives of the current Master Manual during drought periods. This is due to increased release requirements for water supply and endangered species during low runoff periods. The specific details of these adjustments are not certain, absent the completion of review of possible options by the MRBA, the MRNRC, and any other interested parties. However, for planning purposes, we have included projections that utilize two different sets of drought water conservation guidelines in the 5-year extension studies.

The first set of projections presented uses drought water conservation guidelines that call for a 2-week shortening of the navigation season length if System storage falls to 52 MAF by July 1 of any year, and progressive shortening up to 4 weeks at 44 MAF on any July 1. These studies utilize the service level guidelines published in the current Master Manual which call for full service flows if System storage is 54.5 MAF or more on March 15, or 59 MAF or more on July 1 of any year. They also call for minimum service flows if System storage falls to 46 MAF by March 15, or 50.5 MAF by July 1 of any year.

The second set of results presented uses drought water conservation guidelines identical to those published in the current Master Manual. These guidelines call for a 1-week shortening of the navigation season if System storage falls to 40 MAF by any July 1, and would result in a progressive shortening up to 10 weeks at 25 MAF or less on any July 1. This set of guidelines calls for full service flows if System storage is 54.5 MAF or more on March 15, or 59 MAF or more on July 1 of any year. It also calls for minimum service flows if System storage falls to 46 MAF by March 15, or 50.5 MAF by July 1 of any year.

Only one set of Median results is presented since System storage would not fall below the drought water conservation trigger points under either set of guidelines during the study period. For all scenarios, from mid-May through July, Gavins Point releases are set to the anticipated August release required to meet downstream flow targets, to minimize inundation of interior least tern and piping plover nests.

TABLE IX
MISSOURI RIVER MAIN STEM
WATER USE FOR CALENDAR YEARS 1999, 2000, AND 2001 ABOVE SIOUX CITY, IOWA
in Million Acre-Feet (MAF)

	CY 1999 Actual	CY 2000 Basic Forecast	Upper Decile	Upper Quartile	Forecast for Calendar Year 2001			
					Median	Lower Quartile	Lower Decile(7)	Lower Decile(8)
Upstream Depletions (1)								
Irrigation, Tributary Reservoir Evaporation & Other Uses	1.8	1.9						
Tributary Reservoir Storage Change	- 0.1	- 0.4						
Total Upstream Depletions	1.7	1.5	2.4	2.4	2.5	2.5	2.1	2.0
Main Stem Reservoir Evaporation (2)	2.2	1.9	1.2	1.3	1.7	1.9	1.8	1.8
Sioux City Flows								
Navigation Season								
Unregulated Flood Inflows Between Gavins Point & Sioux City (3)	0.0	0.0						
Navigation Service Requirement 15.0	16.0	17.6	16.5	14.9	14.3	13.6	13.0	
Supplementary Releases								
Endangered Species (4)	0.0	0.8	0.0	0.0	0.0	0.0	0.0	0.0
Flood Evacuation (5)	6.4	0.0	1.9	0.3	0.0	0.0	0.0	0.0
Nonnavigation Season								
Flows	4.2	3.5	3.5	3.6	3.3	3.2	3.0	3.1
Flood Evacuation Releases (6)	2.2	0.5	0.5	0.0	0.0	0.0	0.0	0.0
Main Stem System Storage Change	- 0.5	- 7.6	7.4	6.5	2.2	- 2.4	- 5.0	- 4.4
Total	31.2	16.6	34.5	30.6	24.6	19.5	15.5	15.5
Project Releases								
Fort Peck	6.0	5.7	6.3	5.8	5.8	5.6	5.5	5.4
Garrison	17.7	14.9	17.4	15.7	14.2	13.7	13.0	12.7
Oahe	19.9	18.9	17.3	15.6	15.2	15.6	15.2	14.7
Big Bend	20.2	17.9	17.3	15.5	15.1	15.5	15.1	14.6
Fort Randall	21.6	17.8	18.6	16.6	15.8	15.8	15.2	14.8
Gavins Point	24.8	19.8	20.6	18.3	17.1	16.9	16.3	15.8

- (1) Tributary uses, above the 1949 level of development including agricultural depletions and tributary storage effects.
- (2) Net Evaporation is shown for 2001.
- (3) Incremental inflows to reach which exceed those usable in support of navigation at the target level, even if Gavins Point releases were held to as low as 6,000 cfs.
- (4) Increased releases required to maintain navigation release flexibility during the endangered species nesting season.
- (5) Includes flood control releases for flood control storage evacuation and releases used to extend the navigation season beyond the normal December 1 closing date at the mouth of the Missouri River.
- (6) Releases for flood control storage evacuation in excess of a 15,000 cfs Fort Randall release.
- (7) Navigation season shortened at 40 MAF on July 1.
- (8) Navigation season shortened at 52 MAF on July 1.

A. Median Runoff. System storage would begin in March 2002 at 52.5 MAF and would rise to 57.1 MAF by March 2007. The September 1 storage check provided for in the current Master Manual, which sets the Fort Randall winter release, is not followed, resulting in annual increases in System storage of up to 1 MAF. The additional conservation measure of providing minimum winter releases unless the System storage is forecast to return to normal is utilized. Therefore, water conservation during the winter period is followed. Winter releases are 12,000 cfs except 2006-2007 when System storage has refilled. Fort Peck Lake, Lake Sakakawea, and Lake Oahe were unbalanced each March 1 as shown on *Table X*. This follows the pattern of “high,” “float,” “low” described in *Table IV*. The amount of unbalancing was increased each year as System storage refilled to 57.1 MAF on March 1, 2007. Fort Peck releases were set at 18,800 cfs in June 2002, reflecting a 25,000 cfs “spring rise” for 2 weeks, most of which would be discharged through the spillway. This release is also shown 3 years later in June 2005. An 8-month navigation season and full service flows are provided through 2006.

**TABLE X
MARCH 1 RESERVOIR UNBALANCING, AOP EXTENSIONS**

Year	Fort Peck	Garrison	Oahe
2003	0.0 feet	+ 1.0 feet	- 1.0 feet
2004	- 2.2	0.0	+ 1.5
2005	+ 1.8	- 2.0	+ .7
2006	0.0	+ 3.0	- 3.1
2007	- 4.7	0.0	+ 3.0

B. Lower Quartile Runoff – Navigation Season Shortened at 52 MAF on July 1. System storage begins the period at 47.2 MAF and rises to 49.1 MAF by March 2007 due primarily to reduced winter releases. A 12,000 cfs winter release is shown for the entire study period. Navigation service levels are reduced from 3,600 cfs to 5,500 cfs below full service. Navigation season length is 7.5 months in 2002 and 2003, and 8 months from 2004 through 2006 as System storage recovers. Since the upper three reservoirs do not refill under Lower Quartile and Lower Decile runoff, their percent of remaining carryover multiple use storage is balanced each March 1.

C. Lower Quartile Runoff – Navigation Season Shortened at 40 MAF on July 1. System storage rises slightly, from 47.2 MAF in March 2002 to 48.8 MAF in March 2007, and navigation service levels are reduced from 3,800 cfs to 5,500 cfs with no season shortening. A 12,000 cfs winter release is shown for the entire study period.

D. Lower Decile Runoff - Navigation Season Shortened at 52 MAF on July 1. System storage begins the period at 45.0 MAF and falls to 37.6 MAF by March 2007. The navigation season is shortened 3 weeks in 2002 and 4 weeks from 2003 through 2006.

Service level is at minimum service throughout the study period (2002-2006). A 12,000 cfs winter release is shown for the entire study period.


E. Lower Decile Runoff - Navigation Season Shortened at 40 MAF on July 1.

System storage begins the period at 44.5 MAF and falls to 33.8 MAF by March 2007. An 8-month navigation season is provided through 2004, with a 2-week shortening to 7.5 months in 2005 and 2006. Service level is minimum service 2002 through 2006. A 12,000 cfs winter release is shown for the entire study period.

Plate 11 presents System storage, Gavins Point regulated flow, and System peaking capability for Median, Lower Quartile, and Lower Decile for both sets of guidelines, for the period 2002 through March 2007. Peak power, or peaking capability, is the amount of power available when all powerplants are operating at maximum.

Plate 12 presents reservoir elevations for Fort Peck, Garrison, Oahe, and Fort Randall for Median, Lower Quartile, and Lower Decile for both sets of guidelines, for the period 2002 through March 2007.

A Summary of Engineering Data for the Main Stem Reservoir System is shown on **Plate 2**.



MISSOURI RIVER BASIN



▶ TRIBUTARY RESERVOIRS

Summary of Engineering Data -- Missouri River Main Stem Reservoirs							
Item No.	Subject	Fort Peck Lake		Garrison Dam - Lake Sakakawea		Oahe Dam - Lake Oahe	
1	Location of Dam	Near Glasgow, Montana		Near Garrison, ND		Near Pierre, SD	
2	River Mile - 1960 Mileage	Mile 1771.5		Mile 1389.9		Mile 1072.3	
3	Total & incremental drainage areas in square miles	57,500		181,400 (2) 123,900		243,490 (1) 62,090	
4	Approximate length of full reservoir (in valley miles)	134, ending near Zortman, MT		178, ending near Trenton, ND		231, ending near Bismarck, ND	
5	Shoreline in miles (3)	1520 (elevation 2234)		1340 (elevation 1837.5)		2250 (elevation 1607.5)	
6	Average total & incremental inflow in cfs	10,200		25,600 15,400		28,900 3,300	
7	Max. discharge of record near damsite in cfs	137,000 (June 1953)		348,000 (April 1952)		440,000 (April 1952)	
8	Construction started - calendar yr.	1933		1946		1948	
9	In operation (4) calendar yr.	1940		1955		1962	
Dam and Embankment							
10	Top of dam, elevation in feet msl	2280.5		1875		1660	
11	Length of dam in feet	21,026 (excluding spillway)		11,300 (including spillway)		9,300 (excluding spillway)	
12	Damming height in feet (5)	220		180		200	
13	Maximum height in feet (5)	250.5		210		245	
14	Max. base width, total & w/o berms in feet	3500, 2700		3400, 2050		3500, 1500	
15	Abutment formations (under dam & embankment)	Bearpaw shale and glacial fill		Fort Union clay shale		Pierre shale	
16	Type of fill	Hydraulic & rolled earth fill		Rolled earth filled		Rolled earth fill & shale berms	
17	Fill quantity, cubic yards	125,628,000		66,500,000		55,000,000 & 37,000,000	
18	Volume of concrete, cubic yards	1,200,000		1,500,000		1,045,000	
19	Date of closure	24 June 1937		15 April 1953		3 August 1958	
Spillway Data							
20	Location	Right bank - remote		Left bank - adjacent		Right bank - remote	
21	Crest elevation in feet msl	2225		1825		1596.5	
22	Width (including piers) in feet	820 gated		1336 gated		456 gated	
23	No., size and type of gates	16 - 40' x 25' vertical lift gates		28 - 40' x 29' Tainter		8 - 50' x 23.5' Tainter	
24	Design discharge capacity, cfs	275,000 at elev 2253.3		827,000 at elev 1858.5		304,000 at elev 1644.4	
25	Discharge capacity at maximum operating pool in cfs	230,000		660,000		80,000	
Reservoir Data (6)							
26	Max. operating pool elev. & area	2250 msl 246,000 acres		1854 msl 380,000 acres		1620 msl 374,000 acres	
27	Max. normal op. pool elev. & area	2246 msl 240,000 acres		1850 msl 364,000 acres		1617 msl 360,000 acres	
28	Base flood control elev. & area	2234 msl 212,000 acres		1837.5 msl 307,000 acres		1607.5 msl 312,000 acres	
29	Min. operating pool elev. & area	2160 msl 90,000 acres		1775 msl 128,000 acres		1540 msl 117,000 acres	
Storage allocation & capacity							
30	Exclusive flood control	2250-2246 975,000 a.f.		1854-1850 1,489,000 a.f.		1620-1617 1,102,000 a.f.	
31	Flood control & multiple use	2246-2234 2,717,000 a.f.		1850-1837.5 4,222,000 a.f.		1617-1607.5 3,201,000 a.f.	
32	Carryover multiple use	2234-2160 10,785,000 a.f.		1837.5-1775 13,130,000 a.f.		1607.5-1540 13,461,000 a.f.	
33	Permanent	2160-2030 4,211,000 a.f.		1775-1673 4,980,000 a.f.		1540-1415 5,373,000 a.f.	
34	Gross	2250-2030 18,688,000 a.f.		1854-1673 23,821,000 a.f.		1620-1415 23,137,000 a.f.	
35	Reservoir filling initiated	November 1937		December 1953		August 1958	
36	Initially reached min. operating pool	27 May 1942		7 August 1955		3 April 1962	
37	Estimated annual sediment inflow	18,100 a.f. 1030 yrs.		25,900 a.f. 920 yrs.		19,800 a.f. 1170 yrs.	
Outlet Works Data							
38	Location	Right bank		Right Bank		Right Bank	
39	Number and size of conduits	2 - 24' 8" diameter (nos. 3 & 4)		1 - 26' dia. and 2 - 22' dia.		6 - 19.75' dia. upstream, 18.25' dia. downstream	
40	Length of conduits in feet (8)	No. 3 - 6,615, No. 4 - 7,240		1529		3496 to 3659	
41	No., size, and type of service gates	1 - 28' dia. cylindrical gate 6 ports, 7.6' x 8.5' high (net opening) in each control shaft		1 - 18' x 24.5' Tainter gate per conduit for fine regulation		1 - 13' x 22' per conduit, vertical lift, 4 cable suspension and 2 hydraulic suspension (fine regulation)	
42	Entrance invert elevation (msl)	2095		1672		1425	
43	Avg. discharge capacity per conduit & total	Elev. 2250 22,500 cfs - 45,000 cfs		Elev. 1854 30,400 cfs - 98,000 cfs		Elev. 1620 18,500 cfs - 111,000 cfs	
44	Present tailwater elevation (ft msl)	2032-2036 5,000 - 35,000 cfs		1670-1680 15,000 - 60,000 cfs		1423-1428 20,000-55,000 cfs	
Power Facilities and Data							
45	Avg. gross head available in feet (14)	194		161		174	
46	Number and size of conduits	No. 1-24'8" dia., No. 2-22'4" dia.		5 - 29' dia., 25' penstocks		7 - 24' dia., imbedded penstocks	
47	Length of conduits in feet (8)	No. 1 - 5,653, No. 2 - 6,355		1829		From 3,280 to 4,005	
48	Surge tanks	PH#1: 3-40' dia., PH#2: 2-65' dia.		65' dia. - 2 per penstock		70' dia., 2 per penstock	
49	No., type and speed of turbines	5 Francis, PH#1-2: 128.5 rpm, 1-164 rpm, PH#2-2: 128.6 rpm		5 Francis, 90 rpm		7 Francis, 100 rpm	
50	Discharge cap. at rated head in cfs	PH#1, units 1&3 170', 2-140' 8,800 cfs, PH#2-4&5 170'-7,200 cfs		150' 41,000 cfs		185' 54,000 cfs	
51	Generator nameplate rating in kW	1&3: 43,500; 2: 18,250; 4&5: 40,000		3 - 109,250, 2 - 95,000		112,290	
52	Plant capacity in kW	185,250		517,750		786,030	
53	Dependable capacity in kW (9)	181,000		388,000		534,000	
54	Avg. annual energy, million kWh (12)	1,163		2,472		2,908	
55	Initial generation, first and last unit	July 1943 - June 1961		January 1956 - October 1960		April 1962 - June 1963	
56	Estimated cost September 1996 completed project (13)	\$158,428,000		\$299,938,000		\$346,521,000	


Summary of Engineering Data -- Missouri River Main Stem Reservoirs

Big Bend Dam - Lake Sharpe		Fort Randall Dam - Lake Francis Case		Gavins Point Dam - Lewis & Clark Lake		Total	Item No.	Remarks
21 miles upstream Chamberlain, SD		Near Lake Andes, SD		Near Yankton, SD			1	(1) Includes 4,280 square miles of non-contributing areas. (2) Includes 1,350 square miles of non-contributing areas. (3) With pool at base of flood control. (4) Storage first available for regulation of flows. (5) Damming height is height from low water to maximum operating pool. Maximum height is from average streambed to top of dam. (6) Based on latest available storage data. (7) River regulation is attained by flows over low-crested spillway and through turbines. (8) Length from upstream face of outlet or to spiral case. (9) Based on 8th year (1961) of drought drawdown (From study 8-83-1985). (10) Affected by level of Lake Francis case. Applicable to pool at elevation 1350. (11) Spillway crest. (12) 1967-1999 Average (13) Source: Annual Report on Civil Works Activities of the Corps of Engineers. Extract Report Fiscal Year 1996. (14) Based on Study 8-83-1985
Mile 987.4		Mile 880.0		Mile 811.1			2	
249,330 (1)	5,840	263,480 (1)	14,150	279,480 (1)	16,000		3	
80, ending near Pierre, SD		107, ending at Big Bend Dam		25, ending near Niobrara, NE		755 miles	4	
200 (elevation 1420)		540 (elevation 1350)		90 (elevation 1204.5)		5,940 miles	5	
28,900		30,000	1,100	32,000	2,000		6	
440,000 (April 1952)		447,000 (April 1952)		480,000 (April 1952)			7	
1959		1946		1952			8	
1964		1953		1955			9	
1440		1395		1234			10	
10,570 (including spillway)		10,700 (including spillway)		8,700 (including spillway)		71,596	11	
78		140		45		863 feet	12	
95		165		74			13	
1200, 700		4300, 1250		850, 450			14	
Pierre shale & Niobrara chalk		Niobrara chalk		Niobrara chalk & Carlile shale			15	
Rolled earth, shale, chalk fill		Rolled earth fill & chalk berms		Rolled earth & chalk fill			16	
17,000,000		28,000,000 & 22,000,000		7,000,000		358,128,000 cu. yds	17	
540,000		961,000		308,000		5,554,000 cu. yds.	18	
24 July 1963		20 July 1952		31 July 1955			19	
Left bank - adjacent		Left bank - adjacent		Right bank - adjacent			20	
1385		1346		1180			21	
376 gated		1000 gated		664 gated			22	
8 - 40' x 38' Tainter		21 - 40' x 29' Tainter		14 - 40' x 30' Tainter			23	
390,000 at elev 1433.6		620,000 at elev 1379.3		584,000 at elev 1221.4			24	
270,000		508,000		345,000			25	
1423 msl	61,000 acres	1375 msl	102,000 acres	1210 msl	31,000 acres	1,194,000 acres	26	
1422 msl	60,000 acres	1365 msl	95,000 acres	1208 msl	28,000 acres	1,147,000 acres	27	
1420 msl	57,000 acres	1350 msl	77,000 acres	1204.5 msl	24,000 acres	989,000 acres	28	
1415 msl	51,000 acres	1320 msl	38,000 acres	1204.5 msl	24,000 acres	450,000 acres	29	
1423-1422	60,000 a.f.	1375-1365	985,000 a.f.	1210-1208	59,000 a.f.	4,670,000 a.f.	30	
1422-1420	117,000 a.f.	1365-1350	1,309,000 a.f.	1208-1204.5	90,000 a.f.	11,656,000 a.f.	31	
		1350-1320	1,607,000 a.f.			38,983,000 a.f.	32	
1420-1345	1,682,000 a.f.	1320-1240	1,517,000 a.f.	1204.5-1160	321,000 a.f.	18,084,000 a.f.	33	
1423-1345	1,859,000 a.f.	1375-1240	5,418,000 a.f.	1210-1160	470,000 a.f.	73,393,000 a.f.	34	
November 1963		January 1953		August 1955			35	
25 March 1964		24 November 1953		22 December 1955			36	
4,300 a.f.	430 yrs.	18,300 a.f.	250 yrs.	2,600 a.f.	180 yrs.	92,500 a.f.	37	
None (7)		Left Bank		None (7)			38	
		4 - 22' diameter					39	
		1013					40	
		2 - 11' x 23' per conduit, vertical lift, cable suspension					41	
1385 (11)		1229		1180 (11)			42	
		Elev 1375					43	
		32,000 cfs - 128,000 cfs						
1351-1355(10)	25,000-100,000 cfs	1228-1239	5,000-60,000 cfs	1155-1163	15,000-60,000 cfs		44	
70		117		48		764 feet	45	
None: direct intake		8 - 28' dia., 22' penstocks		None: direct intake			46	
		1,074				55,083	47	
None		59' dia, 2 per alternate penstock		None			48	
8 Fixed blade, 81.8 rpm		8 Francis, 85.7 rpm		3 Kaplan, 75 rpm		36 units	49	
67'	103,000 cfs	112'	44,500 cfs	48'	36,000 cfs		50	
3 - 67,276, 5 - 58,500		40,000		44,100			51	
494,320		320,000		132,300		2,435,650 kw	52	
497,000		293,000		74,000		1,967,000 kw	53	
1,055		1,861		756		10,215 million kWh	54	
October 1964 - July 1966		March 1954 - January 1956		September 1956 - January 1957		July 1943 - July 1966	55	
	\$107,498,000		\$199,066,000		\$49,617,000		\$1,161,068,000	56





System Storage







Gavins Point Releases







Fort Peck Elevations and Releases







Garrison Elevations and Releases



Oahe Elevations and Releases




Fort Randall Elevations and Releases




Reservoir Release and Unregulated Flow


Fort Peck




Garrison




Oahe




Gavins Point



System Gross Capacity and Average Monthly Generation




53 55 57 59 61 63 65 67 69 71 73 75 77 79 81 83 85 87 89 91 93 95 97 99



J F M A M J J A S O N D J F M A M J J A S O N D 2000 2001

Tentative Five Year Extensions of 2000-2001 AOP System Storage





1434 316th Lane • Missouri Valley, Iowa 51555 • 712-642-4121 • Fax 712-642-2460

September 1, 2000

Colonel Michael Meuleners
Northwestern Division, Corps of Engineers
12565 W. Center Road
Omaha, NE 68144-3869

Dear Colonel Meuleners:

I am pleased to submit the following recommendations of the Missouri River Natural Resources Committee (MRNRC) for operation of the Missouri River system during 2000/2001. These recommendations were developed with input from our Fish, Wildlife, and Tern and Plover Technical Sections and adopted by our official MRNRC state delegates.

For the past several years the MRNRC has provided comprehensive recommendations regarding seasonal dam releases, reservoir elevations, and operations for interior least terns and piping plovers. The recommendations regarding Fort Peck and Gavins Point Dam releases, minimum flows below the dams, minimum lake elevations in Lake Sakakawea and Lake Oahe, stable discharges below Oahe Dam and Fort Randall Dam, and spiking of water releases and operations for interior least terns and piping plovers cited in our August 26, 1999 letter remain valid and are incorporated herein by reference.

We appreciate the efforts made this year to maintain Lake Sakakawea elevations during rainbow smelt spawning and to maintain more stable discharges from Oahe Dam during walleye spawning. Biologists have already detected substantial numbers of young-of-the-year (YOY) smelt in Lake Sakakawea while low numbers were found in Lake Oahe. The remainder of this letter will concentrate on specific recommendations for the 2000/2001 AOP which pertain to test flows from Fort Peck Dam and unbalancing of storage in Fort Peck Lake, Lake Sakakawea, and Lake Oahe.

It is our understanding that beginning in mid-May 2001, test flows ("the mini-test") will be released through the Fort Peck Dam spillway to test the structural integrity and performance of the spillway. Various combinations of flow from the spillway and powerhouse will be tested up to a maximum combined release of 15,000 cubic-feet-per-second. These combinations will be tested over a 3-4 day period followed by several days of monitoring prior to another test. The testing is to be completed in 25 days. In 2002, larger test flows will be released and accompanied by an unbalancing of storage in Fort Peck Lake, Lake Sakakawea, and Lake Oahe.

The MRNRC supports these preliminary tests as we view them as initial steps in adaptive management of the river. Spring releases from the dams and unbalancing of reservoir storage should be decided annually, and be dependent on storage conditions in the reservoirs and projected basin runoff. In anticipation of the 2002 full Fort Peck test and reservoir unbalancing, MRNRC members are developing elevation triggers and runoff guidelines for Fort Peck Lake, Lake Sakakawea, and Lake Oahe to guide future release and unbalancing efforts. We intend to discuss these guidelines with your staff and the U.S. Fish and Wildlife Service during our annual meeting in September.


Our specific recommendations for 2001 are:

Exhibit 1

- Owing to the current low storage in Fort Peck Lake, Lake Sakakawea, and Lake Oahe, storage should be balanced ;
- Minimum storage in all lakes should be maintained as close as possible to the conservation pool (base of the annual flood control pool);
- Lake Oahe elevations should not fall between April 8 and May 15 for smelt and walleye spawning; levels in Lake Sakakawea should not fall between April 20 and May 20. Smelt spawn in the top six inches to one foot of the water column on reservoir shorelines. Lake Oahe levels dropped approximately one foot this year immediately after the smelt spawned. Stable reservoir levels are necessary during and immediately following spawning to prevent dessication and loss of eggs. Because of its current low smelt numbers, Lake Oahe is the priority for the coming spring and the following spring if this recommendation cannot be implemented in both lakes.
- It is our understanding that the Fort Peck mini-test will not be implemented unless reservoir elevations exceed 2225 and runoff is expected to be above lower quartile. Stable to rising lake levels should be maintained during the test to preserve reservoir fish spawning and nursery habitat. The tests should be delayed until early June. This will make it more likely that inflows would match or exceed the test outflows even during a low runoff year, thus preserving lake levels. Also, in May, reservoir surface temperatures are not likely to be high enough to produce the desired downstream temperature increases from spillway releases.
- Preliminary reports are that interior least terns and piping plovers had a successful nesting year owing to the continued availability of habitat created by the high flows in 1997 and the lower flows that occurred throughout the nesting season. However, vegetation is beginning to significantly encroach on nesting bars, especially in the river reach between Fort Randall Dam and Lewis and Clark Lake. Flow management measures should be instituted next year if water is available to scour and push up new bars.

I trust these recommendations will be helpful to your staff in developing the Annual Operating Plan for next year. If you have any questions concerning these recommendations, please contact me at 402-471-5555 or Tom Gengerke, incoming MRNRC Chair at 712-336-1714.

Sincerely,



Gene Zuerlein
MRNRC Chair
Nebraska Game and Parks Commission

MRNRC Delegates
MRNRC Ex-Officio Members and
Cooperating Agencies
MRNRC Technical Section Chairs
MRBA Executive Director
FWS Missouri River Coordinator (Olson)



1434 316th Lane • Missouri Valley, Iowa 51555 • 712-642-4121 • Fax 712-642-2460

September 21, 2000

Colonel Michael Meuleners
Northwestern Division, Corps of Engineers
12565 W. Center Road
Omaha, NE 68144-3869

Dear Colonel Meuleners:

This is a follow-up to our Annual Operating Plan recommendations of September 1, 2000. After the presentation by your staff on September 13 at our annual meeting and follow-up discussion, we have a better understanding of the plans proposed for the Fort Peck test flows and unbalancing of reservoir storage in 2001 and 2002.

The Missouri River Natural Resources Committee has supported the concept of unbalancing for many years, but only under the right circumstances. This past year has been one of below normal runoff in the Upper Basin. Your staff predicts runoff to be approximately 17.1 million acre-feet which is below Lower Quartile (i.e. occurred in 15 years during the 100-year period from 1898 to 1997). The elevations predicted for Fort Peck Lake, Lake Sakakawea, and Lake Oahe under the basic forecast for next March 1 are below normal for that time of year and infrequently occur under current operations. Since 1968 when the reservoir system was completed, these elevations have been exceeded in roughly 4 out of 5 years. **Therefore, we are concerned that the plans proposed for unbalancing in the next several years may further lower already low reservoirs if a prolonged drought ensues.** For this reason, we believe that the conditions for implementing unbalancing need to be specified to minimize unintended impacts to reservoir fisheries in the event the drought persists.

We agreed at the meeting to provide reservoir elevation guidelines for Fort Peck Lake, Lake Sakakawea, and Lake Oahe for implementing unbalancing. The elevation guidelines are as follows:

1) **Fort Peck Lake:** If the March 1 elevation is greater than the base of the annual flood control pool (2234 ft. msl), implement unbalancing. If the March 1 elevation is between 2227 and 2234 feet msl, implement unbalancing if runoff is projected to raise the reservoir elevation more than three (3) feet after March 1. Unbalancing should not cause lake levels to decline during the important spawning period for forage fish which ranges from April 15-May 30.

2) **Lake Sakakawea:** If the March 1 elevation is greater than the base of the annual flood control pool (1837.5 feet msl), implement unbalancing. If the March 1 elevation is between 1827 feet msl and 1837.5 feet msl, implement unbalancing if runoff is projected to raise the reservoir elevation more than three (3) feet after March 1. Unbalancing should not be implemented until after the critical rainbow smelt and walleye spawning period of April 20-May 20.

3) **Lake Oahe:** If the March 1 elevation is greater than the base of the annual flood control pool (1607.5 feet msl), implement unbalancing. If the March 1 elevation is between 1600 feet msl and 1607.5 feet msl, implement unbalancing if runoff is projected to raise the reservoir elevation more than three (3) feet after March 1. Unbalancing should not be implemented until after the critical rainbow smelt and walleye


Exhibit 2

spawning period of April 8-May 15.

Under the criteria listed above, it would have been possible to implement unbalancing in the reservoirs in the majority of years since 1968. Our analysis of actual end-of-month storage data for the reservoirs indicate that unbalancing would have occurred in 24 of 32 years in Oahe, 24 of 32 years in Sakakawea, and 26 years out of 32 in Fort Peck.

Even with these conditions, it will still be possible to implement the Fort Peck test flows over the next several years without unbalancing Lake Sakakawea. If the drought persists, Sakakawea elevations will continue to decline thereby exposing shoreline habitat and allowing regrowth of vegetation already exposed this year.

I hope these guidelines are helpful to your staff in developing the Annual Operating Plan for next year and the plans for the Fort Peck test flows. If you have any questions concerning these recommendations, please contact me at 402-471-5555 or Tom Gengerke, incoming MRNRC Chair at 712-336-1714.

Sincerely,


Gene Zuerlein
Immediate Past MRNRC Chair
Nebraska Game and Parks Commission

MRNRC Delegates
MRNRC Ex-Officio Members and
Cooperating Agencies
MRNRC Technical Section Chairs
MRBA Executive Director
FWS Missouri River Coordinator (Olson)



News Release

**US Army Corps
of Engineers**
Northwestern Division
Public Affairs Office

12565 West Center Road
Omaha, Nebraska 68144-3869

Contact: Paul Johnston
(402) 697-2552

Phone: (402) 697-2552
Fax: (402) 697-2554

Date: Jan. 12, 2001

FOR IMMEDIATE RELEASE

OMAHA -- The U.S. Army Corps of Engineers announced today its Annual Operating Plan for the Missouri River main stem dams and reservoirs for next year.

"With much of the basin suffering from moderate drought, the plan for the upcoming year will be one of conservation," said Lt. Col. Duane Sims, Northwestern Division Assistant Division Engineer. "The final plan differs slightly from the draft presented at the October public meetings. First, the AOP studies were updated to reflect current basin conditions, and second, lower winter releases are planned as an additional conservation measure while the system storage is below normal," he said.

Three public meetings were conducted on the draft plan Oct. 17-19 at Bismarck, N.D., Fort Peck, Mont., and Kansas City, Mo. As a result of suggestions received from various interests, a winter release rate of 12,000 cubic feet per second (cfs) was used in the final AOP studies.

"Releases this winter should be high enough to provide adequate service to downstream intakes," said Colonel Sims. "However, we will continue to provide modest short-term increases in Gavins Point releases to help alleviate water supply intake problems along the river during ice formation periods."

Releases to support navigation will be in accordance with the operational objectives described in the current Master Water Control Manual. "Flow support for the 2001 navigation season will begin on schedule but at reduced levels, unless the basin experiences a significant turnaround in runoff conditions."

A number of clarifications and word changes were made to the draft to improve readability. Corps officials will distribute the final report later this month. Public meetings will be conducted in April 2001 to update the spring runoff outlook and review the operational plans for the remainder of the year. Specific dates and locations will be announced prior to the meetings.

30NOV00	2000			
INI-SUM	31DEC	31JAN	28FEB	
--FORT PECK--				
NAT INFLOW	970	290	315	365
DEPLETION	-208	-83	-78	-47
EVAPORATION	45	45		
MOD INFLOW	1133	328	393	412
RELEASE	1890	603	676	611
STOR CHANGE	-757	-275	-283	-199
STORAGE	13775	13500	13217	13018
ELEV FTMSL	2228.0	2226.6	2225.1	2224.0
DISCH KCFS	6.3	9.8	11.0	11.0
POWER				
AVE POWER MW		130	145	145
PEAK POW MW		203	201	200
ENERGY GWH	302.4	97.0	108.2	97.2
--GARRISON--				
NAT INFLOW	850	230	260	360
DEPLETION	-47	-46	-12	11
CHAN STOR	-48	-36	-12	0
EVAPORATION	50	50		
REG INFLOW	2689	793	936	960
RELEASE	3124	1076	1076	972
STOR CHANGE	-435	-283	-140	-12
STORAGE	16170	15887	15747	15735
ELEV FTMSL	1830.9	1829.9	1829.4	1829.3
DISCH KCFS	20.8	17.5	17.5	17.5
POWER				
AVE POWER MW		209	208	207
PEAK POW MW		355	353	353
ENERGY GWH	449.0	155.2	154.5	139.3
--OAHE--				
NAT INFLOW	100		10	90
DEPLETION	60	13	18	29
CHAN STOR	15	15		
EVAPORATION	48	48		
REG INFLOW	3130	1029	1068	1033
RELEASE	2638	1051	973	614
STOR CHANGE	492	-21	95	419
STORAGE	15875	15854	15948	16367
ELEV FTMSL	1597.3	1597.2	1597.6	1599.1
DISCH KCFS	24.4	17.1	15.8	11.1
POWER				
AVE POWER MW		208	193	136
PEAK POW MW		652	653	661
ENERGY GWH	390.0	155.0	143.8	91.3
--BIG BEND--				
EVAPORATION	11	11		
REG INFLOW	2627	1039	973	614
RELEASE	2644	1056	973	614
STORAGE	1699	1682	1682	1682
ELEV FTMSL	1420.3	1420.0	1420.0	1420.0
DISCH KCFS	24.1	17.2	15.8	11.1
POWER				
AVE POWER MW		85	77	53
PEAK POW MW		538	537	529
ENERGY GWH	156.4	63.5	57.2	35.7
--FORT RANDALL--				
NAT INFLOW	80	10	20	50
DEPLETION	9	3	3	3
EVAPORATION	10	10		
REG INFLOW	2705	1054	990	661
RELEASE	1753	603	639	511
STOR CHANGE	952	451	351	150
STORAGE	2171	2622	2973	3123
ELEV FTMSL	1335.1	1342.9	1348.0	1350.0
DISCH KCFS	26.2	9.8	10.4	9.2
POWER				
AVE POWER MW		72	81	74
PEAK POW MW		301	324	331
ENERGY GWH	164.0	53.8	60.4	49.8
--GAVINS POINT--				
NAT INFLOW	345	120	100	125
DEPLETION	11	10	1	
CHAN STOR	32	31	-1	2
EVAPORATION	4	4		
REG INFLOW	2115	739	737	638
RELEASE	2141	739	737	664
STOR CHANGE	-26			-26
STORAGE	384	384	384	358
ELEV FTMSL	1207.0	1207.0	1207.0	1206.0
DISCH KCFS	28.8	12.0	12.0	12.0
POWER				
AVE POWER MW		43	43	42
PEAK POW MW		77	77	76
ENERGY GWH	92.1	31.9	31.8	28.4
--GAVINS POINT - SIOUX CITY--				
NAT INFLOW	160	40	35	85
DEPLETION	35	11	12	12
REGULATED FLOW AT SIOUX CITY				
KAF	2266	768	760	737
KCFS		12.5	12.4	13.3
--TOTAL--				
NAT INFLOW	2505	690	740	1075
DEPLETION	-140	-92	-56	8
CHAN STOR	-2	10	-13	2
EVAPORATION	169	169		
STORAGE	50074	49928	49951	50283
SYSTEM POWER				
AVE POWER MW		748	747	657
PEAK POW MW		2125	2145	2150
ENERGY GWH	1553.9	556.4	555.9	441.6
DAILY GWH		17.9	17.9	15.8
INI-SUM	31DEC	31JAN	28FEB	

30NOV00	2000			
INI-SUM	31DEC	31JAN	28FEB	
--FORT PECK--				
NAT INFLOW	1164	348	378	438
DEPLETION	-238	-81	-99	-58
EVAPORATION	34	34		
MOD INFLOW	1368	395	477	496
RELEASE	1902	615	676	611
STOR CHANGE	-534	-220	-199	-115
STORAGE	13775	13555	13356	13241
ELEV FTMSL	2228.0	2226.9	2225.8	2225.2
DISCH KCFS	6.3	10.0	11.0	11.0
POWER				
AVE POWER MW		133	146	145
PEAK POW MW		203	202	201
ENERGY GWH	305.1	99.0	108.4	97.6
--GARRISON--				
NAT INFLOW	1020	276	312	432
DEPLETION	-243	-118	-83	-42
CHAN STOR	-48	-38	-10	0
EVAPORATION	38	38		
REG INFLOW	3079	933	1061	1085
RELEASE	3272	1107	1138	1027
STOR CHANGE	-193	-174	-76	57
STORAGE	16170	15996	15920	15977
ELEV FTMSL	1830.9	1830.3	1830.0	1830.2
DISCH KCFS	20.8	18.0	18.5	18.5
POWER				
AVE POWER MW		215	220	220
PEAK POW MW		356	355	356
ENERGY GWH	471.4	159.8	163.7	147.9
--OAHE--				
NAT INFLOW	120		12	108
DEPLETION	60	13	18	29
CHAN STOR	10	12	-2	
EVAPORATION	36	36		
REG INFLOW	3305	1070	1129	1106
RELEASE	2552	1019	951	582
STOR CHANGE	754	51	178	525
STORAGE	15875	15926	16104	16629
ELEV FTMSL	1597.3	1597.5	1598.1	1600.0
DISCH KCFS	24.4	16.6	15.5	10.5
POWER				
AVE POWER MW		202	189	129
PEAK POW MW		653	656	666
ENERGY GWH	378.1	150.4	140.8	86.9
--BIG BEND--				
EVAPORATION	9	9		
REG INFLOW	2543	1010	951	582
RELEASE	2560	1027	951	582
STORAGE	1699	1682	1682	1682
ELEV FTMSL	1420.3	1420.0	1420.0	1420.0
DISCH KCFS	24.1	16.7	15.5	10.5
POWER				
AVE POWER MW		83	75	50
PEAK POW MW		538	537	529
ENERGY GWH	151.5	61.8	55.9	33.8
--FORT RANDALL--				
NAT INFLOW	96	12	24	60
DEPLETION	9	3	3	3
EVAPORATION	7	7		
REG INFLOW	2640	1029	972	639
RELEASE	1688	578	621	489
STOR CHANGE	952	451	351	150
STORAGE	2171	2622	2973	3123
ELEV FTMSL	1335.1	1342.9	1348.0	1350.0
DISCH KCFS	26.2	9.4	10.1	8.8
POWER				
AVE POWER MW		69	79	71
PEAK POW MW		301	324	331
ENERGY GWH	157.9	51.6	58.7	47.6
--GAVINS POINT--				
NAT INFLOW	414	144	120	150
DEPLETION	11	10	1	
CHAN STOR	33	31	-1	2
EVAPORATION	3	3		
REG INFLOW	2120	740	739	641
RELEASE	2146	740	739	667
STOR CHANGE	-26			-26
STORAGE	384	384	384	358
ELEV FTMSL	1207.0	1207.0	1207.0	1206.0
DISCH KCFS	28.8	12.0	12.0	12.0
POWER				
AVE POWER MW		43	43	42
PEAK POW MW		77	77	76
ENERGY GWH	92.3	31.9	31.9	28.5
--GAVINS POINT - SIOUX CITY--				
NAT INFLOW	192	48	42	102
DEPLETION	35	11	12	12
REGULATED FLOW AT SIOUX CITY				
KAF	2303	777	769	757
KCFS		12.6	12.5	13.6
--TOTAL--				
NAT INFLOW	3006	828	888	1290
DEPLETION	-366	-162	-148	-56
CHAN STOR	-5	6	-14	2
EVAPORATION	127	127		
STORAGE	50074	50165	50419	51010
SYSTEM POWER				
AVE POWER MW		745	752	658
PEAK POW MW		2127	2151	2159
ENERGY GWH	1556.3	554.5	559.4	442.3
DAILY GWH		17.9	18.0	15.8
INI-SUM	31DEC	31JAN	28FEB	

30NOV00	2000			
INI-SUM	31DEC	31JAN	28FEB	
--FORT PECK--				
NAT INFLOW	776	232	252	292
DEPLETION	-89	-46	-36	-7
EVAPORATION	56	56		
MOD INFLOW	809	222	288	299
RELEASE	1724	553	615	555
STOR CHANGE	-915	-332	-327	-256
STORAGE	13775	13443	13116	12860
ELEV FTMSL	2228.0	2226.3	2224.5	2223.2
DISCH KCFS	6.3	9.0	10.0	10.0
POWER				
AVE POWER MW		120	132	131
PEAK POW MW		202	201	199
ENERGY GWH	275.5	89.1	98.3	88.2
--GARRISON--				
NAT INFLOW	680	184	208	288
DEPLETION	-85	-42	-31	-12
CHAN STOR	-38	-28	-10	
EVAPORATION	63	63		
REG INFLOW	2388	689	844	855
RELEASE	3065	1045	1076	944
STOR CHANGE	-678	-357	-232	-89
STORAGE	16170	15813	15581	15492
ELEV FTMSL	1830.9	1829.6	1828.8	1828.5
DISCH KCFS	20.8	17.0	17.5	17.0
POWER				
AVE POWER MW		203	207	200
PEAK POW MW		354	351	351
ENERGY GWH	439.5	150.7	154.0	134.7
--OAHE--				
NAT INFLOW	80		8	72
DEPLETION	60	13	18	29
CHAN STOR	17	17	-2	2
EVAPORATION	61	61		
REG INFLOW	3042	989	1064	989
RELEASE	2731	1083	996	653
STOR CHANGE	310	-94	68	337
STORAGE	15875	15781	15849	16185
ELEV FTMSL	1597.3	1596.9	1597.2	1598.4
DISCH KCFS	24.4	17.6	16.2	11.8
POWER				
AVE POWER MW		214	197	144
PEAK POW MW		650	652	658
ENERGY GWH	403.1	159.6	146.8	96.7
--BIG BEND--				
EVAPORATION	14	14		
REG INFLOW	2717	1068	996	653
RELEASE	2734	1085	996	653
STORAGE	1699	1682	1682	1682
ELEV FTMSL	1420.3	1420.0	1420.0	1420.0
DISCH KCFS	24.1	17.7	16.2	11.8
POWER				
AVE POWER MW		88	79	56
PEAK POW MW		538	537	529
ENERGY GWH	161.6	65.2	58.5	37.9
--FORT RANDALL--				
NAT INFLOW	64	8	16	40
DEPLETION	9	3	3	3
EVAPORATION	12	12		
REG INFLOW	2777	1078	1009	690
RELEASE	1824	627	658	539
STOR CHANGE	953	451	351	151
STORAGE	2171	2622	2973	3124
ELEV FTMSL	1335.1	1342.9	1348.0	1350.0
DISCH KCFS	26.2	10.2	10.7	9.7
POWER				
AVE POWER MW		75	84	78
PEAK POW MW		301	324	331
ENERGY GWH	170.6	55.9	62.1	52.5
--GAVINS POINT--				
NAT INFLOW	276	96	80	100
DEPLETION	11	10	1	
CHAN STOR	31	30	-1	2
EVAPORATION	5	5		
REG INFLOW	2115	738	736	641
RELEASE	2141	738	736	667
STOR CHANGE	-26			-26
STORAGE	384	384	384	358
ELEV FTMSL	1207.0	1207.0	1207.0	1206.0
DISCH KCFS	28.8	12.0	12.0	12.0
POWER				
AVE POWER MW		43	43	42
PEAK POW MW		77	77	76
ENERGY GWH	92.1	31.8	31.8	28.5
--GAVINS POINT - SIOUX CITY--				
NAT INFLOW	128	32	28	68
DEPLETION	35	11	12	12
REGULATED FLOW AT SIOUX CITY				
KAF	2234	759	752	723
KCFS		12.3	12.2	13.0
--TOTAL--				
NAT INFLOW	2004	552	592	860
DEPLETION	-59	-51	-33	25
CHAN STOR	10	19	-13	4
EVAPORATION	212	212		
STORAGE	50074	49726	49585	49702
SYSTEM POWER		742	741	653
AVE POWER MW		2122	2141	2144
PEAK POW MW		3542	3515	3515
ENERGY GWH	1542.4	552.3	551.5	438.5
DAILY GWH		17.8	17.8	15.7
INI-SUM	31DEC	31JAN	28FEB	

28FEB01	INI-SUM	15MAR	2001 22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	2002 30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5100	234	109	140	515	783	996	439	253	242	320	159	74	85	271	205	275
DEPLETION	406	15	7	9	86	227	311	141	-5	-64	-77	-20	-9	-11	-78	-79	-46
EVAPORATION	488							30	94	117	102	46	21	24	53		
MOD INFLOW	4206	220	102	132	429	556	685	268	164	189	295	132	62	71	296	284	321
RELEASE	5562	179	69	89	387	430	476	492	492	293	262	179	111	143	615	707	639
STOR CHANGE	-1356	41	33	43	42	126	209	-224	-328	-104	33	-46	-49	-72	-319	-423	-318
STORAGE	12860	12901	12934	12977	13019	13145	13354	13130	12802	12698	12731	12685	12636	12564	12245	11822	11504
ELEV FTMSL	2223.2	2223.4	2223.6	2223.8	2224.0	2224.7	2225.8	2224.6	2222.8	2222.3	2222.5	2222.2	2221.9	2221.5	2219.8	2217.4	2215.6
DISCH KCFS	10.0	6.0	5.0	5.0	6.5	7.0	8.0	8.0	8.0	4.9	4.3	6.0	8.0	9.0	10.0	11.5	11.5
POWER																	
AVE POWER MW		79	66	66	86	92	106	106	105	64	56	78	104	117	129	147	146
PEAK POW MW		199	200	200	200	201	202	201	199	198	198	198	198	198	196	192	190
ENERGY GWH	876.6	28.4	11.0	14.2	61.6	68.6	76.1	78.7	78.2	46.4	41.5	28.2	17.5	22.5	96.2	109.5	97.9
--GARRISON--																	
NAT INFLOW	7299	270	126	162	700	903	2020	1277	361	277	390	161	75	86	108	160	223
DEPLETION	783	16	8	10	54	150	484	298	22	-103	40	-61	-28	-32	-39	-26	-10
CHAN STOR	-16	41	10		-16	-5	-10			32	7	-18	-21	-10	-10	-16	
EVAPORATION	564							35	109	136	118	53	25	28	60		
REG INFLOW	11499	473	198	241	1017	1178	2002	1436	721	568	501	329	169	223	692	877	872
RELEASE	13131	565	208	268	952	1261	1220	1230	1199	882	756	366	236	301	1230	1291	1166
STOR CHANGE	-1632	-92	-10	-26	65	-82	782	206	-478	-314	-254	-36	-67	-79	-538	-414	-295
STORAGE	15492	15400	15390	15364	15429	15347	16128	16335	15857	15544	15289	15253	15186	15107	14569	14155	13860
ELEV FTMSL	1828.5	1828.1	1828.1	1828.0	1828.2	1827.9	1830.7	1831.5	1829.8	1828.7	1827.7	1827.6	1827.3	1827.1	1825.0	1823.5	1822.3
DISCH KCFS	17.0	19.0	15.0	15.0	16.0	20.5	20.5	20.0	19.5	14.8	12.3	12.3	17.0	19.0	20.0	21.0	21.0
POWER																	
AVE POWER MW		223	176	176	188	240	242	239	233	176	145	144	199	222	231	240	238
PEAK POW MW		350	349	349	350	349	357	359	354	351	348	348	347	346	340	336	332
ENERGY GWH	1860.3	80.4	29.7	38.1	135.5	178.8	174.4	178.0	173.0	126.5	107.8	52.0	33.4	42.6	172.1	178.5	159.7
--OAHE--																	
NAT INFLOW	1049	197	92	118	183	100	215	82	21	64	5	-5	-2	-3	-48	-12	41
DEPLETION	542	21	10	13	44	60	114	129	84	21	-6	2	1	1	10	15	24
CHAN STOR	-19	-9	17	0	-4	-20		2	2	22	12	-23	-10	-5	-5		
EVAPORATION	504							32	99	121	104	47	22	25	55		
REG INFLOW	13115	733	308	373	1087	1281	1321	1153	1040	826	675	312	189	263	1112	1259	1183
RELEASE	14824	474	316	431	1434	1599	1450	1719	1718	1377	791	510	99	141	998	775	994
STOR CHANGE	-1709	259	-8	-57	-347	-318	-129	-566	-678	-551	-116	-197	89	123	115	484	190
STORAGE	16186	16445	16437	16380	16033	15714	15585	15019	14341	13790	13674	13476	13566	13689	13803	14288	14477
ELEV FTMSL	1598.4	1599.4	1599.3	1599.1	1597.9	1596.7	1596.2	1594.0	1591.4	1589.1	1588.6	1587.8	1588.2	1588.7	1589.2	1591.1	1591.9
DISCH KCFS	11.7	15.9	22.8	24.1	24.1	26.0	24.4	28.0	27.9	23.1	12.9	17.1	7.1	8.9	16.2	12.6	17.9
POWER																	
AVE POWER MW		196	280	297	295	316	295	336	331	271	150	199	83	103	189	148	211
PEAK POW MW		662	662	661	655	649	647	636	623	612	609	605	607	609	612	622	626
ENERGY GWH	2142.3	70.5	47.1	64.1	212.6	235.3	212.4	249.7	246.3	195.0	111.5	71.5	13.9	19.8	140.5	110.1	142.0
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	14695	474	316	431	1434	1599	1450	1711	1694	1346	764	498	93	134	983	775	994
RELEASE	14695	474	316	431	1434	1599	1450	1711	1694	1346	764	498	93	134	983	775	994
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	11.7	15.9	22.8	24.1	24.1	26.0	24.4	27.8	27.5	22.6	12.4	16.7	6.7	8.5	16.0	12.6	17.9
POWER																	
AVE POWER MW		75	107	113	113	122	114	130	129	107	63	84	34	43	80	63	86
PEAK POW MW		518	510	509	509	509	509	509	509	523	538	538	538	538	538	538	529
ENERGY GWH	848.0	27.1	17.9	24.4	81.2	90.6	82.1	96.9	95.9	77.4	46.7	30.3	5.7	8.2	59.3	46.5	57.7
--FORT RANDALL--																	
NAT INFLOW	300	55	26	33	43	35	120	13	36	-10	-52	-3	-1	-1	-6	12	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	
EVAPORATION	141							10	32	39	28	10	5	5	13		
REG INFLOW	14770	527	341	463	1473	1625	1558	1696	1683	1291	678	483	88	127	968	766	1003
RELEASE	14769	268	192	446	1473	1625	1558	1696	1683	1606	1578	520	88	127	695	676	539
STOR CHANGE	1	260	149	17				0	0	-315	-900	-37	0	0	273	90	464
STORAGE	3123	3383	3532	3549	3549	3549	3549	3549	3549	3234	2334	2297	2297	2297	2570	2660	3124
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.4	1338.2	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	9.7	9.0	13.8	25.0	24.8	26.4	26.2	27.6	27.4	27.0	25.7	17.5	6.3	8.0	11.3	11.0	9.7
POWER																	
AVE POWER MW		74	116	209	208	221	219	231	229	223	197	127	46	58	84	84	77
PEAK POW MW		344	351	352	352	352	352	352	352	337	278	276	276	276	297	303	332
ENERGY GWH	1453.7	26.7	19.4	45.2	149.5	164.8	158.0	171.9	170.6	160.3	146.5	45.7	7.8	11.2	62.4	62.4	51.5
--GAVINS POINT--																	
NAT INFLOW	1200	87	41	52	120	131	138	76	55	104	45	21	24	67	65	98	
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	1	-9	-21	0	-3	0	-3	0	1	2	15	21	-3	-6	1	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15808	357	223	477	1589	1734	1672	1728	1741	1655	1672	571	126	143	740	741	639
RELEASE	15808	357	223	477	1589	1734	1672	1728	1728	1642	1672	571	126	143	740	741	665
STOR CHANGE								13	13								-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	
DISCH KCFS	12.0	12.0	16.1	2													

	28FEB01		2001										2002				
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5100	234	109	140	515	783	996	439	253	242	320	159	74	85	271	205	275
DEPLETION	406	15	7	9	86	227	311	141	-5	-64	-77	-20	-9	-11	-78	-79	-46
EVAPORATION	485						30	93	116	101	46	21	24	52			
MOD INFLOW	4209	220	102	132	429	556	685	268	165	190	296	133	62	71	297	284	321
RELEASE	5709	179	69	89	387	461	506	523	523	291	261	179	111	143	615	707	666
STOR CHANGE	-1500	41	33	43	42	95	179	-255	-358	-101	35	-46	-49	-72	-318	-423	-345
STORAGE	12860	12901	12934	12977	13019	13114	13293	13039	12681	12580	12614	12569	12519	12447	12129	11706	11361
ELEV FTMSL	2223.2	2223.4	2223.6	2223.8	2224.0	2224.5	2225.5	2224.1	2222.2	2221.6	2221.8	2221.3	2220.9	2220.9	2219.1	2216.7	2214.7
DISCH KCFS	10.0	6.0	5.0	5.0	6.5	7.5	8.5	8.5	8.5	4.9	4.2	6.0	8.0	9.0	10.0	11.5	12.0
POWER																	
AVE POWER MW		79	66	66	86	99	112	112	111	64	55	78	104	117	129	147	151
PEAK POW MW		199	200	200	200	201	202	200	198	198	198	198	197	197	195	192	189
ENERGY GWH	897.8	28.4	11.0	14.2	61.6	73.5	80.8	83.4	82.8	46.0	41.2	28.2	17.5	22.4	96.0	109.2	101.8
--GARRISON--																	
NAT INFLOW	7299	270	126	162	700	903	2020	1277	361	277	390	161	75	86	108	160	223
DEPLETION	783	16	8	10	54	150	484	298	22	-103	40	-61	-28	-32	-39	-26	-10
CHAN STOR	-22	41	10		-16	-10		0		37	7	-18	-21	-10	-10	-16	-5
EVAPORATION	560						35	109	136	117	52	24	28	59			
REG INFLOW	11643	473	198	241	1017	1204	2031	1467	752	573	501	329	169	223	692	877	894
RELEASE	13451	565	208	268	952	1261	1279	1291	1291	929	796	385	236	301	1230	1291	1166
STOR CHANGE	-1808	-92	-10	-26	65	-57	752	176	-539	-356	-295	-56	-67	-79	-538	-414	-272
STORAGE	15492	15400	15390	15364	15429	15372	16124	16300	15761	15405	15109	15054	14987	14908	14371	13957	13685
ELEV FTMSL	1828.5	1828.1	1828.1	1828.0	1828.2	1828.0	1830.7	1831.4	1829.4	1828.2	1827.1	1826.9	1826.6	1826.3	1824.3	1822.7	1821.6
DISCH KCFS	17.0	19.0	15.0	15.0	16.0	20.5	21.5	21.0	21.0	15.6	12.9	12.9	17.0	19.0	20.0	21.0	21.0
POWER																	
AVE POWER MW		223	176	176	188	240	254	251	250	184	152	151	198	221	230	239	236
PEAK POW MW		350	349	349	350	349	357	359	353	350	346	346	345	344	338	334	330
ENERGY GWH	1901.6	80.4	29.7	38.1	135.5	178.8	182.9	186.7	185.9	132.8	113.1	54.5	33.3	42.3	171.3	177.5	158.9
--OAHE--																	
NAT INFLOW	1049	197	92	118	183	100	215	82	21	64	5	-5	-2	-3	-48	-12	41
DEPLETION	542	21	10	13	44	60	114	129	84	21	-6	2	1	1	10	15	24
CHAN STOR	-19	-9	17	0	-4	-20		2		25	13	-20	-10	-5	-5		
EVAPORATION	504						32	99	122	104	46	22	25	54			
REG INFLOW	13435	733	308	373	1087	1281	1376	1214	1129	875	716	332	192	264	1113	1259	1183
RELEASE	15324	474	316	431	1434	1599	1450	1719	1718	1549	1052	438	202	188	985	775	994
STOR CHANGE	-1889	259	-8	-57	-347	-318	-74	-505	-589	-674	-336	-106	-11	76	128	484	190
STORAGE	16186	16445	16437	16380	16033	15714	15640	15136	14547	13873	13537	13431	13421	13496	13624	14108	14298
ELEV FTMSL	1598.4	1599.4	1599.3	1599.1	1597.9	1596.7	1596.4	1594.5	1592.2	1589.5	1588.1	1587.6	1587.6	1587.9	1588.4	1590.4	1591.2
DISCH KCFS	11.7	15.9	22.8	24.1	24.1	26.0	24.4	28.0	27.9	26.0	17.1	14.7	14.6	11.9	16.0	12.6	17.9
POWER																	
AVE POWER MW		196	280	297	295	316	295	336	332	305	199	170	168	137	186	147	210
PEAK POW MW		662	662	661	655	649	648	638	627	613	606	604	604	605	608	618	622
ENERGY GWH	2212.4	70.5	47.1	64.1	212.6	235.3	212.5	250.2	247.1	219.8	148.0	61.3	28.3	26.3	138.2	109.6	141.4
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	15195	474	316	431	1434	1599	1450	1711	1694	1518	1025	426	197	182	971	775	994
RELEASE	15195	474	316	431	1434	1599	1450	1711	1694	1518	1025	426	197	182	971	775	994
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	11.7	15.9	22.8	24.1	24.1	26.0	24.4	27.8	27.5	25.5	16.7	14.3	14.2	11.4	15.8	12.6	17.9
POWER																	
AVE POWER MW		75	107	113	113	122	114	130	129	121	82	72	71	58	79	63	86
PEAK POW MW		518	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	875.9	27.1	17.9	24.4	81.2	90.6	82.1	96.9	95.9	87.1	60.9	25.9	12.0	11.1	58.6	46.5	57.7
--FORT RANDALL--																	
NAT INFLOW	300	55	26	33	43	35	120	13	36	-10	-52	-3	-1	-1		-6	12
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	147						10	32	39	31	12	5	5	13			
REG INFLOW	15268	527	341	463	1473	1625	1558	1696	1683	1462	941	410	190	174	956	766	1003
RELEASE	15267	268	192	446	1473	1625	1558	1696	1683	1606	1578	714	335	196	683	676	539
STOR CHANGE	1	260	149	17	0	0	0	0	-144	-637	-304	-145	-22	273	90	464	
STORAGE	3123	3383	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2570	2660	3124
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	9.7	9.0	13.8	25.0	24.8	26.4	26.2	27.6	27.4	27.0	25.7	24.0	24.1	12.4	11.1	11.0	9.7
POWER																	
AVE POWER MW		74	116	209	208	221	219	231	229	225	205	181	176	90	82	84	77
PEAK POW MW		344	351	352	352	352	352	352	352	345	310	288	277	276	297	303	332
ENERGY GWH	1507.3	26.7	19.4	45.2	149.5	164.8	158.0	171.9	170.6	161.6	152.4	65.2	29.6	17.3	61.3	62.4	51.5
--GAVINS POINT--																	
NAT INFLOW	1200	87	41	52	120	131	138	76	76	55	104	45	21	24	67	65	98
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	1	-9	-21	0	-3	0	-3	0	1	2	3	0	22	2	0	2
EVAPORATION	47						3	9	11	10	5	2	2	5			
REG INFLOW	16306	357	223	477	1589	1734	1672	1728	1741	1655	1672	753	351	237	737	741	639
RELEASE	16306	357	223	477	1589	1734	1672	1728	1728	1642	1672	753	351	237	737	741	665
STOR CHANGE							13	13	384	384	384	384	384	384	384	384	-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0				

	28FEB02	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349
DEPLETION	353	-13	-6	-8	46	329	575	170	-89	-141	-70	-38	-18	-20	-130	-143	-93
EVAPORATION	448							27	85	107	94	43	20	23	49		
MOD INFLOW	6599	277	129	166	582	881	1276	632	328	353	374	182	85	97	391	404	442
RELEASE	6465	179	69	89	417	492	1119	553	553	344	277	134	63	159	615	707	694
STOR CHANGE	135	98	60	77	165	389	157	79	-226	9	97	48	22	-61	-224	-303	-252
STORAGE	13970	14068	14128	14204	14370	14759	14916	14995	14769	14778	14874	14923	14945	14884	14660	14357	14104
ELEV FTMSL	2229.0	2229.5	2229.8	2230.2	2231.0	2232.9	2233.6	2234.0	2232.9	2233.0	2233.4	2233.6	2233.8	2233.5	2232.4	2230.9	2229.7
DISCH KCFS	10.5	6.0	5.0	5.0	7.0	8.0	18.8	9.0	9.0	5.8	4.5	4.5	4.5	10.0	10.0	11.5	12.5
POWER																	
AVE POWER MW		80	67	67	94	108	207	122	122	79	61	61	61	136	135	155	168
PEAK POW MW		205	205	205	206	207	208	208	208	208	208	208	208	208	207	206	205
ENERGY GWH	1023.7	29.0	11.3	14.5	67.9	80.4	149.4	91.0	90.9	56.6	45.6	22.1	10.3	26.1	100.8	115.3	112.7
--GARRISON--																	
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326
DEPLETION	901	-8	-4	-5	-15	215	780	495	13	-124	11	-92	-43	-49	-112	-98	-64
CHAN STOR	-22	46	10		-20	-10	-109	97		32	13			-54	0	-15	-10
EVAPORATION	514							31	100	124	108	48	22	26	55		
REG INFLOW	16029	702	302	376	1264	1690	3188	2190	1022	873	625	369	172	230	925	1027	1074
RELEASE	14933	506	236	303	1190	1414	1488	1506	1476	964	878	425	198	317	1230	1414	1388
STOR CHANGE	1096	196	66	72	74	276	1700	683	-454	-91	-252	-56	-26	-88	-305	-387	-314
STORAGE	16219	16415	16481	16554	16628	16903	18603	19287	18833	18742	18489	18434	18408	18320	18016	17629	17314
ELEV FTMSL	1831.1	1831.8	1832.0	1832.2	1832.5	1833.5	1839.1	1841.2	1839.8	1839.5	1838.7	1838.5	1838.5	1838.2	1837.2	1835.9	1834.9
DISCH KCFS	23.0	17.0	17.0	17.0	20.0	23.0	25.0	24.5	24.0	16.2	14.3	14.3	14.3	20.0	20.0	23.0	25.0
POWER																	
AVE POWER MW		204	205	205	241	278	308	309	303	205	180	180	179	250	249	284	306
PEAK POW MW		360	361	362	362	365	382	390	384	383	381	380	380	379	376	372	369
ENERGY GWH	2237.3	73.5	34.4	44.3	173.6	206.8	221.8	230.1	225.7	147.4	134.0	64.6	30.1	48.1	185.5	211.5	205.9
--OAHE--																	
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20	15	40
DEPLETION	557	22	10	13	45	61	117	134	87	22	-7	2	1	1	11	15	24
CHAN STOR	-9	25			-12	-12	-8	2	2	32	8		0	-25	0	-13	-9
EVAPORATION	464							30	92	112	96	43	20	23	49		
REG INFLOW	16203	826	374	480	1497	1577	2051	1507	1332	980	811	385	180	272	1150	1386	1396
RELEASE	15956	552	144	357	1292	1554	1612	1902	1915	1703	1206	571	263	217	1051	972	645
STOR CHANGE	248	274	230	123	205	23	439	-396	-583	-723	-395	-186	-83	54	99	414	751
STORAGE	17177	17451	17681	17804	18009	18032	18471	18076	17493	16770	16375	16190	16106	16160	16259	16673	17424
ELEV FTMSL	1602.0	1602.9	1603.7	1604.1	1604.8	1604.9	1606.3	1605.0	1603.0	1600.5	1599.1	1598.5	1598.3	1598.2	1598.7	1600.2	1602.8
DISCH KCFS	11.6	18.5	10.3	20.0	21.7	25.3	27.1	30.9	31.1	28.6	19.6	19.2	19.0	13.7	17.1	15.8	11.6
POWER																	
AVE POWER MW		233	131	253	275	320	345	393	392	356	242	236	233	168	210	195	145
PEAK POW MW		681	685	687	691	691	699	692	681	668	661	658	656	657	659	667	680
ENERGY GWH	2421.7	83.7	21.9	54.6	198.1	238.4	248.2	292.7	291.9	256.6	180.3	84.9	39.1	32.3	156.1	145.2	97.6
--BIG BEND--																	
EVAPORATION	103							6	20	25	22	10	5	5	11		
REG INFLOW	15852	552	144	357	1292	1554	1612	1896	1895	1678	1184	561	259	212	1040	972	645
RELEASE	15852	552	144	357	1292	1554	1612	1896	1895	1678	1184	561	259	212	1040	972	645
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	11.6	18.5	10.3	20.0	21.7	25.3	27.1	30.8	30.8	28.2	19.3	18.9	18.6	13.4	16.9	15.8	11.6
POWER																	
AVE POWER MW		87	48	94	102	118	127	144	144	134	94	95	94	68	84	77	56
PEAK POW MW		510	509	509	509	509	509	509	509	517	538	538	538	538	538	537	529
ENERGY GWH	912.9	31.3	8.1	20.2	73.2	88.0	91.3	107.4	107.3	96.2	70.3	34.1	15.7	13.0	62.2	57.1	37.5
--FORT RANDALL--																	
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	118							8	25	31	25	10	4	4	10		
REG INFLOW	16555	673	200	430	1403	1685	1785	1944	1912	1681	1161	552	255	209	1036	969	661
RELEASE	16555	265	183	430	1403	1685	1785	1944	1912	1825	1798	856	400	230	670	658	511
STOR CHANGE	0	408	17				0	0	0	-144	-637	-304	-145	-22	366	311	150
STORAGE	3124	3532	3549	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2974	3124
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1348.0	1350.0
DISCH KCFS	9.2	8.9	13.2	24.1	23.6	27.4	30.0	31.6	31.1	30.7	29.2	28.8	28.8	14.5	10.9	10.7	9.2
POWER																	
AVE POWER MW		74	111	202	198	229	251	264	260	255	233	217	210	105	81	84	74
PEAK POW MW		351	352	352	352	352	352	352	352	345	310	289	278	276	303	324	331
ENERGY GWH	1635.4	26.6	18.7	43.6	142.5	170.7	180.6	196.6	193.3	183.4	173.2	77.9	35.2	20.2	60.6	62.3	49.8
--GAVINS POINT--																	
NAT INFLOW	1450	92	43	55	148	174	166	86	103	77	122	50	23	27	77	79	127
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-37	1	-8	-21	1	-7	-5	-3	1	3	8	4	2	2	7	0	3
EVAPORATION	37							2	7	9	8	4	2	2	4		
REG INFLOW	17853	358	218	464	1547	1832	1922	1986	1999	1899	1912	899	419	279	740	736	641
RELEASE	17853	358	218	464	1547	1832	1922	1986	1986	1886	1912	899	419	279	740	736	667
STOR CHANGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
STORAGE	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0
ELEV FTMSL	12.0	12.0	15.7	26.0	26.0	29.8	32.3	32.3	32.3	31.7	31.1	30.2	30.2	17.6			

	28FEB03		2003										2004				
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB
--FORT PECK--																	
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349
DEPLETION	366	-13	-6	-8	50	324	582	176	-84	-141	-71	-37	-17	-19	-128	-140	-102
EVAPORATION	449							28	87	108	94	42	20	22	48		
MOD INFLOW	6585	277	129	166	578	886	1269	625	321	352	375	182	85	97	390	401	451
RELEASE	6765	179	69	89	476	553	655	646	615	567	413	238	125	159	615	676	690
STOR CHANGE	-181	99	60	77	102	333	614	-20	-294	-215	-38	-56	-40	-62	-225	-275	-239
STORAGE	14104	14203	14263	14340	14442	14775	15389	15369	15075	14860	14822	14765	14725	14664	14438	14163	13924
ELEV FTMSL	2229.7	2230.2	2230.5	2230.8	2231.3	2232.9	2235.8	2235.7	2234.4	2233.4	2233.2	2232.9	2232.7	2232.4	2231.3	2230.0	2228.8
DISCH KCFS	12.5	6.0	5.0	5.0	8.0	9.0	11.0	10.5	10.0	9.5	6.7	8.0	9.0	10.0	11.0	11.0	12.0
POWER																	
AVE POWER MW		81	67	67	108	122	150	143	136	129	91	108	122	135	135	148	161
PEAK POW MW		205	206	206	206	208	210	210	209	208	208	207	207	207	206	205	204
ENERGY GWH	1107.6	29.0	11.3	14.6	77.6	90.5	107.7	106.7	101.4	93.2	67.9	39.1	20.5	26.0	100.4	110.0	111.7
--GARRISON--																	
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326
DEPLETION	919	-7	-3	-4	-9	204	795	516	18	-126	6	-95	-44	-50	-112	-98	-71
CHAN STOR	5	65	10		-30	-10	-20	5	5	5	27	-13	-10	-10	0	-10	-10
EVAPORATION	522							32	102	126	109	49	23	26	56		
REG INFLOW	16330	720	302	375	1308	1762	2798	2168	1081	1068	780	463	226	275	924	1001	1077
RELEASE	16285	506	236	303	1190	1537	1607	1629	1599	1245	1103	534	278	317	1230	1476	1496
STOR CHANGE	45	215	66	72	118	225	1191	539	-517	-177	-323	-71	-52	-42	-306	-474	-418
STORAGE	17314	17529	17595	17666	17784	18010	19201	19740	19222	19045	18722	18651	18600	18558	18252	17778	17360
ELEV FTMSL	1834.9	1835.6	1835.8	1836.0	1836.4	1837.2	1840.9	1842.6	1841.0	1840.5	1839.5	1839.2	1839.1	1838.9	1838.0	1836.4	1835.0
DISCH KCFS	25.0	17.0	17.0	17.0	20.0	25.0	27.0	26.5	26.0	20.9	17.9	17.9	20.0	20.0	20.0	24.0	26.0
POWER																	
AVE POWER MW		209	210	210	247	309	335	335	330	265	227	226	252	251	251	298	318
PEAK POW MW		371	372	373	374	376	388	398	387	385	383	382	382	381	378	374	370
ENERGY GWH	2459.5	75.3	35.2	45.4	177.9	230.0	241.1	249.1	245.2	190.6	168.7	81.4	42.3	48.3	186.4	221.5	221.2
--OAKE--																	
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20	15	40
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2	1	1	11	25	25
CHAN STOR	-4	33			-12	-20	-8	2	2	21	12	0	-9	0	0	-17	-8
EVAPORATION	479							30	94	115	99	45	21	24	52		
REG INFLOW	17532	834	374	480	1497	1691	2168	1625	1450	1246	1037	493	250	296	1147	1444	1502
RELEASE	16436	552	150	370	1334	1603	1666	1958	1970	1756	1261	598	276	259	1043	972	669
STOR CHANGE	1096	282	223	110	163	88	502	-333	-520	-511	-224	-105	-26	37	104	472	833
STORAGE	17424	17706	17930	18040	18203	18291	18793	18460	17940	17430	17206	17100	17074	17111	17215	17687	18521
ELEV FTMSL	1602.8	1603.8	1604.5	1604.9	1605.4	1605.7	1607.4	1606.3	1604.6	1602.8	1602.1	1601.7	1601.6	1601.7	1602.1	1603.7	1606.5
DISCH KCFS	11.6	18.5	10.8	20.7	22.4	26.1	28.0	31.8	32.0	29.5	20.5	20.1	19.9	16.3	17.0	15.8	11.6
POWER																	
AVE POWER MW		234	137	263	285	332	358	407	407	371	257	251	248	204	212	199	148
PEAK POW MW		685	689	691	694	696	704	699	689	680	676	674	674	675	676	685	700
ENERGY GWH	2518.4	84.1	23.0	56.8	205.2	246.9	257.7	303.0	302.5	267.4	191.3	90.4	41.7	39.1	157.9	148.0	103.2
--BIG BEND--																	
EVAPORATION	103							6	20	25	22	10	5	5	11		
REG INFLOW	16333	552	150	370	1334	1603	1666	1952	1950	1731	1240	588	271	254	1031	972	669
RELEASE	16333	552	150	370	1334	1603	1666	1952	1950	1731	1240	588	271	254	1031	972	669
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	11.6	18.5	10.8	20.7	22.4	26.1	28.0	31.7	31.7	29.1	20.2	19.8	19.5	16.0	16.8	15.8	11.6
POWER																	
AVE POWER MW		87	51	97	105	122	131	149	148	138	99	99	98	81	83	77	56
PEAK POW MW		510	509	509	509	509	509	509	509	517	538	538	538	538	538	537	529
ENERGY GWH	940.5	31.3	8.5	21.0	75.5	90.8	94.3	110.5	110.4	99.3	73.5	35.7	16.5	15.5	61.7	57.1	38.9
--FORT RANDALL--																	
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	118							8	25	31	25	10	4	4	10		
REG INFLOW	17035	673	206	443	1445	1734	1839	2000	1967	1735	1216	579	268	250	1028	969	685
RELEASE	17035	265	189	443	1445	1734	1839	2000	1967	1879	1853	883	413	272	662	658	535
STOR CHANGE	0	408	17					0	0	-144	-637	-304	-145	-22	366	311	150
STORAGE	3124	3532	3549	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2974	3124
ELEV FTMSL	1350.0	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1348.0	1350.0
DISCH KCFS	9.2	8.9	13.6	24.8	24.3	28.2	30.9	32.5	32.0	31.6	30.1	29.7	29.7	17.1	10.8	10.7	9.3
POWER																	
AVE POWER MW		74	115	208	204	236	258	272	267	262	240	223	216	124	80	84	75
PEAK POW MW		351	352	352	352	352	352	352	352	345	310	289	278	276	303	324	331
ENERGY GWH	1681.9	26.6	19.4	44.9	146.7	175.7	186.0	202.1	198.8	188.7	178.5	80.3	36.3	23.8	59.8	62.3	52.1
--GAVINS POINT--																	
NAT INFLOW	1450	92	43	55	148	174	166	86	103	77	122	50	23	27	77	79	127
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	1	-9	-21	1	-8	-5	-3	1	1	3	1	0	24	12	0	3
EVAPORATION	37							2	7	9	8	4	2	2	4		
REG INFLOW	18333	358	224	477	1589	1882	1976	2041	2054	1953	1968	925	432	317	737	736	665
RELEASE	18333	358	224	477	1589	1882	1976	2041	2041	1940	1968	925	432	317	737	736	691
STOR CHANGE								13	13								-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0					

	2006				2007												
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	7400	264	123	158	628	1210	1851	829	324	319	398	188	88	100	310	261	349
DEPLETION	399	-13	-6	-8	50	326	595	197	-71	-142	-77	-40	-19	-21	-134	-144	-94
EVAPORATION	456						28	88	110	95	43	20	23	49			
MOD INFLOW	6545	277	129	166	578	884	1256	604	307	351	380	185	86	99	395	405	443
RELEASE	7409	179	69	89	536	615	714	738	631	508	246	115	159	615	738	722	
STOR CHANGE	-865	99	60	77	42	269	542	-134	-431	-279	-128	-61	-28	-60	-220	-333	-279
STORAGE	14898	14997	15057	15134	15176	15446	15988	15853	15422	15143	15015	14954	14925	14865	14645	14312	14033
ELEV FTMSL	2233.5	2234.0	2234.3	2234.6	2234.8	2236.1	2238.6	2238.0	2236.0	2234.7	2234.1	2233.8	2233.7	2233.4	2232.3	2230.7	2229.3
DISCH KCFS	12.0	6.0	5.0	5.0	9.0	10.0	12.0	12.0	12.0	10.6	8.3	8.3	8.3	10.0	10.0	12.0	13.0
POWER																	
AVE POWER MW		82	68	68	123	136	165	165	164	145	112	112	112	136	135	162	174
PEAK POW MW		208	209	209	209	210	212	211	210	209	208	208	208	208	207	206	205
ENERGY GWH	1219.7	29.4	11.4	14.7	88.3	101.5	118.5	122.8	122.3	104.1	83.6	40.4	18.8	26.0	100.7	120.3	116.8
--GARRISON--																	
NAT INFLOW	11001	469	219	282	853	1423	2958	2066	581	497	454	192	89	102	253	237	326
DEPLETION	1181	-6	-3	-4	-7	204	825	564	35	-135	28	-84	-39	-45	-72	-55	-25
CHAN STOR	-10	59	10		-39	-10	-19			13	22			-17	0	-20	-10
EVAPORATION	552						34	108	134	115	51	24	27	58			
REG INFLOW	16668	713	301	375	1357	1824	2828	2206	1176	1142	841	470	219	262	882	1010	1063
RELEASE	17490	506	236	303	1250	1599	1666	1691	1660	1457	1505	728	305	317	1230	1537	1500
STOR CHANGE	-823	207	65	71	107	225	1161	515	-484	-315	-664	-258	-86	-56	-348	-527	-436
STORAGE	18930	19138	19203	19274	19381	19606	20768	21282	20798	20483	19819	19561	19475	19419	19071	18544	18107
ELEV FTMSL	1840.1	1840.7	1840.9	1841.2	1841.5	1842.2	1845.6	1847.1	1845.7	1844.8	1842.8	1842.0	1841.8	1841.6	1840.5	1838.9	1837.5
DISCH KCFS	23.0	17.0	17.0	17.0	21.0	26.0	28.0	27.5	27.0	24.5	24.5	24.5	22.0	20.0	20.0	25.0	27.0
POWER																	
AVE POWER MW		215	215	216	266	330	355	354	348	316	314	312	280	254	253	315	333
PEAK POW MW		386	387	389	392	398	400	401	400	400	399	398	396	394	386	381	377
ENERGY GWH	2691.1	77.4	36.2	46.6	191.7	245.3	255.5	263.5	259.3	227.7	233.5	112.2	47.0	48.8	188.5	234.2	223.8
--OAHE--																	
NAT INFLOW	2300	317	148	190	364	236	689	162	33	118	14	5	2	3	-20		40
DEPLETION	613	23	11	14	47	66	129	151	100	25	-8	2	1	1	11	16	26
CHAN STOR	-15	25			-16	-20	-8	2	2	10			10	8	0	-20	-8
EVAPORATION	501						31	96	119	104	47	22	25	55			
REG INFLOW	18661	824	373	480	1550	1749	2218	1673	1499	1440	1423	684	295	302	1144	1501	1506
RELEASE	16642	474	212	386	1334	1603	1666	1958	1970	1756	1261	598	276	259	1130	1047	711
STOR CHANGE	2019	350	161	93	217	146	552	-285	-471	-316	162	87	19	43	13	454	794
STORAGE	17772	18122	18283	18377	18593	18739	19291	19006	18535	18219	18381	18468	18487	18530	18543	18997	19791
ELEV FTMSL	1604.0	1605.2	1605.7	1606.0	1606.7	1607.2	1609.0	1608.1	1606.5	1605.5	1606.0	1606.3	1606.4	1606.5	1606.6	1608.0	1610.5
DISCH KCFS	11.6	15.9	15.3	21.6	22.4	26.1	28.0	31.8	32.0	29.5	20.5	20.1	19.9	16.3	18.4	17.0	12.8
POWER																	
AVE POWER MW		202	195	276	287	334	361	411	411	376	262	257	255	209	236	219	167
PEAK POW MW		693	695	697	701	703	713	708	700	694	697	699	699	700	700	708	721
ENERGY GWH	2583.9	72.9	32.8	59.7	206.6	248.8	259.9	305.7	305.6	270.8	194.8	92.6	42.8	40.2	175.4	163.3	112.2
--BIG BEND--																	
EVAPORATION	103						6	20	25	22	10	5	5	11			
REG INFLOW	16539	474	212	386	1334	1603	1666	1952	1950	1731	1240	588	271	254	1119	1047	711
RELEASE	16539	474	212	386	1334	1603	1666	1952	1950	1731	1240	588	271	254	1119	1047	711
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	11.6	15.9	15.3	21.6	22.4	26.1	28.0	31.7	31.7	29.1	20.2	19.8	19.5	16.0	18.2	17.0	12.8
POWER																	
AVE POWER MW		75	72	101	105	122	131	149	148	138	99	99	98	81	90	83	61
PEAK POW MW		515	510	509	509	509	509	509	509	517	538	538	538	538	538	537	529
ENERGY GWH	952.8	27.1	12.0	21.9	75.6	90.8	94.3	110.5	110.4	99.3	73.5	35.7	16.5	15.5	66.9	61.5	41.3
--FORT RANDALL--																	
NAT INFLOW	900	122	57	73	115	140	185	74	57	42	2	2	1	1	10		19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	118						8	25	31	25	10	4	4	10			
REG INFLOW	17241	595	269	459	1445	1734	1839	2000	1967	1735	1216	579	268	250	1115	1044	727
RELEASE	17241	263	192	442	1445	1734	1839	2000	1967	1879	1853	883	413	272	749	733	577
STOR CHANGE	0	332	76	17			0	0	0	-144	-637	-304	-145	-22	366	311	150
STORAGE	3124	3456	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2974	3124
ELEV FTMSL	1350.0	1354.1	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1348.0	1350.0
DISCH KCFS	9.2	8.9	13.9	24.8	24.3	28.2	30.9	32.5	32.0	31.6	30.1	29.7	29.7	17.1	12.2	11.9	10.4
POWER																	
AVE POWER MW		73	116	207	204	236	258	272	267	262	240	223	216	124	91	93	84
PEAK POW MW		348	351	352	352	352	352	352	352	345	310	289	278	276	303	324	331
ENERGY GWH	1700.8	26.3	19.6	44.8	146.7	175.7	186.0	202.1	198.8	188.7	178.5	80.3	36.3	23.8	67.7	69.4	56.2
--GAVINS POINT--																	
NAT INFLOW	1450	92	43	55	148	174	166	86	103	77	122	50	23	27	77	79	127
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-3	1	-10	-21	1	-8	-5	-3	1	1	3	1	0	24	9	0	3
EVAPORATION	37						2	7	9	8	4	2	2	4			
REG INFLOW	18537	357	226	477	1589	1882	1976	2041	2054	1953	1968	925	432	317	822	812	707
RELEASE	18537	357	226	477	1589	1882	1976	2041	2041	1940	1968	925	432	317	822	812	733
STOR CHANGE							13	13									-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0				

	28 FEB02		2002				2003										
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	6556	264	123	158	574	1011	1589	692	287	275	354	183	85	98	322	231	309
DEPLETION	356	-8	-4	-5	69	302	484	159	-69	-129	-64	-32	-15	-17	-109	-124	-83
EVAPORATION	497							30	95	119	104	47	22	25	54		
MOD INFLOW	5703	272	127	163	505	709	1105	503	261	285	314	167	78	89	377	355	392
RELEASE	5587	134	62	80	417	461	506	523	523	320	269	130	62	143	615	676	666
STOR CHANGE	115	139	65	83	88	248	599	-20	-262	-35	45	37	16	-54	-238	-321	-274
STORAGE	12136	12274	12339	12422	12511	12758	13358	13338	13076	13041	13086	13123	13139	13085	12847	12526	12251
ELEV FTMSL	2219.2	2219.9	2220.3	2220.7	2221.2	2222.6	2225.8	2225.7	2224.3	2224.1	2224.4	2224.6	2224.7	2224.4	2223.1	2221.3	2219.8
DISCH KCFS	11.0	4.5	4.5	4.5	7.0	7.5	8.5	8.5	8.5	5.4	4.4	4.4	4.5	9.0	10.0	11.0	12.0
POWER																	
AVE POWER MW		58	58	58	91	98	112	113	112	71	58	58	59	119	131	143	155
PEAK POW MW		196	196	197	197	199	202	202	200	200	200	201	201	200	199	197	196
ENERGY GWH	885.0	20.9	9.8	12.6	65.4	72.7	80.5	83.7	83.5	51.1	42.9	20.8	10.0	22.8	97.6	106.5	104.1
--GARRISON--																	
NAT INFLOW	10069	475	221	285	763	1282	2701	1891	532	446	428	175	82	93	238	177	280
DEPLETION	1136	28	13	17	50	187	744	477	52	-94	40	-84	-39	-45	-89	-74	-47
CHAN STOR	-10	68			-26	-5	-10	0		32	10	0	-1	-46	-10	-10	-10
EVAPORATION	580							35	112	140	122	55	25	29	62		
REG INFLOW	13930	649	271	349	1104	1551	2452	1901	891	752	545	334	156	206	869	917	983
RELEASE	13790	476	222	286	1071	1230	1309	1322	1291	952	888	430	207	301	1230	1353	1222
STOR CHANGE	140	173	49	63	32	321	1143	579	-401	-200	-342	-96	-51	-96	-360	-436	-239
STORAGE	14628	14801	14850	14913	14945	15266	16410	16989	16588	16388	16046	15950	15899	15803	15443	15007	14768
ELEV FTMSL	1825.3	1825.9	1826.1	1826.3	1826.5	1827.6	1831.7	1833.8	1832.4	1831.7	1830.5	1830.1	1829.9	1829.6	1828.3	1826.7	1825.8
DISCH KCFS	23.0	16.0	16.0	16.0	18.0	20.0	22.0	21.5	21.0	16.0	14.4	14.4	14.9	19.0	20.0	22.0	22.0
POWER																	
AVE POWER MW		185	186	186	209	233	260	260	254	193	173	172	178	225	236	257	255
PEAK POW MW		343	344	344	345	348	360	366	362	360	356	355	355	354	350	345	343
ENERGY GWH	1971.8	66.6	31.2	40.1	150.5	173.3	187.5	193.2	189.1	138.9	128.9	62.1	29.9	43.3	175.5	190.9	171.0
--OAHE--																	
NAT INFLOW	1761	187	87	112	278	158	701	124	29	79	11				-42	-7	44
DEPLETION	557	22	10	13	45	61	117	134	87	22	-7	2	1	1	11	15	24
CHAN STOR	4	32			-9	-9	-9	2	2	23	7	0	-2	-19	-5	-9	0
EVAPORATION	516							33	101	124	106	48	23	26	57		
REG INFLOW	14482	673	299	385	1295	1318	1884	1282	1135	908	807	380	182	256	1116	1321	1242
RELEASE	14338	443	268	377	1294	1517	1407	1706	1700	1519	1008	242	18	115	1073	945	706
STOR CHANGE	144	230	31	8	1	-199	477	-425	-565	-611	-201	138	164	141	43	376	536
STORAGE	15265	15495	15526	15534	15535	15336	15813	15388	14822	14211	14011	14149	14313	14453	14496	14873	15408
ELEV FTMSL	1595.0	1595.9	1596.0	1596.0	1596.0	1595.3	1597.1	1595.5	1593.3	1590.8	1590.0	1590.6	1591.2	1591.8	1592.0	1593.5	1595.5
DISCH KCFS	12.9	14.9	19.3	21.1	21.8	24.7	23.6	27.8	27.7	25.5	16.4	8.1	1.3	7.3	17.4	15.4	12.7
POWER																	
AVE POWER MW		180	233	255	263	297	286	335	331	302	192	96	15	86	206	183	153
PEAK POW MW		645	646	646	646	642	651	643	632	620	616	619	622	625	626	633	643
ENERGY GWH	2077.3	64.7	39.2	55.2	189.4	221.3	205.9	249.5	246.0	217.2	143.2	34.4	2.5	16.5	153.6	136.0	102.7
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	14210	443	268	377	1294	1517	1407	1699	1676	1489	981	230	12	109	1058	945	706
RELEASE	14210	443	268	377	1294	1517	1407	1699	1676	1489	981	230	12	109	1058	945	706
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	12.9	14.9	19.3	21.1	21.8	24.7	23.6	27.6	27.3	25.0	16.0	7.7	0.9	6.8	17.2	15.4	12.7
POWER																	
AVE POWER MW		70	90	99	102	115	111	129	128	119	78	39	4	35	85	74	61
PEAK POW MW		517	510	509	509	509	509	509	509	517	538	538	538	538	538	536	526
ENERGY GWH	816.4	25.4	15.2	21.4	73.3	85.9	79.7	96.2	94.9	85.4	58.3	14.1	0.7	6.7	63.0	55.4	40.8
--FORT RANDALL--																	
NAT INFLOW	643	88	41	53	82	66	167	33	63	30	2				6	-6	19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	148							10	32	39	31	12	5	6	13		
REG INFLOW	14624	529	308	429	1372	1574	1562	1704	1692	1472	951	217	6	102	1048	936	722
RELEASE	14561	256	173	412	1372	1574	1562	1704	1692	1617	1588	521	86	124	683	664	533
STOR CHANGE	63	273	135	17				0	0	-144	-638	-304	-80	-22	366	272	189
STORAGE	3124	3397	3532	3549	3549	3549	3549	3549	3549	3404	2767	2462	2383	2361	2726	2998	3187
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1339.0	1338.6	1344.5	1348.3	1350.8
DISCH KCFS	9.7	8.6	12.4	23.1	23.1	25.6	26.3	27.7	27.5	27.2	25.8	17.5	6.2	7.8	11.1	10.8	9.6
POWER																	
AVE POWER MW		71	104	193	194	215	220	232	231	226	206	133	46	58	84	85	78
PEAK POW MW		345	351	352	352	352	352	352	352	345	310	288	282	281	308	325	335
ENERGY GWH	1446.8	25.5	17.5	41.8	139.4	159.7	158.4	172.6	171.5	162.7	153.4	47.8	7.7	11.1	62.3	63.2	52.2
--GAVINS POINT--																	
NAT INFLOW	1335	98	46	59	132	147	153	87	85	62	112	50	23	27	75	73	107
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-7	-20	0	-5	-1	-3	0	1	3	16	21	-3	-6	1	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15735	356	211	450	1499	1697	1690	1746	1759	1673	1691	577	126	143	736	737	642
RELEASE	15735	356	211	450	1499	1697	1690	1746	1746	1660	1691	577	126	143	736	737	668
STOR CHANGE								13	13								-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0
DISCH KCFS	12.0	12.0	15.2	25.2	25.2												

	2003			2004													
	28 FEB03 INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB
--FORT PECK--																	
NAT INFLOW	6613	267	124	160	579	1019	1603	698	289	278	357	185	86	98	325	233	312
DEPLETION	365	-21	-10	-13	44	302	540	167	-65	-130	-66	-31	-14	-17	-108	-122	-91
EVAPORATION	499							30	95	119	105	47	22	25	55		
MOD INFLOW	5749	288	134	173	535	717	1063	501	259	289	318	168	78	90	378	355	403
RELEASE	5602	134	62	80	357	430	595	584	553	305	256	124	69	127	615	676	633
STOR CHANGE	146	154	72	92	178	287	468	-84	-295	-17	62	44	9	-37	-236	-321	-230
STORAGE	12251	12405	12477	12570	12748	13034	13502	13419	13124	13107	13170	13214	13223	13185	12949	12627	12398
ELEV FTMSL	2219.8	2220.7	2221.1	2221.6	2222.5	2224.1	2226.6	2226.1	2224.6	2224.5	2224.8	2225.1	2225.1	2224.9	2223.6	2221.9	2220.6
DISCH KCFS	12.0	4.5	4.5	4.5	6.0	7.0	10.0	9.5	9.0	5.1	4.2	4.2	5.0	8.0	10.0	11.0	11.0
POWER																	
AVE POWER MW		58	59	59	78	92	132	126	119	68	55	55	66	106	131	144	143
PEAK POW MW		197	197	198	199	200	203	202	201	201	201	201	201	201	200	198	197
ENERGY GWH	890.4	21.0	9.8	12.7	56.4	68.3	95.1	93.7	88.5	48.8	41.0	19.9	11.1	20.3	97.8	106.8	99.2
--GARRISON--																	
NAT INFLOW	10134	478	223	287	768	1290	2718	1903	535	449	431	176	82	94	240	178	282
DEPLETION	1004	2	1	1	6	204	722	477	57	-97	36	-89	-41	-47	-94	-78	-57
CHAN STOR	11	78			-16	-10	-31	5	5	39	10		-9	-31	-20	-10	
EVAPORATION	587							36	114	142	123	55	26	29	63		
REG INFLOW	14156	688	284	366	1103	1506	2560	1979	923	749	538	333	159	208	865	922	972
RELEASE	13976	476	194	250	1012	1230	1369	1383	1353	980	886	429	208	301	1230	1353	1323
STOR CHANGE	180	212	90	116	92	276	1192	596	-430	-231	-348	-95	-50	-93	-364	-431	-351
STORAGE	14768	14980	15070	15186	15278	15554	16746	17342	16912	16681	16333	16238	16188	16095	15731	15300	14949
ELEV FTMSL	1825.8	1826.6	1826.9	1827.3	1827.7	1828.7	1832.9	1834.9	1833.5	1832.7	1831.5	1831.1	1831.0	1830.6	1829.3	1827.8	1826.5
DISCH KCFS	22.0	16.0	14.0	14.0	17.0	20.0	23.0	22.5	22.0	16.5	14.4	14.4	15.0	19.0	20.0	22.0	23.0
POWER																	
AVE POWER MW		186	163	164	199	235	274	274	268	200	174	173	180	227	237	258	267
PEAK POW MW		345	346	347	348	351	364	370	365	363	359	358	358	357	353	348	345
ENERGY GWH	2012.3	66.9	27.4	35.4	143.3	174.6	197.3	203.6	199.5	143.9	129.4	62.3	30.2	43.6	176.7	192.3	186.2
--OAHE--																	
NAT INFLOW	1794	190	89	114	283	161	714	127	30	80	11				-43	-7	45
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2		1	11	15	25
CHAN STOR	-5	27	9		-13	-13	-13	2	2	25	10		-3	-19	-5	-9	-5
EVAPORATION	519							33	101	124	107	48	23	26	57		
REG INFLOW	14676	671	282	351	1236	1315	1949	1342	1194	937	807	379	182	256	1114	1321	1338
RELEASE	14492	398	250	383	1315	1540	1432	1736	1728	1548	1039	250	17	115	1072	946	724
STOR CHANGE	184	273	32	-32	-79	-224	517	-394	-534	-611	-232	129	165	141	43	375	614
STORAGE	15408	15682	15714	15682	15603	15379	15896	15502	14968	14357	14125	14254	14419	14560	14603	14978	15593
ELEV FTMSL	1595.5	1596.6	1596.7	1596.6	1596.3	1595.4	1597.4	1595.9	1593.8	1591.4	1590.5	1591.0	1591.7	1592.2	1592.4	1593.9	1596.2
DISCH KCFS	12.7	13.4	18.0	21.4	22.1	25.0	24.1	28.2	28.1	26.0	16.9	8.4	1.2	7.2	17.4	15.4	12.6
POWER																	
AVE POWER MW		162	218	260	268	302	291	342	337	308	199	99	14	86	207	183	152
PEAK POW MW		648	649	648	647	643	652	645	635	623	618	621	624	627	628	635	647
ENERGY GWH	2104.3	58.4	36.7	56.2	192.8	224.8	209.8	254.3	250.7	222.0	148.0	35.7	2.4	16.5	153.8	136.5	105.7
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	14363	398	250	383	1315	1540	1432	1728	1703	1517	1012	238	11	108	1057	946	724
RELEASE	14363	398	250	383	1315	1540	1432	1728	1703	1517	1012	238	11	108	1057	946	724
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	12.7	13.4	18.0	21.4	22.1	25.0	24.1	28.1	27.7	25.5	16.5	8.0	0.8	6.8	17.2	15.4	12.6
POWER																	
AVE POWER MW		63	84	100	103	117	113	132	130	121	81	40	4	35	85	75	60
PEAK POW MW		517	510	509	509	509	509	509	509	517	538	538	538	538	538	536	526
ENERGY GWH	825.2	22.8	14.2	21.7	74.5	87.2	81.1	97.9	96.5	87.0	60.1	14.6	0.7	6.7	63.0	55.5	41.9
--FORT RANDALL--																	
NAT INFLOW	659	90	42	54	84	67	171	34	65	31	2				7	-7	20
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	148							10	32	39	31	12	5	6	13		
REG INFLOW	14794	486	291	436	1395	1598	1591	1734	1722	1502	982	225	5	102	1048	936	741
RELEASE	14794	256	176	419	1395	1598	1591	1734	1722	1646	1619	529	86	124	683	664	552
STOR CHANGE	-1	230	115	17				0	0	-144	-638	-304	-80	-22	366	272	189
STORAGE	3187	3417	3532	3549	3549	3549	3549	3549	3549	3404	2767	2462	2382	2360	2725	2997	3186
ELEV FTMSL	1350.8	1353.6	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1339.0	1338.6	1344.5	1348.3	1350.8
DISCH KCFS	9.6	8.6	12.7	23.5	23.4	26.0	26.7	28.2	28.0	27.7	26.3	17.8	6.2	7.8	11.1	10.8	9.6
POWER																	
AVE POWER MW		71	107	197	197	218	224	236	234	230	210	135	46	58	84	85	78
PEAK POW MW		346	351	352	352	352	352	352	352	345	310	288	282	281	308	325	335
ENERGY GWH	1470.0	25.6	17.9	42.5	141.7	162.0	161.3	175.7	174.5	165.7	156.3	48.5	7.7	11.1	62.2	63.2	54.1
--GAVINS POINT--																	
NAT INFLOW	1342	98	46	59	133	148	154	87	86	62	112	51	24	27	75	73	108
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-8	-21	0	-5	-1	-3	0	1	3	16	22	-3	-6	1	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15975	357	214	457	1523	1722	1720	1777	1790	1703	1722	586	127	143	736	737	662
RELEASE	15975	357	214	457	1523	1722	1720	1777	1777	1690	1722	586	127	143	736	737	688
STOR CHANGE								13	13								-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0
DISCH KCFS	12.0	12.0	15.4	25.6	25.6	28.0	28.9	28.9	28.9	28.4	28.0	19.7	9.1	9.0	12.0	12.0	12.0
POWER																	
AVE POWER MW		42	54	88	88	95	98	98	99	98	97	69	33	32	43	43	42
PEAK POW MW		114	114	114	114	114	114	114	115	115	115	115	115	115	77	77	76
ENERGY GWH	667.1	15.1	9.0	18.9	63.1	71.0	70.7	73.1	73.4	70.7	72.4	25.0	5.5	6.2	31.8	31.8	29.4
--GAVINS POINT - SIOUX CITY--																	
NAT INFLOW	1160	149	69	89	116	224	161	97	72	45	31	16	7	9	17	-3	61
DEPLETION	241	6	3	3	20	34	29	36	33	22	9	5	2	3	11	12	13
REGULATED FLOW AT SIOUX CITY																	
KAF	16894		281	543	1619	1912	1852	1838	1816	1713	1744	597	132	149	742	722	736
KCFS	16.8	20.2	30.4	27.2	31.1	31.1	29.9										

	28 FEB05		2005				NAVIGATION SEASON SHORTENED AT 52 MAF ON JULY 1										2006	
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB	
--FORT PECK--																		
NAT INFLOW	6751	272	127	163	591	1041	1636	712	295	284	365	188	88	100	332	238	318	
DEPLETION	388	-21	-10	-13	44	304	549	181	-57	-131	-70	-34	-16	-18	-112	-125	-84	
EVAPORATION	503						31	96	120	105	48	22	25	55				
MOD INFLOW	5860	294	137	176	547	737	1087	500	256	295	330	174	81	93	389	363	402	
RELEASE	5800	134	62	80	357	553	595	584	553	337	283	137	64	127	615	707	611	
STOR CHANGE	60	160	75	96	190	184	492	-84	-298	-42	47	37	17	-34	-226	-344	-209	
STORAGE	12460	12620	12695	12791	12981	13164	13656	13572	13275	13233	13279	13316	13334	13299	13073	12729	12520	
ELEV FTMSL	2221.0	2221.8	2222.3	2222.8	2223.8	2224.8	2227.4	2226.9	2225.4	2225.2	2225.4	2225.6	2225.7	2225.5	2224.3	2222.4	2221.3	
DISCH KCFS	11.0	4.5	4.5	4.5	6.0	9.0	10.0	9.5	9.0	5.7	4.6	4.6	4.6	8.0	10.0	11.5	11.0	
POWER																		
AVE POWER MW		59	59	59	79	118	132	126	119	75	61	61	61	106	132	150	143	
PEAK POW MW		198	198	199	200	201	203	203	202	201	202	202	202	202	200	198	197	
ENERGY GWH	924.6	21.1	9.9	12.7	56.7	88.1	95.4	94.0	88.8	54.0	45.3	22.0	10.3	20.3	98.1	111.9	96.1	
--GARRISON--																		
NAT INFLOW	10290	485	226	291	779	1310	2760	1932	543	456	438	179	84	95	243	181	287	
DEPLETION	899	1	0	1	3	178	717	483	63	-103	26	-102	-48	-54	-110	-92	-64	
CHAN STOR	0	68			-15	-31	-10	5	5	34	11	0		-35	-20	-15	5	
EVAPORATION	591						36	115	143	123	55	26	29	63				
REG INFLOW	14600	686	288	371	1118	1654	2628	2002	923	787	582	362	169	213	884	965	967	
RELEASE	14542	446	194	250	1012	1322	1428	1445	1476	1071	935	452	278	317	1230	1353	1333	
STOR CHANGE	58	240	94	121	106	332	1200	557	-552	-284	-353	-90	-108	-105	-346	-388	-366	
STORAGE	15026	15266	15360	15481	15587	15919	17119	17676	17124	16839	16487	16397	16288	16184	15838	15450	15084	
ELEV FTMSL	1826.8	1827.6	1828.0	1828.4	1828.8	1830.0	1834.2	1836.1	1834.2	1833.2	1832.0	1831.7	1831.3	1830.9	1829.7	1828.3	1827.0	
DISCH KCFS	24.0	15.0	14.0	14.0	17.0	21.5	24.0	23.5	24.0	18.0	15.2	15.2	20.0	20.0	22.0	24.0		
POWER																		
AVE POWER MW		175	165	165	200	254	288	288	294	219	184	183	240	239	238	259	280	
PEAK POW MW		348	349	350	352	355	367	373	367	364	361	360	359	358	354	350	346	
ENERGY GWH	2105.0	63.2	27.6	35.6	144.3	189.0	207.5	214.1	218.6	157.8	137.0	66.0	40.3	45.9	177.1	192.9	188.1	
--OAH--																		
NAT INFLOW	1877	199	93	119	297	168	747	132	31	84	12				-45	-7	47	
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25	
CHAN STOR	-1	40	4		-13	-20	-11	2	-2	27	13		-22	0	0	-9	-9	
EVAPORATION	528						33	103	127	109	49	23	26	57				
REG INFLOW	15293	663	281	356	1249	1405	2038	1399	1305	1031	859	402	232	290	1117	1321	1346	
RELEASE	15236	436	272	388	1338	1564	1456	1770	1761	1582	1074	471	218	195	1065	946	699	
STOR CHANGE	57	227	9	-32	-89	-159	582	-371	-456	-551	-215	-69	14	95	51	374	647	
STORAGE	15673	15901	15910	15878	15789	15630	16212	15840	15384	14833	14618	14549	14563	14658	14709	15083	15731	
ELEV FTMSL	1596.5	1597.4	1597.4	1597.3	1597.0	1596.4	1598.5	1597.2	1595.4	1593.3	1592.5	1592.2	1592.3	1592.6	1592.8	1594.3	1596.8	
DISCH KCFS	12.6	14.6	19.6	21.7	22.5	25.4	24.5	28.8	28.6	26.6	17.5	15.8	15.7	12.3	17.3	15.4	12.6	
POWER																		
AVE POWER MW		178	239	265	273	308	298	351	346	318	208	188	186	146	206	184	152	
PEAK POW MW		652	653	652	650	648	658	651	643	632	628	627	627	629	630	637	649	
ENERGY GWH	2223.8	64.2	40.1	57.2	196.9	229.4	214.5	261.0	257.5	229.1	154.6	67.6	31.3	28.1	153.3	136.8	102.2	
--BIG BEND--																		
EVAPORATION	129						8	24	31	27	12	6	7	14				
REG INFLOW	15107	436	272	388	1338	1564	1456	1762	1737	1551	1047	459	212	189	1051	946	699	
RELEASE	15107	436	272	388	1338	1564	1456	1762	1737	1551	1047	459	212	189	1051	946	699	
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	
DISCH KCFS	12.6	14.6	19.6	21.7	22.5	25.4	24.5	28.7	28.2	26.1	17.0	15.4	15.3	11.9	17.1	15.4	12.6	
POWER																		
AVE POWER MW		69	92	102	105	119	115	134	132	124	84	78	77	60	85	75	60	
PEAK POW MW		517	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529	
ENERGY GWH	870.2	25.0	15.4	22.0	75.8	88.6	82.5	99.8	98.3	89.0	62.2	27.9	12.9	11.6	62.9	55.7	40.6	
--FORT RANDALL--																		
NAT INFLOW	696	95	44	57	89	71	181	36	68	32	2				7	-7	21	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3	
EVAPORATION	147						10	32	39	31	12	5	5	13				
REG INFLOW	15576	529	316	444	1423	1626	1625	1770	1758	1537	1017	446	207	183	1042	936	717	
RELEASE	15576	256	180	427	1423	1626	1625	1770	1758	1681	1654	750	352	205	676	664	528	
STOR CHANGE	0	273	135	17			0	0	-144	-637	-304	-145	-22	366	272	189		
STORAGE	3124	3397	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2935	3124	
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1347.4	1350.0	
DISCH KCFS	9.5	8.6	13.0	23.9	23.9	26.4	27.3	28.8	28.6	28.3	26.9	25.2	25.3	12.9	11.0	10.8	9.5	
POWER																		
AVE POWER MW		71	109	201	201	222	229	241	239	235	215	190	185	94	82	84	76	
PEAK POW MW		345	351	352	352	352	352	352	352	345	310	288	277	276	303	321	331	
ENERGY GWH	1539.9	25.5	18.3	43.3	144.5	164.9	164.7	179.3	178.0	169.1	159.6	68.4	31.0	18.1	61.1	62.7	51.3	
--GAVINS POINT--																		
NAT INFLOW	1362	100	47	60	135	150	156	88	87	63	114	51	24	27	76	75	110	
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1		
CHAN STOR	-1	2	-8	-21	0	-5	-2	-3	0	1	3	3	0	23	4	0	2	
EVAPORATION	47						3	9	11	10	5	2	2	5				
REG INFLOW	16777	358	219	466	1553	1752	1755	1814	1827	1739	1759	794	371	251	741	738	640	
RELEASE	16777	358	219	466	1553	1752	1755	1814	1814	1726	1759	794	371	251	741	738	666	
STOR CHANGE							13	13									-26	
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358	
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	
DISCH KCFS	12.0																	

	28 FEB02	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	6556	264	123	158	574	1011	1589	692	287	275	354	183	85	98	322	231	309
DEPLETION	356	-8	-4	-5	69	302	484	159	-69	-129	-64	-32	-15	-17	-109	-124	-83
EVAPORATION	494							30	94	118	103	47	22	25	54		
MOD INFLOW	5706	272	127	163	505	709	1105	503	262	286	315	168	78	89	377	355	392
RELEASE	5721	134	62	80	417	492	536	553	553	326	273	132	62	143	615	676	666
STOR CHANGE	-15	139	65	83	88	217	569	-51	-292	-40	41	35	16	-53	-238	-321	-274
STORAGE	12136	12274	12339	12422	12511	12728	13297	13247	12955	12915	12956	12991	13008	12954	12717	12395	12121
ELEV FTMSL	2219.2	2219.9	2220.3	2220.7	2221.2	2222.4	2225.5	2225.2	2223.7	2223.5	2223.7	2223.9	2224.0	2223.7	2222.4	2220.6	2219.1
DISCH KCFS	11.0	4.5	4.5	4.5	7.0	8.0	9.0	9.0	9.0	5.5	4.4	4.4	4.4	9.0	10.0	11.0	12.0
POWER																	
AVE POWER MW		58	58	58	91	104	118	119	118	72	59	59	59	118	131	143	154
PEAK POW MW		196	196	197	197	198	202	201	200	200	200	200	200	200	198	197	195
ENERGY GWH	904.3	20.9	9.8	12.6	65.4	77.5	85.1	88.5	88.1	51.8	43.5	21.1	9.8	22.7	97.3	106.2	103.8
--GARRISON--																	
NAT INFLOW	10069	475	221	285	763	1282	2701	1891	532	446	428	175	82	93	238	177	280
DEPLETION	1136	28	13	17	50	187	744	477	52	-94	40	-84	-39	-45	-89	-74	-47
CHAN STOR	-10	68			-26	-10	-10			36	10	0	0	-47	-10	-10	-10
EVAPORATION	577							35	111	139	121	54	25	29	62		
REG INFLOW	14067	649	271	349	1104	1576	2482	1932	922	762	551	337	157	205	870	917	983
RELEASE	14086	476	222	286	1131	1291	1369	1383	1353	1012	821	397	185	301	1230	1353	1277
STOR CHANGE	-19	173	49	63	-27	285	1114	549	-431	-249	-269	-61	-28	-96	-360	-436	-294
STORAGE	14628	14801	14850	14913	14886	15171	16284	16833	16402	16153	15884	15823	15795	15699	15339	14903	14609
ELEV FTMSL	1825.3	1825.9	1826.1	1826.3	1826.2	1827.3	1831.3	1833.2	1831.7	1830.8	1829.9	1829.7	1829.6	1829.2	1827.9	1826.3	1825.2
DISCH KCFS	23.0	16.0	16.0	16.0	19.0	21.0	23.0	22.5	22.0	17.0	13.3	13.3	13.3	19.0	20.0	22.0	23.0
POWER																	
AVE POWER MW		185	186	186	220	244	271	271	265	204	160	159	159	225	235	256	265
PEAK POW MW		343	344	344	344	347	359	364	360	357	355	354	354	353	349	344	341
ENERGY GWH	2008.1	66.6	31.2	40.1	158.6	181.5	195.4	201.4	197.2	146.8	118.7	57.2	26.7	43.2	175.0	190.5	178.1
--OAHE--																	
NAT INFLOW	1761	187	87	112	278	158	701	124	29	79	11				-42	-7	44
DEPLETION	557	22	10	13	45	61	117	134	87	22	-7		1	1	11	15	24
CHAN STOR	-1	32			-13	-9	-9		2	23	17	0	0	-27	-5	-9	-5
EVAPORATION	521							33	102	126	108	48	22	26	56		
REG INFLOW	14769	673	299	385	1350	1379	1944	1343	1195	966	748	347	162	248	1116	1321	1293
RELEASE	14789	443	268	377	1294	1517	1407	1706	1701	1520	1008	439	203	188	1066	945	706
STOR CHANGE	-20	230	31	8	56	-138	536	-364	-506	-554	-261	-92	-41	60	50	376	587
STORAGE	15265	15495	15526	15534	15590	15452	15989	15625	15119	14565	14305	14213	14172	14232	14282	14658	15245
ELEV FTMSL	1595.0	1595.9	1596.0	1596.0	1596.2	1595.7	1597.7	1596.4	1594.4	1592.3	1591.2	1590.8	1590.7	1590.9	1591.1	1592.6	1594.9
DISCH KCFS	12.9	14.9	19.3	21.1	21.8	24.7	23.6	27.8	27.7	25.5	16.4	14.8	14.6	11.9	17.3	15.4	12.7
POWER																	
AVE POWER MW		180	233	255	263	298	287	337	333	304	194	174	172	140	204	182	152
PEAK POW MW		645	646	646	647	644	654	647	638	627	622	620	619	621	622	629	640
ENERGY GWH	2145.9	64.7	39.2	55.2	189.5	221.7	206.5	250.5	247.5	218.8	144.3	62.6	28.9	26.8	152.0	135.4	102.3
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	14660	443	268	377	1294	1517	1407	1699	1676	1489	981	427	197	182	1052	945	706
RELEASE	14660	443	268	377	1294	1517	1407	1699	1676	1489	981	427	197	182	1052	945	706
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	12.9	14.9	19.3	21.1	21.8	24.7	23.6	27.6	27.3	25.0	16.0	14.3	14.2	11.4	17.1	15.4	12.7
POWER																	
AVE POWER MW		70	90	99	102	115	111	129	128	119	78	72	72	58	85	75	61
PEAK POW MW		517	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	844.5	25.4	15.2	21.4	73.3	85.9	79.7	96.2	94.9	85.4	58.3	26.0	12.0	11.1	62.9	55.7	41.0
--FORT RANDALL--																	
NAT INFLOW	643	88	41	53	82	66	167	33	63	30	2				6	-6	19
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	0	0	1	3	3	3
EVAPORATION	147							10	32	39	31	12	5	5	13		
REG INFLOW	15076	529	308	429	1372	1574	1562	1704	1692	1473	951	414	192	176	1042	936	722
RELEASE	15076	256	173	412	1372	1574	1562	1704	1692	1617	1588	718	337	198	676	664	533
STOR CHANGE	0	273	135	17			0	0	-144	-637	-304	-145	-22	366	272	189	
STORAGE	3124	3397	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2935	3124
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	9.7	8.6	12.4	23.1	23.1	25.6	26.3	27.7	27.5	27.2	25.8	24.1	24.3	12.5	11.0	10.8	9.6
POWER																	
AVE POWER MW		71	104	193	194	215	220	232	231	226	206	182	177	91	82	84	77
PEAK POW MW		345	351	352	352	352	352	352	352	345	310	288	277	276	303	321	331
ENERGY GWH	1491.0	25.5	17.5	41.8	139.4	159.7	158.4	172.6	171.5	162.7	153.4	65.5	29.8	17.4	61.1	62.7	51.8
--GAVINS POINT--																	
NAT INFLOW	1335	98	46	59	132	147	153	87	85	62	112	50	23	27	75	73	107
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-7	-20	0	-5	-1	-3	0	1	3	3	0	22	3	0	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	16250	356	211	450	1499	1697	1690	1746	1759	1673	1691	762	355	242	739	736	642
RELEASE	16250	356	211	450	1499	1697	1690	1746	1746	1660	1691	762	355	242	739	736	668
STOR CHANGE								13	13								-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	
DISCH KCFS	12.0	12.0	15.2	25.2	25.2	27.6	28.4	28.4	28.4	27.9	27.5</						

	28 FEB03		2003				2004										
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB
--FORT PECK--																	
NAT INFLOW	6613	267	124	160	579	1019	1603	698	289	278	357	185	86	98	325	233	312
DEPLETION	365	-21	-10	-13	44	302	540	167	-65	-130	-66	-31	-14	-17	-108	-122	-91
EVAPORATION	493							30	94	118	103	47	22	25	54		
MOD INFLOW	5755	288	134	173	535	717	1063	501	260	290	320	169	79	90	379	355	403
RELEASE	5713	134	62	80	417	492	595	584	523	318	267	129	60	127	615	676	633
STOR CHANGE	43	154	72	92	118	225	468	-83	-263	-28	53	39	18	-37	-236	-321	-230
STORAGE	12121	12275	12347	12439	12558	12783	13251	13167	12905	12877	12929	12969	12987	12950	12714	12393	12163
ELEV FTMSL	2219.1	2219.9	2220.3	2220.8	2221.5	2222.7	2225.3	2224.8	2223.4	2223.2	2223.5	2223.7	2223.8	2223.6	2222.4	2220.6	2219.3
DISCH KCFS	12.0	4.5	4.5	4.5	7.0	8.0	10.0	9.5	8.5	5.3	4.3	4.3	4.3	8.0	10.0	11.0	11.0
POWER																	
AVE POWER MW		58	58	58	91	104	131	125	112	70	57	57	57	105	131	143	142
PEAK POW MW		196	196	197	198	199	201	201	199	199	200	200	200	200	198	197	195
ENERGY GWH	902.9	20.9	9.8	12.6	65.5	77.6	94.5	93.2	83.1	50.6	42.5	20.6	9.6	20.2	97.3	106.2	98.7
--GARRISON--																	
NAT INFLOW	10134	478	223	287	768	1290	2718	1903	535	449	431	176	82	94	240	178	282
DEPLETION	1004	2	1	1	6	204	722	477	57	-97	36	-89	-41	-47	-94	-78	-57
CHAN STOR	10	78			-26	-10		5	10	32	10	0	0	-37	-21	-10	
EVAPORATION	582							36	113	141	122	55	25	29	62		
REG INFLOW	14271	688	284	366	1153	1568	2570	1980	898	756	550	339	158	202	866	922	972
RELEASE	14215	476	194	250	1012	1291	1398	1414	1383	994	899	435	203	301	1230	1353	1381
STOR CHANGE	56	212	90	116	141	276	1172	565	-486	-239	-349	-96	-45	-100	-364	-431	-409
STORAGE	14609	14821	14911	15027	15168	15444	16616	17181	16696	16457	16108	16012	15968	15868	15504	15073	14664
ELEV FTMSL	1825.2	1826.0	1826.3	1826.8	1827.3	1828.3	1832.5	1834.4	1832.7	1831.9	1830.7	1830.3	1830.2	1829.8	1828.5	1826.9	1825.4
DISCH KCFS	23.0	16.0	14.0	14.0	17.0	21.0	23.5	23.0	22.5	16.7	14.6	14.6	14.6	19.0	20.0	22.0	24.0
POWER																	
AVE POWER MW		185	163	163	198	246	279	279	273	202	176	175	175	226	236	257	277
PEAK POW MW		343	344	346	347	350	362	368	363	361	357	356	356	354	351	346	342
ENERGY GWH	2037.6	66.6	27.3	35.2	142.8	182.7	201.0	207.4	203.1	145.3	130.7	62.9	29.3	43.3	175.7	191.2	192.9
--QAHE--																	
NAT INFLOW	1794	190	89	114	283	161	714	127	30	80	11				-43	-7	45
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2	1	1	11	15	25
CHAN STOR	-5	32	9		-13	-18		2	2	26	10	0	0	-21	-5	-9	-9
EVAPORATION	518							33	101	125	107	48	22	26	56		
REG INFLOW	14916	676	282	351	1236	1372	1981	1373	1224	953	820	385	180	254	1115	1321	1391
RELEASE	14858	441	267	375	1291	1515	1414	1718	1710	1531	1021	445	205	189	1065	946	724
STOR CHANGE	58	235	15	-25	-55	-143	567	-345	-485	-578	-201	-59	-26	65	50	375	667
STORAGE	15245	15480	15495	15471	15415	15273	15839	15494	15009	14431	14230	14171	14145	14210	14260	14635	15302
ELEV FTMSL	1594.9	1595.8	1595.9	1595.8	1595.6	1595.0	1597.2	1595.9	1594.0	1591.7	1590.9	1590.7	1590.6	1590.8	1591.0	1592.5	1595.1
DISCH KCFS	12.7	14.8	19.2	21.0	21.7	24.6	23.8	27.9	27.8	25.7	16.6	14.9	14.8	11.9	17.3	15.4	12.6
POWER																	
AVE POWER MW		179	232	254	262	296	287	338	334	305	196	176	174	141	204	182	151
PEAK POW MW		645	645	645	644	641	651	645	636	625	621	619	619	620	621	629	641
ENERGY GWH	2151.2	64.4	39.0	54.9	188.6	220.6	206.9	251.5	248.2	219.8	145.7	63.3	29.2	27.0	151.7	135.5	105.0
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	14729	441	267	375	1291	1515	1414	1710	1685	1500	994	432	200	183	1051	946	724
RELEASE	14729	441	267	375	1291	1515	1414	1710	1685	1500	994	432	200	183	1051	946	724
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	12.7	14.8	19.2	21.0	21.7	24.6	23.8	27.8	27.4	25.2	16.2	14.5	14.4	11.5	17.1	15.4	12.6
POWER																	
AVE POWER MW		70	90	98	102	115	111	130	128	119	79	73	73	58	85	75	60
PEAK POW MW		517	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	848.5	25.3	15.1	21.3	73.2	85.8	80.1	96.8	95.4	86.0	59.1	26.3	12.2	11.2	62.9	55.7	42.1
--FORT RANDALL--																	
NAT INFLOW	659	90	42	54	84	67	171	34	65	31	2				7	-7	20
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	147							10	32	39	31	12	5	5	13		
REG INFLOW	15161	529	308	428	1371	1573	1573	1716	1704	1485	964	419	194	177	1042	936	741
RELEASE	15161	256	173	411	1371	1573	1573	1716	1704	1629	1601	723	339	199	676	664	552
STOR CHANGE	0	273	135	17			0	0	-144	-637	-304	-145	-22	366	272	189	
STORAGE	3124	3397	3532	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2935	3124	
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1345.1	1340.4	1337.9	1337.5	1343.5	1347.4	1350.0	
DISCH KCFS	9.6	8.6	12.4	23.0	23.0	25.6	26.4	27.9	27.7	27.4	26.0	24.3	24.4	12.6	11.0	10.8	9.6
POWER																	
AVE POWER MW		71	104	193	194	214	222	234	232	228	208	183	178	91	82	84	77
PEAK POW MW		345	351	352	352	352	352	352	352	345	310	288	277	276	303	321	331
ENERGY GWH	1499.3	25.5	17.5	41.7	139.3	159.6	159.5	173.9	172.6	163.9	154.6	66.0	30.0	17.5	61.1	62.7	53.7
--GAVINS POINT--																	
NAT INFLOW	1342	98	46	59	133	148	154	87	86	62	112	51	24	27	75	73	108
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-7	-20	0	-5	-2	-3	0	1	3	3	0	22	3	0	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	16342	357	211	450	1499	1697	1702	1759	1772	1685	1703	768	358	243	739	736	662
RELEASE	16342	357	211	450	1499	1697	1702	1759	1772	1685	1703	768	358	243	739	736	688
STOR CHANGE									13	13							-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0
DISCH KCFS	12.0																

	29 FEB04		2004				2005										
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	6720	271	126	163	588	1036	1629	709	294	282	363	188	88	100	330	237	317
DEPLETION	379	-21	-10	-13	44	303	545	174	-61	-130	-68	-33	-15	-17	-111	-125	-83
EVAPORATION	495							30	95	118	104	47	22	25	54		
MOD INFLOW	5846	292	136	175	544	733	1084	505	260	294	327	173	81	92	387	362	400
RELEASE	5713	134	62	80	357	553	595	584	553	314	263	127	59	127	615	676	611
STOR CHANGE	133	158	74	95	187	180	489	-79	-293	-20	64	45	21	-35	-228	-314	-211
STORAGE	12163	12322	12396	12491	12678	12857	13346	13267	12974	12954	13018	13063	13084	13049	12821	12507	12296
ELEV FTMSL	2219.3	2220.2	2220.6	2221.1	2222.2	2223.1	2225.8	2225.3	2223.8	2223.7	2224.0	2224.3	2224.4	2224.2	2222.9	2221.2	2220.1
DISCH KCFS	11.0	4.5	4.5	4.5	6.0	9.0	10.0	9.5	9.0	5.3	4.3	4.3	4.3	8.0	10.0	11.0	11.0
POWER																	
AVE POWER MW		58	58	59	78	118	132	126	119	69	56	57	57	105	131	143	142
PEAK POW MW		196	197	197	198	199	202	201	200	200	200	200	200	200	199	197	196
ENERGY GWH	905.1	21.0	9.8	12.6	56.3	87.4	94.7	93.5	88.2	50.0	42.0	20.4	9.5	20.2	97.5	106.5	95.6
--GARRISON--																	
NAT INFLOW	10262	484	226	290	777	1306	2752	1927	542	455	437	179	83	95	243	180	286
DEPLETION	939	1	0	1	3	178	707	467	63	-100	31	-93	-43	-49	-96	-79	-52
CHAN STOR	0	68			-16	-31	-10	5	5	38	10	0	0	-38	-20	-10	0
EVAPORATION	586							36	114	142	123	55	26	29	63		
REG INFLOW	14449	685	288	370	1115	1650	2630	2013	924	765	557	343	160	204	871	925	949
RELEASE	14291	446	194	250	1012	1291	1398	1414	1383	1071	889	430	278	317	1230	1353	1333
STOR CHANGE	159	239	93	120	104	359	1231	599	-460	-306	-332	-87	-117	-113	-359	-428	-384
STORAGE	14664	14903	14996	15116	15220	15579	16811	17410	16950	16644	16311	16224	16107	15994	15635	15207	14823
ELEV FTMSL	1825.4	1826.3	1826.6	1827.1	1827.5	1828.8	1833.1	1835.2	1833.6	1832.6	1831.4	1831.1	1830.7	1830.3	1829.0	1827.4	1826.0
DISCH KCFS	24.0	15.0	14.0	14.0	17.0	21.0	23.5	23.0	22.5	18.0	14.5	14.5	20.0	20.0	20.0	22.0	24.0
POWER																	
AVE POWER MW		174	163	163	199	246	280	280	274	218	175	174	239	238	237	258	278
PEAK POW MW		344	345	346	348	351	364	370	366	362	359	358	357	356	352	347	343
ENERGY GWH	2056.1	62.6	27.4	35.3	143.0	183.1	201.7	208.3	204.2	157.2	129.9	62.5	40.1	45.7	176.2	191.8	186.9
--OAHE--																	
NAT INFLOW	1860	197	92	118	294	167	740	131	31	83	12				-45	-7	46
DEPLETION	585	22	10	13	46	64	123	143	93	23	-8	2	1	1	11	16	25
CHAN STOR	-1	41	4		-13	-18	-11	2	2	20	16	0	-26	0	0	-9	-9
EVAPORATION	521							33	102	125	108	48	23	26	56		
REG INFLOW	15044	662	281	355	1246	1376	2004	1372	1222	1026	818	380	228	291	1117	1320	1345
RELEASE	14882	437	265	374	1291	1522	1417	1727	1718	1541	1031	450	208	191	1065	946	699
STOR CHANGE	162	226	15	-19	-45	-146	587	-355	-496	-514	-213	-70	20	100	52	374	646
STORAGE	15302	15528	15543	15525	15479	15333	15920	15564	15068	14554	14341	14271	14292	14392	14444	14818	15464
ELEV FTMSL	1595.1	1596.0	1596.1	1596.0	1595.8	1595.3	1597.5	1596.1	1594.2	1592.2	1591.4	1591.1	1591.2	1591.6	1591.8	1593.3	1595.8
DISCH KCFS	12.6	14.7	19.1	20.9	21.7	24.8	23.8	28.1	27.9	25.9	16.8	15.1	15.0	12.0	17.3	15.4	12.6
POWER																	
AVE POWER MW		177	231	253	262	298	288	340	336	308	198	178	177	142	205	183	151
PEAK POW MW		646	646	646	645	642	653	646	637	627	623	621	622	624	625	632	644
ENERGY GWH	2159.1	63.8	38.8	54.7	188.8	221.9	207.6	253.2	249.7	221.7	147.6	64.2	29.7	27.3	152.4	136.0	101.6
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	14753	437	265	374	1291	1522	1417	1719	1694	1510	1004	438	202	184	1051	946	699
RELEASE	14753	437	265	374	1291	1522	1417	1719	1694	1510	1004	438	202	184	1051	946	699
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	12.6	14.7	19.1	20.9	21.7	24.8	23.8	28.0	27.5	25.4	16.3	14.7	14.6	11.6	17.1	15.4	12.6
POWER																	
AVE POWER MW		69	90	98	102	116	112	131	129	120	80	74	73	59	85	75	60
PEAK POW MW		517	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	849.9	25.0	15.0	21.2	73.2	86.2	80.3	97.4	95.9	86.6	59.7	26.7	12.3	11.3	62.9	55.7	40.6
--FORT RANDALL--																	
NAT INFLOW	690	94	44	56	88	70	179	36	68	32	2				7	-7	21
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	0	0	1	3	3	3
EVAPORATION	147							10	32	39	31	12	5	5	13		
REG INFLOW	15217	529	308	429	1375	1583	1584	1727	1715	1495	974	425	197	178	1042	936	717
RELEASE	15217	529	308	429	1375	1583	1584	1727	1715	1495	974	425	197	178	1042	936	717
STOR CHANGE	0	273	135	17			0	0	0	-144	-637	-304	-145	-22	366	272	189
STORAGE	3124	3397	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2935	3124
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	9.6	8.6	12.5	23.1	23.1	25.8	26.6	28.1	27.9	27.6	26.2	24.5	24.6	12.6	11.0	10.8	9.5
POWER																	
AVE POWER MW		71	105	194	194	216	223	235	234	229	209	185	180	92	82	84	76
PEAK POW MW		345	351	352	352	352	352	352	352	345	310	288	277	276	303	321	331
ENERGY GWH	1504.7	25.5	17.6	41.8	139.7	160.6	160.6	175.0	173.8	165.0	155.5	66.5	30.2	17.6	61.1	62.7	51.3
--GAVINS POINT--																	
NAT INFLOW	1359	100	47	60	135	150	155	88	87	63	114	51	24	27	76	74	109
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-7	-20	0	-5	-2	-3	0	1	3	0	0	22	3	0	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	16414	358	212	452	1505	1709	1714	1771	1784	1697	1716	774	361	245	740	737	639
RELEASE	16414	358	212	452	1505	1709	1714	1771	1784	1697	1716	774	361	245	740	737	665
STOR CHANGE								13	13								-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.	

	2005				2006												
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	6751	272	127	163	591	1041	1636	712	295	284	365	188	88	100	332	238	318
DEPLETION	388	-21	-10	-13	44	304	549	181	-57	-131	-70	-34	-16	-18	-112	-125	-84
EVAPORATION	499							30	95	119	104	47	22	25	55		
MOD INFLOW	5864	294	137	176	547	737	1087	501	257	296	331	174	81	93	389	363	402
RELEASE	5752	134	62	80	357	553	595	584	553	330	277	134	63	127	615	676	611
STOR CHANGE	112	160	75	96	190	184	492	-84	-297	-34	54	40	19	-34	-225	-313	-209
STORAGE	12296	12456	12531	12626	12816	13000	13492	13408	13112	13078	13131	13171	13190	13156	12930	12617	12408
ELEV FTMSL	2220.1	2220.9	2221.3	2221.9	2222.9	2223.9	2226.5	2226.1	2224.5	2224.3	2224.6	2224.8	2224.9	2224.7	2223.5	2221.8	2220.7
DISCH KCFS	11.0	4.5	4.5	4.5	6.0	9.0	10.0	9.5	9.0	5.5	4.5	4.5	4.5	8.0	10.0	11.0	11.0
POWER																	
AVE POWER MW		58	59	59	78	118	132	126	119	73	60	60	60	106	131	143	143
PEAK POW MW		197	197	198	199	200	203	202	201	200	201	201	201	201	200	198	197
ENERGY GWH	914.0	21.0	9.8	12.7	56.5	87.7	95.0	93.7	88.5	52.7	44.3	21.4	10.0	20.3	97.7	106.8	95.8
--GARRISON--																	
NAT INFLOW	10290	485	226	291	779	1310	2760	1932	543	456	438	179	84	95	243	181	287
DEPLETION	899	1	0	1	3	178	717	483	63	-103	26	-102	-48	-54	-110	-92	-64
CHAN STOR	0	68			-16	-31	-10	5	5	35	11	0		-36	-20	-10	0
EVAPORATION	589							36	114	142	123	55	26	29	63		
REG INFLOW	14554	686	288	371	1118	1654	2628	2002	924	782	576	360	168	212	884	939	962
RELEASE	14418	446	194	250	1012	1291	1398	1414	1445	1071	934	452	278	317	1230	1353	1333
STOR CHANGE	136	240	94	121	106	363	1229	588	-521	-290	-357	-92	-110	-105	-345	-414	-371
STORAGE	14823	15063	15157	15278	15384	15747	16976	17564	17043	16754	16396	16304	16195	16089	15744	15330	14959
ELEV FTMSL	1826.0	1826.9	1827.2	1827.7	1828.1	1829.4	1833.7	1835.7	1833.9	1832.9	1831.7	1831.4	1831.0	1830.6	1829.4	1827.9	1826.5
DISCH KCFS	24.0	15.0	14.0	14.0	17.0	21.0	23.5	23.0	23.5	18.0	15.2	15.2	20.0	20.0	20.0	22.0	24.0
POWER																	
AVE POWER MW		175	164	164	199	247	281	281	287	219	184	183	239	239	237	259	279
PEAK POW MW		346	347	348	349	353	366	372	367	364	360	359	358	357	353	349	345
ENERGY GWH	2081.0	62.8	27.5	35.5	143.6	183.9	202.5	209.0	213.7	157.5	136.6	65.8	40.2	45.8	176.7	192.4	187.5
--OAHE--																	
NAT INFLOW	1877	199	93	119	297	168	747	132	31	84	12				-45	-7	47
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25
CHAN STOR	-1	40	4		-13	-18	-11	2	-2	25	13		-22	0	0	-9	-9
EVAPORATION	524							33	102	126	108	49	23	26	57		
REG INFLOW	15174	663	281	356	1249	1376	2008	1368	1275	1030	858	402	232	291	1117	1320	1346
RELEASE	15035	436	268	381	1314	1540	1432	1746	1737	1559	1049	459	212	193	1065	946	699
STOR CHANGE	139	228	13	-25	-65	-163	576	-377	-461	-529	-191	-57	20	98	52	374	647
STORAGE	15464	15692	15705	15680	15615	15452	16028	15651	15189	14661	14470	14413	14432	14530	14582	14956	15603
ELEV FTMSL	1595.8	1596.6	1596.7	1596.6	1596.3	1595.7	1597.9	1596.5	1594.7	1592.6	1591.9	1591.7	1591.7	1592.1	1592.3	1593.8	1596.3
DISCH KCFS	12.6	14.6	19.3	21.3	22.1	25.0	24.1	28.4	28.2	26.2	17.1	15.4	15.3	12.1	17.3	15.4	12.6
POWER																	
AVE POWER MW		178	235	259	268	302	292	345	340	312	202	183	181	144	205	183	152
PEAK POW MW		649	649	648	647	644	655	648	639	629	625	624	625	627	628	635	647
ENERGY GWH	2186.8	63.9	39.4	55.9	192.7	225.0	210.3	256.4	252.9	224.8	150.6	65.7	30.4	27.6	152.9	136.4	101.9
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	14906	436	268	381	1314	1540	1432	1738	1712	1528	1022	447	206	186	1051	946	699
RELEASE	14906	436	268	381	1314	1540	1432	1738	1712	1528	1022	447	206	186	1051	946	699
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	12.6	14.6	19.3	21.3	22.1	25.0	24.1	28.3	27.8	25.7	16.6	15.0	14.9	11.7	17.1	15.4	12.6
POWER																	
AVE POWER MW		69	91	100	103	117	113	132	130	122	82	76	75	59	85	75	60
PEAK POW MW		517	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	858.6	25.0	15.2	21.6	74.4	87.2	81.1	98.4	97.0	87.6	60.8	27.2	12.6	11.4	62.9	55.7	40.6
--FORT RANDALL--																	
NAT INFLOW	696	95	44	57	89	71	181	36	68	32	2				7	-7	21
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	147							10	32	39	31	12	5	5	13		
REG INFLOW	15375	529	312	437	1399	1602	1601	1746	1733	1513	992	434	201	180	1042	936	717
RELEASE	15375	256	177	420	1399	1602	1601	1746	1733	1657	1629	738	346	203	676	664	528
STOR CHANGE	0	273	135	17				0	0	-144	-637	-304	-145	-22	366	272	189
STORAGE	3124	3397	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2663	2935	3124
ELEV FTMSL	1350.0	1353.4	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1343.5	1347.4	1350.0
DISCH KCFS	9.5	8.6	12.7	23.5	23.5	26.0	26.9	28.4	28.2	27.9	26.5	24.8	24.9	12.8	11.0	10.8	9.5
POWER																	
AVE POWER MW		71	107	197	197	218	225	238	236	232	211	187	182	93	82	84	76
PEAK POW MW		345	351	352	352	352	352	352	352	345	310	288	277	276	303	321	331
ENERGY GWH	1520.2	25.5	17.9	42.6	142.1	162.4	162.3	176.8	175.6	166.8	157.3	67.3	30.6	17.8	61.1	62.7	51.3
--GAVINS POINT--																	
NAT INFLOW	1362	100	47	60	135	150	156	88	87	63	114	51	24	27	76	75	110
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-8	-21	0	-5	-2	-3	0	1	3	3	0	23	3	0	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	16575	358	215	459	1529	1728	1732	1789	1802	1715	1734	782	365	248	740	738	640
RELEASE	16575	358	215	459	1529	1728	1732	1789	1789	1702	1734	782	365	248	740	738	666
STOR CHANGE									13	13							-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0
DISCH KCFS	12.0	12.0															

28FEB03 INI-SUM	15MAR	2003										2004					
		22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB	
--FORT PECK--																	
NAT INFLOW	5615	258	120	155	567	862	1097	483	279	266	352	175	81	93	298	226	303
DEPLETION	365	-6	-3	-3	67	299	488	148	-54	-124	-54	-32	-15	-17	-106	-124	-100
EVAPORATION	444						27	85	106	93	42	20	22	48			
MOD INFLOW	4806	264	123	158	500	563	609	308	248	284	313	164	76	87	356	350	403
RELEASE	5357	119	56	71	298	430	506	523	523	313	263	149	97	143	615	676	575
STOR CHANGE	-550	145	67	87	202	133	103	-215	-274	-30	50	15	-21	-55	-259	-326	-172
STORAGE	10570	10715	10782	10869	11071	11204	11307	11093	10818	10789	10838	10854	10833	10778	10518	10192	10020
ELEV FTMSL	2210.0	2210.9	2211.3	2211.8	2213.0	2213.8	2214.4	2213.2	2211.5	2211.3	2211.6	2211.7	2211.6	2211.3	2209.7	2207.7	2206.6
DISCH KCFS	11.0	4.0	4.0	4.0	5.0	7.0	8.5	8.5	8.5	5.3	4.3	5.0	7.0	9.0	10.0	11.0	10.0
POWER																	
AVE POWER MW	50	50	50	62	88	107	107	106	65	53	62	87	111	123	134	121	
PEAK POW MW	184	184	185	187	188	188	188	185	184	185	185	185	184	182	179	178	
ENERGY GWH	803.0	17.8	8.3	10.8	45.0	65.3	76.8	79.3	78.7	47.1	39.6	22.4	14.6	21.4	91.7	99.9	84.3
--GARRISON--																	
NAT INFLOW	8444	312	146	187	810	1045	2337	1477	418	320	451	187	87	99	125	185	258
DEPLETION	1044	28	13	17	24	211	694	450	52	-114	15	-77	-36	-41	-82	-64	-46
CHAN STOR	11	76			-11	-21	-16	0		34	11	-8	-21	-21	-11	-11	11
EVAPORATION	516						32	100	125	108	49	23	26	55			
REG INFLOW	12251	479	188	242	1073	1243	2133	1518	789	657	602	355	176	236	756	915	890
RELEASE	12931	446	167	214	893	1168	1190	1230	1230	936	802	388	236	301	1230	1291	1208
STOR CHANGE	-680	33	22	28	180	75	943	288	-441	-279	-201	-33	-60	-66	-474	-377	-318
STORAGE	12730	12763	12784	12812	12992	13067	14010	14298	13857	13577	13377	13344	13284	13218	12744	12368	12050
ELEV FTMSL	1817.8	1817.9	1818.0	1818.1	1818.9	1819.2	1822.9	1824.0	1822.3	1821.2	1820.4	1820.3	1820.0	1819.8	1817.8	1816.3	1814.9
DISCH KCFS	20.5	15.0	12.0	12.0	15.0	19.0	20.0	20.0	20.0	15.7	13.1	13.1	17.0	19.0	20.0	21.0	21.0
POWER																	
AVE POWER MW	165	132	132	165	210	224	227	227	177	146	146	189	211	220	228	226	
PEAK POW MW	320	320	320	322	323	334	338	332	329	327	327	326	325	319	315	311	
ENERGY GWH	1736.3	59.3	22.2	28.5	119.1	156.0	161.0	169.1	168.8	127.7	108.9	52.5	31.8	40.5	163.8	169.8	157.2
--OAHE--																	
NAT INFLOW	1263	238	111	143	220	120	259	99	25	77	6	-6	-3	-3	-58	-14	50
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2	1	1	11	15	25
CHAN STOR	-3	27	14		-14	-19	-5			22	14	-21	-10	-5	-5		
EVAPORATION	438						28	85	104	90	41	19	22	49			
REG INFLOW	13184	689	282	344	1053	1207	1324	1163	1079	909	740	340	193	265	1107	1257	1233
RELEASE	13882	452	280	367	1255	1492	1400	1705	1697	1372	597	227	122	137	991	771	1015
STOR CHANGE	-698	237	2	-24	-202	-285	-76	-542	-617	-464	143	112	70	128	116	486	218
STORAGE	13319	13555	13557	13534	13332	13046	12970	12428	11811	11347	11490	11603	11673	11801	11917	12402	12621
ELEV FTMSL	1587.2	1588.2	1588.2	1588.1	1587.2	1586.0	1585.7	1583.3	1580.5	1578.3	1578.9	1579.5	1579.8	1580.4	1580.9	1583.2	1584.1
DISCH KCFS	17.8	15.2	20.2	20.6	21.1	24.3	23.5	27.7	27.6	23.1	9.7	7.6	8.8	8.7	16.1	12.5	17.6
POWER																	
AVE POWER MW	176	233	238	243	278	268	313	307	253	106	84	97	96	179	140	199	
PEAK POW MW	607	607	606	602	595	594	581	566	555	558	561	563	566	569	580	586	
ENERGY GWH	1892.8	63.3	39.2	51.4	175.2	206.8	193.3	233.0	228.3	182.2	79.2	30.3	16.4	18.4	133.0	104.4	138.5
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	13753	452	280	367	1255	1492	1400	1697	1672	1341	570	215	117	131	977	771	1015
RELEASE	13753	452	280	367	1255	1492	1400	1697	1672	1341	570	215	117	131	977	771	1015
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	17.8	15.2	20.2	20.6	21.1	24.3	23.5	27.6	27.2	22.5	9.3	7.2	8.4	8.2	15.9	12.5	17.6
POWER																	
AVE POWER MW	72	95	96	99	114	110	129	127	107	47	37	43	42	79	62	85	
PEAK POW MW	518	510	509	509	509	509	509	509	523	538	538	538	538	538	538	529	
ENERGY GWH	792.8	25.9	15.9	20.8	71.1	84.5	79.3	96.1	94.7	77.1	34.9	13.2	7.2	8.0	58.9	46.3	58.9
--FORT RANDALL--																	
NAT INFLOW	404	74	35	44	58	47	161	18	48	-13	-69	-4	-2	-2	-8	16	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	
EVAPORATION	140						10	32	39	27	10	5	5	13			
REG INFLOW	13930	525	314	411	1309	1530	1549	1687	1674	1283	466	201	110	123	962	760	1028
RELEASE	13930	265	165	394	1309	1530	1549	1687	1674	1598	1403	201	110	123	689	670	564
STOR CHANGE	0	260	148	17	0	0	0	0	-315	-937	0	0	0	273	90	464	
STORAGE	3123	3384	3532	3549	3549	3549	3549	3549	3549	3234	2297	2297	2297	2297	2570	2660	3124
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.4	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0	
DISCH KCFS	9.7	8.9	11.9	22.1	22.0	24.9	26.0	27.4	27.2	26.9	22.8	6.7	7.9	7.7	11.2	10.9	9.8
POWER																	
AVE POWER MW	73	100	185	185	209	218	230	228	222	175	49	58	56	83	83	77	
PEAK POW MW	344	351	352	352	352	352	352	352	352	337	275	276	276	297	303	332	
ENERGY GWH	1374.6	26.4	16.8	40.0	133.1	155.3	157.1	171.0	169.6	159.5	130.1	17.7	9.7	10.8	61.8	61.8	53.9
--GAVINS POINT--																	
NAT INFLOW	1242	90	42	54	124	136	143	79	79	57	108	47	22	25	69	67	101
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-6	-19	0	-6	-2	-3	0	1	8	30	-2	0	-6	1	2
EVAPORATION	47						3	9	11	10	5	2	2	5			
REG INFLOW	15011	357	202	429	1428	1642	1666	1722	1735	1649	1506	268	125	143	736	737	667
RELEASE	15011	357	202	429	1428	1642	1666	1722	1722	1636	1506	268	125	143	736	737	693
STOR CHANGE							13	13									-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	
DISCH KCFS	12.0	12.0	14.5														

	29FEB04		2004				2005										
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5748	264	123	158	580	882	1123	495	285	273	361	179	83	95	305	231	310
DEPLETION	378	-11	-5	-7	71	304	495	155	-50	-124	-55	-34	-16	-18	-109	-127	-92
EVAPORATION	435						26	83	104	91	41	19	22	47			
MOD INFLOW	4935	275	128	165	509	578	628	314	252	293	325	171	80	91	367	358	402
RELEASE	5308	119	56	71	298	430	506	523	523	310	260	126	97	143	615	676	555
STOR CHANGE	-372	156	73	94	211	148	122	-209	-271	-17	65	45	-18	-52	-248	-318	-153
STORAGE	10020	10176	10249	10343	10554	10702	10824	10615	10344	10327	10392	10437	10419	10367	10119	9801	9647
ELEV FTMSL	2206.6	2207.6	2208.1	2208.6	2209.9	2210.8	2211.6	2210.3	2208.6	2208.5	2209.2	2209.2	2209.1	2208.8	2207.2	2205.2	2204.3
DISCH KCFS	10.0	4.0	4.0	4.0	5.0	7.0	8.5	8.5	8.5	5.2	4.2	4.2	7.0	9.0	10.0	11.0	10.0
POWER																	
AVE POWER MW		49	49	49	62	86	105	105	104	64	52	52	86	110	122	133	120
PEAK POW MW		179	180	181	182	184	185	183	181	181	181	182	181	181	179	176	175
ENERGY GWH	785.0	17.5	8.2	10.6	44.3	64.3	75.8	78.2	77.6	46.0	38.7	18.7	14.4	21.1	90.5	98.6	80.4
--GARRISON--																	
NAT INFLOW	8762	324	151	194	840	1084	2425	1533	433	332	468	194	90	103	130	192	268
DEPLETION	980	5	2	3	9	211	704	466	57	-117	10	-80	-37	-43	-90	-72	-48
CHAN STOR	0	65			-11	-22	-16	0	35	10			-30	-22	-11	-11	11
EVAPORATION	504						31	98	122	105	47	22	25	54			
REG INFLOW	12586	504	205	263	1118	1282	2211	1559	801	672	623	352	173	242	770	929	882
RELEASE	13035	417	167	214	893	1261	1220	1261	1261	952	805	390	236	301	1230	1291	1139
STOR CHANGE	-450	87	38	49	225	21	991	298	-460	-280	-182	-37	-63	-60	-460	-362	-256
STORAGE	12050	12137	12175	12224	12449	12470	13461	13759	13299	13019	12838	12800	12737	12678	12218	11856	11600
ELEV FTMSL	1814.9	1815.3	1815.5	1815.7	1816.6	1816.7	1820.7	1821.9	1820.1	1819.0	1818.2	1818.1	1817.8	1817.6	1815.7	1814.1	1813.0
DISCH KCFS	21.0	14.0	12.0	12.0	15.0	20.5	20.5	20.5	20.5	16.0	13.1	13.1	17.0	19.0	20.0	21.0	20.5
POWER																	
AVE POWER MW		151	130	130	163	222	225	230	229	178	145	144	186	208	217	225	217
PEAK POW MW		312	312	313	316	316	328	331	326	323	321	320	319	319	313	309	305
ENERGY GWH	1723.4	54.3	21.8	28.1	117.1	165.4	162.4	170.8	170.5	127.8	107.6	51.9	31.3	39.9	161.3	167.2	146.1
--OAHE--																	
NAT INFLOW	1323	249	116	149	231	126	271	103	26	81	7	-7	-3	-3	-61	-15	52
DEPLETION	585	22	10	13	46	64	123	143	93	23	-8	2	1	1	11	16	25
CHAN STOR	2	35	10		-15	-27				24	15		-21	-11	-5	-5	3
EVAPORATION	431						27	83	104	90	40	19	21	47			
REG INFLOW	13345	679	282	350	1063	1295	1368	1193	1111	930	745	342	193	265	1105	1255	1168
RELEASE	13805	447	275	360	1238	1490	1387	1704	1693	445	1530	225	122	137	991	772	989
STOR CHANGE	-461	232	7	-9	-175	-195	-19	-510	-582	485	-785	117	71	128	114	483	179
STORAGE	12621	12852	12860	12850	12675	12480	12461	11950	11369	11854	11068	11185	11256	11384	11498	11981	12160
ELEV FTMSL	1584.1	1585.2	1585.2	1585.1	1584.4	1583.5	1583.4	1581.1	1578.4	1580.7	1576.9	1577.5	1577.8	1578.4	1579.0	1581.2	1582.1
DISCH KCFS	17.6	15.0	19.8	20.1	20.8	24.2	23.3	27.7	27.5	7.5	24.9	7.6	8.8	8.6	16.1	12.6	17.8
POWER																	
AVE POWER MW		171	226	229	236	273	262	309	302	83	272	82	96	95	177	139	198
PEAK POW MW		591	591	591	587	582	582	570	555	567	547	551	552	556	558	570	575
ENERGY GWH	1859.1	61.4	37.9	49.5	169.9	203.2	188.8	229.8	224.8	59.4	202.3	29.7	16.1	18.2	131.4	103.3	133.3
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	13676	447	275	360	1238	1490	1387	1696	1668	414	1503	213	117	131	977	772	989
RELEASE	13676	447	275	360	1238	1490	1387	1696	1668	414	1503	213	117	131	977	772	989
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	17.6	15.0	19.8	20.1	20.8	24.2	23.3	27.6	27.1	7.0	24.4	7.2	8.4	8.2	15.9	12.6	17.8
POWER																	
AVE POWER MW		71	93	94	97	113	109	129	127	35	122	36	43	42	79	62	85
PEAK POW MW		518	510	509	509	509	509	509	509	538	538	538	538	538	538	538	529
ENERGY GWH	792.6	25.6	15.6	20.4	70.1	84.4	78.6	96.0	94.5	25.4	91.1	13.1	7.2	8.0	58.9	46.3	57.4
--FORT RANDALL--																	
NAT INFLOW	433	80	37	48	62	50	174	19	52	-15	-75	-4	-2	-2	-9	17	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	130						10	32	33	22	10	5	5	13			
REG INFLOW	13886	525	312	407	1296	1531	1549	1687	1674	345	1403	200	110	123	962	760	1003
RELEASE	13887	265	164	390	1296	1531	1549	1687	1674	1598	1403	201	110	123	689	670	539
STOR CHANGE	-1	260	148	17			0	0	-1252	0	0	0	0	0	273	90	464
STORAGE	3124	3384	3532	3549	3549	3549	3549	3549	3549	2296	2296	2296	2296	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1337.5	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	9.8	8.9	11.8	21.8	21.8	24.9	26.0	27.4	27.2	26.9	22.8	6.7	7.9	7.7	11.2	10.9	9.7
POWER																	
AVE POWER MW		73	99	183	183	209	218	230	228	209	164	49	58	56	83	83	77
PEAK POW MW		344	351	352	352	352	352	352	352	274	276	276	276	276	297	303	332
ENERGY GWH	1353.3	26.4	16.6	39.6	131.8	155.3	157.1	171.0	169.6	150.3	122.2	17.7	9.7	10.8	61.8	61.8	51.5
--GAVINS POINT--																	
NAT INFLOW	1246	91	42	54	125	136	143	79	79	57	108	47	22	25	70	68	101
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-6	-19	0	-6	-2	-3	0	1	8	30	-2	0	-6	1	2
EVAPORATION	47						9	11	10	5	2	2	2	5			
REG INFLOW	14972	358	201	425	1416	1642	1666	1722	1735	1649	1506	268	125	143	737	738	642
RELEASE	14972	358	201	425	1416	1642	1666	1722	1722	1636	1506	268	125	143	737	738	668
STOR CHANGE							13	13									-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	1206.0
DISCH KCFS																	

	28FEB05		2005										2006				
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5919	272	127	163	598	909	1156	509	294	281	371	184	86	98	314	238	319
DEPLETION	388	-11	-5	-7	70	305	500	162	-46	-125	-57	-34	-16	-18	-110	-128	-92
EVAPORATION	429						26	82	102	90	41	19	22	47			
MOD INFLOW	5102	283	132	170	528	604	656	321	258	304	338	177	83	95	377	366	411
RELEASE	5259	119	56	71	298	430	506	523	523	309	259	126	97	127	584	676	555
STOR CHANGE	-157	164	77	98	230	174	150	-202	-264	-5	79	52	-15	-32	-207	-310	-144
STORAGE	9647	9811	9888	9986	10217	10390	10540	10339	10074	10069	10147	10199	10185	10152	9945	9635	9490
ELEV FTMSL	2204.3	2205.3	2205.8	2206.4	2207.9	2208.9	2209.8	2208.6	2207.0	2206.9	2207.4	2207.8	2207.7	2207.5	2206.2	2204.2	2203.3
DISCH KCFS	10.0	4.0	4.0	4.0	5.0	7.0	8.5	8.5	8.5	5.2	4.2	4.2	7.0	8.0	9.5	11.0	10.0
POWER																	
AVE POWER MW		48	48	48	61	86	104	104	103	63	51	52	85	97	115	132	119
PEAK POW MW		176	177	178	180	181	182	181	179	178	179	180	179	179	177	175	174
ENERGY GWH	771.8	17.3	8.1	10.5	43.8	63.7	75.1	77.5	77.0	45.5	38.2	18.5	14.3	18.7	85.5	98.1	80.0
--GARRISON--																	
NAT INFLOW	9185	340	158	204	881	1136	2542	1607	454	349	491	203	95	108	136	201	281
DEPLETION	965	2	1	1	3	211	714	482	63	-120	6	-84	-39	-45	-98	-79	-54
CHAN STOR	0	66			-11	-22	-16	0		35	10		-30	-11	-16	-16	11
EVAPORATION	501						31	97	121	105	47	22	25	54			
REG INFLOW	12979	523	213	274	1165	1334	2317	1617	817	693	650	364	179	244	748	940	901
RELEASE	13172	387	167	214	893	1261	1250	1291	1291	952	795	385	236	301	1230	1353	1166
STOR CHANGE	-193	136	46	60	272	73	1068	326	-475	-259	-145	-20	-57	-58	-481	-413	-265
STORAGE	11600	11736	11783	11842	12114	12188	13255	13581	13106	12847	12702	12682	12624	12567	12085	11672	11407
ELEV FTMSL	1813.0	1813.6	1813.8	1814.1	1815.2	1815.5	1819.9	1821.2	1819.3	1818.3	1817.7	1817.6	1817.4	1817.1	1815.1	1813.3	1812.2
DISCH KCFS	20.5	13.0	12.0	12.0	15.0	20.5	21.0	21.0	21.0	16.0	12.9	12.9	17.0	19.0	20.0	22.0	21.0
POWER																	
AVE POWER MW		138	128	128	161	220	229	234	233	177	142	142	186	207	216	234	221
PEAK POW MW		307	308	308	312	313	326	329	324	321	319	318	318	317	311	306	303
ENERGY GWH	1730.3	49.8	21.5	27.7	115.9	163.8	165.1	174.0	173.7	127.2	105.9	51.1	31.2	39.8	160.7	174.2	148.7
--OAHE--																	
NAT INFLOW	1408	265	123	159	245	134	288	110	28	86	7	-7	-3	-3	-64	-16	56
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25
CHAN STOR	-2	38	5		-15	-28	-3			27	17		-22	-11	-5	-11	5
EVAPORATION	415						27	81	98	85	39	18	21	46			
REG INFLOW	13566	667	285	360	1076	1302	1409	1228	1142	942	742	338	192	266	1103	1310	1202
RELEASE	13763	440	272	355	1232	1484	1369	1702	1688	1375	609	227	122	137	991	773	987
STOR CHANGE	-198	228	13	5	-156	-182	40	-474	-545	-433	133	111	70	128	112	537	216
STORAGE	12160	12388	12401	12406	12250	12068	12108	11634	11088	10656	10789	10899	10969	11098	11210	11747	11962
ELEV FTMSL	1582.1	1583.1	1583.2	1583.2	1582.5	1581.6	1581.8	1579.6	1577.0	1574.8	1575.5	1576.1	1576.4	1577.1	1577.6	1580.2	1581.2
DISCH KCFS	17.8	14.8	19.6	19.9	20.7	24.1	23.0	27.7	27.5	23.1	9.9	7.6	8.8	8.6	16.1	12.6	17.8
POWER																	
AVE POWER MW		166	220	223	232	269	256	306	299	248	106	82	95	94	175	138	197
PEAK POW MW		580	580	580	577	572	573	562	548	537	540	543	545	548	551	565	570
ENERGY GWH	1833.0	59.7	36.9	48.3	167.2	200.1	184.4	227.4	222.2	178.7	79.1	29.7	16.0	18.0	130.3	102.7	132.3
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	13634	440	272	355	1232	1484	1369	1694	1663	1344	582	215	117	131	977	773	987
RELEASE	13634	440	272	355	1232	1484	1369	1694	1663	1344	582	215	117	131	977	773	987
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	17.8	14.8	19.6	19.9	20.7	24.1	23.0	27.6	27.1	22.6	9.5	7.2	8.4	8.2	15.9	12.6	17.8
POWER																	
AVE POWER MW		70	92	93	97	113	108	129	127	107	48	37	43	42	79	62	85
PEAK POW MW		518	510	509	509	509	509	509	509	523	538	538	538	538	538	538	529
ENERGY GWH	786.1	25.2	15.4	20.1	69.8	84.0	77.6	95.9	94.2	77.3	35.7	13.2	7.2	8.0	58.9	46.4	57.3
--FORT RANDALL--																	
NAT INFLOW	476	88	41	53	68	55	191	21	57	-16	-82	-4	-2	-2	-10	19	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	
EVAPORATION	140						10	32	39	27	10	5	5	13			
REG INFLOW	13883	526	312	406	1296	1530	1548	1687	1674	1283	465	200	109	123	962	760	1003
RELEASE	13883	265	164	389	1296	1530	1548	1687	1674	1598	1402	200	110	123	689	670	539
STOR CHANGE	1	261	148	17	0	0	0	0	-315	-937	0	0	0	273	90	464	
STORAGE	3123	3384	3532	3549	3549	3549	3549	3549	3549	3234	2297	2297	2297	2297	2570	2660	3124
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.4	1337.5	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	9.7	8.9	11.8	21.8	21.8	24.9	26.0	27.4	27.2	26.9	22.8	6.7	7.9	7.7	11.2	10.9	9.7
POWER																	
AVE POWER MW		73	99	183	183	209	218	230	228	222	175	49	57	56	83	83	77
PEAK POW MW		344	351	352	352	352	352	352	352	337	275	276	276	276	297	303	332
ENERGY GWH	1370.0	26.4	16.6	39.6	131.8	155.2	157.0	171.0	169.6	159.5	130.0	17.7	9.7	10.8	61.8	61.8	51.5
--GAVINS POINT--																	
NAT INFLOW	1252	91	42	55	125	137	144	79	79	57	109	47	22	25	70	68	102
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-6	-19	0	-6	-2	-3	0	1	8	30	-2	0	-7	1	2
EVAPORATION	47						3	9	11	10	5	2	2	5			
REG INFLOW	14973	358	201	425	1416	1642	1666	1722	1735	1649	1506	268	125	143	737	738	643
RELEASE	14973	358	201	425	1416	1642	1666	1722	1722	1636	1506	268	125	143	737	738	669
STOR CHANGE							13	13									-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	1206.0
DISCH KCFS	12.0	12.0	14.5	23.8	23.8	26.7											

	28FEB02		2002										2003				
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5435	250	116	150	549	834	1061	468	270	258	341	169	79	90	289	218	293
DEPLETION	444	-4	-2	-2	77	311	543	141	-57	-123	-52	-32	-15	-17	-107	-126	-91
EVAPORATION	454							28	87	109	95	43	20	23	49		
MOD INFLOW	4537	254	118	152	472	523	518	299	240	272	298	158	74	84	347	344	384
RELEASE	5671	119	56	71	298	430	536	553	553	378	299	149	97	143	615	707	666
STOR CHANGE	-1133	135	63	81	174	93	-18	-254	-314	-106	-1	9	-23	-58	-268	-363	-282
STORAGE	11361	11495	11558	11639	11813	11906	11888	11634	11320	11214	11213	11223	11199	11141	10873	10510	10227
ELEV FTMSL	2214.7	2215.5	2215.9	2216.3	2217.3	2217.9	2217.8	2216.3	2214.5	2213.9	2213.9	2213.9	2213.8	2213.4	2211.8	2209.7	2207.9
DISCH KCFS	12.0	4.0	4.0	4.0	5.0	7.0	9.0	9.0	9.0	6.4	4.9	5.0	7.0	9.0	10.0	11.5	12.0
POWER																	
AVE POWER MW		51	51	51	64	89	115	115	114	80	61	63	88	113	125	142	146
PEAK POW MW		190	190	191	192	193	193	191	189	188	188	188	188	187	185	182	180
ENERGY GWH	861.5	18.2	8.5	11.0	45.9	66.6	82.8	85.2	84.6	57.6	45.5	22.6	14.8	21.6	92.7	105.4	98.4
--GARRISON--																	
NAT INFLOW	8026	297	138	178	770	993	2221	1404	397	305	429	177	83	94	119	176	245
DEPLETION	1281	22	10	13	38	135	714	464	77	-81	50	-58	-27	-31	-33	-16	2
CHAN STOR	0	85			-11	-21	-21			28	16	-1	-21	-11	-16	-5	
EVAPORATION	526							33	102	127	110	49	23	26	56		
REG INFLOW	11889	478	184	236	1019	1267	2021	1461	771	665	584	332	162	220	700	883	904
RELEASE	13269	446	167	214	893	1261	1250	1291	1291	952	792	383	264	317	1230	1353	1166
STOR CHANGE	-1380	32	17	22	126	7	772	170	-520	-287	-208	-51	-101	-97	-530	-470	-262
STORAGE	13685	13717	13734	13755	13882	13888	14660	14830	14310	14023	13815	13764	13663	13566	13036	12566	12304
ELEV FTMSL	1821.6	1821.7	1821.8	1821.9	1822.4	1822.4	1825.4	1826.0	1824.1	1822.9	1822.1	1821.9	1821.5	1821.2	1819.0	1817.1	1816.0
DISCH KCFS	21.0	15.0	12.0	12.0	15.0	20.5	21.0	21.0	21.0	16.0	12.9	12.9	19.0	20.0	20.0	22.0	21.0
POWER																	
AVE POWER MW		169	136	136	170	231	239	242	241	182	146	146	214	224	222	241	227
PEAK POW MW		331	331	331	333	333	342	343	338	332	331	330	330	329	323	317	314
ENERGY GWH	1807.7	60.9	22.8	29.3	122.1	172.1	172.3	180.2	179.4	131.3	108.8	52.4	35.9	43.0	165.3	179.1	152.8
--OAHE--																	
NAT INFLOW	1184	223	104	134	206	113	242	92	24	72	6	-6	-3	-3	-54	-13	47
DEPLETION	557	22	10	13	45	61	117	134	87	22	-7	2	1	1	11	15	24
CHAN STOR	-1	28	14		-14	-26				25	16	-31	-5	0	-10	5	
EVAPORATION	461							30	91	111	95	42	20	23	49		
REG INFLOW	13434	675	274	335	1040	1287	1372	1219	1137	915	726	334	209	286	1115	1315	1194
RELEASE	14850	459	282	368	1250	1500	1417	1708	1702	1544	1053	434	201	186	985	770	991
STOR CHANGE	-1416	216	-8	-34	-210	-213	-45	-488	-565	-629	-327	-100	9	100	130	544	204
STORAGE	14298	14514	14506	14472	14262	14049	14004	13515	12950	12322	11995	11895	11903	12003	12133	12678	12881
ELEV FTMSL	1591.2	1592.1	1592.0	1591.9	1591.0	1590.2	1590.0	1588.0	1585.6	1582.8	1581.3	1580.8	1580.9	1581.3	1582.0	1584.4	1585.3
DISCH KCFS	17.9	15.4	20.3	20.6	21.0	24.4	23.8	27.8	27.7	25.9	17.1	14.6	14.5	11.7	16.0	12.5	17.8
POWER																	
AVE POWER MW		182	240	244	248	286	278	322	317	293	191	162	160	131	179	141	203
PEAK POW MW		626	626	625	621	617	616	606	593	578	571	568	568	571	574	587	591
ENERGY GWH	2063.6	65.7	40.4	52.7	178.4	212.7	200.5	239.7	235.8	210.8	142.3	58.4	27.0	25.1	133.0	105.0	136.2
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	14721	459	282	368	1250	1500	1417	1700	1677	1513	1026	422	195	180	971	770	991
RELEASE	14721	459	282	368	1250	1500	1417	1700	1677	1513	1026	422	195	180	971	770	991
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	17.9	15.4	20.3	20.6	21.0	24.4	23.8	27.6	27.3	25.4	16.7	14.2	14.0	11.3	15.8	12.5	17.8
POWER																	
AVE POWER MW		73	95	97	98	114	112	129	128	121	82	71	71	57	79	62	86
PEAK POW MW		518	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	849.1	26.3	16.0	20.9	70.8	84.9	80.3	96.3	95.0	86.8	61.0	25.7	11.9	11.0	58.6	46.2	57.5
--FORT RANDALL--																	
NAT INFLOW	366	67	31	40	52	42	146	16	44	-12	-62	-3	-1	-2	-7	15	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	
EVAPORATION	147							10	32	39	31	12	5	5	13		
REG INFLOW	14861	524	313	408	1298	1533	1551	1688	1675	1455	932	406	188	172	956	760	1003
RELEASE	14861	265	164	391	1298	1533	1551	1688	1675	1599	1569	710	333	194	683	670	539
STOR CHANGE	0	260	148	17				0	0	-144	-637	-304	-145	-22	273	90	464
STORAGE	3124	3384	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2570	2660	3124
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	9.7	8.9	11.8	21.9	21.8	24.9	26.1	27.5	27.2	26.9	25.5	23.9	24.0	12.2	11.1	10.9	9.7
POWER																	
AVE POWER MW		73	99	184	183	209	219	230	228	224	204	180	175	89	82	83	77
PEAK POW MW		344	351	352	352	352	352	352	352	345	310	288	277	276	297	303	332
ENERGY GWH	1466.8	26.4	16.7	39.7	132.0	155.5	157.3	171.1	169.7	161.0	151.5	64.8	29.4	17.1	61.3	61.8	51.5
--GAVINS POINT--																	
NAT INFLOW	1229	89	42	53	123	134	141	78	78	56	107	46	21	25	69	67	100
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-6	-19	0	-6	-2	-3	0	1	3	3	0	22	2	0	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15929	356	200	425	1416	1642	1666	1722	1735	1649	1666	750	350	236	738	737	641
RELEASE	15929	356	200	425	1416	1642	1666	1722	1722	1636	1666	750	350	236	738	737	667
STOR CHANGE								13	13								-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	1206.0
DISCH KCFS	12.0	12.0	14.4	23.8	23.8												

	28FEB03		2003										2004				
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB
--FORT PECK--																	
NAT INFLOW	5615	258	120	155	567	862	1097	483	279	266	352	175	81	93	298	226	303
DEPLETION	365	-6	-3	-3	67	299	488	148	-54	-124	-54	-32	-15	-17	-106	-124	-100
EVAPORATION	434						27	83	104	91	41	19	22	47			
MOD INFLOW	4816	264	123	158	500	563	609	308	250	286	315	165	77	88	357	350	403
RELEASE	5639	119	56	71	298	461	536	553	553	321	270	149	97	143	615	707	690
STOR CHANGE	-823	145	67	87	202	102	73	-245	-303	-35	45	16	-20	-55	-258	-357	-287
STORAGE	10227	10372	10439	10526	10729	10830	10904	10659	10356	10320	10366	10382	10361	10306	10048	9691	9404
ELEV FTMSL	2207.9	2208.8	2209.2	2209.8	2211.0	2211.6	2212.0	2210.6	2208.7	2208.8	2208.9	2208.7	2208.7	2208.4	2204.6	2204.6	2202.7
DISCH KCFS	12.0	4.0	4.0	4.0	5.0	7.5	9.0	9.0	9.0	5.4	4.4	5.0	7.0	9.0	10.0	11.5	12.0
POWER																	
AVE POWER MW		49	49	49	62	93	112	111	111	66	54	61	86	110	121	138	143
PEAK POW MW		181	182	182	184	185	185	183	181	181	181	181	181	180	178	175	173
ENERGY GWH	833.4	17.6	8.3	10.6	44.5	69.2	80.4	82.9	82.2	47.6	40.0	22.1	14.4	21.1	90.4	102.8	99.2
--GARRISON--																	
NAT INFLOW	8444	312	146	187	810	1045	2337	1477	418	320	451	187	87	99	125	185	258
DEPLETION	1044	28	13	17	24	211	694	450	52	-114	15	-77	-36	-41	-82	-64	-46
CHAN STOR	0	87			-11	-27	-16			39	11	-7	-22	-22	-11	-16	-6
EVAPORATION	501						31	98	121	105	47	22	25	53			
REG INFLOW	12537	491	188	242	1073	1268	2162	1549	822	673	612	358	176	237	758	940	989
RELEASE	13537	446	167	214	893	1261	1279	1322	952	863	418	264	317	1230	1353	1237	
STOR CHANGE	-1000	44	22	28	180	8	883	227	-500	-279	-252	-60	-87	-81	-472	-413	-248
STORAGE	12304	12348	12370	12398	12578	12586	13469	13696	13196	12916	12665	12605	12518	12437	11965	11552	11304
ELEV FTMSL	1816.0	1816.2	1816.3	1816.4	1817.2	1817.2	1820.8	1821.7	1819.7	1818.5	1817.5	1817.3	1816.9	1816.6	1814.6	1812.8	1811.7
DISCH KCFS	21.0	15.0	12.0	12.0	15.0	20.5	21.5	21.5	21.5	16.0	14.0	14.0	19.0	20.0	20.0	22.0	21.5
POWER																	
AVE POWER MW		163	130	131	163	223	237	240	240	177	154	154	207	217	215	233	226
PEAK POW MW		315	315	315	317	318	328	331	325	321	318	318	317	316	310	305	302
ENERGY GWH	1784.8	58.5	21.9	28.2	117.6	166.0	170.5	178.9	178.2	127.5	114.9	55.3	34.7	41.7	160.1	173.6	157.1
--OAHE--																	
NAT INFLOW	1263	238	111	143	220	120	259	99	25	77	6	-6	-3	-3	-58	-14	50
DEPLETION	570	22	10	13	45	62	120	138	90	23	-7	2	1	1	11	15	25
CHAN STOR	-4	30	15		-15	-27	-5			28	10	-27	-5	0	-11	3	
EVAPORATION	425						28	85	103	87	39	18	21	45			
REG INFLOW	13801	692	282	344	1053	1291	1413	1255	1172	932	800	371	216	287	1115	1313	1264
RELEASE	14827	452	278	363	1243	1493	1400	1705	1697	1544	1059	434	201	186	985	771	1015
STOR CHANGE	-1025	240	4	-20	-190	-201	13	-449	-525	-612	-259	-63	15	101	130	542	250
STORAGE	12881	13121	13125	13105	12915	12713	12726	12277	11752	11140	10881	10818	10833	10934	11064	11606	11856
ELEV FTMSL	1585.3	1586.3	1586.3	1586.2	1585.4	1584.5	1584.6	1582.6	1580.2	1577.3	1576.0	1575.6	1575.7	1576.2	1576.9	1579.5	1580.7
DISCH KCFS	17.8	15.2	20.0	20.4	20.9	24.3	23.5	27.7	27.6	25.9	17.2	14.6	14.5	11.7	16.0	12.5	17.6
POWER																	
AVE POWER MW		174	230	233	238	275	266	312	306	283	186	157	155	127	173	137	195
PEAK POW MW		597	597	597	592	588	588	577	565	549	543	541	541	544	548	561	567
ENERGY GWH	1995.1	62.6	38.6	50.4	171.7	204.9	191.8	231.8	227.7	203.9	138.4	56.6	26.1	24.3	128.9	102.0	135.6
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	14698	452	278	363	1243	1493	1400	1697	1672	1513	1032	422	195	180	971	771	1015
RELEASE	14698	452	278	363	1243	1493	1400	1697	1672	1513	1032	422	195	180	971	771	1015
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	17.8	15.2	20.0	20.4	20.9	24.3	23.5	27.6	27.2	25.4	16.8	14.2	14.0	11.3	15.8	12.5	17.6
POWER																	
AVE POWER MW		72	94	95	98	114	110	129	127	121	82	71	71	57	79	62	85
PEAK POW MW		518	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529
ENERGY GWH	847.8	25.9	15.8	20.6	70.4	84.5	79.3	96.1	94.7	86.8	61.3	25.7	11.9	11.0	58.6	46.3	58.9
--FORT RANDALL--																	
NAT INFLOW	404	74	35	44	58	47	161	18	48	-13	-69	-4	-2	-2	-8	16	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	
EVAPORATION	147						10	32	39	31	12	5	5	13			
REG INFLOW	14875	525	312	407	1297	1531	1549	1687	1674	1454	931	406	188	172	956	760	1028
RELEASE	14875	265	164	390	1297	1531	1549	1687	1674	1598	1568	710	333	194	683	670	564
STOR CHANGE	0	260	148	17			0	0	-144	-637	-304	-145	-22	273	90	464	
STORAGE	3124	3384	3532	3549	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2570	2660	3124
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1353.5	1345.1	1340.4	1337.9	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	9.7	8.9	11.8	21.8	21.8	24.9	26.0	27.4	27.2	26.9	25.5	23.9	24.0	12.2	11.1	10.9	9.8
POWER																	
AVE POWER MW		73	99	183	183	209	218	230	228	223	204	180	175	89	82	83	77
PEAK POW MW		344	351	352	352	352	352	352	352	345	310	288	277	276	297	303	332
ENERGY GWH	1468.1	26.4	16.6	39.6	131.9	155.3	157.1	171.0	169.6	160.9	151.4	64.8	29.4	17.1	61.3	61.8	53.9
--GAVINS POINT--																	
NAT INFLOW	1242	90	42	54	124	136	143	79	79	57	108	47	22	25	69	67	101
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-6	-19	0	-6	-2	-3	0	1	3	3	0	22	2	0	2
EVAPORATION	47						9	11	10	5	2	2	2	5			
REG INFLOW	15956	357	201	425	1416	1642	1666	1722	1735	1649	1666	750	350	236	738	737	667
RELEASE	15956	357	201	425	1416	1642	1666	1722	1722	1636	1666	750	350	236	738	737	693
STOR CHANGE							13	13									-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	

	29FEB04				2004				2005											
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB			
--FORT PECK--																				
NAT INFLOW	5748	264	123	158	580	882	1123	495	285	273	361	179	83	95	305	231	310			
DEPLETION	378	-11	-5	-7	71	304	495	155	-50	-124	-55	-34	-16	-18	-109	-127	-92			
EVAPORATION	417						26	80	100	87	40	18	21	45						
MOD INFLOW	4953	275	128	165	509	578	628	314	255	297	329	172	80	92	369	358	402			
RELEASE	5585	119	56	71	298	461	536	553	316	265	128	97	143	615	707	666				
STOR CHANGE	-631	156	73	94	211	117	92	-239	-298	-18	64	44	-17	-51	-246	-349	-264			
STORAGE	9404	9560	9633	9727	9938	10055	10148	9909	9611	9592	9656	9700	9683	9633	9386	9037	8773			
ELEV FTMSL	2202.7	2203.7	2204.2	2204.8	2206.1	2206.9	2207.4	2205.9	2204.0	2203.9	2204.3	2204.6	2204.5	2204.2	2202.6	2200.3	2198.5			
DISCH KCFS	12.0	4.0	4.0	4.0	5.0	7.5	9.0	9.0	9.0	5.3	4.3	4.3	7.0	9.0	10.0	11.5	12.0			
POWER																				
AVE POWER MW		48	48	48	60	91	109	109	108	64	52	52	84	108	119	135	139			
PEAK POW MW		174	175	176	177	178	179	177	175	174	175	175	175	175	173	170	167			
ENERGY GWH	806.7	17.2	8.1	10.4	43.4	67.5	78.6	81.0	80.3	45.7	38.5	18.6	14.1	20.7	88.4	100.5	93.7			
--GARRISON--																				
NAT INFLOW	8762	324	151	194	840	1084	2425	1533	433	332	468	194	90	103	130	192	268			
DEPLETION	980	5	2	3	9	211	704	466	57	-117	10	-80	-37	-43	-90	-72	-48			
CHAN STOR	0	88			-11	-27	-16			40	11		-29	-22	-11	-17	-6			
EVAPORATION	482						30	94	117	101	45	21	24	51						
REG INFLOW	12884	527	205	263	1118	1307	2240	1591	835	688	633	357	174	243	773	954	977			
RELEASE	13651	417	167	214	893	1291	1309	1353	942	895	433	264	317	1230	1353	1222				
STOR CHANGE	-767	110	38	49	225	15	931	238	-517	-254	-262	-76	-89	-74	-457	-398	-245			
STORAGE	11304	11414	11452	11501	11726	11741	12672	12910	12393	12139	11877	11801	11711	11637	11180	10782	10537			
ELEV FTMSL	1811.7	1812.2	1812.4	1812.6	1813.6	1813.6	1817.5	1818.5	1816.4	1815.3	1814.2	1813.9	1813.5	1813.2	1811.2	1809.4	1808.2			
DISCH KCFS	21.5	14.0	12.0	12.0	15.0	21.0	22.0	22.0	22.0	15.8	14.6	14.6	19.0	20.0	20.0	22.0	22.0			
POWER																				
AVE POWER MW		147	127	127	159	223	236	241	240	171	156	155	202	212	210	227	225			
PEAK POW MW		303	303	304	307	307	319	321	315	312	309	308	307	306	300	295	291			
ENERGY GWH	1756.0	53.1	21.3	27.4	114.6	165.7	170.3	179.0	178.3	123.3	116.3	56.0	33.9	40.7	156.2	169.1	150.9			
--OAKE--																				
NAT INFLOW	1323	249	116	149	231	126	271	103	26	81	7	-7	-3	-3	-61	-15	52			
DEPLETION	585	22	10	13	46	64	123	143	93	23	-8	2	1	1	11	16	25			
CHAN STOR	-4	39	10		-15	-31	-5			33	7		-25	-6	0	-11	0			
EVAPORATION	399						26	79	96	82	37	17	20	43						
REG INFLOW	13986	682	283	350	1062	1322	1452	1287	1206	937	835	388	218	288	1115	1311	1249			
RELEASE	14771	447	275	360	1238	1490	1387	1704	1693	1546	1065	434	201	186	985	772	989			
STOR CHANGE	-785	236	7	-9	-176	-167	65	-417	-487	-609	-230	-46	18	102	130	539	260			
STORAGE	11856	12092	12099	12090	11914	11747	11811	11394	10908	10299	10069	10023	10041	10142	10272	10811	11071			
ELEV FTMSL	1580.7	1581.8	1581.8	1581.7	1580.9	1580.2	1580.5	1578.5	1576.1	1573.0	1571.8	1571.5	1571.6	1572.2	1572.6	1575.6	1576.9			
DISCH KCFS	17.6	15.0	19.8	20.1	20.8	24.2	23.3	27.7	27.5	26.0	17.3	14.6	14.5	11.7	16.0	12.6	17.8			
POWER																				
AVE POWER MW		167	221	225	231	268	257	304	298	276	182	153	151	123	169	134	192			
PEAK POW MW		573	573	573	569	565	566	556	543	527	521	519	520	523	526	541	548			
ENERGY GWH	1936.7	60.1	37.1	48.5	166.5	199.1	185.2	225.9	221.5	198.9	135.5	55.1	25.4	23.7	125.6	99.6	129.0			
--BIG BEND--																				
EVAPORATION	129						8	24	31	27	12	6	7	14						
REG INFLOW	14642	447	275	360	1238	1490	1387	1696	1668	1515	1038	422	195	180	971	772	989			
RELEASE	14642	447	275	360	1238	1490	1387	1696	1668	1515	1038	422	195	180	971	772	989			
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682			
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0			
DISCH KCFS	17.6	15.0	19.8	20.1	20.8	24.2	23.3	27.6	27.1	25.5	16.9	14.2	14.0	11.3	15.8	12.6	17.8			
POWER																				
AVE POWER MW		71	93	94	97	113	109	129	127	121	83	71	71	57	79	62	85			
PEAK POW MW		518	510	509	509	509	509	509	509	517	538	538	538	538	538	538	529			
ENERGY GWH	844.6	25.6	15.6	20.4	70.1	84.4	78.6	96.0	94.5	86.9	61.7	25.7	11.9	11.0	58.6	46.3	57.4			
--FORT RANDALL--																				
NAT INFLOW	433	80	37	48	62	50	174	19	52	-15	-75	-4	-2	-2		-9	17			
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3			
EVAPORATION	147						10	32	39	31	12	5	5	13						
REG INFLOW	14849	525	312	407	1296	1531	1549	1687	1674	1454	931	406	188	172	956	760	1003			
RELEASE	14849	265	164	390	1296	1531	1549	1687	1674	1598	1568	710	333	194	683	670	539			
STOR CHANGE	0	260	148	17			0	0	-144	-637	-304	-145	-22	273	90	464				
STORAGE	3124	3384	3532	3549	3549	3549	3549	3549	3405	2768	2464	2319	2297	2570	2660	3124				
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1345.1	1340.4	1337.9	1337.5	1342.1	1343.5	1350.0				
DISCH KCFS	9.8	8.9	11.8	21.8	21.8	24.9	26.0	27.4	27.2	26.9	25.5	23.9	24.0	12.2	11.1	10.9	9.7			
POWER																				
AVE POWER MW		73	99	183	183	209	218	230	228	223	204	180	175	89	82	83	77			
PEAK POW MW		344	351	352	352	352	352	352	352	345	310	288	277	276	297	303	332			
ENERGY GWH	1465.6	26.4	16.6	39.6	131.8	155.3	157.1	171.0	169.6	160.9	151.4	64.8	29.4	17.1	61.3	61.8	51.5			
--GAVINS POINT--																				
NAT INFLOW	1246	91	42	54	125	136	143	79	79	57	108	47	22	25	70	68	101			
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1				
CHAN STOR	-1	2	-6	-19	0	-6	-2	-3	0	1	3	3	0	22	2	0	2			
EVAPORATION	47						3	9	11	10	5	2	2	5						
REG INFLOW	15934	358	201	425	1416	1642	1666	1722	1735	1649	1666	750	350	236	739	738	642			
RELEASE	15934	358	201	425	1416	1642	1666	1722	1722	1636	1666	750	350	236	739	738	668			
STOR CHANGE							13	13									-26			
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358			
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0				
DISCH KCFS	12.0	12.0	14.5	23.8	23.8	26.7	28.0	28.0	28.0											

	28FEB05		2005										2006				
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5919	272	127	163	598	909	1156	509	294	281	371	184	86	98	314	238	319
DEPLETION	388	-11	-5	-7	70	305	500	162	-46	-125	-57	-34	-16	-18	-110	-128	-92
EVAPORATION	404							25	77	96	85	39	18	21	44		
MOD INFLOW	5127	283	132	170	528	604	656	322	263	310	343	179	84	96	380	366	411
RELEASE	5383	119	56	71	298	461	536	553	553	289	243	117	97	143	615	676	555
STOR CHANGE	-256	164	77	98	230	143	120	-231	-290	21	101	62	-13	-47	-235	-310	-144
STORAGE	8773	8937	9013	9112	9342	9485	9606	9374	9084	9105	9205	9267	9254	9207	8972	8661	8517
ELEV FTMSL	2198.5	2199.6	2200.1	2200.8	2202.3	2203.2	2204.0	2202.5	2200.6	2200.7	2201.4	2201.8	2201.7	2201.4	2199.9	2197.8	2196.8
DISCH KCFS	12.0	4.0	4.0	4.0	5.0	7.5	9.0	9.0	9.0	4.9	3.9	3.9	7.0	9.0	10.0	11.0	10.0
POWER																	
AVE POWER MW		47	47	47	59	89	107	107	106	57	47	47	83	106	117	127	115
PEAK POW MW		169	169	170	172	174	175	173	170	170	171	172	172	171	169	166	164
ENERGY GWH	765.2	16.8	7.9	10.2	42.6	66.2	77.2	79.6	78.9	41.2	34.7	16.8	13.9	20.4	87.1	94.8	77.1
--GARRISON--																	
NAT INFLOW	9185	340	158	204	881	1136	2542	1607	454	349	491	203	95	108	136	201	281
DEPLETION	965	2	1	1	3	211	714	482	63	-120	6	-84	-39	-45	-98	-79	-54
CHAN STOR	23	90			-11	-28	-17			45	10	0	-34	-22	-11	-11	11
EVAPORATION	472							29	92	114	99	44	21	23	50		
REG INFLOW	13153	547	213	274	1164	1358	2347	1649	852	689	639	359	176	250	788	945	902
RELEASE	13468	387	167	214	893	1291	1309	1353	1353	952	803	389	264	317	1230	1353	1194
STOR CHANGE	-315	160	46	60	272	67	1038	296	-501	-263	-164	-30	-87	-67	-442	-408	-292
STORAGE	10537	10697	10743	10803	11075	11142	12180	12476	11975	11713	11548	11519	11431	11364	10922	10515	10222
ELEV FTMSL	1808.2	1809.0	1809.2	1809.5	1810.7	1811.0	1815.5	1816.7	1814.6	1813.5	1812.8	1812.7	1812.3	1812.0	1810.0	1808.1	1806.7
DISCH KCFS	22.0	13.0	12.0	12.0	15.0	21.0	22.0	22.0	22.0	16.0	13.1	13.1	19.0	20.0	22.0	22.0	21.5
POWER																	
AVE POWER MW		133	124	124	156	218	233	237	237	171	139	138	200	210	208	225	217
PEAK POW MW		294	294	295	299	299	313	316	310	307	305	304	303	302	297	291	287
ENERGY GWH	1708.2	48.0	20.8	26.8	112.0	162.3	167.4	176.6	176.1	123.0	103.3	49.8	33.6	40.3	154.8	167.5	145.9
--OAHE--																	
NAT INFLOW	1408	265	123	159	245	134	288	110	28	86	7	-7	-3	-3	-64	-16	56
DEPLETION	597	22	10	13	46	65	126	147	96	24	-8	2	1	1	11	16	25
CHAN STOR	2	48	5		-16	-32	-5			33	16		-34	-6	0	-11	3
EVAPORATION	383							25	75	92	78	35	16	19	42		
REG INFLOW	13898	677	285	360	1076	1328	1466	1291	1209	955	756	346	210	288	1113	1310	1228
RELEASE	14221	439	271	355	1232	1484	1369	1702	1688	1375	974	341	100	140	991	773	987
STOR CHANGE	-324	238	14	5	-156	-155	96	-411	-479	-420	-218	5	110	148	121	536	241
STORAGE	11071	11309	11323	11327	11171	11016	11112	10702	10223	9803	9585	9590	9700	9848	9970	10506	10747
ELEV FTMSL	1576.9	1578.1	1578.1	1578.2	1577.4	1576.6	1577.1	1575.1	1572.6	1570.3	1569.1	1569.2	1569.8	1570.6	1571.3	1574.1	1575.3
DISCH KCFS	17.8	14.8	19.5	19.9	20.7	24.1	23.0	27.7	27.4	23.1	15.8	11.5	7.2	8.8	16.1	12.6	17.8
POWER																	
AVE POWER MW		161	213	217	225	261	249	297	290	241	164	118	74	92	168	133	190
PEAK POW MW		554	554	554	550	546	549	538	525	513	507	507	510	515	518	533	539
ENERGY GWH	1832.1	57.8	35.8	46.8	162.1	194.0	179.0	220.9	216.0	173.7	122.0	42.6	12.5	17.7	125.1	98.8	127.4
--BIG BEND--																	
EVAPORATION	129							8	24	31	27	12	6	7	14		
REG INFLOW	14093	439	271	355	1232	1484	1369	1694	1663	1344	947	329	94	134	977	773	987
RELEASE	14093	439	271	355	1232	1484	1369	1694	1663	1344	947	329	94	134	977	773	987
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	17.8	14.8	19.5	19.9	20.7	24.1	23.0	27.6	27.1	22.6	15.4	11.0	6.8	8.4	15.9	12.6	17.8
POWER																	
AVE POWER MW		70	92	93	97	113	108	129	127	107	77	56	34	43	79	62	85
PEAK POW MW		518	510	509	509	509	509	509	509	523	538	538	538	538	538	538	529
ENERGY GWH	813.6	25.1	15.4	20.1	69.8	84.0	77.6	95.9	94.2	77.3	57.5	20.1	5.8	8.2	58.9	46.4	57.3
--FORT RANDALL--																	
NAT INFLOW	476	88	41	53	68	55	191	21	57	-16	-82	-4	-2	-2	-10	19	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	1	0	1	3	3	3
EVAPORATION	142							10	32	39	29	11	5	5	13		
REG INFLOW	14346	525	311	406	1296	1530	1548	1687	1674	1283	836	313	87	126	962	760	1003
RELEASE	14347	265	164	389	1296	1530	1548	1687	1674	1598	1567	519	87	126	689	670	539
STOR CHANGE	0	260	148	17	0	0	0	0	-315	-731	-206	0	0	273	90	464	
STORAGE	3124	3384	3532	3549	3549	3549	3549	3549	3549	3234	2503	2297	2297	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.4	1341.0	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	9.7	8.9	11.8	21.8	21.8	24.9	26.0	27.4	27.2	26.9	25.5	17.4	6.3	7.9	11.2	10.9	9.7
POWER																	
AVE POWER MW		73	99	183	183	209	218	230	228	221	198	128	46	58	83	83	77
PEAK POW MW		344	351	352	352	352	352	352	352	337	291	276	276	276	297	303	332
ENERGY GWH	1414.1	26.4	16.6	39.6	131.8	155.2	157.0	171.0	169.6	159.5	147.4	46.1	7.7	11.1	61.8	61.8	51.5
--GAVINS POINT--																	
NAT INFLOW	1252	91	42	55	125	137	144	79	79	57	109	47	22	25	70	68	102
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-6	-19	0	-6	-2	-3	0	1	3	15	21	-3	-6	1	2
EVAPORATION	47							3	9	11	10	5	2	2	5		
REG INFLOW	15437	358	201	425	1416	1642	1666	1722	1735	1649	1666	571	126	143	737	738	643
RELEASE	15437	358	201	425	1416	1642	1666	1722	1722	1636	1666	571	126	143	737	738	669
STOR CHANGE								13	13								-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0	
DISCH KCFS	12.0	12.0	14.5	23.8	23.8	26.7	28.0	28.0	28.0	27.5	27.1	19.2	9.0				

	2006				2007												
	INI-SUM	15MAR	22MAR	31MAR	30APR	31MAY	30JUN	31JUL	31AUG	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	28FEB
--FORT PECK--																	
NAT INFLOW	5961	274	128	164	602	915	1164	513	296	283	374	185	86	99	317	240	321
DEPLETION	400	-11	-5	-7	70	306	504	169	-41	-125	-59	-35	-16	-19	-110	-128	-93
EVAPORATION	397						24	76	95	83	38	18	20	43			
MOD INFLOW	5164	285	133	171	532	609	660	320	261	313	350	182	85	97	384	368	414
RELEASE	5403	119	56	71	298	461	536	553	553	298	250	121	97	143	615	676	555
STOR CHANGE	-239	166	77	100	234	148	124	-234	-292	15	100	61	-12	-46	-231	-308	-141
STORAGE	8517	8683	8761	8860	9095	9242	9367	9133	8841	8856	8956	9017	9005	8959	8728	8419	8278
ELEV FTMSL	2196.8	2197.9	2198.4	2199.1	2200.7	2201.6	2202.5	2200.9	2199.0	2199.1	2199.7	2200.2	2200.1	2199.8	2198.2	2196.1	2195.1
DISCH KCFS	10.0	4.0	4.0	4.0	5.0	7.5	9.0	9.0	9.0	5.0	4.1	4.1	7.0	9.0	10.0	11.0	10.0
POWER																	
AVE POWER MW		46	47	47	59	88	106	106	105	58	48	48	82	105	116	126	113
PEAK POW MW		166	167	168	170	171	173	170	168	168	169	169	169	169	167	163	162
ENERGY GWH	760.9	16.6	7.8	10.1	42.2	65.7	76.5	78.9	78.2	42.1	35.4	17.2	13.8	20.2	86.4	93.7	76.1
--GARRISON--																	
NAT INFLOW	9293	344	160	206	891	1150	2572	1626	460	353	496	205	96	109	137	204	284
DEPLETION	1053	-1	0	-1	-2	211	724	498	68	-123	1	-87	-41	-46	-70	-50	-28
CHAN STOR	0	68			-11	-28	-17			44	10		-32	-22	-11	-11	11
EVAPORATION	465						29	91	112	97	44	20	23	49			
REG INFLOW	13178	531	216	278	1179	1372	2367	1653	855	705	658	369	181	253	761	919	879
RELEASE	13469	387	167	214	893	1291	1309	1353	1353	952	804	389	264	317	1230	1353	1194
STOR CHANGE	-291	144	50	64	287	81	1058	300	-498	-247	-145	-20	-83	-64	-468	-434	-315
STORAGE	10222	10367	10416	10480	10767	10848	11905	12205	11707	11460	11315	11295	11212	11148	10680	10246	9931
ELEV FTMSL	1806.7	1807.4	1807.7	1808.0	1809.3	1809.7	1814.3	1815.6	1813.5	1812.4	1811.8	1811.7	1811.3	1811.0	1808.9	1806.9	1805.3
DISCH KCFS	21.5	13.0	12.0	12.0	15.0	21.0	22.0	22.0	22.0	16.0	13.1	13.1	19.0	20.0	20.0	22.0	21.5
POWER																	
AVE POWER MW		132	122	122	154	216	230	235	235	169	138	138	199	208	206	223	215
PEAK POW MW		289	290	291	294	296	309	313	307	304	302	301	300	300	293	287	283
ENERGY GWH	1692.5	47.4	20.5	26.5	110.7	160.5	165.9	175.2	174.6	122.0	102.6	49.5	33.4	40.0	153.6	165.8	144.3
--OAHE--																	
NAT INFLOW	1429	269	125	161	249	136	293	112	29	87	7	-7	-3	-4	-65	-16	56
DEPLETION	613	23	11	14	47	66	129	151	100	25	-8	2	1	1	11	16	26
CHAN STOR	-1	46	5		-16	-32	-5			33	17		-34	-6	0	-11	3
EVAPORATION	374						24	74	90	76	34	16	19	41			
REG INFLOW	13911	678	287	362	1079	1329	1468	1290	1208	958	759	346	210	289	1113	1309	1227
RELEASE	14209	437	270	353	1230	1483	1365	1702	1686	1375	976	341	100	140	991	773	986
STOR CHANGE	-298	241	17	8	-151	-154	102	-412	-478	-417	-217	6	110	148	122	536	241
STORAGE	10747	10988	11005	11013	10862	10708	10811	10399	9921	9503	9286	9292	9402	9550	9672	10208	10449
ELEV FTMSL	1575.3	1576.5	1576.6	1576.6	1575.9	1575.1	1575.6	1573.5	1571.0	1568.7	1567.5	1567.5	1568.1	1568.9	1569.6	1572.5	1573.8
DISCH KCFS	17.8	14.7	19.5	19.8	20.7	24.1	22.9	27.7	27.4	23.1	15.9	11.5	7.2	8.8	16.1	12.6	17.7
POWER																	
AVE POWER MW		158	210	214	223	258	246	294	287	239	163	117	74	91	166	131	188
PEAK POW MW		546	546	546	542	538	541	530	517	505	499	499	502	506	510	525	531
ENERGY GWH	1812.1	56.9	35.3	46.2	160.3	192.0	176.8	218.8	213.6	171.8	120.9	42.1	12.4	17.5	123.7	97.7	126.1
--BIG BEND--																	
EVAPORATION	129						8	24	31	27	12	6	7	14			
REG INFLOW	14080	437	270	353	1230	1483	1365	1694	1661	1344	949	329	94	134	977	773	986
RELEASE	14080	437	270	353	1230	1483	1365	1694	1661	1344	949	329	94	134	977	773	986
STORAGE	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682	1682
ELEV FTMSL	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	17.8	14.7	19.5	19.8	20.7	24.1	22.9	27.6	27.0	22.6	15.4	11.0	6.8	8.4	15.9	12.6	17.7
POWER																	
AVE POWER MW		70	91	93	97	113	107	129	126	107	77	56	34	43	79	62	85
PEAK POW MW		518	510	509	509	509	509	509	509	523	538	538	538	538	538	538	529
ENERGY GWH	812.9	25.0	15.3	20.0	69.7	84.0	77.3	95.9	94.1	77.3	57.6	20.1	5.8	8.2	58.9	46.4	57.2
--FORT RANDALL--																	
NAT INFLOW	489	90	42	54	70	56	195	21	59	-16	-84	-4	-2	-2	-10	20	
DEPLETION	80	1	1	1	4	9	12	18	15	7	1	0	0	3	3	3	
EVAPORATION	142						10	32	39	29	11	5	5	13			
REG INFLOW	14347	526	311	406	1296	1530	1548	1687	1674	1283	836	313	87	126	962	760	1003
RELEASE	14347	265	164	389	1296	1530	1548	1687	1674	1598	1567	519	87	126	689	670	539
STOR CHANGE	0	261	148	17			0	0	-315	-731	-206	0	0	273	90	464	
STORAGE	3123	3384	3532	3549	3549	3549	3549	3549	3549	3234	2503	2297	2297	2296	2569	2659	3123
ELEV FTMSL	1350.0	1353.2	1355.0	1355.2	1355.2	1355.2	1355.2	1355.2	1355.2	1351.4	1341.0	1337.5	1337.5	1337.5	1342.1	1343.5	1350.0
DISCH KCFS	9.7	8.9	11.8	21.8	21.8	24.9	26.0	27.4	27.2	26.9	25.5	17.4	6.3	7.9	11.2	10.9	9.7
POWER																	
AVE POWER MW		73	99	183	183	209	218	230	228	222	198	128	46	58	83	83	77
PEAK POW MW		344	351	352	352	352	352	352	352	337	291	276	276	276	297	303	332
ENERGY GWH	1414.1	26.4	16.6	39.6	131.8	155.2	157.0	171.0	169.6	159.5	147.4	46.1	7.7	11.1	61.8	61.8	51.5
--GAVINS POINT--																	
NAT INFLOW	1252	91	42	55	125	137	144	79	79	57	109	47	22	25	70	68	102
DEPLETION	114	0	0	0	5	19	24	39	10	-5	2	5	2	3	10	1	
CHAN STOR	-1	2	-6	-19	0	-6	-2	-3	0	1	3	15	21	-3	-6	1	2
EVAPORATION	47						3	9	11	10	5	2	2	5			
REG INFLOW	15437	358	201	425	1416	1642	1666	1722	1735	1649	1666	571	126	143	737	738	643
RELEASE	15437	358	201	425	1416	1642	1666	1722	1722	1636	1666	571	126	143	737	738	669
STOR CHANGE							13	13									-26
STORAGE	358	358	358	358	358	358	358	358	371	384	384	384	384	384	384	384	358
ELEV FTMSL	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1207.0	1206.0
DISCH KCFS	12.0	12.0	14.5	23.8	23.8	26.7	28.0	28.0	28.0	27.5	27.1	19.2	9.0	9.0	12.0	12.0	12.0