

# LNG Construction Inspection – Inspection Modules

## Introduction & Instructions

The construction of an LNG facility usually takes approximately two years. The PHMSA **Form 18 Evaluation of LNG Facility Siting, design, Construction, and Equipment (Rev. 3/18/09)** (“Form 18”) consists of 40 pages addressing the construction requirements of 49 CFR Part 193. The purpose of this document is to break the Form 18 into inspection modules that can be individually accomplished more or less bimonthly so that all of the elements of the Form 18 can be addressed prior to operation of new LNG facilities. Note that not all modules will apply to all LNG facilities, more than one module may be completed per site visit, and an individual module may take more than one site visit to complete. The modules are solely for the convenience of the Inspector and the Operator. All of the usual inspection procedures apply and the entire Form 18 must be completed before the inspection is complete and the documentation added to the permanent Operator File..

Use of the Form 18 Post Inspection Memorandum (PIM) is NOT recommended. An Activity ID should be established for each new LNG facility. Information regarding each site visit should be recorded as a separate assignment under the same Activity ID number. At the conclusion of the inspection, the Activity Report should be used as the Post Inspection Memorandum. Be sure to consider this as the Assignment Activity report is prepared for each site visit. Above all, keep up with the Assignment Activity entries and the entries into the overall Form 18 as each site visit is completed.

A completed Form 18 should be submitted to the Regional Director within 60 days of completion of the inspection. The Assignment Activity Report (serving as the PIM) should be completed and submitted to the Regional Director within 30 days of completion of the inspection (completion of all Modules) and must be filed with the final copy of the Form 18.

## Modules (hyperlinked)

1. [Preliminaries – Cover Sheet, Subpart A – Reporting & Subpart B – Siting Requirements](#) (pp. 2-6)
2. [Subpart C – Design; Subpart D- Construction; NFPA 59A Emergency Shutdown](#) (pp. 7-10)
3. [Protective Enclosures, Security, Power Sources](#) (pp. 11-12)
4. [Plant Siting & Layout, Soil Protection, Process Equipment & Vaporization Facilities, General & Basic Design](#) (pp. 13-17)
5. [Seismic Design, Container Insulation, Foundations, API 620 Tanks & Field-Fabricated Containers \(193.2101\)](#) (pp. 18-20)
6. [High Pressure Tanks \(>15 psi\)](#) (p. 21-22)
7. [Concrete Tanks, Relief Devices, Piping Systems & Components, Welded Pipe Tests & Inspection](#) (pp. 23-26)
8. [Corrosion Control \(NFPA 59A & 193.2304\)](#) (p. 27)
9. [LNG Level Gauging, Refrigerant & Process Fluids, Pressure & Vacuum Gauges, Temperature Monitoring](#) (p. 28)
10. [Electrical Equipment, Grounding & Bonding](#) (p. 29-30)
11. [Transfer of LNG & Refrigerants](#) (pp. 31-32)
12. [Fire Protection Provisions](#) (pp. 33-34)
13. [ASME Small Containers \(max 100,000 gal/tank and 280,000 gal aggregate\)](#) (pp. 35-38)
14. [Construction Acceptance \(193.2303\); Design & Fabrication \(193.2703\); Construction, Installation, Inspection and Testing \(193.2705\); Records \(193.2119\); Warning Signs \(193.2917\)](#) (pp. 39-40)

# Module 1

## Preliminaries – Cover Sheet & Subpart B – Siting Requirements

<b>Name of Operator:</b>			
<b>OP ID No.</b> <sup>(1)</sup>		<b>Unit ID No.</b>	
<b>H.Q. Address:</b>		<b>System/Unit Name &amp; Address:</b>	
<b>Co. Official:</b>		<b>Activity Record ID#:</b>	
<b>Phone No.:</b>		<b>Phone No.:</b>	
<b>Fax No.:</b>		<b>Fax No.:</b>	
<b>Emergency Phone No.:</b>		<b>Emergency Phone No.:</b>	
<b>Persons Interviewed</b>		<b>Titles</b>	
<b>OPS Representative(s)</b>		<b>Inspection Date(s)</b>	
<b>Company System Maps (copies for Region Files):</b>			
<b>Type of Facility:</b>	<b>Base Load</b> <input type="checkbox"/>	<b>Satellite</b> <input type="checkbox"/>	<b>Peak Shaving</b> <input type="checkbox"/> <b>Mobile/Temporary</b> <input type="checkbox"/>
Note: Some mobile and temporary LNG facilities must meet the requirements of Section 2.3.4 of NFPA 59A (2001 edition) in lieu of the requirements of Part 193 per 193.2019.			
<input type="checkbox"/> <b>Replacement, relocation, or significant alteration of an existing LNG facility</b>		<input type="checkbox"/> <b>Construction of a new LNG facility</b>	
<b>Year original facility was placed into operation:</b>		<b>Construction start date:</b>	
<b>Rated plant send-out capacity (mmcf/d):</b>		<b>Rated plant send-out capacity (mmcf/d):</b>	
Existing <input type="checkbox"/>	Project completion <input type="checkbox"/>	Rated liquefaction rate (mmcf/d equivalent):	
<b>Rated liquefaction rate (mmcf/d equivalent):</b>		<b>Type of liquefaction Cycle:</b>	
Existing <input type="checkbox"/>	Project completion <input type="checkbox"/>	<b>Number of vaporizers &amp; capacities:</b>	

<b>Project Description</b>
----------------------------

**SUBPART A – GENERAL**

		<b>193.2011 REPORTING</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
	Incidents, safety-related conditions, and annual pipeline summary data for LNG plants or facilities must be reported in accordance with the requirements of Part 191 of this subchapter.					
191.22	(c) Changes. Each operator of a gas pipeline, gas pipeline facility, LNG plant or LNG facility must notify PHMSA electronically through the National Registry of Pipeline and LNG Operators at <a href="https://opsweb.phmsa.dot.gov">https://opsweb.phmsa.dot.gov</a> of certain events. (1) An operator must notify PHMSA of any of the following events not later than 60 days before the event occurs: (i) Construction or any planned rehabilitation, replacement, modification, upgrade, uprate, or update of a facility, other than a section of line pipe, that costs \$10 million or more. If 60 day notice is not feasible because of an emergency, an operator must notify PHMSA as soon as practicable; (iii) Construction of a new LNG plant or LNG facility.					

**Comments:**

**SUBPART B – SITING REQUIREMENTS**

		<b>' 193.2051 SCOPE</b>
		Each LNG facility designed, constructed, replaced, relocated or significantly altered after March 31, 2000 must be provided with <b>siting requirements</b> in accordance with the requirements of this part and of NFPA 59A.

		<b>' 193.2057 THERMAL RADIATION PROTECTION</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
	Each LNG container and LNG transfer system must have a thermal exclusion zone in accordance with section 2.2.3.2 of NFPA 59A with the following exception (to NFPA-59A 2.2.3.2): (a) The thermal radiation distances shall be calculated using Gas Research Institute's (GRI) report GRI-04/0032, (available as the "LNGFIRE3" computer model produced by GRI), <b>or other alternate models which take into account the same physical factors and have been validated by experimental test data shall be permitted subject to the Administrator's approval.</b> (b) In calculating exclusion distances, the wind speed producing the maximum exclusion distances shall be used except for <b>wind speeds that occur less than 5 percent of the time</b> based on recorded data for the area.					

		193.2057 THERMAL RADIATION PROTECTION			
		S	U	N/A	N/C
(c) In calculating exclusion distances, the <b>ambient temperature</b> and <b>relative humidity</b> that produce the maximum exclusion distances shall be used except for values that <b>occur less than five percent of the time</b> based on recorded data for the area.					
NFPA 59A 2.2.3.2	Provisions shall be made to prevent thermal radiation flux from a fire from exceeding the following limits and damaging effects of fire reaching beyond a property line that can be built upon: ( <i>Note:</i> Volume of LNG determined in accordance with 2.2.2.1)				
	(1) 1600 Btu/hr/ft <sup>2</sup> (5000 W/m <sup>2</sup> ) at a property line that can be built upon for ignition of a design spill (as specified in 2.2.3.5),				
	(2) 1600 Btu/hr/ft <sup>2</sup> (5000 W/m <sup>2</sup> ) at the nearest point located outside the owner's property line that, <b>at the time of plant siting</b> , is used for outdoor assembly by groups of 50 or more persons for a fire over an impounding area containing a volume, <i>V</i> ,				
	(3) 3000 Btu/hr/ft <sup>2</sup> (9000 W/m <sup>2</sup> ) at the nearest point of the building or structure outside the owner's property line <b>that is in existence at the time of plant siting</b> and used for occupancies classified by NFPA 101®, <i>Life Safety Code</i> ®, as assembly, educational, health care, detention and correction or residential for a fire over an impounding area containing a volume, <i>V</i> , and				
	(4) 10,000 Btu/hr/ft <sup>2</sup> (30,000 W/m <sup>2</sup> ) at a property line that can be built upon for a fire over an impounding area containing a volume, <i>V</i> .				

**Comments:**

193.2059 FLAMMABLE VAPOR-GAS DISPERSION PROTECTION		S	U	N/A	N/C
	<p>Each LNG container and LNG transfer system must have a dispersion exclusion zone in accordance with sections 2.2.3.3 and 2.2.3.4 of NFPA 59A with the following exception (to NFPA-59A 2.2.3.3 and 2.2.3.4):</p> <p>(a) Flammable vapor-gas dispersion distances must be determined in accordance with the model described in the Gas Research Institute report GRI-89/0242 and Gas Research Institute report GRI-96/0396.5, <b>or other alternate models which take into account the same physical factors and have been validated by experimental test data shall be permitted, subject to the Administrator's approval</b></p> <p>(b) The following dispersion parameters must be used in computing dispersion distances:</p> <p>(1) Average gas concentration in air = 2.5 percent.</p> <p>(2) Dispersion conditions are a combination of those which result in longer predicted downwind dispersion distances than other weather <b>conditions at the site at least 90 percent of the time</b>, based on figures maintained by National Weather Service of the U.S. Department of Commerce, or as an <b>alternative where the model used gives longer distances at lower wind speeds</b>, percent, and atmospheric temperature = average in the region.</p> <p>(3) The elevation for contour (receptor) output H = 0.5 meters.</p> <p>(4) A surface roughness factor of 0.03 meters shall be used. <b>Higher values for the roughness factor may be used if it can be shown that the terrain both upwind and downwind of the vapor cloud has dense vegetation and that the vapor cloud height is more than ten times the height of the obstacles encountered by the vapor cloud.</b></p> <p>(c) The design spill shall be determined in accordance with section 2.2.3.5.</p>				
NFPA 59A 2.2.3.3	The spacing of an LNG tank impoundment to the property line that can be built upon shall be such that, in the event of an LNG spill specified in 2.2.3.5, an average concentration of methane in air of 50 percent of the lower flammability limit (LFL) does not extend beyond the property line that can be built upon, using calculations in 2.2.3.3.				
NFPA 59A 2.2.3.4	Make provisions to minimize the possibility of a flammable mixture of vapors from a design spill specified in 2.2.3.5, as appropriate, reaching a property line that can be built upon and that would result in a distinct hazard. Flammable mixture dispersion distances shall be determined in accordance 2.2.3.4 (a-b).				

**Comments:**

	<b>' 193.2067 WIND FORCES</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
(a) LNG facilities must be designed to withstand without loss of structural or functional integrity:					
(1) The direct effect of wind forces;					
(2) The pressure differential between the interior and exterior of a confining, or partially confining, structure; and					
(3) In the case of impounding systems for LNG storage tanks, impact forces and potential penetrations by wind borne missiles.					
(b) The wind forces at the location of the specific facility must be based on one of the following:					
(1) For shop fabricated containers of LNG or other hazardous fluids with a capacity of not more than 70,000 gallons, use applicable wind load data in ASCE 7-05.					
(2) For all other LNG facilities					
(i) An assumed sustained wind velocity of not less than 150 miles per hour, unless the Administrator finds a lower velocity is justified by adequate supportive data; or					
(ii) The most critical combination of wind velocity and duration, with respect to the effect on the structure.					

**Comments:**

[Return to List](#)

## Module 2

### Subpart C – Design; Subpart D- Construction; NFPA 59A Emergency Shutdown

<b>SUBPART C – DESIGN</b> <b>SUBPART D- CONSTRUCTION</b>
---

	S	U	N/A	N/C
<b>193.2155 STRUCTURAL REQUIREMENTS</b>				
(a) The structural members of an impoundment system must be designed and constructed to prevent impairment of the system’s performance reliability and structural integrity as a result of the following:				
(1) Imposed loading from— (i) Full hydrostatic head of impounded LNG; (ii) Hydrodynamic action from injected material; (iii) Impingement of LNG jet trajectory discharged at any predictable angle; (iv) Anticipated hydraulic forces from a credible opening in the component or item served, assuming the discharge pressure equals design pressure.				
(2) Erosive action from a spill, including jetting of spilling LNG, and any other anticipated erosive action including surface water runoff, ice formation, dislodgement of ice formation, and snow removal.				
(3) Effect of the temperature, any thermal gradient, and any other anticipated degradation resulting from sudden or localized contact with LNG.				
(4) Fire exposure from impounded LNG or LNG from other sources.				
(5) If applicable, the potential impact and loading on the dike due to – (i) Collapse of the component or item served or adjacent components; (ii) If the LNG facility adjoins the right-of-way of any highway or railroad, collision by or explosion of a train, tank car, or tank truck that could reasonably be expected to cause the most severe loading.				
(b) An LNG storage tank must not be located within a horizontal distance of one mile (1.6 km) from the ends, or ¼ mile (0.4 km) from the nearest point of a runway, whichever is longer. The height of LNG structures in the vicinity of an airport must comply with FAA, 14 CFR Section 1.1.				

**Comments:**

	S	U	N/A	N/C
<b>193.2161 DIKES</b>				
An outer wall of a component served by an impounding system may not be used as a dike unless the outer wall is constructed of concrete.				

**Comments:**

	<b>193.2167 COVERED SYSTEMS</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
A covered impounding system is prohibited except for <b>concrete wall designed tanks</b> where the concrete wall is an outer wall serving as a dike.					

**Comments:**

	<b>193.2173 WATER REMOVAL</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
(a) Impoundment areas must be designed so all areas drain completely, to prevent water collection. Drainage pumps and piping must be provided to remove water from collecting in the impoundment area. Alternative means of draining approved by the Administrator may be acceptable.					
(b) The water removal system must have adequate capacity to remove water at a rate equal to 25% of the maximum predictable collection rate from a storm of 10-year frequency and 1-hour duration, and other natural causes.					
(c) Sump pumps for water removal must: (1) Be operated as necessary to keep the impounding space as dry as practical; and (2) If designed for automatic operation, must have redundant automatic shutdown controls to prevent operation when LNG is present.					

**Comments:**

	<b>' 193.2181 IMPOUNDMENT CAPACITY: LNG STORAGE TANKS</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
Each impounding system serving an LNG storage tank must have a minimum volumetric liquid impoundment capacity of: (a) 110 percent of the LNG tank's maximum liquid capacity for an impoundment serving a single tank; (b) 100 percent of all tanks or 110 percent of the largest tank's maximum liquid capacity, whichever is greater, for the impoundment serving more than one tank; or (c) If the dike is designed to account for a surge in the event of catastrophic failure, then the impoundment capacity may be reduced to 100 percent in lieu of 110 percent.					

**Comments:**



	<b>' 193.2187 NONMETALLIC MEMBRANE LINER</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
A flammable nonmetallic membrane liner may not be used as an inner container in a storage tank.					

**Comments:**

	<b>' 193.2441 CONTROL CENTER</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
Each LNG plant must have a control center from which operations and warning devices are monitored as required by this part. A control center must have the following capabilities and characteristics:					
(a) It must be located apart or protected from other LNG facilities so that it is operational during a controllable emergency.					
(b) Each remotely actuated control system and each automatic shutdown control system required by this part must be operable from the control center.					
(c) Each control center must have personnel in continuous attendance while any of the components under its control are in operation, unless the control is being performed from another control center which has personnel in continuous attendance.					
(d) If more than one control center is located at an LNG Plant, each control center must have more than one means of communication with each other center.					
(e) Each control center must have a means of communicating a warning of hazardous conditions to other locations within the plant frequented by personnel.					

	<b>' 193.2445 SOURCES OF POWER</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
(a) Electrical control systems, means of communication, emergency lighting, and firefighting systems must have at least two sources of power which function so that failure of one source does not affect the capability of the other source.					
(b) Where auxiliary generators are used as a second source of electrical power: (1) They must be located apart or protected from components so that they are not unusable during a controllable emergency; and (2) Fuel supply must be protected from hazards.					

	<b>' 193.2519 COMMUNICATION SYSTEMS.</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
(a) Each LNG plant must have a primary communication system that provides for verbal communications between all operating personnel at their work stations in the LNG plant.					
(b) Each LNG plant in excess of 70,000 gallons (265,000 liters) storage capacity must have an emergency communication system that provides for verbal communications between all persons and locations necessary for the orderly shutdown of operating equipment and the operation of safety equipment in time of emergency. The emergency communication system must be independent of and physically separated from the primary communication system and the security communication system under ' 193.2909.					
(c) Each communication system required by this part must have an auxiliary source of power, except sound-powered equipment.					

**Comments:**

Unless otherwise noted, all references are to 49CFR Part 193. S - Satisfactory U - Unsatisfactory N/A - Not Applicable N/C - Not Checked  
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

**Comments:**

NFPA 59A reference	<b>I &amp; E: EMERGENCY SHUTDOWN Ref. 193.2101</b>	S	U	N/A	N/C
7.5	<b>Instrumentation</b> for liquefaction, storage, and vaporization facilities shall be designed so that, if a power or instrument air failure occurs, the system will proceed to a <b>failsafe condition</b> and maintain that condition until the operators take appropriate action to reactivate or secure the system.				

**Comments:**

[Return to List](#)

### Module 3

#### Protective Enclosures, Security, Power Sources

		<b>' 193.2905 PROTECTIVE ENCLOSURES.</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
(a) The following facilities must be surrounded by a protective enclosure (1) Storage tanks; (2) Impounding systems; (3) Vapor barriers; (4) Cargo transfer systems; (5) Process, liquefaction, and vaporization equipment; (6) Control rooms and stations; (7) Control systems; (8) Fire control equipment; (9) Security communications systems; and (10) Alternative power sources. The protective enclosure may be one or more separate enclosures surrounding a single facility or multiple facilities.						
(b) Ground elevations outside a protective enclosure must be graded in a manner that does not impair the effectiveness of the enclosure.						
(c) Protective enclosures may not be located near features outside of the facility, such as trees, poles, or buildings, which could be used to breach the security.						
(d) At least two accesses must be provided in each protective enclosure and be located to minimize the escape distance in the event of emergency.						
(e) Each access must be locked unless it is continuously guarded. During normal operations, an access may be unlocked only by persons designated in writing by the operator. During an emergency, a means must be readily available to all facility personnel within the protective enclosure to open each access.						
		<b>' 193.2907 PROTECTIVE ENCLOSURE CONSTRUCTION.</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
(a) Each protective enclosure must have sufficient strength and configuration to obstruct unauthorized access to the facilities enclosed.						
(b) Openings in or under protective enclosures must be secured by grates, doors or covers of construction and fastening of sufficient strength such that the integrity of the protective enclosure is not reduced by any opening.						
		<b>' 193.2909 SECURITY COMMUNICATIONS. ' 193.2911 SECURITY LIGHTING. ' 193.2913 SECURITY MONITORING.</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
.2909	A means must be provided for:					
	(a) Prompt communications between personnel having supervisory security duties and law enforcement officials; and (b) Direct communications between all on-duty personnel having security duties and all control rooms and control stations.					
.2911	Where security warning systems are not provided for security monitoring under ' 193.2913, the area around the facilities listed under ' 193.2905(a) and each protective enclosure must be illuminated with a minimum in service lighting intensity of not less than 2.2 lux (0.2 ft <sup>c</sup> ) between sunset and sunrise.					

		' 193.2909 SECURITY COMMUNICATIONS.	S	U	N/A	N/C
		' 193.2911 SECURITY LIGHTING.				
		' 193.2913 SECURITY MONITORING.				
.2913	Each protective enclosure and the area around each facility listed in ' 193.2905(a) must be monitored for the presence of unauthorized persons. Monitoring must be by visual observation in accordance with the schedule in the security procedures under ' 193.2903(a) or by security warning systems that continuously transmit data to an attended location. At an LNG plant with less than 40,000 m <sup>3</sup> (250,000 bbl) of storage capacity, only the protective enclosure must be monitored.					

		' 193.2915 ALTERNATIVE POWER SOURCES.	S	U	N/A	N/C
		An alternative source of power that meets the requirements of ' 193.2445 must be provided for security lighting and security monitoring and warning systems required under ' ' 193.2911 and 193.2913.				

**Comments:**

[Return to List](#)

## Module 4

### Plant Siting & Layout, Soil Protection, Process Equipment & Vaporization Facilities, General & Basic Design

NFPA 59A reference	PLANT SITING AND LAYOUT Ref. 193.2051 & .2101	S	U	N/A	N/C
2.1.2	Site preparation included for retention of spilled LNG, flammable refrigerants, liquids, and surface water drainage within limits of the plant.				
2.1.3	The maximum allowable working pressure shall be specified for all components.				
2.1.4	Soil and general investigations of the site shall be made to determine the design basis for the facility.				
2.2.1.1	Provisions made to minimize the possibility of the accidental discharge of LNG at containers from endangering adjoining property or important process equipment and structures or from reaching waterways in accordance with one of three stated methods.				
2.2.1.2(4)	Areas immediately surrounding flammable refrigerant and flammable liquid storage tanks shall be graded, drained, or provided with impoundment in a manner that minimizes the possibility of accidental spills and leaks important structures, equipment, or adjoining property or that could reach waterway.				
2.2.1.4	Flammable liquid and flammable refrigerant storage tanks shall not be located within an LNG container impounding area.				
2.2.3.6	LNG container impounding areas located so that the heat flux from a fire over the impounding area shall not cause major structural damage to any LNG marine carrier that could prevent its movement.				
2.2.3.7	Containers with an aggregate storage of 70,000 gal (265 m <sup>3</sup> ) or less on one site shall be permitted to be installed in accordance with Table 2.2.4.1 and be equipped with failsafe equipment and appurtenances.				
2.2.4.1	The minimum distance between LNG containers or flammable refrigerants tanks and exposures shall be in accordance with Table 2.2.4.1.				
2.2.4.2	A clear space of at least 3 ft (0.9 m) shall be provided for access to all isolation valves serving multiple containers.				
2.2.4.3	LNG containers of greater than 125-gal (0.5-m <sup>3</sup> ) capacity shall not be located in buildings.				
2.2.5.1	If intermediate heat transfer fluid is flammable, vaporizers and their primary heat sources shall be located $\geq$ 50 ft (15 m) from any other source of ignition. (N/A for nonflammable fluid). (Note: multiple vaporizer installations, adjacent vaporizer or primary heat source shall not be considered to be a source of ignition. Process heaters or other units of fired equipment shall not be considered to be sources of ignition with respect to vaporizer siting if they are interlocked so that they cannot be operated while a vaporizer is operating or while the piping system serving the vaporizer is either cooled down or being cooled down.)				
2.2.5.2	Integral heated vaporizers shall be located $\geq$ 100 ft (30 m) from a property line that can be built upon and $\geq$ 50 ft (15 m) from the following: (1) Any impounded LNG, flammable refrigerant, or flammable liquid ( <i>see</i> 2.2.4), or the paths of travel of such fluids between any other source of accidental discharge and the impounding area (2) LNG, flammable liquid, flammable refrigerant, or flammable gas storage containers or tanks, unfired process equipment containing such fluids, or loading and unloading connections used in the transfer of such fluids (3) Control buildings, offices, shops, and other occupied or important plant structures <i>Exception: Vaporizers used in conjunction with LNG containers having a capacity <math>\leq</math> 70,000 gal (265 m<sup>3</sup>) IAW the exception to 2.2.5.4.</i>				

NFPA 59A reference	PLANT SITING AND LAYOUT Ref. 193.2051 & .2101	S	U	N/A	N/C
2.2.5.3	<b>Heaters or heat sources</b> of remote heated vaporizers shall comply with 2.2.5.2. <i>Exception: If the intermediate heat transfer liquid is nonflammable, the property line clearance and 2.2.5.2(3) shall not apply.</i>				
2.2.5.4	Remote heated, ambient, and process <b>vaporizers</b> shall be located $\geq$ 100 ft (30 m) from a property line that can be built upon. Remote heated and ambient vaporizers shall be permitted to be located within an impounding area. <i>Exception: Vaporizers used in conjunction with LNG containers having a capacity <math>\leq</math> 70,000 gal (265 m<sup>3</sup>) shall be located with respect to the property line IAW Table 2.2.4.1, assuming the vaporizer to be a container with a capacity equal to the largest container to which it is connected.</i>				
2.2.5.5	A clearance $\geq$ 5 ft (1.5 m) shall be maintained between vaporizers.				
2.2.6.1	<b>Process equipment</b> containing LNG, refrigerants, flammable liquids, or flammable gases shall be located $\geq$ 50 ft (15 m) from sources of ignition, a property line that can be built upon, control rooms, offices, shops, and other occupied structures. (Excluding control rooms located in a building housing flammable gas compressors where the building construction complies with 2.3.1).				
2.2.6.2	<b>Fired equipment</b> and other <b>sources of ignition</b> shall be located $\geq$ 50 ft (15 m) from any impounding area or container drainage system				
2.2.7.2	LNG and flammable refrigerant loading and unloading connections shall be $\geq$ 50 ft (15 m) from uncontrolled sources of ignition, process areas, storage containers, control buildings, offices, shops, and other occupied or important plant structures. ( <i>Excluding structures or equipment directly associated with the transfer operation.</i> )				

**Comments:**

NFPA 59A reference	SOIL PROTECTION FOR CRYOGENIC EQUIPMENT Ref. 193.2101 & .2301	S	U	N/A	N/C
2.5	LNG containers, cold boxes, piping and pipe supports, and other cryogenic apparatus shall be designed and constructed properly to prevent damage to these structures and equipment due to freezing or frost heaving in the soil.				

NFPA 59A reference	PROCESS EQUIPMENT & VAPORIZATION FACILITIES Ref. 193.2101, .2301, .2401	S	U	N/A	N/C
3.2.3	<b>Pumps and compressors</b> shall be provided with a pressure relieving device on the discharge to limit the pressure to the maximum safe working pressure of the casing and downstream piping and equipment, unless these are designed for the maximum discharge pressure of the pumps and compressors.				
3.2.4	Each <b>pump</b> shall be provided with an adequate vent, relief valve, or both, that will prevent over-pressuring the pump case during the maximum possible rate of cooldown.				
3.4.2	<b>Boilers</b> shall be designed and fabricated IAW the ASME <i>Boiler and Pressure Vessel Code</i> , Section I, or CSA Standard B 51, <i>Boiler, Pressure Vessel and Pressure Piping Code</i> , and pressure vessels shall be designed and fabricated IAW the ASME <i>Boiler and Pressure Vessel Code</i> , Section VIII, Division 1 or Division 2, or CSA Standard B 51, <i>Boiler, Pressure Vessel and Pressure Piping Code</i> , and shall be <b>code-stamped</b> .				

NFPA 59A reference	PROCESS EQUIPMENT & VAPORIZATION FACILITIES Ref. 193.2101, .2301, .2401	S	U	N/A	N/C
3.4.5	A <b>boil-off and flash gas</b> handling system separate from container relief valves shall be installed for the safe disposal of vapors generated in the process equipment and LNG containers. Boil-off and flash gases shall discharge safely into the atmosphere or into a closed system. The boil-off venting system shall be designed so that it cannot normally inspirate air during operation.				
3.4.6	If <b>internal vacuum conditions</b> can occur in any piping, process vessels, cold boxes, or other equipment, the facilities subject to vacuum shall be designed to withstand the vacuum conditions or provision shall be made to prevent the development of a vacuum in the equipment that might create a hazardous condition. If gas is introduced to obviate this problem, it shall be of such composition or so introduced that it does not create a flammable mixture within the system.				
5.2.1	<b>Vaporizers</b> shall be designed, fabricated, and inspected IAW ASME <i>Boiler and Pressure Vessel Code</i> , Section VIII, Division 1. (Because vaporizers operate over a temperature range of -260°F to +100°F (-162°C to +37.7°C), the rules of the ASME <i>Boiler and Pressure Vessel Code</i> , Section I, Part PVG, are not applicable.				
5.3.1	<b>Manifolded vaporizers</b> shall have both inlet and discharge block valves at each vaporizer.				
5.3.2	The discharge valve of each <b>vaporizer</b> and the piping components and relief valves installed upstream of each vaporizer discharge valve shall be designed for operation at LNG temperatures [-260°F (-162°C)].				
5.3.3	Provide <b>automatic equipment</b> to prevent the discharge of either LNG or vaporized gas into a distribution system at a temperature either above or below the design temperatures of the sendout system. Such automatic equipment shall be independent of all other flow control systems and shall incorporate a line valve(s) used only for emergency purposes.				
5.3.4	Provide two inlet valves to isolate an <b>idle, manifolded vaporizer</b> to prevent leakage of LNG into that vaporizer. Provide a safe means of disposing of the LNG or gas that can accumulate between the valves. [Not required for ambient vaporizers having inlets ≤ 2 in. (50 mm).]				
5.3.5	Provide each <b>heated vaporizer</b> with a device (operated both locally and remotely) to shut off the heat source. The remote location shall be ≥ 50 ft (15 m) from the vaporizer.				
5.3.6	The <b>LNG line to a heated vaporizer</b> shall have a <b>shutoff valve</b> installed at least 50 ft (15 m) from the vaporizer. If the vaporizer is installed in a building, the shutoff valve shall be installed at least 50 ft (15 m) from the building. (This valve can be the same valve addressed in 6.3.3.2.) This shutoff valve shall be operable either at its installed location or from a remote location, and the valve shall be protected from becoming inoperable due to external icing conditions. <i>Exception: Where the vaporizer is closer than 50 ft (15 m) to the container from which it is supplied (see 2.2.5.4), in which case the provisions of 5.3.7 shall apply.</i>				
5.3.7	Any <b>ambient vaporizer</b> or a heated vaporizer installed within 50 ft (15 m) of an LNG container shall be equipped with an automatic shutoff valve in the liquid line. This valve shall be located at least 10 ft (3 m) from the vaporizer and shall close when loss of line pressure (excess flow) occurs, when abnormal temperature is sensed in the immediate vicinity of the vaporizer (fire), or when low temperature in the vaporizer discharge line occurs. At attended facilities, remote operation of this valve from a point at least 50 ft (15 m) from the vaporizer shall be permitted.				
5.3.8	If a flammable intermediate fluid is used with a remote heated vaporizer, <b>shutoff valves</b> (located at least 50 ft (15 m) from the vaporizer) shall be provided on both the hot and cold lines of the intermediate fluid system. Valve controls shall be located at least 50 ft (15 m) from the vaporizer.				

NFPA 59A reference	PROCESS EQUIPMENT & VAPORIZATION FACILITIES Ref. 193.2101, .2301, .2401	S	U	N/A	N/C
5.4.1	Each <b>vaporizer</b> shall be provided with a safety <b>relief valve(s)</b> sized in accordance with <b>either</b> of the following requirements: (a) <b>Heated or process vaporizers</b> - relief valve capacity shall allow discharge at 110% of rated vaporizer natural gas flow capacity without allowing the pressure to rise > 10% above the vaporizer maximum allowable working pressure. (b) <b>Ambient vaporizers</b> - relief valve capacity shall allow discharges $\geq$ 150% of rated vaporizer natural gas flow capacity (as specified for standard operating conditions) without allowing the pressure to rise > 10% above the vaporizer maximum allowable working pressure.				
5.4.2	<b>Relief valves on heated vaporizers</b> shall be so located that they are not subjected to temperatures exceeding 140°F (60°C) during normal operation unless designed to withstand higher temperatures.				

NFPA 59A reference	GENERAL and BASIC DESIGN - STATIONARY LNG STORAGE CONTAINERS Ref. 193.2101, .2303	S	U	N/A	N/C
4.1.2.1	The operator shall specify (1) the maximum allowable working pressure, which includes a margin above the normal operating pressure, and (2) the maximum allowable vacuum.				
4.1.2.2	Those parts of LNG containers that normally are in contact with LNG and all materials used in contact with LNG or cold LNG vapor [vapor at a temperature below -20°F] shall be physically and chemically compatible with LNG and intended for service at -270°F.				
4.1.2.3	All piping that is a part of an LNG container, including all piping internal to the container, within insulation spaces, within void spaces, and external piping attached or connected to the container up to the first circumferential external joint of the piping shall be in accordance with NFPA-59A Chapter 6 "Piping Systems and Components". Inert gas purge systems wholly within the insulation spaces are exempt from this provision. For ASME containers, all piping that is a part of an LNG container, including piping between the inner and outer containers, shall be in accordance with either the ASME Boiler and Pressure Vessel Code, Section VIII, or ASME B 31.3, Process Piping.				
4.1.2.4	All LNG containers shall be designed to accommodate both top and bottom filling unless other positive means are provided to prevent stratification.				
4.1.2.5	Any portion of the outer surface area of an LNG container that could accidentally be exposed to low temperatures resulting from the leakage of LNG or cold vapor from flanges, valves, seals, or other nonwelded connections shall be intended for such temperatures or protected from the effects of such exposure.				
4.1.2.6	Where two or more containers are sited in a common dike, the container <b>foundations</b> shall be capable of withstanding contact with LNG or shall be protected against contact with an accumulation of LNG that might endanger structural integrity.				
4.1.2.7	Assume the <b>density</b> of the LNG is the actual mass per unit volume at the minimum storage temperatures except in no case assume the density to be < 29.3 lb/ft <sup>3</sup> ( 470 kg/m <sup>3</sup> ).				
4.1.4	Use procedures outlined in ASCE 7, <i>Minimum Design Loads for Buildings and Other Structures</i> to determine <b>snow loads</b> for LNG storage containers design. Where a probabilistic approach is used, a 100-year mean occurrence interval shall be used.				

**Comments:**



Unless otherwise noted, all references are to 49CFR Part 193. S - Satisfactory U - Unsatisfactory N/A - Not Applicable N/C - Not Checked  
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

[Return to List](#)

## Module 5

### Seismic Design, Container Insulation, Foundations, API 620 Tanks

NFPA 59A reference	<b>SEISMIC DESIGN - STATIONARY LNG STORAGE CONTAINERS Ref. 193.2101 &amp; .2301</b>	S	U	N/A	N/C
4.1.3.1	Seismic loads shall be considered in the design of the LNG container and its impoundment system.				
4.1.3.2 & 4.1.3.3	The LNG container, its impounding system, LNG container isolation components, fire protection system, and structures or systems whose failure could affect the integrity of the LNG container and its isolation components shall be designed for two levels of seismic ground motion, the operating basis earthquake (OBE) and the safe shutdown earthquake(SSE).				
4.1.3.4	The LNG container, its impounding system, LNG container isolation components, fire protection system, and structures or systems whose failure could affect the integrity of the LNG container and its isolation components shall be designed to remain operable during and after an OBE and to isolate and maintain the LNG container during and after the SSE.				
4.1.3.6	The LNG container shall be designed for the OBE, and a stress-limit check shall be made for the SSE to ensure compliance with 4.1.3.4.				
4.1.3.7	The design of the LNG container and associated structural components including pile caps shall incorporate a dynamic analysis that includes the effects of sloshing and restrained liquid.				
4.1.3.9	The container and its supports shall be designed for the resultant seismic forces in combination with the operating loads.				
4.1.3.11	Instrumentation capable of measuring the ground motion to which containers are subjected shall be provided on the site.				
7.2.2.1 (2006)	A site-specific investigation shall be performed for all installations except those provided for in 7.2.3 to determine the characteristics of seismic ground motion and associated response spectra. (Address all subparts A-I.)				
7.2.2.2 (2006)	<b>7.2.2.2</b> The LNG container and its impounding system shall be designed for the following two levels of seismic ground motion: (1) The safe shutdown earthquake (SSE) as defined in 7.2.2.3 (2) The operating basis earthquake (OBE) as defined in 7.2.2.4				
7.2.2.3 (2006)	The SSE shall be represented by a ground motion response spectrum in which the spectral acceleration at any period, <i>T</i> , shall be equal to the spectral acceleration of the MCE ground motion defined in 7.2.2.1.				
7.2.2.4 (2006)	The OBE ground motion shall be the motion represented by an acceleration response spectrum having a 10 percent probability of exceedance within a 50-year period (mean return interval of 475 years).				
7.2.2.5 (2006)	The two levels of ground motion defined in 7.2.2.3 and 7.2.2.4 shall be used for the earthquake-resistant design of the following structures and systems: (1) An LNG container and its impounding system (2) System components required to isolate the LNG container and maintain it in a safe shutdown condition (3) Structures or systems, including fire protection systems, the failure of which could affect the integrity of 7.2.2.5(1) or 7.2.2.5(2) (Address all subparts A-E.)				
7.2.2.6 (2006)	The impounding system shall, as a minimum, be designed to withstand an SSE while empty and an OBE while holding the volume, <i>V</i> , as specified in 2.2.2.1.				
7.2.2.7 (2006)	After an OBE or an SSE, there shall be no loss of containment capability.				

NFPA 59A reference	<b>SEISMIC DESIGN - STATIONARY LNG STORAGE CONTAINERS</b> <b>Ref. 193.2101 &amp; .2301</b>	S	U	N/A	N/C
7.2.2.8 (2006)	An LNG container shall be designed for the OBE, and a stress-limit check shall be made for the SSE to ensure compliance with 7.2.2.5. (Address all subparts A-C.)				
7.2.2.9 (2006)	After an SSE event, the container shall be emptied and inspected prior to resumption of container-filling operations.				
7.2.2.10 (2006)	The design of the LNG container and structural components shall incorporate a dynamic analysis that includes the effects of sloshing and restrained liquid. (Address all subparts A-C.)				

NFPA 59A reference	<b>CONTAINER INSULATION - STATIONARY LNG STORAGE CONTAINERS</b> <b>Ref. 193.2101 &amp; .2301</b>	S	U	N/A	N/C
4.1.5.1	Any exposed insulation shall be noncombustible, shall contain or inherently shall be a vapor barrier, shall be water free, and shall resist dislodgment by fire hose streams. Where an outer shell is used to retain loose insulation, the shell shall be constructed of steel or concrete. Exposed weatherproofing shall have a flame spread rating not greater than 25, as per 1.7.14.				
4.1.5.2	The space between the inner tank and the outer tank shall contain insulation that is compatible with LNG and natural gas and that is noncombustible. See Exception in 4.1.5.2.				

NFPA 59A reference	<b>FOUNDATIONS - STATIONARY LNG STORAGE CONTAINERS</b> <b>Ref. 193.2101 &amp; .2301</b>	S	U	N/A	N/C
4.1.7.1	LNG container foundations shall be designed by a qualified engineer and constructed in accordance with recognized structural engineering practices. Prior to the start of design and construction of the foundation, a subsurface investigation shall be conducted by a qualified soils engineer to determine the stratigraphy and physical properties of the soils underlying the site.				
4.1.7.2	The bottom of the outer tank shall be above the groundwater table or otherwise protected from contact with groundwater at all times. The outer tank bottom material in contact with soil shall be one of the following: (1) Selected to minimize corrosion (2) Coated or otherwise protected to minimize corrosion (3) Protected by a cathodic protection system				
4.1.7.3	Where an outer tank is in contact with the soil, a heating system shall be provided to prevent the 32°F isotherm from penetrating the soil and be designed IAW NFPA-59A, 4.1.7.3.				
4.1.7.4	If the foundation is installed to provide air circulation in lieu of a heating system, the bottom of the outer tank shall be of a material compatible with the temperatures to which it can be exposed.				
4.1.7.5	If a tank bottom temperature monitoring system is installed, it must be capable of measuring the temperature on a predetermined pattern over the entire surface area of the bottom insulation and any tank foundation heating system..				
4.1.7.6	The LNG container foundation shall be monitored periodically for settlement during construction, hydrostatic testing, and commissioning. Any settlement in excess of that anticipated in the design shall be investigated and corrective action taken as required.				

NFPA 59A reference	<b>WELDED STATIONARY LNG STORAGE CONTAINERS, OPERATION ≤ 15 psi</b> <b>Ref. 193.2101, .2301, .2303</b>	S	U	N/A	N/C
4.2.1	Welded containers designed to operate ≤ 15 psi shall comply with <b>API 620</b> , Design and Construction of Large, Welded, Low-Pressure Storage Tanks.				

**Comments:**

Unless otherwise noted, all references are to 49CFR Part 193. S - Satisfactory U - Unsatisfactory N/A - Not Applicable N/C - Not Checked  
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

[Return to List](#)

## Module 6

### High Pressure Tanks (>15 psi)

NFPA 59A reference	<b>STATIONARY LNG STORAGE TANKS DESIGNED FOR OPERATION at &gt;15 psi Ref. 193.2101, .2301, .2303, .2321</b>	S	U	N/A	N/C
4.1.6	Containers designed to operate in excess of 15 psi shall have a device(s) that prevents the container from becoming <b>liquid full</b> or from covering the inlet of the relief device(s) with liquid when the pressure in the container reaches the set pressure of the relieving device(s).				
4.2.2.1	Containers shall be double-walled, with the inner tank holding the LNG surrounded by insulation contained within the outer tank. The insulation shall be evacuated or purged.				
4.2.2.2	The inner tank shall be of welded construction and IAW Section VIII of the ASME Boiler and Pressure Vessel Code and shall be ASME-stamped and registered with the National Board of Boiler and Pressure Vessel Inspectors or other agencies that register pressure vessels.				
4.2.2.3	The outer tank shall be of welded construction: (a) Appropriate carbon steel, IAW applicable stated standards, (b) If vacuum insulation is used, IAW applicable stated standards, (c) Maximum allowable working pressures shall be specified for all components, (d) Have a properly designed relief valve, (e) Thermal barriers shall be provided, (f) Saddles and legs designed IAW recognized structural practices, and (g) Foundations and supports be protected to have fire-resistance rating of not less than 2 hours.				
4.2.2.4	Stress concentrations from the support system shall be minimized by the use of such items as pads and load rings.				
4.2.2.5	Internal piping within the insulation space between the inner and outer tanks shall be designed for the maximum allowable working pressure of the inner tank, with allowance for thermal stresses. Bellows shall not be permitted within the insulation space.				
4.2.2.6	The inner tank shall be supported concentrically within the outer tank by either a metallic or a nonmetallic system that is capable of sustaining the maximum loading.				
	<b>193.2321(a)</b> The butt welds in metal shells of storage tanks with <b>internal design pressure above 15 psig</b> must be radiographically tested in accordance with ASME Boiler and Pressure Vessel Code (Section VII Division 1), except that hydraulic load bearing shells with curved surfaces that are subject to cryogenic temperatures, 100 percent of both longitudinal (or meridional) and circumferential (or latitudinal) welds must be radiographically tested.				
4.5.2	Containers designed for pressures > 15 psi [103 kPa(g)] shall be tested IAW: (a) Shop-fabricated containers shall be pressure tested by the manufacturer prior to shipment to the installation site. (b) The inner tank shall be tested IAW the ASME <i>Boiler and Pressure Vessel Code</i> or CSA B 51, <i>Boiler, Pressure Vessel and Pressure Piping Code</i> . The outer tank shall be leak tested. Piping shall be tested in accordance with Section 6.6. (c) Containers and associated piping shall be leak tested prior to filling the container with LNG.				
	<b>193.2321(b)</b> For storage tanks with <b>internal design pressures at 15 psig or less</b> , ultrasonic examinations of welds on metal containers must comply with the following:				

NFPA 59A reference	<b>STATIONARY LNG STORAGE TANKS DESIGNED FOR OPERATION at &gt;15 psi Ref. 193.2101, .2301, .2303, .2321</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
7.3.1.2 (2006)	(1) Section 7.3.1.2 of NFPA 59A (2006):  API 620, Appendix Q, shall be applicable for LNG with the following changes: (1) In Q-7.6.5, "twenty-five percent" shall be changed to "all." (2) In Q-7.6.1 through Q-7.6.4, 100 percent examination of all vertical and horizontal butt welds associated with the container wall, except for the shell-to-bottom welds associated with a flat bottom container, shall be required. (3) API 620, Appendix C, C.11, shall be a mandatory requirement.				
	<b>192.2321(b)(2)</b> Appendices Q and C of API 620 Standard				
	<b>192.2321(c)</b> Ultrasonic examination records must be retained for the life of the facility. If electronic records are kept, they must be retained in a manner so that they cannot be altered by any means; and				
	<b>192.2321(d)</b> The ultrasonic equipment used in the examination of welds must be calibrated at a frequency no longer than eight hours. Such calibrations must verify the examination of welds against a calibration standard. If the ultrasonic equipment is found to be out of calibration, all previous weld inspections that are suspect must be reexamined.				

**Comments:**

[Return to List](#)

## Module 7

### Concrete Tanks, Relief Devices, Piping Systems & Components, Welded Pipe Tests & Inspection

NFPA 59A reference	<b>STATIONARY LNG CONCRETE STORAGE CONTAINERS</b> <b>Ref. 193.2101, .2301, .2303</b>	S	U	N/A	N/C
4.3.2.1	The design of concrete containers shall be in accordance with 4.3.2.2 through 4.3.2.5 and shall comply with standards ACI 318, Building Code Requirements for Reinforced Concrete.				
4.3.2.2	Allowable stresses for normal design considerations shall be based on room temperature specified minimum strength values.				
4.3.2.3	Tensile stresses (exclusive of direct temperature and shrinkage effects) in carbon steel reinforcing bars when exposed to LNG temperatures under design conditions shall be limited to the allowable stresses listed in Table 4.3.2.3.				
4.3.2.4	Steel wire or strands, as specified in 4.3.3.4 and used as unstressed reinforcement, shall be designed with a maximum allowable stress as follows: (1) Crack control applications — 30,000 psi (2) Other applications — 80,000 psi				
4.3.2.5	External forces imposed on the container by backfill restraint during warm-up shall be considered.				
4.3.3.1	Concrete shall be in accordance with the requirements of ACI 304R, Guide for Measuring, Mixing, Transportation and Placing of Concrete, and ACI 318, Building Code Requirements for Reinforced Concrete.				
4.3.3.2	Aggregate shall be specified by ASTM C 33, Standard Specification for Concrete Aggregates .				
4.3.3.3	Pneumatic mortar shall be in accordance with ACI Standard 506.2, <i>Specification for Materials, Proportioning, and Application of Shotcrete</i> .				
4.3.3.4	High tensile strength elements for prestressed concrete shall meet the applicable stated standards.				
4.3.3.5	Reinforcing steel for reinforced concrete shall be as specified by applicable stated standards.				
4.3.3.6 & 4.3.3.7	Nonstructural metallic barriers incorporated in prestressed concrete shall be of a metal classified for either “primary components” or “secondary components”.				
4.3.4.1	Concrete LNG containers shall be built in accordance with ACI 318R, Building Code Requirements for Structural Concrete; Section 9 of ACI 301, Specifications for Structural Concrete; ACI 372R, Design and Construction of Circular Wire and Strand Wrapped Prestressed Concrete Structures; and ACI 373R, Design and Construction of Circular Prestressed Concrete Structures with Circumferential Tendons.				
4.3.4.2	Concrete LNG containers shall be inspected in accordance with ACI Standard 311.4R, Guide for Concrete Inspection, and Section 6.5 of this standard.				
4.3.4.3	Metal components shall be constructed and tested in accordance with the applicable provisions in Appendix Q of API Standard 620, Design and Construction of Large, Welded, Low- Pressure Storage Tanks.				
4.5.1	<b>Testing of LNG Containers:</b> Where no specific single construction code is applicable, the equivalent of API 620, <i>Design and Construction of Large, Welded, Low-Pressure Storage Tanks</i> , shall be applied for containers designed for ≤ 15 psi (103 kPa).				

NFPA 59A reference	RELIEF DEVICES - STATIONARY LNG STORAGE CONTAINERS Ref. 193.2101 & .2301	S	U	N/A	N/C
4.7.1	All containers shall be equipped with pressure and vacuum relief devices in accordance with: (a) API 620, for containers <b>designed to operate at ≤ 15 psi</b> . (b) The ASME Boiler and Pressure Vessel Code, Section VIII, for containers <b>designed to operate &gt; 15 psig</b> The relief devices shall be sized in accordance with Section 4.7.				
4.7.2	Relief devices shall vent directly with the atmosphere. Vacuum relieving devices shall be installed if the container can be exposed to a vacuum condition in excess of that for which the container is designed.				
4.7.2.1	Each pressure and vacuum safety relief valve for LNG containers shall be able to be isolated from the container for maintenance or other purposes by means of a manual full opening stop valve and sufficient pressure and vacuum relief valves shall be installed on the LNG container as described in this section.				
4.7.2.3	Safety relief valve discharge stacks or vents shall be designed and installed to prevent an accumulation of water, ice, snow, or other foreign matter and shall discharge vertically upward.				
4.7.3.1	The pressure relief devices shall be sized to relieve the flow capacity determined for the largest single contingency or any reasonable and probable combination of contingencies.				
4.7.3.2	The <b>minimum pressure relieving capacity</b> in kg/hr (lb/hr) shall not be less than 3 percent of the full tank contents in 24 hours.				
4.7.3.3	The capacity of <b>vacuum relief devices</b> shall be based on the following: (1) Withdrawal of liquid or vapor at the maximum rate (2) Rise in barometric pressure (3) Reduction in vapor space pressure as a result of filling with subcooled liquid. The vacuum relief devices shall be sized to relieve the flow capacity determined for the largest single contingency or any reasonable and probable combination of contingencies, less the vaporization rate that is produced from the minimum normal heat gain to the tank contents. No vacuum relief capacity credit shall be permitted for gas-repressuring or vapor makeup systems.				
4.7.3.4	The <b>pressure relieving capacity</b> required for <b>fire exposure</b> shall be computed by the formula listed in 4.7.3.4.				

NFPA 59A reference	PIPING SYSTEMS AND COMPONENTS Ref. 193.2101 & .2301	S	U	N/A	N/C
6.1.1	<b>All piping systems</b> shall be IAW ASME B 31.3, <i>Process Piping</i> . The additional provisions of this chapter shall apply to piping systems and components for flammable liquids and flammable gases with service temperatures below -20°F (-29°C). <i>Exception: Fuel gas systems covered by NFPA 54, National Fuel Gas Code.</i>				
6.1.2	The <b>seismic ground motion</b> used in the <b>piping design</b> shall be the OBE. ( <i>See 4.1.3.2.</i> ) The piping loads shall be determined by a <b>dynamic analysis</b> or by applying an amplification factor of 0.60 to the maximum design spectral acceleration, SDS, as defined in 4.1.3.8. The allowable stress for the piping shall be in accordance with the requirements of ASME B 31.3, <i>Process Piping</i> . Container-associated piping up to and including the first container shutoff valve in LNG lines shall be designed to meet the provisions of 4.1.3.3(2).				
6.1.3	Piping systems and components shall be designed to accommodate the effects of <b>thermal cycling fatigue</b> to which the systems will be subjected. Particularly consider changes in size of wall thicknesses that occur between pipes, fittings, valves, and components.				
6.1.4	Provide for <b>expansion and contraction</b> of piping and piping joints due to temperature changes IAW ASME B 31.3, <i>Process Piping</i> , Section 319.				
6.2.1.1	All piping materials, including gaskets and thread compounds, used with the liquids and gases shall be <b>compatible throughout the range of temperatures</b> to which they are subjected, IAW ASME B 31.3, <i>Process Piping</i> .				



NFPA 59A reference	<b>PIPING SYSTEMS AND COMPONENTS</b> <b>Ref. 193.2101 &amp; .2301</b>	S	U	N/A	N/C
6.2.1.2	Piping that can be <b>exposed to the cold</b> of an LNG or refrigerant spill or the heat of an ignited spill during an emergency where such exposure could result in a failure of the piping that would significantly increase the emergency shall be IAW <b>one</b> of the following: (1) Made of material(s) that can withstand both its normal operating temperature and the extreme temperature to which it might be subjected during the emergency (2) Protected by insulation or other means to delay failure due to such extreme temperatures until corrective action can be taken by the operator (3) Capable of being isolated and having the flow stopped where piping is exposed only to the heat of an ignited spill during the emergency.				
6.2.4.1	In addition to complying with ASME B 31.3, <i>Process Piping</i> , Section 307, <b>valves</b> shall comply with ASME B 31.5, <i>Refrigeration Piping</i> ; ASME B 31.8, <i>Gas Transmission and Distribution Piping Systems</i> ; or API 6D, <i>Specification for Pipeline Valves</i> , if design conditions fall within the scope of these standards.				
6.3.2.4	<b>Gasket material</b> selection shall consider exposure to fire.				
6.3.3.1	<b>Extended bonnet valves</b> shall be installed with packing seals in a position that prevents leakage or malfunction due to freezing. If the extended bonnet in a cryogenic liquid line is installed at an angle greater than 45 degrees from the upright vertical position, evidence of satisfactory service in the installed position shall be demonstrated.				
6.3.3.2	<b>Shutoff valves</b> are required on container, tank, and vessel connections. <i>Exception No. 1: Relief valve connections. [Shutoff valves shall be permitted only at connections for relief valves IAW with the ASME Boiler and Pressure Vessel Code, Section VIII, Division 1, UG-125(d), and Appendix M, M-5 and M-6.]</i> <i>Exception No. 2: Connections for liquid level alarms shall be as required by 7.1.1.2.</i> <i>Exception No. 3: Connections that are blind flanged or plugged.</i> Shutoff valves shall be located as close as practical to such containers, tanks, and vessels and shall be located inside the impounding area.				
6.3.3.5	Valves and valve controls shall be designed to allow operation under <b>icing conditions</b> , if such conditions can exist.				
6.3.3.6	Emergency shutoff valves that would require <b>excessive time</b> to operate during an emergency [or valves $\geq$ 8 in. (200 mm)] shall have powered operators and have a means for manual operation.				
6.3.4.1	<b>Welder</b> qualification and performance shall be IAW Section 328.2 of ASME B 31.3, <i>Process Piping</i> , and 6.3.4.2 of NFPA-59A.				
6.3.4.2	Use qualified <b>welding procedures</b> selected to minimize degradation of the low-temperature properties of the pipe when welding <b>impact-tested materials</b> . Use procedures and techniques to minimize the danger of burn-throughs when welding attachments to unusually thin pipe.				
6.6.1	<b>Pressure tests (piping)</b> shall be conducted in accordance with ASME B 31.3, <i>Process Piping</i> , Section 345. To avoid possible brittle failure, carbon and low-alloy steel piping shall be pressure tested at metal temperatures suitably above their nil ductility transition temperature.				
6.6.2	<b>Records</b> of pressure, test medium temperature, and ambient temperature shall be maintained for the duration of each test. These records shall be maintained for the life of the facility or until such time as a retest is conducted.				
6.8.1	<b>Pressure-relieving safety</b> devices shall be arranged so that the possibility of damage to piping or appurtenances is reduced to a minimum. The means for adjusting relief valve set pressure shall be sealed.				
6.8.2	A <b>thermal expansion relief valve</b> shall be installed as required to prevent overpressure in any section of a liquid or cold vapor pipeline that can be isolated by valves.				

NFPA 59A reference	PIPING SYSTEMS AND COMPONENTS Ref. 193.2101 & .2301	S	U	N/A	N/C
6.8.2.1	A <b>thermal expansion relief valve</b> shall be set to discharge at or below the design pressure of the line it protects.				
6.8.2.2	Discharge from <b>thermal expansion relief valves</b> shall be directed to minimize hazard to personnel and other equipment.				

NFPA 59A reference	WELDED PIPE TESTS & INSPECTION Ref. 193.2101, .2301, .2303	S	U	N/A	N/C
6.6.3.1	Longitudinal or spiral welded pipe that is subjected to service temperatures below $-20^{\circ}\text{F}$ ( $-29^{\circ}\text{C}$ ) shall have a design pressure of less than 2/3 of the mill proof test pressure or subsequent shop or field hydrostatic test pressure. <i>Exception: Pipe that has been subjected to 100 % radiographic or ultrasonic inspection of the longitudinal or spiral weld.</i>				
6.6.3.2	All <b>circumferential butt welds</b> shall be examined fully by radiographic or ultrasonic inspection. <i>Exception No. 1: Liquid drain and vapor vent piping with an operating pressure that produces a hoop stress of less than 20% specified minimum yield stress shall not be required to be nondestructively tested if it has been inspected visually in accordance with ASME B 31.3, Process Piping, Section 344.2.</i> <i>Exception No. 2: Pressure piping operating above <math>-20^{\circ}\text{F}</math> (<math>-29^{\circ}\text{C}</math>) shall have 30% of each day's circumferentially welded pipe joints nondestructively tested over the entire circumference IAW ASME B 31.3.</i>				
6.6.3.3	All socket welds and fillet welds shall be examined fully by liquid penetrant or magnetic particle inspection.				
6.6.3.4	All fully penetrated groove welds for branch connections (as required by ASME B 31.3, <i>Process Piping</i> , Section 328.5.4) shall be examined fully by in-process examination IAW ASME B 31.3, Section 344.7, as well as by liquid penetrant or magnetic particle techniques after the final pass of the weld. <i>Exception: If specified in the engineering design or specifically authorized by the inspector, examination by radiographic or ultrasonic techniques shall be permitted to be substituted for the examinations required by 6.6.3.4.</i>				
6.6.4	Nondestructive examination methods, limitations on defects, the qualifications of the authorized inspector, and the personnel performing the examination shall meet the requirements of ASME B 31.3, <i>Process Piping</i> , Sections 340 and 344. <i>Exception: Substitution of in-process examination for radiography or ultrasonics as permitted in ASME B 31.3, Paragraph 341.4.1, shall be prohibited.</i>				

<p><b>Comments:</b></p>
-------------------------

[Return to List](#)

## Module 8

### Corrosion Control (NFPA 59A & 193.2304)

NFPA 59A reference	<b>CORROSION CONTROL</b> <b>Ref. 193.2101, .2301, .2629</b>	S	U	N/A	N/C
6.9.1	Underground and submerged piping shall be protected and maintained IAW the principles of NACE RP 0169, <i>Control of External Corrosion of Underground or Submerged Metallic Piping Systems</i> and 49 CFR, Part 192.461 & .463.				
6.9.2	Austenitic stainless steels and aluminum alloys shall be protected to minimize corrosion and pitting from corrosive atmospheric and industrial substances during storage, construction, fabrication, testing, and service. Tapes or other packaging materials that are corrosive to the pipe or piping components shall not be used. Where insulation materials can cause corrosion of aluminum or stainless steels, inhibitors or waterproof barriers shall be utilized.				

' 193.2304 CORROSION CONTROL OVERVIEW	S	U	N/A	N/C
(a) Subject to paragraph (b) of this section, components may not be constructed, repaired, replaced, or significantly altered until a person qualified under ' 193.2707(c) reviews the applicable design drawings and materials specifications from a corrosion control viewpoint and determines that the materials involved will not impair the safety or reliability of the component or any associated components. (b) The repair, replacement, or significant alteration of components must be reviewed only if the action to be taken: (1) Involves a change in the original materials specified; (2) Is due to a failure caused by corrosion; or (3) Is occasioned by inspection revealing a significant deterioration of the component due to corrosion.				

<b>Comments:</b>
------------------

[Return to list](#)

## Module 9

### LNG Level Gauging, Refrigerant & Process Fluids, Pressure & Vacuum Gauges, Temperature Monitoring

NFPA 59A reference	<b>LNG LEVEL GAUGING – LNG CONTAINERS</b> <b>Ref. 193.2301</b>	S	U	N/A	N/C
7.1.1.1	LNG containers shall be equipped with two independent liquid level gauging devices. The devices shall be designed and installed so they can be replaced without taking the tank out of operation.				
7.1.1.2	The container shall be provided with two, independent high-liquid level alarms, which may be part of the liquid level gauging devices. The high-liquid-level flow cutoff device required in 7.1.1.3 shall not be considered as a substitute for the alarm.				
7.1.1.3	The LNG container shall be equipped with a high-liquid-level flow cutoff device, which shall be separate from all gauges.				

NFPA 59A reference	<b>REFRIGERANT &amp; PROCESS FLUIDS</b> <b>Ref. 193.2101, .2301</b>	S	U	N/A	N/C
3.3	Installation of <b>storage tanks for flammable refrigerants and liquids</b> shall comply with NFPA 30, Flammable and Combustible Liquids Code; NFPA 58, Liquefied Petroleum Gas Code; NFPA 59, Utility LP Gas Plant Code; API 2510, Design and Construction of Liquefied Petroleum Gas (LPG) Installations; or Section 2.2 of this standard.				
7.1.2.1	I & E: Each storage tank (refrigerant or process fluids) shall be equipped with a <b>liquid level gauging device</b> . If it is possible to overfill the tank, a high-liquid level alarm shall be provided in accordance with 7.1.1.2.				
7.1.2.2	I & E: Flammable refrigerants containers shall be equipped with a <b>high-liquid-level flow cutoff device</b> , which shall be separate from all gauges.				

NFPA 59A reference	<b>I &amp; E: PRESSURE AND VACUUM GAUGES</b> <b>Ref. 193.2301</b>	S	U	N/A	N/C
7.2	Each <b>container</b> shall be equipped with a <b>pressure gauge</b> connected to the container at a point above the maximum intended liquid level.				
7.3	<b>Vacuum-jacketed equipment</b> shall be equipped with instruments or connections for checking absolute pressure in the annular space.				

NFPA 59A reference	<b>I &amp; E: TEMPERATURE MONITORING</b> <b>Ref. 193.2301</b>	S	U	N/A	N/C
7.4	<b>Temperature-monitoring devices</b> shall be provided in <b>field-erected containers</b> to assist in controlling temperatures when placing the container into service or as a method of checking and calibrating liquid level gauges.				
7.4.1	<b>Vaporizers</b> require inlet and outlet <b>temperature monitors</b>				
7.4.2	<b>Temperature-monitoring systems</b> shall be provided where <b>foundations</b> supporting cryogenic containers and equipment could be affected adversely by freezing or frost heaving of the ground.				

[Return to List](#)

## Module 10

### Electrical Equipment, Grounding & Bonding

NFPA 59A reference	<b>I &amp; E: ELECTRICAL EQUIPMENT, GROUNDING, AND BONDING</b> <b>Ref. 193.2301</b>	S	U	N/A	N/C
7.6.1	Electrical equipment and wiring shall be of the type specified by and shall be installed in accordance with <b>NFPA 70, National Electrical Code®</b> .				
7.6.2	Fixed electrical equipment and wiring installed within the classified areas specified in Table 7.6.2 shall comply with Table 7.6.2 and Figures 7.6.2(a) through 7.6.2(d) and shall be installed in accordance with <b>NFPA 70</b> .				
7.6.3	Each interface between a flammable fluid system and an electrical conduit or wiring system, including process instrumentation connections, integral valve operators, foundation heating coils, canned pumps, and blowers, shall be sealed or isolated to prevent the passage of flammable fluids to another portion of the electrical installation.				
7.6.3.1	Each <b>seal</b> , barrier, or other means used to comply with 7.6.3 shall be designed to prevent the passage of flammable fluids through the conduit, stranded conductors, and cables.				
7.6.3.2	A <b>primary seal</b> shall be provided between the flammable fluid system and the electrical conduit wiring system. If the failure of the primary seal allows the passage of flammable fluids to another portion of the conduit or wiring system, an additional approved seal, barrier, or other means shall be provided to prevent the passage of the flammable fluid beyond the additional device or means if the primary seal fails.				
7.6.3.3	Each <b>primary seal</b> shall be designed to withstand the service conditions to which it can be exposed. Each additional seal or barrier and interconnecting enclosure shall be designed to meet the pressure and temperature requirements of the condition to which it could be exposed in the event of failure of the primary seal unless other approved means are provided to accomplish the purpose.				
7.6.3.4	Where <b>secondary seals</b> are used, the space between the primary and secondary seals shall be continuously vented to the atmosphere. Similar provisions shall be made on double-integrity primary sealant systems of the type used for submerged motor pumps.				
7.6.3.5	The <b>seals</b> specified in 7.6.3, 7.6.4, and 7.6.5 shall not be used to meet the sealing requirements of NFPA 70, <i>National Electrical Code</i> , or CSA C 22.1, <i>Canadian Electrical Code</i> .				
7.6.4	Where <b>primary seals</b> are installed, drains, vents, or other devices shall be provided for monitoring purposes to detect flammable fluids and leakage.				
7.6.5	The <b>venting of a conduit system</b> shall be done in a manner that minimizes the possibility of damage to personnel and equipment, considering the properties of the liquid or gas and the potential for ignition.				
7.7.1	General. Electrical <b>grounding and bonding</b> shall be provided.				
7.7.3	If <b>stray currents or impressed current</b> can be present or is used on loading and unloading systems (such as for cathodic protection), protective measures to prevent ignition shall be taken.				
7.7.4	<b>Lightning protection</b> shall not be required on LNG storage containers. <i>Exception: Lightning protection ground rods shall be provided for tanks supported on nonconductive foundations for personnel and foundation protection.</i>				

**Comments:**

Unless otherwise noted, all references are to 49CFR Part 193. S - Satisfactory U - Unsatisfactory N/A - Not Applicable N/C - Not Checked  
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

[Return to List](#)

## Module 11

### Transfer of LNG & Refrigerants

NFPA 59A reference	<b>TRANSFER OF LNG AND REFRIGERANTS Ref. 193.2101, .2301</b>	S	U	N/A	N/C
8.2.1	Isolation valves shall be installed so that each <b>transfer system</b> can be isolated at its extremities. Where power-operated isolation valves are installed, an analysis shall be made to determine that the closure time will not produce a hydraulic shock capable of causing line or equipment failure. If excessive stresses are indicated by the analysis, an increase of the valve closure time or other methods shall be used to reduce the stresses to a safe level.				
8.2.2	A <b>pipng system</b> used for periodic transfer of cold fluid shall be provided with a means for precooling before use.				
8.2.3	<b>Check valves</b> shall be provided as required in <b>transfer systems</b> to prevent backflow and shall be located as close as practical to the point of connection to any system from which backflow might occur.				
<b>Pump and Compressor Control</b>					
8.3.1	In addition to a locally mounted device for shutdown of the pump or compressor drive, a readily accessible, remotely located device shall be provided a $\geq 25$ ft (7.6 m) away from the equipment to shut down the pump or compressor in an emergency. Remotely located pumps and compressors used for loading or unloading tank cars, tank vehicles, or marine vessels shall be provided with controls to stop their operation that are located at the loading or unloading area and at the pump or compressor site. Controls located aboard a marine vessel shall be considered to be in compliance with this provision.				
8.3.2	Signal lights shall be provided at the loading or unloading area to indicate when a remotely located pump or compressor used for loading or unloading is idle or in operation.				
<b>Tank Vehicle and Tank Car Loading and Unloading Facilities</b>					
8.5.2	A rack structure, if provided, shall be constructed of noncombustible material, such as steel or concrete.				
8.5.3	A tank vehicle loading and unloading area shall be of sufficient size to accommodate the vehicles without excessive movement or turning.				
8.5.4	Transfer piping, pumps, and compressors shall be located or protected by barriers so that they are safe from damage by rail or vehicle movements.				
8.5.5	Isolation valving and bleed connections shall be provided at the loading or unloading manifold for both liquid and vapor return lines so that hoses and arms can be blocked off, drained of liquid, and depressurized before disconnecting. Bleeds or vents shall discharge to a safe area.				
8.5.6	In addition to the isolation valving at the manifold, an emergency valve shall be provided in each liquid and vapor line $\geq 25$ ft (7.6 m) but $< 100$ ft (30 m) from each loading or unloading area. These valves shall be readily accessible for emergency use. A single valve shall be permitted to be installed in a common line to multiple loading or unloading areas. In installations where the loading or unloading area is closer than 25 ft (7.6 m) to the sending or receiving container, a valve that can be operated remotely from a point 25 ft to 100 ft (7.6 m to 30 m) from the area shall be permitted to be used.				
8.5.7	Pipelines used for liquid unloading only shall be provided with a check valve at the manifold adjacent to the manifold isolation valve.				
<b>Communications and Lighting</b>					

Unless otherwise noted, all references are to 49CFR Part 193. S - Satisfactory U - Unsatisfactory N/A - Not Applicable N/C - Not Checked  
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

NFPA 59A reference	<b>TRANSFER OF LNG AND REFRIGERANTS Ref. 193.2101, .2301</b>	S	U	N/A	N/C
8.8.1	Communications shall be provided at loading and unloading locations so that the operator can be in contact with other remotely located personnel who are associated with the loading or unloading operation. Communications shall be permitted to be by means of telephone, public address system, radio, or signal lights.				
8.8.2	Facilities transferring LNG during the night shall have lighting at the transfer area.				

**Comments:**

[Return to List](#)



## Module 12

### Fire Protection Provisions

NFPA 59A reference	<b>FIRE PROTECTION PROVISIONS</b> <b>Ref. 193.2101, .2301</b>	S	U	N/A	N/C
	Note: For plants existing on March 31, 2000, operators have until September 12, 2005 to bring the LNG facility's ESD system, water delivery systems, detection systems, and personnel qualification and training into compliance with NFPA-59A.				
	<b>193.2801</b> Each operator must <b>provide</b> . . . fire protection at LNG plants according to sections 9.1 through 9.7 and section 9.9 of NFPA 59A.				
9.1.2	The operator must conduct a fire protection evaluation.				
	(1) The type, quantity, and location of equipment necessary for the detection and control of fires, leaks, and spills of LNG, flammable refrigerants, or flammable gases.				
	(2) The type, quantity, and location of equipment necessary for the detection and control of potential electrical fires and fires not involving LNG processes.				
	(3) The methods necessary for protection of the equipment and structures from the effects of fire exposure.				
	(4) Fire protection water systems.				
	(5) Fire extinguishing and other fire control equipment.				
	(6) The equipment and processes to be incorporated within the ESD system, including analysis of subsystems, if any, and the need for depressurizing specific vessels or equipment.				
	(7) The type and location of sensors necessary to initiate automatic operation of the ESD system or its subsystems.				
9.2.1	LNG Facility shall incorporate an ESD system(s) that when operated isolates or shuts off sources of LNG and all other flammable liquids or gases, and shuts down equipment that adds or sustains an emergency if continued to operate.				
9.2.2	Equipment, that when shutdown, introduces an additional hazard or result in substantial mechanical damage to equipment, may be omitted from the ESD system as long as the effects of the continued release of flammable or combustible fluids are controlled.				
9.2.3	The ESD system(s) shall be of a failsafe design or shall be installed, located, or protected from becoming inoperative during an emergency or failure at the normal control system. ESD systems that are not of a failsafe design, all components that are located within 50 ft (15 m) of the equipment it controls shall be: (1) Installed or located where they cannot be exposed to a fire, <b>or</b> (2) Protected against failure due to a fire exposure for at least 10 minutes.				
9.2.5	Initiation of the ESD system(s) shall be manual, automatic, or both manual and automatic. Manual actuators shall be located in an area accessible in an emergency, and at least 50 ft (15 m) from the equipment they serve, and shall be distinctly marked with their designated function.				
9.3.1	Areas, including enclosed buildings, that have a potential for flammable gas concentration, LNG, or flammable refrigerant spills and fire must be monitored for the presence of gas or spilled liquid.				
9.3.2	Flammable gas detectors must activate visual and audible alarms at the plant site and at an attended location if the facility is not constantly attended.				
9.3.2	The low-temperature sensors or flammable gas detection system shall sound an alarm at a constantly attended location. Flammable gas detection system must be set no higher than 25% of the LFL of the gas being monitored.				

NFPA 59A reference	<b>FIRE PROTECTION PROVISIONS</b>				
	<b>Ref. 193.2101, .2301</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
	Note: For plants existing on March 31, 2000, operators have until September 12, 2005 to bring the LNG facility's ESD system, water delivery systems, detection systems, and personnel qualification and training into compliance with NFPA-59A.				
9.3.3	Fire detectors must sound an alarm at the plant site and at an attended location if the facility is not constantly attended. If so determined IAW 9.1.2 fire detectors shall activate portions of the ESD system.				
9.3.4	The detection systems required of the fire protection evaluation ( 9.1.2) shall be designed and installed IAW NFPA-72 or NFPA-1221.				
9.4.1	A fire water supply and delivery system must be provided, unless the fire protection evaluation (9-1.2) indicates that fire water is unnecessary or impractical.				
9.4.2	The fire water supply and distribution systems shall provide for the simultaneous supply of fixed fire protection systems, at their design flow and pressure, plus 1000 gpm (63 L/sec) for not less than 2 hours.				
9.5.1	Portable or wheeled fire extinguishers, recommended for gas fires, available at strategic locations.				

**Comments:**

[Return to List](#)

## Module 13

### ASME Small Containers (max 100,000 gal/tank and 280,000 gal aggregate)

NFPA 59A reference	<b>ALTERNATE REQUIREMENTS FOR STATIONARY APPLICATIONS: LNG INSTALLATIONS USING ASME CONTAINERS (MAXIMUM CAPACITY 100,000 GALS/TANK AND 280,000 GALS. AGGREGATE) Ref. 193.2101, .2301, .2303</b>	S	U	N/A	N/C
10.2.1	Site preparation shall include provisions for retention of spilled LNG, within the limits of plant property, and for surface water drainage.				
10.2.2	All-weather accessibility to the site for emergency services equipment shall be provided.				
10.2.7	The maximum allowable working pressure shall be specified for all pressure-containing components.				
10.3.1	All piping that is a part of an LNG container, including piping between the inner and outer containers, shall be IAW applicable standards.				
10.3.2	Internal piping between the inner and outer tanks and within the insulation space shall be designed for the maximum allowable working pressure of the inner tank. Bellows shall not be permitted within the insulation space.				
10.3.3	Containers shall be double-walled, with the inner tank holding LNG surrounded by insulation contained within the outer tank.				
10.3.4	The inner tank shall be of welded construction in accordance with the ASME Boiler and Pressure Vessel Code, Section VIII, and shall be ASME-stamped and registered with the National Board of Boiler and Pressure Vessel Inspectors or other agency that registers pressure vessels.				
10.3.5	The inner tank supports shall be designed for shipping, seismic, and operating loads.				
10.3.6	The outer tank shall be of welded construction: (a) Appropriate carbon steel, IAW applicable stated standards, (b) If vacuum insulation is used, IAW applicable stated standards, (c) Maximum allowable working pressures shall be specified for all components, and (d) Thermal barriers shall be provided.				
10.3.7.1	Shop-built containers designed and constructed IAW with ASME Boiler and Pressure Vessel Code, and their support systems, shall be designed for the dynamic forces associated with horizontal and vertical accelerations.				
10.3.8	Each container shall be identified by the attachment of a nameplate(s) in an accessible location marked with the information required by the ASME Boiler and Pressure Vessel Code and the following: (1) Builder's name and date built (2) Nominal liquid capacity (3) Design pressure at the top of the container (4) Maximum permitted liquid density (5) Maximum filling level (6) Minimum design temperature				
10.3.9	All penetrations on storage containers shall be identified. Markings shall be legible under all conditions.				
10.4	Containers designed to operate at a pressure > 15 psi shall be equipped with a device(s) that prevents the container from becoming liquid full or from covering the inlet of the relief device(s) with liquid when the container pressure reaches the set pressure of the relieving device(s) under all conditions.				

NFPA 59A reference	<b>ALTERNATE REQUIREMENTS FOR STATIONARY APPLICATIONS: LNG INSTALLATIONS USING ASME CONTAINERS (MAXIMUM CAPACITY 100,000 GALS/TANK AND 280,000 GALS. AGGREGATE) Ref. 193.2101, .2301, .2303</b>	S	U	N/A	N/C
10.5.1	(1) LNG container foundations, including saddles and legs, shall be designed and constructed in accordance with recognized structural and geotechnical engineering practices, including provisions for seismic loading as specified in 10.3.7, including those for shipping loads, erection loads, wind loads, and thermal loads. (2) Foundations and supports shall be protected to have a fire resistance rating of not less than 2 hours. (3) If insulation is used to achieve this requirement, it shall be resistant to dislodgement by fire hose streams.				
10.5.2	LNG storage containers installed in areas subject to flooding, shall be secured in a manner that prevents the release of LNG or container flotation in the event of a flood.				
10.6.1	LNG containers of 1000 gal and smaller shall be located: (1) 125 gal or less, 0 ft from buildings and the line of adjoining property (2) 1000 gal or less, 10 ft from buildings and the line of adjoining property				
10.6.2	The minimum distance from edge of impoundment or container drainage system to buildings and property lines and between containers shall be in accordance with Table 10.6.2 for aboveground and mounded tanks larger than 1000 gal (3.8 m3).				
10.6.3	Underground LNG tanks shall be installed in accordance with Table 10.6.3.				
10.6.4	Buried and underground containers shall be provided with means to prevent the 32°F isotherm from penetrating the soil. Where heating systems are used, they shall be installed such that any heating element or temperature sensor used for control can be replaced.				
10.6.5	All buried or mounded components in contact with the soil shall be constructed from corrosion-resistant material or protected from corrosion deterioration.				
10.6.6	A clear space of at least 3 ft shall be provided for access to all isolation valves serving multiple containers.				
10.6.7	LNG containers > 125-gal capacity shall not be located in buildings.				
10.6.9	LNG tanks and their associated equipment shall not be located where exposed to failure of overhead electric power lines operating at over 600 volts.				
10.7	All liquid and vapor connections, except relief valve and instrument connections, shall be equipped with automatic failsafe <b>product retention valves</b> . These automatic valves shall be designed to close on the occurrence of any of the following conditions: (1) Fire detection or exposure (2) Uncontrolled flow of LNG from the container (3) Manual operation from a local and remote location Connections used only for flow into the container shall be permitted to be equipped with two backflow valves, in series, in lieu of the requirements in 10.7(1) through (3). The appurtenances shall be installed as close to the container as practical so that a break resulting from external strain shall occur on the piping side of the appurtenance while maintaining intact the valve and piping on the container side of the appurtenance.				
10.8.1	Provide with impoundment (dikes), topography, or other methods to direct LNG spills to a safe location and to prevent LNG spills from entering water drains, sewers, waterways, or any closed-top channel.				
10.8.2	Flammable liquid storage tanks shall not be located within an LNG container impoundment area.				
10.8.3	<b>Impounding areas</b> serving aboveground and mounded LNG containers shall have a minimum volumetric holding capacity, including any useful holding capacity of the drainage area and with allowance made for the displacement of snow accumulation, other containers, and equipment.				

NFPA 59A reference	<b>ALTERNATE REQUIREMENTS FOR STATIONARY APPLICATIONS: LNG INSTALLATIONS USING ASME CONTAINERS (MAXIMUM CAPACITY 100,000 GALS/TANK AND 280,000 GALS. AGGREGATE) Ref. 193.2101, .2301, .2303</b>	S	U	N/A	N/C
10.9.1	Prior to initial operation, containers shall be <b>inspected</b> to ensure compliance with the engineering design and material, fabrication, assembly, and test provisions of the chapter. The operator shall be responsible for this inspection.				
10.10.1	Shop-fabricated containers shall be <b>pressure tested</b> by the manufacturer prior to shipment to the installation site. The inner tank shall be tested in accordance with the ASME <i>Boiler and Pressure Vessel Code</i> . The outer tank shall be leak tested. Piping shall be tested in accordance with ASME B 31.3, <i>Process Piping</i> .				
10.10.2	Containers and associated piping shall be <b>leak tested</b> prior to filling the container with LNG.				
10.11.1	All piping that is part of an LNG container and the associated facility for handling cryogenic liquid or flammable fluid shall be IAW with ASME B 31.3.				
10.11.2	The following requirements shall apply. (a) <b>NO</b> type F piping, spiral welded piping, and furnace butt-welded steel products. (b) Welding or brazing performed persons qualified under ASME Boiler and Pressure Vessel Code, Section IX. (c) <b>NO</b> Oxygen-fuel gas welding is permitted. (d) Brazing filler metal shall have a melting point exceeding 1000°F. (e) Austenitic stainless steel pipe and tubing for all services < -20°F. (f) Piping and piping components a minimum melting point of 1500°F. Exception No. 1: Gaskets, seats, and packing. Exception No. 2: Aluminum permitted for use downstream of a product retention valve in vaporizer service. (g) <b>NO</b> Compression-type couplings used where subjected to temperatures < -20°F unless they meet the requirements of ASME B 31.3., Section 315. (h) <b>NO</b> stab-in branch connections are permitted. (i) Extended bonnet valves shall be used for all cryogenic liquid service-bonnet angle is ≤ 45 degrees from the upright vertical position. (j) The level of inspection of piping shall be specified.				
10.12.1	Instrumentation for LNG facilities shall be designed if power or instrument air fails, the system will go into a failsafe condition that can be maintained until the operators can take action to reactivate or secure the system.				
10.12.2	LNG containers shall be equipped with two independent liquid level devices. One shall provide a continuous level indication ranging from full to empty and shall be maintainable or replaceable without taking the container out of service.				
10.12.3.1	Each container shall be equipped with a pressure gauge connected to the container above the maximum liquid level; the gauge dial shall have a permanent mark indicating the maximum allowable working pressure (MAWP) of the container.				
10.12.3.2	Vacuum-jacketed equipment shall be equipped with instruments or connections for checking the pressure in the annular space.				
10.12.4.1	(a) Safety relief valves are required on containers designed > 15 psi maintain LNG pressure IAWASME Boiler and Pressure Vessel Code. (b) The valve will be sized IAW NFPA-59A, Sect. 4.7.3 or CGA S-1.3. (c) The valves shall communicate directly with the atmosphere.				

NFPA 59A reference	<b>ALTERNATE REQUIREMENTS FOR STATIONARY APPLICATIONS: LNG INSTALLATIONS USING ASME CONTAINERS (MAXIMUM CAPACITY 100,000 GALS/TANK AND 280,000 GALS. AGGREGATE) Ref. 193.2101, .2301, .2303</b>	S	U	N/A	N/C
10.12.4.2	(a) Each pressure relief valve for inner LNG containers shall be able to be isolated from the container for maintenance by means of a manual full opening stop valve that is lockable or sealable in the fully open position. (b) Pressure relief valves shall be installed to allow each relief valve to be isolated individually for testing or maintenance while maintaining the full relieving capacities. (c) Where only one pressure relief valve is required, a full-port opening three-way valve under the pressure relief valve and its required spare is permitted in lieu of individual valves beneath each pressure relief valve.				
10.12.4.4	Safety relief valve discharge stacks or vents are designed and installed to prevent accumulation of water, ice, snow, or other foreign matter. If arranged to discharge directly into the atmosphere, shall discharge vertically upward.				

**Comments:**

[Return to List](#)

## Module 14

Construction Acceptance (193.2303); Design & Fabrication (193.2703); Construction, Installation, Inspection and Testing (193.2705); Records (193.2119); Warning Signs (193.2917)

	<b>' 193.2303 CONSTRUCTION ACCEPTANCE</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
No component may be placed in service until it passes all applicable inspections and tests prescribed by Subpart D and NFPA 59A.					

**Comments:**

	<b>COMPETENCE AND PERFORMANCE</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
<b>' 193.2703 DESIGN AND FABRICATION</b> (Demonstrated competence by training or experience)					
<b>' 193.2705 CONSTRUCTION, INSTALLATION, INSPECTION, AND TESTING</b> (Satisfactory performance)					

**Comments:**

	<b>' 193.2119 RECORDS</b>	<b>S</b>	<b>U</b>	<b>N/A</b>	<b>N/C</b>
Each operator shall keep a record of all materials for components, buildings, foundations, and support systems, as necessary to verify that material properties meet the requirements of this part. These records must be maintained for the life of the item concerned.					

**Comments:**

	' 193.2917 WARNING SIGNS.	S	U	N/A	N/C
(a)	Warning signs must be conspicuously placed along each protective enclosure at intervals so that at least one sign is recognizable at night from a distance of 30m (100 ft.) from any way that could reasonably be used to approach the enclosure.				
(b)	Signs must be marked with at least the following on a background of sharply contrasting color: The words "NO TRESPASSING", or words of comparable meaning.				

**Comments:**

NFPA 59A reference	GENERAL and BASIC DESIGN - STATIONARY LNG STORAGE CONTAINERS Ref. 193.2101, .2303	S	U	N/A	N/C
4.1.1	Prior to initial operation, containers shall be inspected to ensure compliance with the engineering design and material, fabrication, assembly, and test provisions of this standard. Exception: ASME containers.				

**Comments:**

[Return to List](#)