

Some Decision Support Systems


Charles D. D. Howard, P.E., P.Eng.

CddHoward Consulting Ltd

Victoria, BC, Canada

<http://www.CddHoward.com>

Example Decision Support System



- **Overview of DSS Components**
- **Project Inflows**
- **Unit Commitment and Base Points**
- **Pre-Scheduling**
- **Generation Scheduling and Bidding**
- **Unit Maintenance Scheduling**
- **Project Sites: Some Specific Issues**

Project Inflows

- Hydrologic Data
- Hydrologic Forecasting


Powell River BC Basin



High Elevation Hydromet Station



Hydrometric Data Management & Quality Assurance






- Streamflow
- Temperature
- Precipitation
- Snow (water equivalent)
- Reservoir Level
- None

Date Period

Start Date:
 ▼

End Date:
 ▼

Reload



Tahtsa Lake Snowfall - Apr 21, 1998 to May 11, 1998 00:00 Pacific Daylight Time

Run Forecast



Compare

Gate Setting

Quit



Watershed Simulation Results



Discharge | Watershed Conditions

Simulation Period: Jan 1, 1975 to Jul 1, 1980

Weather data from:

Basin Characteristics | Water Budget | Time Constants | Weather Stations | Meteorology


Soil Moisture Loss Threshold (mm):	250	<input type="text" value="250"/>
Fast Runoff Soil Moisture Deficit Control (mm):	250	<input type="text" value="250"/>
Threshold Limit for Groundwater Allocation (mm/day):	7	<input type="text" value="7"/>
Depressional Storage Allocation:	1.00	<input type="text" value="1.00"/>
Deep Zone Storage Allocation:	0.50	<input type="text" value="0.50"/>

Inputs:
Weather
Data

Outputs:
Snow in
Elev. Zones
& G'Water

Hydrologic Forecast Model

Cumulative Inflow Forecasts



Historical weather provides samples of possible future weather.

Forecasts are conditional on watershed conditions at Time Now, and possible future weather.


Stochastic Hydro-Thermal Scheduling

System Reliability Percent	Thermal Generation M\$	Hydro Generation M\$
90	1.75	47.29
92	1.84	48.33
94	1.90	50.47
96	1.96	53.10
98	2.04	55.84
99	2.07	59.04




Operations Center and Scheduling

- Plant Efficiency
- Unit Operations




Can Plant Operate More Efficiently?


Actual Performance May - July 2002




Optimized Plant H/K, Preferred Loading




1 Minute Hydroelectric Plant Operations 22 June 2009.





Idealized Hill Curve:
Monotonic
Symmetrical
Centered



Actual Hill Curve:
Not monotonic
Not Symmetrical
Not Centered

GURI 20



Plant Selection


- GURI 20
 - Unit1
 - Unit2
 - Unit3
 - Unit4
 - Unit5
 - Unit6

Controls

Turbine Data Auto Optimize

Report

Power-Discharge KW/CMS



Current Status for GURI 20

Time/Date: Jun 26 02:39:53

Headwater Level: 180 m

Tailwater Level: 50 m

Current Status				
Unit #	Status	MW	CMS	
12	On	600	513	
13	On	600	513	
14	On	600	513	
15	On	600	513	
16	On	600	513	
17	On	600	513	
18	On	565	435	
19	On	565	435	
20	On	565	435	

Totals: 8322 MW, 7,045 CMS

Difference: -20 MW, -11 CMS

Optimal Dispatch

Time/Date: Jun 26 02:39:53

Headwater Level: 180 m

Tailwater Level: 50 m

Maximized MW		Minimized CMS	
MW	CMS	MW	CMS
591	490	599	511
591	490	599	511
591	490	599	511
591	490	599	511
591	490	599	511
591	490	599	511
591	490	599	511
591	490	599	511
591	490	566	437
591	490	566	437
591	490	566	437
8302	7,000	8322	7,034
-20			-11

Charles Howard & Associates Ltd.
Professional Water Resource Engineers


Near Real Time Unit Loading

Optimized Loadings Table for 11 Units

Plant Discharge	Plant 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6	Unit 7	Unit 8	Unit 9	Unit 10	Unit 11	Unit Power	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6	Unit 7
2,298.3	2,298	0	0	0	0	0	0	0	0	0	0	6,302	6,302	0	0	0	0	0	0
4,596.6	4,597	0	0	0	0	0	0	0	0	0	0	28,463	28,463	0	0	0	0	0	0
6,895.0	6,895	0	0	0	0	0	0	0	0	0	0	47,802	47,802	0	0	0	0	0	0
9,193.3	9,193	0	0	0	0	0	0	0	0	0	0	64,818	64,818	0	0	0	0	0	0
11,491.6	11,492	0	0	0	0	0	0	0	0	0	0	81,491	81,491	0	0	0	0	0	0
13,789.9	13,790	0	0	0	0	0	0	0	0	0	0	97,805	97,805	0	0	0	0	0	0
16,088.3	16,088	0	0	0	0	0	0	0	0	0	0	113,280	113,280	0	0	0	0	0	0
18,386.6	12,768	5,618	0	0	0	0	0	0	0	0	0	129,065	90,643	38,421	0	0	0	0	0
20,684.9	13,117	7,568	0	0	0	0	0	0	0	0	0	146,011	93,088	52,923	0	0	0	0	0
22,983.2	13,790	9,193	0	0	0	0	0	0	0	0	0	162,623	97,805	64,818	0	0	0	0	0
25,281.6	14,158	11,124	0	0	0	0	0	0	0	0	0	179,214	100,330	78,883	0	0	0	0	0
27,579.9	15,044	12,536	0	0	0	0	0	0	0	0	0	195,353	106,358	88,995	0	0	0	0	0
29,878.2	15,699	14,179	0	0	0	0	0	0	0	0	0	211,298	110,813	100,485	0	0	0	0	0
32,176.5	16,088	16,088	0	0	0	0	0	0	0	0	0	226,560	113,280	113,280	0	0	0	0	0
34,474.9	15,716	12,675	6,084	0	0	0	0	0	0	0	0	242,835	110,938	89,977	41,920	0	0	0	0
36,773.2	15,616	13,601	7,556	0	0	0	0	0	0	0	0	259,537	110,229	96,465	52,843	0	0	0	0
39,071.5	15,528	14,026	9,517	0	0	0	0	0	0	0	0	276,235	109,611	99,395	67,229	0	0	0	0
41,369.8	15,640	14,631	11,099	0	0	0	0	0	0	0	0	292,678	110,397	103,573	78,708	0	0	0	0
43,668.2	16,062	15,058	12,548	0	0	0	0	0	0	0	0	308,634	113,094	106,460	89,080	0	0	0	0
45,966.5	16,164	15,659	14,144	0	0	0	0	0	0	0	0	324,576	113,813	110,532	100,230	0	0	0	0
48,264.8	16,591	16,088	15,586	0	0	0	0	0	0	0	0	339,577	116,283	113,280	110,014	0	0	0	0
50,563.1	16,020	15,519	13,016	6,008	0	0	0	0	0	0	0	356,112	112,799	109,547	92,371	41,394	0	0	0
52,861.5	16,110	15,607	13,593	7,552	0	0	0	0	0	0	0	372,817	113,434	110,164	96,408	52,811	0	0	0
55,159.8	16,046	15,545	14,041	9,528	0	0	0	0	0	0	0	389,516	112,986	109,728	99,501	67,301	0	0	0
57,458.1	16,129	16,129	14,617	10,584	0	0	0	0	0	0	0	405,585	113,564	113,564	103,472	74,986	0	0	0
59,756.4	16,069	16,069	15,567	12,052	0	0	0	0	0	0	0	421,726	113,144	113,144	109,882	85,556	0	0	0
62,054.8	16,515	16,014	15,514	14,012	0	0	0	0	0	0	0	437,313	115,747	112,758	109,507	99,301	0	0	0
64,353.1	16,591	16,088	16,088	15,586	0	0	0	0	0	0	0	452,857	116,283	113,280	113,280	110,014	0	0	0
66,651.4	17,039	16,538	16,538	16,538	0	0	0	0	0	0	0	466,230	118,505	115,908	115,908	115,908	0	0	0
68,949.7	16,608	16,105	15,602	13,589	7,046	0	0	0	0	0	0	485,399	116,404	113,398	110,129	96,377	49,090	0	0
71,248.0	16,558	16,056	15,554	14,049	9,031	0	0	0	0	0	0	502,130	116,049	113,052	109,793	99,560	63,677	0	0
73,546.4	16,510	16,010	16,010	14,509	10,507	0	0	0	0	0	0	518,324	115,718	112,730	112,730	102,712	74,435	0	0
75,844.7	16,575	16,073	16,073	15,068	12,055	0	0	0	0	0	0	534,630	116,173	113,173	113,173	106,534	85,578	0	0
78,143.0	16,530	16,530	16,029	15,528	13,525	0	0	0	0	0	0	550,115	115,857	115,857	112,865	109,611	95,924	0	0
80,441.3	16,591	16,591	16,088	16,088	15,083	0	0	0	0	0	0	565,761	116,283	116,283	113,280	113,280	106,635	0	0
82,739.7	17,049	16,548	16,548	16,548	16,046	0	0	0	0	0	0	579,508	118,579	115,981	115,981	115,981	112,986	0	0
85,038.0	16,507	16,507	16,007	15,507	13,506	7,003	0	0	0	0	0	598,145	115,697	115,697	112,709	109,459	95,791	48,792	0
87,336.3	16,564	16,564	16,062	16,062	14,054	8,031	0	0	0	0	0	614,314	116,092	116,092	113,094	113,094	99,597	56,345	0
89,634.6	16,525	16,525	16,024	16,024	14,522	10,015	0	0	0	0	0	630,952	115,819	115,819	112,828	112,828	102,801	70,857	0
91,933.0	16,578	16,578	16,076	16,076	15,071	11,554	0	0	0	0	0	647,311	116,192	116,192	113,192	113,192	106,552	81,992	0
94,231.3	16,541	16,541	16,541	16,039	15,538	13,032	0	0	0	0	0	662,887	115,930	115,930	115,930	112,936	109,680	92,483	0

No unnecessary On-Off

Short Term Operational Benefits



Project Base Points

- Contract Commitments
- Transmission Constraints




GO



ACS

1. Water Resources and Targets

Southeastern
Power
Administration
System



Starting Date: Sat. Aug. 23, 1997

Ending Date: Fri. Aug. 29, 1997


Navigation icons: Home, Undo, Redo, Print, Save, and a 'GO' button.

Day selection buttons: S S M T W T F

Buttons: Print icon, and 'ACS' buttons.


3. Electrical Loads

Hourly Loads (MWh) For SCPSA - August 23, 1997 to August 29, 1997



- Sources
- Hartwell
 - Russell
 - Thurmond
 - Buford
 - West Point
 - WF George
 - Allatoona
 - Carless
 - R.F. Henry
 - M. Ferry

Hourly Loads (MWh) For SCPSA - Monday Aug 25, 1997



Customer

- South Carolina Public Service Authority - SCPSA
- Southern Company Services - SCS
- Alabama Electric Cooperative on-system - AEC-on
- Alabama Electric Cooperative off-system - AEC-off
- Oglethorpe Power Cooperative - OPC
- Municipal Energy Authority of Georgia - MEAG
- Duke Power Company - DPC
- South Carolina Public Service Authority - SCPSA
- South Carolina Electric & Gas - SCE&G

Hours	00 - 01	01
SCPSA	0	
System	12	

	08	08 - 09	09 - 10	10 - 11	11 - 12
08	0	0	0	0	0
12	2	12	12	100	313

Load Forecasts and Contracts

Operations Scheduling

- River Basins
- Projects
- Market Bids

River Basin Week Summary

RHOM-HYDROPS: Dispatch Decision Support System

File Edit Basin Options Windows Help

GO

Daily Results by Plant (Tables) - Kennebec River

Kennebec River Daily Results Starting Tuesday, Sep 14, 1999

Plant	Starting Obs	Tue, Sep 14	Wed, Sep 15	Thu, Sep 16	Fri, Sep 17	Sat, Sep 18	Sun, Sep 19	Mon, Sep 20	Weekly Totals
BASIN TOTAL									
Revenue (\$)		39715	54956	79110	76333	67677	73190	72135	463115
Generation (MWh)		2009.5	2820.5	3434.2	3378.5	3096.7	3214.3	3052.2	21306
HARRIS									
Generation (MWh)		619.0	740.1	1141.6	1026.7	654.3	849.0	943.0	5974
Gen. Disch. (cfs)		2286	2743	4235	3809	2425	3130	3461	22088
Spill (cfs)									
MOOSEHEAD LAKE (cfs)									
Total Inflow (cfs)		1802	3089	3089	3089	3089	3089	3089	20336
Storage (cfs)	7101	3898	7220	7052	6310	6785	7410	7544	46222
Ending Level (ft)	954.5	954.3	954.6	953.9	953.8	954.5	954.6	954.5	
WYMAN									
Generation (MWh)		774.2	1029.4	1238.0	1298.8	1362.6	1292.4	1320.9	8316
Gen. Disch. (cfs)		3088	4065	4935	5184	5424	5153	5248	33099
Spill (cfs)									
FLAGSTAFF LAKE (cfs)									
Total Inflow (cfs)		29	50	50	50	50	50	50	329
Storage (cfs)	47673	27804	47729	47609	48008	48904	49071	49158	318182
Ending Level (ft)	484.0	484.1	484.1	484.2	484.8	484.8	485.0	484.9	
WILLIAMS									
Generation (MWh)		191.3	320.4	323.6	317.9	337.8	330.8	346.2	2168
Gen. Disch. (cfs)		2579	4422	4422	4422	4422	4422	4422	29110

54

Daily Pre-Schedule

RHDM-HYDROPS: Dispatch Decision Support System

File Edit Basin Options Windows Help

GO

Hourly Results by Unit [Tables] - Kennebec River

Harris Hourly Results for Wednesday, September 15, 1999

Hour	1	2	3	4	Totals
00 - 01	0.1			1.5	1.6
01 - 02	0.1			1.5	1.6
02 - 03	0.1			1.5	1.6
03 - 04	0.1			1.5	1.6
04 - 05	0.1			1.5	1.6
05 - 06	0.1			1.5	1.6
06 - 07	0.1			1.5	1.6
07 - 08	0.1			1.5	1.6
08 - 09	15.3	27.0	27.1		69.4
09 - 10	15.3	28.7	28.4	1.5	73.9
10 - 11	16.7	28.6	28.5	1.5	75.3
11 - 12	15.3	28.6	28.5	1.5	73.9
12 - 13	15.3	26.9	27.1	1.4	70.7
13 - 14	14.9	26.9	27.1		68.9
14 - 15	0.1			1.5	1.6
15 - 16	0.1			1.5	1.6
16 - 17	0.1			1.5	1.6
17 - 18	15.3	26.9	27.1		69.3
18 - 19	15.3	26.9	27.1		69.3
19 - 20	15.3	28.6	27.0	1.5	72.4
20 - 21	16.6	28.5	28.4	1.5	75.0
21 - 22	0.1			1.5	1.6
22 - 23	0.1			1.5	1.6
23 - 00	0.1			1.5	1.6
Totals	156.6	277.7	276.2	29.5	740.1

Plant Option

- Harris
- Wyman
- Williams
- Weston
- Shawmut
- Lockwood

Day Option

- Tuesday
- Wednesday
- Thursday
- Friday
- Saturday
- Sunday
- Monday

Display Option

- Generation, MWh
- Discharge, cfs-hrs
- Efficiency, %
- Run Time, mins

44

Runtime < 60 minutes

Ready... Start Date: Tuesday Sep 14, 1999 10hrs End Date: Monday Sep 20, 1999 Midnight

Bids to Independent System Operator

RHDM-HYDROPS: Dispatch Decision Support System

File Edit Basin Options Windows Help

GO

Frozen Schedule - Kennebec River

Kennebec River ISO Generation Schedule on Wednesday, Sep 15, 1999

Frozen:

Hour	HA1432	HA2433	HA3434	HA4757	WY1636	WY2637	WY3638	WI 621	WE 617	SH 761	LO 460	Totals
00 - 01	0	0	0	1	0	0	19	14	13	9	8	64
01 - 02	0	0	0	1	0	0	19	14	13	9	8	64
02 - 03	0	0	0	1	0	0	19	14	13	9	8	64
03 - 04	0	0	0	1	0	0	19	14	13	9	8	64
04 - 05	0	0	0	1	0	0	19	13	13	9	8	63
05 - 06	0	0	0	1	0	0	19	13	13	9	8	63
06 - 07	0	0	0	1	0	0	19	13	13	9	8	63
07 - 08	0	0	0	1	0	0	19	13	13	9	8	63
08 - 09	15	27	27	0	22	21	20	13	13	9	8	175
09 - 10	15	29	28	2	22	22	20	13	13	9	8	181
10 - 11	17	29	28	2	22	22	20	13	13	9	8	183
11 - 12	15	29	28	2	22	22	20	13	13	9	8	181
12 - 13	15	27	27	1	22	22	20	13	13	9	8	177
13 - 14	15	27	27	0	22	21	20	13	13	9	8	175
14 - 15	0	0	0	1	21	0	20	13	13	9	8	85
15 - 16	0	0	0	1	21	0	20	13	13	9	8	85
16 - 17	0	0	0	1	21	21	20	13	13	9	8	106
17 - 18	15	27	27	0	22	21	20	13	13	9	8	175
18 - 19	15	27	27	0	22	21	20	14	13	9	8	176
19 - 20	15	29	27	2	22	22	20	14	13	9	8	181
20 - 21	17	29	28	2	22	22	20	14	13	9	8	184
21 - 22	0	0	0	1	21	15	20	14	13	9	8	101
22 - 23	0	0	0	1	0	0	19	14	13	9	8	64
23 - 00	0	0	0	1	0	0	19	14	13	9	8	64
Totals	154	280	274	25	304	252	470	322	312	216	192	2,801

Day Option

Tuesday
 Wednesday
 Thursday
 Friday
 Saturday
 Sunday

Frozen Option

Tuesday
 Wednesday
 Thursday
 Friday
 Saturday
 Sunday

Notes
The Generation Value is MWh.
The Number in the heading is the ISO Hydro Unit ID.

45

Ready... Start Date: Tuesday Sep 14, 1999 10hrs End Date: Monday Sep 20, 1999 Midnight

Optimized Unit Maintenance

- Work Required
- Crews Available
- Regular Hours and Overtime



GO



List of Scheduled Outages

Plant	Unit	Window Start	Window End	Outage Duration (wks)	Optimal Window Start	Optimal Window End	Energy Value / Week	MW Outage	Opt
Wyman	2	Nov. 13, 1999 00:00	Jan. 1, 2000 00:00	7.00	Nov. 13, 1999 00:00	Jan. 1, 2000 00:00	NA	27.13	<input type="checkbox"/>
Weston	2	Oct. 16, 1999 00:00	Oct. 23, 1999 00:00	1.00	Oct. 16, 1999 00:00	Oct. 23, 1999 00:00	NA	3.38	<input type="checkbox"/>
Weston	3	Oct. 23, 1999 00:00	Oct. 30, 1999 00:00	1.00	Oct. 23, 1999 00:00	Oct. 30, 1999 00:00	NA	3.55	<input type="checkbox"/>
Weston	4	Oct. 30, 1999 00:00	Nov. 6, 1999 00:00	1.00	Oct. 30, 1999 00:00	Nov. 6, 1999 00:00	NA	3.63	<input type="checkbox"/>
Lockwood	7	Sep. 18, 1999 00:00	Oct. 9, 1999 00:00	3.00	Sep. 18, 1999 00:00	Oct. 9, 1999 00:00	NA	2.45	<input type="checkbox"/>
Williams	1	Oct. 18, 1999 06:00	Oct. 22, 1999 16:00	0.57	Oct. 18, 1999 06:00	Oct. 22, 1999 16:00	NA	8.00	<input type="checkbox"/>
Williams	2	Oct. 12, 1999 06:00	Oct. 15, 1999 16:00	0.43	Oct. 12, 1999 06:00	Oct. 15, 1999 16:00	NA	6.50	<input type="checkbox"/>
Wyman	2	Nov. 13, 1999 00:00	Jan. 1, 2000 00:00	7.00	Nov. 13, 1999 00:00	Jan. 1, 2000 00:00	NA	27.13	<input type="checkbox"/>

Scheduled Outages [Unscheduled Outages](#) [Optimized Values](#)

Select Unavailable Units

At Plant:

Unit Number:

Window Start Date:

Window End Date:

Lockwood
 Shawmut
 Weston
 Williams
 Wyman
 Harris

Weeks of Down Time Required:

Max simultaneous outages:


Optimize within window
 Rigid schedule - Do not optimize

Site Specific Features

- Hydraulic Constraints
- Encroachment from below and above



Tailwater Encroachment Data



Effect of Hydraulic Control



**Reservoir
Looking Upstream**




**Reservoir
Looking Downstream**

Project Coordination Issues


- Owners
- Governments
- Economics and Politics

Mid-Columbia Hydro System Optimization Model of Fully Integrated Operations





Mid-Columbia System (12,700 MW)



Objective of the Study

- **Seven major hydro plants, two major reservoirs**
- **Four completely different owners.**
- **Determine the energy benefit of fully coordinated and integrated hourly operations.**

Global System Water Management

- **Conflicting Constraints, TDG vs Fish Spills**
- **Ramping Constraints**
- **Flood Management**
- **Water Level Management**
- **Water Quality Management**
- **Coordination with Downstream Projects**
- **Natural Channel Controls on Storage**
- **Hydro Plant Efficiency Curves**
- **System Base Points (Loads among Plants)**

Optimal Generation Management

- Representation of Hill Curves
- Validation with Historical Operations Data
- Run Times for Operations Planning Studies
- Run Times for Scheduling Operations
- Run Times for Near Real-Time Operations
- Unit Priorities and Maintenance
- Hydro Plant Efficiency Curves
- Operations Constraints

Topics for Discussion



- 1. The hydro enterprise should recognize that optimization is a normal tool for hydro systems operations and it has been used in many systems, some more successfully than others.
- 2. Operations optimization will minimize errors in judgment and identify good choices from many that are feasible. This can be pivotal when changes in regulations, market conditions, the hydro system, or staff make past experience less valuable.
- 3. Data issues often dominate the design of the software and its ultimate acceptance. The model builder must anticipate that data was recorded for other prior purposes and is incomplete for the purposes of model design and verification.

- 4. Optimization software usually consists of several separate modules that deal with decisions on different time scales and spatial scope. These are sensitive issues for time and cost of model development, the execution time on a computer, and its verification and acceptance.
- 5. Models should be outwardly simple, understandable, and foolproof. User interfaces must be useful to the actual operators, not just modelers.
- 6. Before serious development effort begins, as the goals and expectations are discussed, the developer and the client should agree on criteria for acceptance, and what not to model.

- 7. For validation of its water management functions an optimization model can be run in a simulation mode using optimization output for selected variables as inputs.
- 8. Validation of optimized unit dispatch and loading should compare the optimized MW plant output with actual plant output over 24-hours at a one minute time step under a range of operating constraints and seasonal constraints.
- 9. The allocation of "base points" in a system of hydro plants should consider the oscillating shape of the plant efficiency curves as they are affected by the dispatch order of the generating units. Base points throughout the system should be selected from peaks of the plant curves to avoid asking a plant to generate in a lower efficiency trough.

- 10. Methods That are least risky for development, least expensive in time and money, and most reliable use some variant of linear programming, such as quadratic linear programming, stochastic linear programming, etc.
- 11. A useful optimization approach combines quadratic linear programming for managing the water balance with dynamic programming to dispatch generating units and construct optimized plant efficiency curves from the unit hill surfaces.
- 12. It is likely that stochastic, non-linear methods will become the methods of choice when new software makes modern multiprocessor boards with hundreds of processors more convenient for rapid integrated system-wide optimization.

- 13. The current advances in real-time wireless data acquisition and management will profoundly change the applications for optimization methods in water management and power operations.
- 14. Acceptance of the software relies on more than simply putting it in front of the intended users. The process of model validation can be an important step in training people to understand its limitations and advantages.

- 15. The software design should focus on fundamentals: reading, writing, and arithmetic of the software and its specific application. Users should not need a map to untangle a plethora of drop boxes that lead to still more drop boxes.
- 16. Stochastic optimization is a well understood method for dealing with uncertainty and probability in hydrology. It is well understood by modelers and has the potential to incorporate other factors like prices and loads to estimate risk on an ongoing basis