


# **State of Mississippi** ENERGY SECTOR RISK PROFILE



The Risk Profile highlights risk considerations relating to the electric, petroleum and natural gas infrastructures to become more aware of risks to these energy systems and assets.

### MISSISSIPPI STATE FACTS

### **State Overview**

Population: 2.99 million (1% total U.S.) Housing Units: 1.28 million (1% total U.S.) Business Establishments: 0.06 million (1% total U.S.)

### **Annual Energy Consumption**

Electric Power: 48.4 TWh (1% total U.S.) Coal: 5,200 MSTN (1% total U.S.) Natural Gas: 251 Bcf (1% total U.S.)

Motor Gasoline: 38,100 Mbarrels (1% total U.S.) Distillate Fuel: 20,400 Mbarrels (1% total U.S.)

#### **Annual Energy Production**

Electric Power Generation: 54.6 TWh (1% total U.S.)


Coal: 7.2 TWh, 13% [2.9 GW total capacity]
Petroleum: 0 TWh, 0% [0 GW total capacity]
Natural Gas: 38.5 TWh, 71% [12.9 GW total capacity]
Nuclear: 7.3 TWh, 13% [1.4 GW total capacity]
Hydro: 0 TWh, 0% [0 GW total capacity]

Other Renewable: 0 TWh, <1% [0.2 GW total capacity]

Coal: 3,000 MSTN (<1% total U.S.) Natural Gas: 60 Bcf (<1% total U.S.) Crude Oil: 24,200 Mbarrels (1% total U.S.) Ethanol: 1,000 Mbarrels (<1% total U.S.)

### NATURAL HAZARDS OVERVIEW


# Annual Frequency of Occurrence of Natural Hazards in Mississippi (1996–2014)



# According to NOAA, the most common natural hazard in Mississippi is Thunderstorm & Lightning, which occurs once every 2.9 days on the average during the months of March to October.

The second-most common natural hazard in Mississippi is Flood, which occurs once every 11.8 days on the average.


# Annualized Property Loss due to Natural Hazards in Mississippi (1996–2014)



- As reported by NOAA, the natural hazard in Mississippi that caused the greatest overall property loss during 1996 to 2014 is Hurricane at \$373.5 million per year.
- The natural hazard with the second-highest property loss in Mississippi is Tornado at \$57.3 million per year.

ENERGY SECTOR RISK PROFILE State of Mississippi

# **ELECTRIC**




State of Mississippi ENERGY SECTOR RISK PROFILE


### **Electric Transmission**

- According to NERC, the leading cause of electric transmission outages in Mississippi is Faulty Equipment/Human Error.
- Mississippi experienced 34 electric transmission outages from 1992 to 2009, affecting a total of 1,729,515 electric customers.
- **Natural Disaster Hurricane/Tropical Storm** affected the largest number of electric customers as a result of electric transmission outages.

# Electric Customers Disrupted by NERC-Reported Electric Transmission Outages by Cause (1992–2009)




Number of NERC-Reported Electric Transmission Outages by Cause (1992–2009)



Data Source: NERC


### **Electric Distribution**

#### Electric-Utility Reported Power Outages by Month (2008–2013)




- **)** Between 2008 and 2013, the greatest number of electric outages in Mississippi has occurred during the month of **August**.
- The leading cause of electric outages in Mississippi during 2008 to 2013 was Weather/Falling Trees.
- On average, the number of people affected annually by electric outages during 2008 to 2013 in Mississippi was **81,888**.
- The average duration of electric outages in Mississippi during 2008 to 2013 was 1,162 minutes or 19.4 hours a year.

### Causes of Electric-Utility Reported Outages (2008–2013)



### Utility Outage Data (2008–2013)




NOTE: # of Incidents – The number within each pie slice is the number of event incidents attributable to each cause.

PAGE | 3

ENERGY SECTOR RISK PROFILE State of Mississippi


# **PETROLEUM**



State of Mississippi ENERGY SECTOR RISK PROFILE

### **Petroleum Transport**


### Top Events Affecting Petroleum Transport by Truck and Rail (1986-2014)



The leading event type affecting the transport of petroleum product by rail and truck in Mississippi during 1986 to 2014 was Incorrect Operation for rail transport and Miscellaneous/Unknown for truck transport, with an average 0.5 (or one incident every 2 years) and 6.0 incidents per year, respectively.

Data Source: DOT PHMSA

### Top Events Affecting Crude Oil and Refined Product Pipelines in Mississippi (1986–2014)



The leading event type affecting crude oil pipeline and petroleum product pipelines in Mississippi during 1986 to 2014 was Equipment Failure for crude oil pipelines and Equipment Failure for product pipelines, with an average 0.55 and 0.59 incidents per year (or one incident every 1.8 and 1.7 years), respectively.


### **Petroleum Refinery**

The leading cause of petroleum refinery disruptions in Mississippi from 2003 to 2014 was **Equipment Failure or Damage**. Mississippi's petroleum refineries experienced **51 major incidents** from 2003 to 2014. The average production impact from disruptions of Mississippi's refineries from 2003 to 2014 is **77.4 thousand barrels per day**.

# Top-Five Causes of Petroleum Refinery Disruptions in Mississippi (2003–2014)



## Average Production Impact (thousand barrels per day) from Petroleum Refinery Outages in Mississippi (2003–2014)




Data Source: DOE OE

PAGE | 5

ENERGY SECTOR RISK PROFILE State of Mississippi

# **NATURAL GAS**




State of Mississippi ENERGY SECTOR RISK PROFILE

### **Natural Gas Transport**

The leading event type affecting natural gas transmission and distribution pipelines in Mississippi during 1986 to 2014 was Miscellaneous/Unknown for Transmission Pipelines and Miscellaneous/Unknown for Distribution Pipelines, with an average 0.74 and 0.35 incidents per year (or one incident every 1.3 and 2.8 years), respectively.

Top Events Affecting Natural Gas Transmission and Distribution in Mississippi (1986-2014)




Data Source: DOT PHMSA


### **Natural Gas Processing**

- According to data derived from DOE's Energy Assurance Daily, the leading cause of natural gas processing plant disruptions in Mississippi from 2005 to 2014 is Operational Upset or Process Problem.
- Mississippi's natural gas processing plants experienced 3 disruptions from 2005 to 2014.
- The average production impact from disruptions of Mississippi's natural gas processing plants from 2005 to 2014 is 1,333 million cubic feet per day (MMcfd).

# Top-Three Causes of Natural Gas Processing Plant Disruptions in Mississippi (2005–2014)



# Average Production Impact (MMcfd) from Natural Gas Processing Plant Disruptions in Mississippi (2005–2014)



Data Source: DOE OE

### **DATA SOURCES**

#### **Overview Information**

NOAA (2014) Storms Events Database [www.ncdc.noaa.gov/data-access/severe-weather]

• Census Bureau (2012) State and County QuickFacts [http://quickfacts.census.gov/qfd/ download\_data.html]

Bcf – Billion Cubic Feet
GW – Gigawatt
kV – Kilovolt
Mbarrels – Thousand Barrels
Mbpd – Thousand Barrels per Day
MMcfd – Million Cubic Feet per Day
MSTN – Thousand Short Tons
TWh – Terawatt hours

#### **Production Numbers**

- EIA (2012) Table P1 Energy Production Estimates in Physical Units [http://www.eia.gov/state/seds/sep\_prod/pdf/P1.pdf]
- EIA (2013) Natural Gas Gross Withdrawals and Production [http://www.eia.gov/dnav/ng/ng\_prod\_sum\_a\_EPG0\_VGM\_mmcf\_a.htm]
- EIA (2012) Electric Power Annual, Table 3.6. Net Generation by State, by Sector, 2012 and 2011 (Thousand Megawatt hours) [http://www.eia.gov/electricity/annual/pdf/epa.pdf]
- EIA (2012) Electric Power Annual, Existing Nameplate and Net Summer Capacity by Energy Source, Producer Type and State (EIA-860) [http://www.eia.gov/electricity/data/state/]

### **Consumption Numbers**

- EIA (2012) Electric Power Annual, Fossil Fuel Consumption for Electricity Generation by Year, Industry Type and State (EIA-906, EIA-920, and EIA-923) [http://www.eia.gov/electricity/data/state/]
- EIA (2013) Prime Supplier Sales Volumes [http://www.eia.gov/dnav/pet/pet\_cons\_prim\_dcu\_nus\_m.htm]
- EIA (2012) Adjusted Sales of Fuel Oil and Kerosene [http://www.eia.gov/petroleum/data.cfm#consumption]
- > EIA (2012) Annual Coal Consumption [http://www.eia.gov/coal/data.cfm]

### **Electricity**

- ) EIA (2013) Form-860 Power Plants [http://www.eia.gov/electricity/data/eia860/]
- > Platts (2014 Q2) Transmission Lines (Miles by Voltage Level)
- > Platts (2014 Q2) Power Plants (Production and Capacity by Type)

### **Petroleum**

- Argonne National Laboratory (2012) Petroleum Terminal Database
- Argonne National Laboratory (2014) Ethanol Plants
- ) EIA (2013) Petroleum Refinery Capacity Report [http://www.eia.gov/petroleum/refinerycapacity/]
- NPMS (2011) Petroleum Product Pipeline (Miles of Interstate Pipeline)
- NPMS (2011) Crude Pipeline (Miles of Interstate Pipeline)

#### **Natural Gas**

- EIA (2013) Form-767 Natural Gas Processing Plants [http://www.eia.gov/cfapps/ngqs/ngqs.cfm?f\_report=RP9]
- FIA (2013) Number of Producing Gas Wells [http://www.eia.gov/dnav/ng/ng\_prod\_wells\_s1\_a.htm]
- NPMS (2011) Natural Gas Pipeline (Miles of Interstate Pipeline)
- > Platts (2014 Q2) Local Distribution Companies (LDCs)

### **Event Related**

- DOE OE (2014) Form 417 Electric Disturbance Events [http://www.oe.netl.doe.gov/OE417\_annual\_summary.aspx]
- DOE OE (2014) Energy Assurance Daily (EAD) [http://www.oe.netl.doe.gov/ead.aspx]
- ▶ Eaton (2014) Blackout and Power Outage Tracker [http://powerquality.eaton.com/blackouttracker/default.asp?id=&key=&Quest\_user\_id=&leadg\_Q\_QRequired=&site=&menu=&cx=3&x=16&y=11]
- DOT PHMSA (2013) Hazardous Material Incident System (HMIS) [https://hazmatonline.phmsa.dot/gov/IncidentReportsSearch/search.aspx]
- NERC (2009) Disturbance Analysis Working Group [http://www.nerc.com/pa/rrm/ea/Pages/EA-Program.aspx]\*

  \*The NERC disturbance reports are not published after 2009.

### Notes

- Natural Hazard, Other, includes extreme weather events such as astronomical low tide, dense smoke, frost/freeze, and rip currents.
- Each incident type is an assembly of similar causes reported in the data source. Explanations for the indescribable incident types are below.
  - ) Outside Force refers to pipeline failures due to vehicular accident, sabotage, or vandalism.
  - ) Natural Forces refers to damage that occurs as a result of naturally occurring events (e.g., earth movements, flooding, high winds, etc.)
  - Miscellaneous/Unknown includes releases or failures resulting from any other cause not listed or of an unknowable nature.
  - ) Overdemand refers to outages that occur when the demand for electricity is greater than the supply, causing forced curtailment.
- Number (#) of Incidents The number within each pie chart piece is the number of outages attributable to each cause.

FOR MORE INFORMATION CONTACT:
Office of Electricity Delivery and Energy Reliability

U.S. Department of Energy Phone: 202-586-2264

Email: energyresponsecenter@hq.doe.gov