


Gulf Coast Region ENERGY SECTOR RISK PROFILE



This Energy Risk Profile examines the relative magnitude of the risks that the Gulf Coast Region's energy infrastructure routinely encounters in comparison with the probable impacts. The Gulf Coast Region consists of the States of Alabama, Arkansas, Louisiana, Mississippi, New Mexico and Texas. Natural and man-made hazards with the potential to cause disruption of the energy infrastructure are identified.

The Risk Profile highlights risk considerations relating to the electric, petroleum and natural gas infrastructures to become more aware of risks to these energy systems and assets.

GULF COAST REGION FACTS

Region Overview

Population: 44 million (14% total U.S.) Housing Units: 18 million (14% total U.S.) Business Establishments: 1 million (12% total U.S.)

Annual Energy Consumption

Electric Power: 654.4 TWh (18% total U.S.)
Coal: 174,055 MSTN (20% total U.S.)
Natural Gas: 6,560 Bcf (28% total U.S.)

Motor Gasoline: 499,900 Mbarrels (17% total U.S.) Distillate Fuel: 286,500 Mbarrels (21% total U.S.)

Annual Energy Production

Electric Power Generation: 842.3 TWh (21% total U.S.)


Coal: 265.8 TWh, 32% [56.4 GW total capacity]
Petroleum: 4.7 TWh, <1% [130.6 GW total capacity]
Natural Gas: 392.6 TWh, 47% [0.2 GW total capacity]
Nuclear: 117.7 TWh, 14% [15.8 GW total capacity]
Hydro: 11.2 TWh, 1% [5.4 GW total capacity]

Other Renewable: 50.3 TWh, 6% [16.2 GW total capacity]

Coal: 93,100 MSTN (9% total U.S.) Natural Gas: 13,070 Bcf (55% total U.S.) Crude Oil: 921,900 Mbarrels (49% total U.S.) Ethanol: 9,700 Mbarrels (3% total U.S.)

NATURAL HAZARDS OVERVIEW


Annual Frequency of Occurrence of Natural Hazards (1996-2014)



According to NOAA, the most common natural hazard in the Gulf Coast Region is Flood, which occurs once every 1.4 days on the average during the months of March to October.

The second-most common natural hazard in the region is Tornadoes, which occurs once every 3.7 days on the average.


Annualized Property Loss due to Natural Hazards (1996-2014)



- As reported by NOAA, the natural hazard the Gulf Coast Region that caused the greatest overall property loss during 1996 to 2014 is Hurricane at \$1,191.8 million per year.
- The natural hazard with the second-highest property loss in the region is Drought at \$782.2 million per year.

ENERGY SECTOR RISK PROFILE Gulf Coast Region


ELECTRIC



Electric Transmission


- According to NERC, the leading cause of electric transmission outages in the Gulf Coast Region is Other Causes.
- The region experienced 228 electric transmission outages from 1992 to 2009, affecting a total of 19.4 million electric customers.
- Natural Disaster Hurricane/Tropical Storm affected the largest number of electric customers as a result of electric transmission outages.

Electric Customers Disrupted by NERC-Reported Electric Transmission Outages by Cause (1992-2009)




Data Source: NERC

Number of NERC-Reported Electric Transmission Outages by Cause (1992-2009)



Electric Distribution


Electric Utility Reported Power Outages by Month (2008-2013)



Data Source: Eaton


- Between 2008 and 2013, the greatest number of electric outages has occurred during the month of August in the Gulf Coast Region.
-) The leading cause of electric outages during 2008 to 2013 was Weather/Falling Trees.
- In On average, the number of people affected annually by electric outages during 2008 to 2013 was 2.4 million.
- **)** The average duration of electric outages in the region during 2008 to 2013 was 16,265 minutes or 271 hours a year.

Causes of Electric-Utility Reported Outages (2008–2013)



NOTE: # of Incidents – The number within each pie slice is the number of event incidents attributable to each cause.


Utility Outage Data (2008-2013)



PAGE | 3

ENERGY SECTOR RISK PROFILE Gulf Coast Region


PETROLEUM



Gulf Coast Region ENERGY SECTOR RISK PROFILE

Petroleum Transport


Top Events Affecting Petroleum Transport by Truck and Rail (1986–2014)



The leading event type affecting the transport of petroleum product by rail and truck during 1986 to 2014 was Incorrect Operation for rail transport and Miscellaneous/Unknown for truck transport, with an average 15 and 50.3 incidents per year, respectively.

Data Source: DOT PHMSA

Top Events Affecting Crude Oil and Refined Product Pipelines (1986–2014)




The leading event type affecting crude oil pipeline and petroleum product pipelines during 1986 to 2014 was Corrosion for crude oil pipelines and Equipment Failure for product pipelines, with an average 22.14 and 10.93 incidents per year, respectively.


Petroleum Refinery

The leading cause of petroleum refinery disruptions in the Gulf Coast Region from 2003 to 2014 was All Other Causes. The region's petroleum refineries experienced 3,966 major incidents from 2003 to 2014. The weighted average production impact from all disruptions at the refineries within the region from 2003 to 2014 is 216.5 thousand barrels per day.

Top-Five Causes of Petroleum Refinery Disruptions (2003–2014)



Average Production Impact by Disruption Type (thousand barrels per day) at Petroleum Refineries (2003–2014)




Data Source: DOE OE

PAGE | 5

ENERGY SECTOR RISK PROFILE Gulf Coast Region

NATURAL GAS




Gulf Coast Region ENERGY SECTOR RISK PROFILE

Natural Gas Transport

The leading event type affecting natural gas transmission and distribution pipelines in the Gulf Coast Region during 1986 to 2014 was Corrosion for Transmission Pipelines and Outside Force for Distribution Pipelines, with an average 13.61 and 14.81 incidents per year, respectively.


Top Events Affecting Natural Gas Transmission and Distribution (1986–2014)




Natural Gas Processing

- According to data derived from DOE's Energy Assurance Daily, the leading cause of natural gas processing plant disruptions in the Gulf Coast Region from 2005 to 2014 is Operational Upset or Process Problem.
- The region's natural gas processing plants experienced 1,355 disruptions from 2005 to 2014.
- The weighted average production impact from all disruptions at the natural gas processing plants within the region from 2005 to 2014 is 149 million cubic feet per day (MMcfd).

Top-Five Causes of Natural Gas Processing Plant Disruptions (2005–2014)



Average Production Impact by Disruption Type (MMcfd) at Natural Gas Processing Plants (2005–2014)



Data Source: DOE OE

DATA SOURCES

Overview Information

NOAA (2014) Storms Events Database [www.ncdc.noaa.gov/data-access/severe-weather]

• Census Bureau (2012) State and County QuickFacts [http://quickfacts.census.gov/qfd/ download_data.html]

Bcf – Billion Cubic Feet
GW – Gigawatt
kV – Kilovolt
Mbarrels – Thousand Barrels
Mbpd – Thousand Barrels per Day
MMcfd – Million Cubic Feet per Day
MSTN – Thousand Short Tons
TWh – Terawatt hours

Production Numbers

- EIA (2012) Table P1 Energy Production Estimates in Physical Units [http://www.eia.gov/state/seds/sep_prod/pdf/P1.pdf]
- EIA (2013) Natural Gas Gross Withdrawals and Production [http://www.eia.gov/dnav/ng/ng_prod_sum_a_EPG0_VGM_mmcf_a.htm]
- EIA (2012) Electric Power Annual, Table 3.6. Net Generation by State, by Sector, 2012 and 2011 (Thousand Megawatt hours) [http://www.eia.gov/electricity/annual/pdf/epa.pdf]
- EIA (2012) Electric Power Annual, Existing Nameplate and Net Summer Capacity by Energy Source, Producer Type and State (EIA-860) [http://www.eia.gov/electricity/data/state/]

Consumption Numbers

- EIA (2012) Electric Power Annual, Fossil Fuel Consumption for Electricity Generation by Year, Industry Type and State (EIA-906, EIA-920, and EIA-923) [http://www.eia.gov/electricity/data/state/]
- EIA (2013) Prime Supplier Sales Volumes [http://www.eia.gov/dnav/pet/pet_cons_prim_dcu_nus_m.htm]
- EIA (2012) Adjusted Sales of Fuel Oil and Kerosene [http://www.eia.gov/petroleum/data.cfm#consumption]
- > EIA (2012) Annual Coal Consumption [http://www.eia.gov/coal/data.cfm]

Electricity

-) EIA (2013) Form-860 Power Plants [http://www.eia.gov/electricity/data/eia860/]
- > Platts (2014 Q2) Transmission Lines (Miles by Voltage Level)
- > Platts (2014 Q2) Power Plants (Production and Capacity by Type)

Petroleum

- Argonne National Laboratory (2012) Petroleum Terminal Database
- Argonne National Laboratory (2014) Ethanol Plants
-) EIA (2013) Petroleum Refinery Capacity Report [http://www.eia.gov/petroleum/refinerycapacity/]
- NPMS (2011) Petroleum Product Pipeline (Miles of Interstate Pipeline)
- NPMS (2011) Crude Pipeline (Miles of Interstate Pipeline)

Natural Gas

- EIA (2013) Form-767 Natural Gas Processing Plants [http://www.eia.gov/cfapps/ngqs/ngqs.cfm?f_report=RP9]
-) EIA (2013) Number of Producing Gas Wells [http://www.eia.gov/dnav/ng/ng prod wells s1 a.htm]
- NPMS (2011) Natural Gas Pipeline (Miles of Interstate Pipeline)
- > Platts (2014 Q2) Local Distribution Companies (LDCs)

Event Related

- DOE OE (2014) Form 417 Electric Disturbance Events [http://www.oe.netl.doe.gov/OE417_annual_summary.aspx]
- DOE OE (2014) Energy Assurance Daily (EAD) [http://www.oe.netl.doe.gov/ead.aspx]
- ▶ Eaton (2014) Blackout and Power Outage Tracker [http://powerquality.eaton.com/blackouttracker/default.asp?id=&key=&Quest_user_id=&leadg_Q_QRequired=&site=&menu=&cx=3&x=16&y=11]
- DOT PHMSA (2013) Hazardous Material Incident System (HMIS) [https://hazmatonline.phmsa.dot/gov/IncidentReportsSearch/search.aspx]
- NERC (2009) Disturbance Analysis Working Group [http://www.nerc.com/pa/rrm/ea/Pages/EA-Program.aspx]*

 *The NERC disturbance reports are not published after 2009.

Notes

- Natural Hazard, Other, includes extreme weather events such as astronomical low tide, dense smoke, frost/freeze, and rip currents.
- Each incident type is an assembly of similar causes reported in the data source. Explanations for the indescribable incident types are below.
 -) Outside Force refers to pipeline failures due to vehicular accident, sabotage, or vandalism.
 -) Natural Forces refers to damage that occurs as a result of naturally occurring events (e.g., earth movements, flooding, high winds, etc.)
 - Miscellaneous/Unknown includes releases or failures resulting from any other cause not listed or of an unknowable nature.
 -) Overdemand refers to outages that occur when the demand for electricity is greater than the supply, causing forced curtailment.
- Number (#) of Incidents The number within each pie chart piece is the number of outages attributable to each cause.

FOR MORE INFORMATION CONTACT:
Office of Electricity Delivery and Energy Reliability

U.S. Department of Energy Phone: 202-586-2264

Email: energyresponsecenter@hq.doe.gov