

PACIFICORP

Oregon

2003 Analysis of System Losses

April 2005

Prepared by:



Management Applications Consulting, Inc.
1103 Rocky Drive – Suite 201
Reading, PA 19609
Phone: (610) 670-9199 / Fax: (610) 670-9190



MANAGEMENT APPLICATIONS CONSULTING, INC.

1103 Rocky Drive • Suite 201 • Reading, PA 19609-1157 • 610/670-9199 • fax 610/670-9190 • www.manapp.com

March 31, 2005

Mr. Jack E. Stamper, P.E.
Regulatory Manager, Transmission Systems
PacifiCorp
700 N.E. Multnomah, Suite 550-POP
Portland, Oregon 97232

RE: 2003 LOSS ANALYSES –Oregon

Dear Mr. Stamper:

Transmitted herewith are the results of the 2003 Analysis of System Losses for the Oregon operations. These results consist of an Annual analysis which develops cumulative expansion factors (loss factors) for both demand (peak) and energy (average) losses by discrete voltage levels. The loss calculations were made using a separate transmission loss model which was then incorporated into the Oregon loss model to derive the final results prescribed herein. The Loss Models being provided to you in this study represent the most current version.

The continuing reduction in power losses in recent years as a result of system improvements and load growth has resulted in a sizable lowering of loss factors as evidenced in our studies and shown on Tables 1 and 2 of the report's Executive Summary. To this end, future studies should extend review efforts and data gathering enhancement in the area of power flow modeling, estimates of unbilled sales, and primary circuit analyses.

On behalf of MAC, we appreciate the opportunity to assist you in performing the loss analysis contained herein. The level of detail, multiple databases, and state jurisdictions coupled with load flow studies and updates are consistent with prior loss studies and reflect a reasonable representation of the power losses on the PacifiCorp system. Our review of these calculated loss results support the loss factors as presented herein for your use in various cost of service, rate studies, and demand analyses.

Should you require any additional information, please let us know at your earliest convenience.

Sincerely,

A handwritten signature in black ink, appearing to read 'Paul M. Normand', written in a cursive style.

Paul M. Normand
Principal

PACIFICORP - OREGON
2003 ANALYSIS OF SYSTEM LOSSES

TABLE OF CONTENTS

1.0	EXECUTIVE SUMMARY	1
2.0	INTRODUCTION	3
2.1	Conduct of Study	3
2.2	Description of Model	4
3.0	METHODOLOGY	5
3.1	Background	5
3.2	Analysis and Calculations.....	7
3.2.1	Bulk, Transmission and Subtransmission Lines	7
3.2.2	Transformers	8
3.2.3	Distribution System	8
4.0	DISCUSSION OF RESULTS	10

Appendix A - Results of PacifiCorp Transmission 2003 Loss Analysis

Appendix B – Results of PacifiCorp Oregon 2003 Loss Analysis

Appendix C - Discussion of Hoebel Coefficient

Oregon 2003 Analysis of System Losses

1.0 EXECUTIVE SUMMARY

This report presents PacifiCorp's 2003 Analysis of System Losses for Oregon's power systems as performed by Management Applications Consulting, Inc. (MAC). The study developed separate demand (kW) and energy (kWh) loss factors (loss factors) for each voltage level of service in the power system. The loss factor results, as presented herein, can be used to adjust metered sales data in Oregon for losses in performing cost of service studies, determining voltage discounts, and other analyses which may require a loss adjustment. Typically, these factors are used to adjust metered kW and kWh data prior to the allocation of costs in order to equitably account for losses related to the consumption of power on the power system.

The procedures used in the overall study were consistent with prior studies and emphasized the use of "in house" resources where possible. To this end, extensive use was made of the Company's peak hour load flow studies and transformer plant investments in the modeling. In addition, estimated load data provided a means of calculating reasonable estimates of losses by using a "top-down" and "bottom-up" procedure. In the "top-down" approach, losses from the high voltage system, through and including distribution substations, were calculated along with load flow results, transformer loss estimates, and metered sales.


At this point in the analysis, system loads and losses at the input into the distribution substation system are known with reasonable accuracy. However, it is the remaining loads and losses on the distribution substations, primary system, secondary circuits, and services which are generally difficult to estimate. The load data provided the starting point for performing a "bottom-up" approach for estimating the remaining distribution losses. Basically, this "bottom-up" approach develops line loadings by first determining loads and losses at each level beginning at a customer's service entrance and then going through secondary lines, line transformers, primary lines and finally distribution substation. These distribution system loads and associated losses are then compared with the initial calculated input into Distribution Substation loadings for reasonableness prior to finalizing the loss factors. An overview of the loss study is shown on Figure 1 on the next page.

Appendix A presents the results of the PacifiCorp system-wide Transmission 2003 Loss Analysis for the integrated PacifiCorp System. Appendix B presents the PacifiCorp Oregon 2003 Loss Analyses.

Table 1 on Page 2 provides the final results from Appendix A and B for the calendar year. The distribution system losses are calculated in Appendix B for all voltage levels except transmission which was obtained from Appendix A. These loss expansion factors are applicable only to metered sales at the point of receipt for adjustment to the power system's input level.

MANAGEMENT APPLICATIONS CONSULTING, INC.

ELECTRIC LOSS MODEL OVERVIEW



Oregon 2003 Analysis of System Losses

Table 2 presents a three-year summary of the declining PacifiCorp power system losses as well as the Oregon only losses over this same period of time. These major declines in losses have had a marked effect on the loss factors as can be noted in Table 1 by voltage delivery level.

These improving loss factors signal an excellent trend in system utilization and efficiency through investments, operations, and load growth. Future studies should encompass an expanded review of the power system by enhancing its power flow model, reviewing the detailed unbilled calculations and additional primary circuit analyses.

TABLE 1
Loss Factors at Sales Level
Oregon

<u>Voltage Level of Service</u>	<u>2003</u>	<u>2002</u>	<u>2001</u>
<u>Demand (kW)</u>			
Transmission ¹	1.04775	1.05144	1.05697
Primary	1.08658	1.09134	1.09755
Secondary	1.11606	1.12187	1.12746
<u>Energy (kWh)</u>			
Transmission ¹	1.03788	1.04020	1.04543
Primary	1.05846	1.06240	1.06908
Secondary	1.08421	1.09146	1.09950

TABLE 2
Summary of System MWH Losses

	<u>2003</u>	<u>2002</u>	<u>2001</u>
<u>Energy (MWH)</u>			
Total Company	61,994,956	67,157,785	65,985,214
Losses	3,820,026	4,275,859	4,655,892
% of Total	6.16	6.37	7.06
Total Oregon	16,718,140	18,650,778	18,631,289
Losses	1,107,774	1,267,440	1,404,993
% of Total	6.63	6.80	7.54

¹Reference Appendix A for development of Transmission loss factors.

2.0 INTRODUCTION

This report of the 2003 Analysis of System Losses for Oregon provides a summary of results, conceptual background or methodology, description of the analyses, and input information related to the study.

2.1 Conduct of Study

Typically, between five to ten percent of the total kWh requirements of an electric utility is lost or unaccounted for in the delivery of power to its customers. However, investments must be made in facilities which support the total load including losses or unaccounted for "load". Revenue requirements associated with load losses are an important concern to utilities and regulators in that customers must equitably share in these cost responsibilities. Loss expansion factors are the mechanism by which customers' metered demand and energy data are mathematically adjusted to the generation level (point of reference) when performing cost and revenue calculations.

Fortunately, a reasonable accounting of losses can be made on an ongoing basis by using available engineering, system, and customer data along with empirical relationships. This loss analysis for the delivery of demand and energy utilizes such an approach. A microcomputer LOSS MODEL² is utilized as the vehicle to organize the available data, develop the relationships, calculate the losses, and provide an efficient and timely avenue for future updates and sensitivity analyses. Our procedures and calculations are consistent with prior loss studies and relied on numerous databases that include customer statistics and power system investments.

Company personnel performed most of the data gathering and data processing efforts and checked for reasonableness. MAC provided assistance as necessary to load input, construct databases, transfer files, perform calculations, and check the reasonableness of results. A review of the preliminary results provided for additions to the database and modifications to certain initial assumptions based on available data. Once updated, the loss models were turned over to the Company's staff for further use. Efforts in determining the data required to perform the loss analysis centered on information which was available from existing studies or reports within the Company.

²Copyright by Management Applications Consulting, Inc.

Oregon 2003 Analysis of System Losses

From an overall perspective, our efforts concentrated on three major areas:

1. System information by state jurisdiction (monthly and annual)
2. High voltage power system (power flows)
3. Distribution system (primary and secondary)

2.2 Description of Model

The Loss Model is a customized applications model, constructed using Excel. Documentation consists primarily of the model equations at each cell location. References can also be made to the applicable paragraphs in the Excel manual to support the technical aspects of the model construction. A significant advantage of such a model is that the actual formulas and their corresponding computed values at each cell of the model are immediately available to the analyst.

A brief description of the three (3) major categories of effort for the preparation of each loss model is as follows:

- Main sheet which contains calculations for all primary and secondary losses, summaries of all conductor and transformer calculations from other sheets discussed below, output reports and supporting results.
- Transformer sheet which contains data input and loss calculations for each distribution substation and high voltage transformer. Separate iron and copper losses are calculated for each transformer by identified type.
- Conductor sheet containing summary data by major voltage level as to circuit miles, loading assumptions, and kW and kWh loss calculations. Separate loss calculations for each line segment were made in the Company's power flow models with summaries by voltage level incorporated in this model.

Appendix A presents a separate loss study result which derived the loss factors for the Company's system wide transmission only portion of the PacifiCorp power system. These transmission results formed the basis and starting point with which to derive the final Oregon loss factors for each remaining voltage level as presented in Appendix B and summarized on Table 1 of the Executive Summary.

3.0 METHODOLOGY

3.1 Background

The objective of a Loss Study is to provide a reasonable set of energy (average) and demand (peak) loss expansion factors which account for system losses associated with the transmission and delivery of power to each voltage level over a designated period of time. The focus of this study is to identify the difference between total energy inputs and the associated sales with the difference being equitably allocated to all delivery levels. Several key elements are important in establishing the methodology for calculating and reporting the Company's losses. These elements are:

- Selection of voltage level of services,
- Recognition of losses associated with conductors, transformations, and other equipment/components within voltage levels,
- Identification of customers and loads at various voltage levels,
- Review of generation or net power supply input at each level for the test period, and
- Analysis of kWh sales by voltage levels within the test period.

The three major areas of concentration with respect to data gathering and calculations in the loss analysis were as follows:

1. System Information (monthly and annual)
 - MWH generation and MWH sales.
 - Coincident peak estimates and net power supply input from all sources and voltage levels.
 - Customer load data estimates from available load research information, adjusted MWH sales, and number of customers in the customer groupings and voltage levels identified in the model.
 - System default values, such as power factor, loading factors, and load factors by voltage level.

Oregon 2003 Analysis of System Losses

2. High Voltage System (Appendix A)

- Conductor information was summarized from a database by the Company which reflects the transmission system by voltage level. Extensive use was made of the Company's load flow results with the losses incorporated into the final loss calculations.
- Transformer information was developed in a database to model transformation at each voltage level. Substation power, step-up, and auto transformers were individually identified along with any operating data related to loads and losses.
- Power load flow analysis of peak condition was the primary source of equipment loadings and load losses in the high voltage loss calculations (greater than 46 kV).

3. Distribution System (Appendix B)

- Distribution Substations – data was developed for modeling each substation, size and estimated loading of the transformers. Loss calculations were developed for load and no load losses separately.
- Primary lines - Line loading and loss characteristics for urban and rural circuits were obtained from distribution feeder analyses from a prior loss study. These loss results developed kW loss per MW of load by Primary Voltage level. An average was calculated to derive the primary loss estimate after weighting the proper rural versus urban customer mix.
- Line transformers - Losses in line transformers were based on each customer service group's size, as well as the number of customers per transformer. Accounting and load data provided the foundation with which to model the transformer loadings and calculate load and no load losses.
- Secondary network - Typical secondary networks were estimated for conductor sizes, lengths, loadings, and customer penetration for residential and small general service customers.
- Services - Typical services were estimated for each secondary service class of customers identified in the study with respect to type, length, and loading.

Oregon 2003 Analysis of System Losses

The loss analysis was thus performed by constructing the model in segments and subsequently calculating the composite until the constraints of peak demand and energy were met:

- Information as to the physical characteristics and loading of each transformer and conductor segment was modeled.
- Conductors, transformers, and distribution were grouped by voltage level, and unadjusted losses were calculated.
- The loss factors calculated at each voltage level were determined by "compounding" the per-unit losses. Equivalent sales at the supply point were obtained by dividing sales at a specific level by the compounded loss factor to determine losses by voltage level.
- The resulting demand and energy loss expansion factors were then used to adjust all sales to the generation or input level in order to estimate the difference.
- Reconciliation of kW and kWh sales by voltage level using the reported system kW and kWh was accomplished by adjusting the initial loss factor estimates until the mismatch or difference was eliminated.

3.2 Analysis and Calculations

This section provides a discussion of the input data, assumptions, and calculations performed in the loss analysis. Specific appendices have been included in order to provide documentation of the input data utilized in the model.

3.2.1 Bulk, Transmission and Subtransmission Lines

The transmission and subtransmission line losses were calculated based on a modeling of unique voltage levels identified by the Company's load flow configuration for the entire integrated PacifiCorp Power System. Specific information as to length of line, type of conductor, voltage level, peak load, maximum load, etc., were also provided based on Company records and utilized as data input summaries in the loss model.

MW and MVA line loadings were based on PacifiCorp's peak load estimate. Calculations of line losses were performed by the Company's power load flow for each line segment separately and combined by voltage levels for reporting

Oregon 2003 Analysis of System Losses

purposes as shown in the Discussion of Results (Section 4.0) of this report. The loss calculations consisted of determining a circuit current value based on MVA line loadings and evaluating the I^2R results for each line segment.

After system coincident peak hour losses were identified for each voltage level, a separate calculation was then made to develop annual average energy losses based on a loss factor approach. Load factors were determined for each voltage level based on system and customer load information. An estimate of the Hoebel coefficient (see Appendix C) was then used to calculate energy losses for the period analyzed. The results are presented in Section 4.0 of this report.

3.2.2 Transformers

The transformer loss analysis required several steps in order to properly consider the characteristics associated with various transformer types; such as, step-up, auto transformers, distribution substations, and line transformers. In addition, further efforts were required to identify both iron and copper losses within each of these transformer types in order to obtain reasonable peak (kW) and average energy (kWh) losses. While iron losses were considered essentially constant for each hour, recognition had to be made for the varying degree of copper losses due to hourly equipment loadings.

Standardized test data tables were used to represent no load (fixed) and full load losses for different types and sizes of transformers. This test data was incorporated into the Loss Model to develop relationships representing copper and iron losses for the transformer loss calculation. These results were then totaled by various groups, as identified and discussed in Section 4.0.

3.2.3 Distribution System

The results of the distribution substation loadings and customer load data were combined to estimate distribution system losses. The load data at the substation and customer level, coupled with primary and secondary network information, was sufficient to model the distribution system in adequate detail to calculate losses. Substation transformers final loadings were estimated using the sum of the calculated loads and losses of the distribution system.

Primary Lines

Primary line loadings take into consideration the available distribution load along with the actual customer loads including losses. Based on prior loss analyses, estimates were made of primary line losses by the different levels of distribution

Oregon 2003 Analysis of System Losses

voltage. These estimates consider substations, feeders per substation, voltage levels, loadings, total circuit miles, wire size, and single- to three-phase investment estimates. All of these factors were considered in calculating the actual demand (kW) and energy (kWh) for the primary system.

Line Transformers

Losses in line transformers were determined based on typical transformer sizes for each secondary customer service group and the estimated or calculated number of customers per transformer. Accounting records and estimates of load data provided the necessary database with which to model the loadings. These calculations also made it possible to determine separate copper and iron losses for distribution line transformers, based on a table of representative losses for various transformer sizes.

Secondary Network

An analysis of secondary network losses was performed for loads served through secondary line investments. Estimates of typical conductor sizes, lengths, loadings and customer class penetrations were made to obtain total circuit miles and losses for the secondary network. Customer loads which do not have secondary line requirements were also identified so that a reasonable estimate of losses and circuit miles of investments could be made.

Services and Meters

Services were estimated for each secondary customer reflecting conductor size, length, loadings, and miles of service to obtain demand losses. A separate calculation was also performed using customer maximum demands to obtain kWh losses.

Meter loss estimates were also made for each customer and incorporated into the calculations of kW and kWh losses included in the Summary Results of this report.

Oregon 2003 Analysis of System Losses

4.0 DISCUSSION OF RESULTS

A brief description of each Exhibit provided in Appendices A and B as follows:

Exhibit 1 - Summary of Company Data

Reflects system information used to determine percent losses and any deviations from estimated values.

Exhibit 2 - Summary of Conductor Information

A summary of MW and MWH load and no load losses for conductor circuit miles by voltage levels. The sum of all calculated losses by voltage level is based on input data information provided in Appendix A. Percent losses are based on a ratio to the total system.

Exhibit 3 - Summary of Transformer Information

This exhibit summarizes transformer losses by various types and voltage levels throughout the system. Load losses reflect the copper portion of transformer losses while iron losses reflect the no load or constant losses. MWH losses are estimated using a calculated loss factor for copper and the test year hours times no load losses for no load.

Exhibit 4 - Summary of Losses Diagram (2 Pages)

This loss diagram represents the inputs and output of power at system peak conditions. Page 1 details information from all points of the power system and what is provided into the distribution system for primary loads. This portion of the summary can be viewed as a "top down" summary into the distributor system.

Page 2 represents a summary of the development of primary line loads and distribution substations based on a "bottom up" approach. Basically, loadings are developed from the customer meter through the Company's physical investments based on load research and other metered information by voltage level to arrive at MW and MVA requirements during peak load conditions by voltage levels.

Exhibit 5 - Summary of Sales and Calculated Losses

Summary of Calculated Losses represents a tabular summary of MW and MWH load and no load losses by discrete areas of delivery within each voltage level. Losses have been identified and are derived based on summaries obtained from Exhibits 2 and 3 and losses associated with meters, capacitors and regulators.

Oregon 2003 Analysis of System Losses

Exhibit 6 - Development of Loss Factors, Unadjusted

This exhibit calculates demand and energy losses and loss factors by specific voltage levels based on sales level requirements. The actual results reflect loads by level and summary totals of losses at that level, or up to that level, based on the results as shown in Exhibit 5. Finally, the estimated values at generation are developed and compared to actual generation to obtain any difference.

Exhibit 7 - Development of Loss Factors, Adjusted

The adjusted loss factors are the results of adjusting Exhibit 6 for any difference. All differences between estimated and actual are prorated to each level based on the ratio of each level's total load plus losses to the system total. These new loss factors reflect an adjustment in losses due only to mismatch.

Appendix A

Results of 2003 PacifiCorp Transmission System Loss Analysis



PACIFICORP TRANSMISSION 2003 LOSS ANALYSIS

PACIFICORP TRANSMISSION

EXHIBIT 1

SUMMARY OF COMPANY DATA

ANNUAL PEAK	9,925	MW
ANNUAL ENERGY INPUT	61,994,956	MWH
ANNUAL SALES	58,174,930	MWH
Total System Losses	3,820,026	(% of Input) or 6.16%
TOTAL TRANS LOSSES	2,262,596	(% of Total) 59.23%

SUMMARY OF LOSSES - OUTPUT RESULTS

SERVICE	KV	MW	% TOTAL	MWH	% TOTAL
TRANS	345,161,115	357.2	78.99%	1,795,865	79.37%
			3.60%	2.90%	
SUBTRANS	69, 57, 46	95.0	21.01%	466,731	20.63%
			0.96%	0.75%	
TOTAL TRANS LOSSES		452.3	100.00%	2,262,596	100.00%
(percent at input)		4.56%		3.65%	

SUMMARY OF LOSS FACTORS

CUMULATIVE SALES EXPANSION FACTORS					
SERVICE	KV	DEMAND		ENERGY	
		d	1/d	e	1/e
TRANS	345,161,115	1.04775	0.95443	1.03788	0.96350
	69, 57, 46				

SUMMARY OF CONDUCTOR INFORMATION

EXHIBIT 2


DESCRIPTION	CIRCUIT MILES	LOADING % RATING	LOAD	MWLOSSES	NO LOAD	TOTAL
--- BULK ---	345 KV OR GREATER					
TIE LINES	0.0	0.00%	0.000	0.000	0.000	0.000
BULK TRANS	<u>2,593.0</u>	<u>0.00%</u>	<u>79,600</u>	<u>10,372</u>	<u>89,972</u>	<u>89,972</u>
SUBTOT	2,593.0	10.372	79,600	10,372	89,972	89,972
--- TRANS ---	115 KV TO 345.00 KV					
TIE LINES	0	0.00%	0.000	0.000	0.000	0.000
TRANS1	161 KV	0.00%	79,100	3,525	82,625	82,625
TRANS2	<u>115 KV</u>	<u>0.00%</u>	<u>103,100</u>	<u>0,000</u>	<u>103,100</u>	<u>103,100</u>
SUBTOT	6,786.0	3.525	182,200	3,525	185,725	185,725
--- SUBTRANS ---	34 KV TO 115 KV					
TIE LINES	0	0.00%	0.000	0.000	0.000	0.000
SUBTRANS1	60 KV	0.00%	32,700	0.000	32,700	32,700
SUBTRANS2	40 KV	0.00%	40,500	0.000	40,500	40,500
SUBTRANS3	<u>34 KV</u>	<u>0.00%</u>	<u>0,000</u>	<u>0,000</u>	<u>0,000</u>	<u>0,000</u>
SUBTOT	5,597.0	0.000	73,200	0.000	73,200	73,200
TOTAL	14,976	13.897	335,000	13,897	348,897	348,897

LOAD	MWLOSSES	NO LOAD	TOTAL
0	0	0	0
<u>457,426</u>	<u>90,859</u>	<u>90,859</u>	<u>548,285</u>
457,426	90,859	90,859	548,285
0	0	0	0
298,051	30,879	30,879	328,930
<u>432,502</u>	<u>0</u>	<u>0</u>	<u>432,502</u>
730,553	30,879	30,879	761,432
0	0	0	0
142,507	0	0	142,507
149,082	0	0	149,082
0	0	0	0
291,589	0	0	291,589
1,479,568	121,738	121,738	1,601,306

SUMMARY OF TRANSFORMER INFORMATION

EXHIBIT 3

DESCRIPTION	KV CAPACITY VOLTAGE	MVA	NUMBER TRANSFMR	AVERAGE SIZE	LOADING %	MVA LOAD	MW LOSSES		MWH LOSSES		TOTAL
							LOAD	NO LOAD	LOAD	NO LOAD	
BULK STEP-UP	345	4,816.0	13	370.5	70.11%	3,377	5,940	3,122	41,494	27,346	68,841
BULK - BULK		0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
BULK - TRANS1	161	6,779.1	18	376.6	61.00%	4,135	3,319	8,440	12,507	73,934	86,441
BULK - TRANS2	115	5,916.1	19	311.4	50.00%	2,958	1,995	7,174	8,367	62,847	71,214
TRANS1 STEP-UP	161	2,200.6	12	183.4	72.48%	1,595	3,388	3,420	22,030	29,961	51,991
TRANS1 - TRANS2	115	7,755.5	46	168.6	50.00%	3,878	3,061	10,422	12,843	91,294	104,136
TRANS1-SUBTRANS1	60	3,181.0	39	81.6	42.00%	1,336	1,086	4,221	4,733	36,980	41,713
TRANS1-SUBTRANS2	40	383.8	7	54.8	41.50%	159	0.148	0.540	544	4,726	5,270
TRANS1-SUBTRANS3	34	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
TRANS2 STEP-UP	115	1,613.8	33	48.9	60.70%	980	3,589	4,212	15,614	36,895	52,508
TRANS2-SUBTRANS1	60	2,457.6	58	42.4	42.00%	1,032	0.948	3,588	4,132	31,434	35,566
TRANS2-SUBTRANS2	40	5,333.2	66	80.8	41.50%	2,213	1,553	7,490	5,716	65,615	71,332
TRANS2-SUBTRANS3	34	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN1 STEP-UP	60	155.6	15	10.4	50.90%	79	0.254	0.601	2,782	5,264	8,046
SUBTRAN2 STEP-UP	40	264.7	17	15.6	11.71%	31	0.091	0.852	2,201	7,465	9,667
SUBTRAN3 STEP-UP	34	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN1-SUBTRANS2	40	217.9	10	21.8	41.50%	90	0.109	0.359	402	3,147	3,549
SUBTRAN1-SUBTRANS3	34	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRANS2-SUBTRANS3	34	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
DISTRIBUTION SUBSTATIONS											
TRANS1 -	161	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
TRANS1 -	161	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
TRANS1 -	161	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
TRANS2 -	115	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
TRANS2 -	115	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
TRANS2 -	115	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN1 -	60	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN1 -	60	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN1 -	60	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN2 -	40	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN2 -	40	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN2 -	40	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN3 -	34	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN3 -	34	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
SUBTRAN3 -	34	0.0	0	0.0	0.00%	0	0.000	0.000	0	0	0
TOTAL		41,075	353	25,482		79,923	54,442	133,365	476,909	610,273	



SUMMARY of SALES and CALCULATED LOSSES

EXHIBIT 5

LOSS # AND LEVEL	MW LOAD	NO LOAD +	LOAD =	TOT LOSS	EXP FACTOR	CUM EXP FAC	MWH LOAD	NO LOAD +	LOAD =	TOT LOSS	EXP FACTOR	CUM EXP FAC
1 BULK XFMR	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0	0
2 BULK LINES	3,309.0	13.49	85.54	99.03	1.030852	1.030852	25,339,614	118,205	498,920	617,125	1.0249621	1.0249621
3 TRANS1 XFMR	4,052.5	8.44	3.32	11.76	1.002910	1.033852	22,649,203	73,934	12,507	86,441	1.0038312	1.0288889
4 TRANS1 LINES	5,639.0	6.95	105.94	112.89	1.020428	1.045253	34,193,410	60,840	371,098	431,938	1.0127938	1.0321742
5 TRANS2TR1 SD	3,800.2	10.42	3.06	13.48	1.003561	1.048974	22,503,747	91,294	12,843	104,136	1.0046490	1.0369728
6 TRANS2BLK SD	2,898.9	7.17	1.99	9.17	1.003173	1.034123	17,166,525	62,847	8,367	71,214	1.0041657	1.0292318
7 TRANS2 LINES	7,659.1	4.21	106.69	110.90	1.014692	1.052454	45,604,033	36,895	448,116	485,010	1.0107496	1.0403122
8 STR1BLK SD	9,924.7	50.69	306.54	357.23	1.037338	1.037338	61,994,956	444,014	1,351,851	1,795,865	1.0298321	1.0298321
9 STR1T1 SD	1309.3	4.22	1.09	5.31	1.004070	1.049507	7,913,856	36,980	4,733	41,713	1.0052988	1.0376435
10 STR1T2 SD	1,011.5	3.59	0.95	4.54	1.004505	1.057195	6,114,204	31,434	4,132	35,566	1.0058509	1.0463990
11 SUBTRANS1 LINES	2,398.5	0.60	32.95	33.56	1.014189	1.066061	14,752,127	5,264	145,289	150,553	1.0103107	1.0501419
12 STR2T1 SD	156.1	0.54	0.15	0.69	1.004422	1.049875	861,433	4,726	544	5,270	1.0061553	1.0385275
13 STR2T2 SD	2,169.0	7.49	1.55	9.04	1.004187	1.056860	11,970,348	65,615	5,716	71,332	1.0059947	1.0465486
14 STR2S1 SD	88.6	0.36	0.11	0.47	1.005315	1.071728	489,076	3,147	402	3,549	1.0073102	1.0578186
15 SUBTRANS2 LINES	2,444.1	0.85	40.59	41.44	1.017249	1.074465	13,964,476	7,465	151,283	158,749	1.0114988	1.0563112
16 STR3T1 SD	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
17 STR3T2 SD	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
18 STR3S1 SD	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
19 STR3S2 SD	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
20 SUBTRANS3 LINES	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
21 SUBTRANS LOSS FAC	9,924.7	68.34	383.93	452.27	1.047746	1.047746	61,994,956	598,646	1,663,950	2,262,596	1.0378789	1.0378789
22 TRANSMN LOSS FAC												
DISTRIBUTION SUBST												
TRANS1	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
TRANS2	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
SUBTR1	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
SUBTR2	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
SUBTR3	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
WEIGHTED AVERAGE	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
PRIMARY INTRCHANGE	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
Average Dist Sub Losses	0.0	0.00	0.00	0.00	0.000000	0.000000	0	0	0	0	0.0000000	0.0000000
TOTAL SYSTEM		68.34	383.93	452.27			598,646	1,663,950	2,262,596			

DEVELOPMENT of LOSS FACTORS
SYSTEM WIDE
DEMAND

EXHIBIT 6

LOSS FACTOR LEVEL	CUSTOMER SALES MW	CALC LOSS TO LEVEL	SALES MW @ GEN	CUM SALES EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	9,472.4	452.3	9,924.7	1.04775	0.95443
SUBTRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS LINES	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>	0.00000	0.00000
TOTALS	9,472.4	452.3	9,924.7		

DEVELOPMENT of LOSS FACTORS
SYSTEM WIDE
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH	CALC LOSS TO LEVEL	SALES MWH @ GEN	CUM SALES EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0.00000	0.00000
TRANS LINES	59,732,360	2,262,596	61,994,956	1.03788	0.96350
SUBTRANS SUBS	0	0	0	0.00000	0.00000
SUBTRANS LINES	<u>0</u>	<u>0</u>	<u>0</u>	0.00000	0.00000
TOTALS	59,732,360	2,262,596	61,994,956		

Adjusted Losses and Loss Factors by Facility

Losses by Segment		
	MW	MWH
46-57 kV Line Losses (ST2)	41.44293	158,749
T1 - ST2 Transformation Losses	0.68720	5,270
T2 - ST2 Transformation Losses	9.04323	71,332
ST1 - ST2 Transformation Losses	0.46853	3,549
69 kV Line Losses (ST1)	33.55514	150,553
T1 - ST1 Transformation Losses	5.30749	41,713
T2 - ST1 Transformation Losses	4.53645	35,566
115-138 kV Line Losses (T2)	110.90120	485,010
B - T2 Transformation Losses	9.16887	71,214
T1 - T2 Transformation Losses	13.48309	104,136
161-230 kV Line Losses (T1)	112.88506	431,938
B - T1 Transformation Losses	11.75931	86,441
<u>345-500 kV Line Losses (B)</u>	<u>99.03345</u>	<u>617,125</u>
Total	452.27195	2,262,596
Loss Factors by Segment		
Deliveries from Sub Transmission 2 Lines	2444.10	13,964,476
ST2 Line Losses	41.44	158,749
T1 - ST2 Transformation Losses	0.69	5,270
T2 - ST2 Transformation Losses	9.04	71,332
<u>ST1 - ST2 Transformation Losses</u>	<u>0.47</u>	<u>3,549</u>
Input to ST2 System	2495.74	14,203,375
ST2 Loss Factor	1.02113	1.01711
Deliveries from Sub Transmission 1 Lines	2398.47	14,752,127
ST1 Line Losses	33.56	150,553
T1 - ST1 Transformation Losses	5.31	41,713
<u>T2 - ST1 Transformation Losses</u>	<u>4.54</u>	<u>35,566</u>
Input to ST1 System	2441.87	14,979,958
ST1 Loss Factor	1.01809	1.01544
Deliveries from Transmission 2 Lines	7659.07	45,604,033
T2 Line Losses	110.90	485,010
B - T2 Transformation Losses	9.17	71,214
<u>T1 - T2 Transformation Losses</u>	<u>13.48</u>	<u>104,136</u>
Input to T2 System	7792.62	46,264,394
T2 Loss Factor	1.01744	1.01448
Deliveries from Transmission 1 Lines	5639.00	34,193,410
T1 Line Losses	112.89	431,938
<u>B - T1 Transformation Losses</u>	<u>11.76</u>	<u>86,441</u>
Input to T1 System	5763.64	34,711,790
T1 Loss Factor	1.02210	1.01516
Deliveries from Bulk Lines	3309.00	25,339,614
B Line Losses	99.03	617,125
Input to B System	3408.03	25,956,739
B Loss Factor	1.02993	1.02435
Total Deliveries from Transmission	9472.42	59,732,360
Total Transmission Losses	<u>452.27</u>	<u>2,262,596</u>
Input to Transmission System	9924.69	61,994,956
Transmission Loss Factor	1.04775	1.03788

Appendix B

Results of PacifiCorp Oregon 2003 Loss Analysis



PACIFICORP OREGON 2003 LOSS ANALYSIS

PACIFICORP OREGON

EXHIBIT 1

SUMMARY OF COMPANY DATA

ANNUAL PEAK	2,661 MW
ANNUAL GENERATION	16,718,140 MWH
ANNUAL SALES	15,610,366 MWH
System Losses	1,107,774 or 6.63%
SYSTEM LOAD FACTOR	71.7%

SUMMARY OF LOSSES - OUTPUT RESULTS

SERVICE	KV	MW	% TOTAL	MWH	% TOTAL
TRANS	345,161,115	121.3	50.78%	610,153	55.08%
			4.56%	3.65%	
PRIMARY	69,34,12,1	73.3	30.69%	246,993	22.30%
			2.75%	1.48%	
SECONDARY		44.3	18.53%	250,629	22.62%
			1.66%	1.50%	
TOTAL		238.9	100.00%	1,107,774	100.00%
			8.97%	6.63%	

SUMMARY OF LOSS FACTORS

SERVICE	KV	CUMMULATIVE SALES EXPANSION FACTORS			
		DEMAND		ENERGY	
		d	1/d	e	1/e
TRANS	345,161,115	1.04775	0.95443	1.03788	0.96350
PRIM SUBS	69,46,35	0.00000	0.00000	0.00000	0.00000
PRIMARY	69,34,12,1	1.08658	0.92032	1.05846	0.94477
SECONDARY		1.11606	0.89601	1.08421	0.92233

SUMMARY OF CONDUCTOR INFORMATION

EXHIBIT 2

DESCRIPTION	CIRCUIT MILES	LOADING % RATING	----- MWH LOSSES -----		TOTAL
			LOAD	NO LOAD	
--- BULK -----					
TIE LINES	0.0	0.00%	0.000	0.000	0.000
BULK TRANS	<u>0.0</u>	<u>0.00%</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
--- TRANS -----	TO 345.00 KV				
TIE LINES	0	0.00%	0.000	0.000	0.000
TRANS1	0.0	0.00%	0.000	0.000	0.000
TRANS2	<u>0.0</u>	<u>0.00%</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
--- SUBTRANS -----	TO 115 KV				
TIE LINES	0	0.00%	0.000	0.000	0.000
SUBTRANS1	0.0	0.00%	0.000	0.000	0.000
SUBTRANS2	0.0	0.00%	0.000	0.000	0.000
SUBTRANS3	<u>0.0</u>	<u>0.00%</u>	<u>0.000</u>	<u>0.000</u>	<u>0.000</u>
SUBTOT	0.0		0.000	0.000	0.000
PRIMARY LINES	18,455		59,182	6,263	65,444
SECONDARY LINES	5,412		2,867	0.000	2,867
SERVICES	11,684		9,322	1,487	10,808
TOTAL	35,550		71,371	7,750	79,120

		----- MWH LOSSES -----		TOTAL
LOAD	NO LOAD	LOAD	NO LOAD	
0	0	0	0	0
<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>0</u>
0	0	0	0	0
0	0	0	0	0
0	0	0	0	0
0	0	0	0	0
0	0	0	0	0
0	0	0	0	0
0	0	0	0	0
185,867	57,818	185,867	57,818	243,685
15,055	0	15,055	0	15,055
49,215	13,024	49,215	13,024	62,239
250,137	70,845	250,137	70,845	320,982

SUMMARY OF TRANSFORMER INFORMATION


DESCRIPTION	KV CAPACITY VOLTAGE	MVA	NUMBER TRANSFMR	AVERAGE SIZE	LOADING %	MVA LOAD	LOAD	MW LOSSES NO LOAD	LOAD	MW LOSSES NO LOAD	LOAD	MWH LOSSES NO LOAD	TOTAL
BULK STEP-UP	345	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
BULK - BULK		0.0	0	0.0	0.00%	0	0	0.000	0	0.000	0	0	0
BULK - TRANS1	161	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
BULK - TRANS2	115	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS1 STEP-UP	161	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS1 - TRANS2	115	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS1-SUBTRANS1	69	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS1-SUBTRANS2	46	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS1-SUBTRANS3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS2 STEP-UP	115	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS2-SUBTRANS1	69	18.8	1	18.8	55.00%	10	0.021	0.024	96	0.045	207	303	303
TRANS2-SUBTRANS2	46	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS2-SUBTRANS3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN1 STEP-UP	69	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN2 STEP-UP	46	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN3 STEP-UP	35	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN1-SUBTRAN2	46	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN1-SUBTRAN3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN2-SUBTRAN3	35	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0

DISTRIBUTION SUBSTATIONS


TRANS1 -	161	70.0	3	23.3	42.00%	29	0.037	0.082	170	0.118	714	884	884
TRANS1 -	161	85.0	3	28.3	44.00%	37	0.038	0.099	176	0.137	863	1,040	1,040
TRANS1 -	161	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	863	863
TRANS2 -	115	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
TRANS2 -	115	2,548.4	120	21.2	44.00%	1,121	1.518	3.042	6,997	4.561	26,652	33,649	33,649
TRANS2 -	115	7.3	2	3.6	44.00%	3	0.008	0.015	37	0.022	127	164	164
SUBTRAN1 -	69	9.4	2	4.7	42.00%	4	0.010	0.019	47	0.029	166	213	213
SUBTRAN1 -	69	1,799.9	130	13.8	44.00%	792	1.312	2.489	6,045	3.800	21,801	27,846	27,846
SUBTRAN1 -	69	88.2	21	4.2	44.00%	39	0.095	0.171	440	0.266	1,496	1,936	1,936
SUBTRAN2 -	46	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN2 -	46	39.6	4	9.9	44.00%	17	0.029	0.051	132	0.080	446	578	578
SUBTRAN2 -	46	75.2	8	9.4	44.00%	33	0.067	0.119	308	0.186	1,044	1,352	1,352
SUBTRAN3 -	35	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN3 -	35	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
SUBTRAN3 -	35	0.0	0	0.0	0.00%	0	0.000	0.000	0	0.000	0	0	0
PRIMARY - PRIMARY		174.1	41	4.2	44.00%	77	0.187	0.334	863	0.521	2,925	3,788	3,788
LINE TRANSFMR		7,815.8	201,430	38.8	23.35%	1,825	5.925	25.791	13,551	31.716	225,927	239,478	239,478
TOTAL		12,792	201,766			9,248	32.234	41.482	28,862	283.233	312,096	312,096	312,096

SUMMARY OF LOSSES DIAGRAM - DEMAND MODEL - SYSTEM PEAK

2661.351324 MW



FROM HIGH VOLTAGE SYSTEM



PRIMARY LINES

LOADING	2044.718 MW
@ SYS PF	2086.446 MVA
LOAD LOSS	59.182 MW
NOLD LOSS	6.263 MW
TOT LOSS	65.444 MW

PRIM/PRIM TRANS

LOADING	76.607 MW
NOLD LOSS	0.334 MW
LOAD LOSS	0.187 MW
AVG SIZE	4.25
NUMBER	41

PRIM CUST LOADS

NO LINES	0.000 MW
CUST SUB	0.000 MVA
NO LINES	0.000 MW
CO. SUB	0.000 MVA
PRIM WITH LINES	301,528 MW
TOTAL	317,398 MVA

LINE TRANSFORMERS

LOADING	1677.224 MW
NOLD LOSS	25.791 MW
LOAD LOSS	5.925 MW
AVG SIZE	38.8 KVA
NUMBER	201430

SECONDARY LINES

LOAD	590.576 MW
LOAD LOSS	2.867 MW
NOLD LOSS	0.000 MW
TOT LOSS	2.867 MW

NO SECONDARY LINES

LOAD	1054.932 MW
------	-------------

SERVICES

LOAD	1642.641 MW
LOAD LOSS	9.322 MW
NOLD LOSS	1.487 MW
TOT LOSS	10,808 MW

CUSTOMER SECONDARY LOAD

LOAD	1631.832 MW
------	-------------

SUMMARY of SALES and CALCULATED LOSSES

LOSS # AND LEVEL	MW LOAD	NO LOAD +	TOT LOSS	EXP FACTOR	CUM EXP FAC	MWH LOAD	NO LOAD +	LOAD	TOT LOSS	EXP FACTOR	CUM EXP FAC
1 BULK XFMMR	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0	0
2 BULK LINES	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
3 TRANS1 XFMR	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
4 TRANS1 LINES	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
5 TRANS2TR1 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
6 TRANS2BLK SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
7 TRANS2 LINES	0.0	0.00	0.00	0.000000	0.000000	0	3	0	3	0.000000	0.000000
TOTAL TRAN	0.0	0.00	0.00	0.000000	0.000000	0	3	0	3	0.000000	0.000000
8 STR1BLK SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
9 STR1T1 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
10 SRT1T2 SD	10.1	0.02	0.02	1.004428	0.000000	62,945	207	96	303	1.004428	0.000000
11 SUBTRANS1 LINES	10.1	0.00	0.00	1.000000	0.000000	62,945	0	0	0	1.000000	0.000000
12 STR2T1 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
13 STR2T2 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
14 STR2S1 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
15 SUBTRANS2 LINES	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
16 STR3T1 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
17 STR3T2 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
18 STR3S1 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
19 STR3S2 SD	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
20 SUBTRANS3 LINES	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
21 SUBTRANS TOTAL	10.1	0.02	0.02	1.004428	0.000000	62,945	207	96	303	1.004428	0.000000
22 TRANSMN LOSS FAC	2,661.4	18.33	102.95	1.047746	1.047746	16,718,140	161,437	448,716	610,153	1.0378789	1.0378789
DISTRIBUTION SUBST											
TRANS1	65.5	0.18	0.08	1.003913	0.000000	407,733	2,441	346	2,787	1.0068818	0.000000
TRANS2	1,098.9	3.06	1.53	1.004188	0.000000	6,863,587	26,779	7,034	33,813	1.0049509	0.000000
SUBTR1	818.0	2.68	1.42	1.005032	0.000000	5,094,839	23,464	6,531	29,995	1.0059223	0.000000
SUBTR2	49.5	0.17	0.10	1.005394	0.000000	308,223	1,490	439	1,930	1.0063003	0.000000
SUBTR3	0.0	0.00	0.00	0.000000	0.000000	0	0	0	0	0.000000	0.000000
WEIGHTED AVERAGE	2,031.8	6.1	3.1	1.004548	1.052512	12,674,383	54,174	14,351	68,525	1.0054360	0.000000
PRIMARY INTRCHNGE	14.5			1.000000	0.000000	103,020				1.000000	0.000000
PRIMARY LINES	2,044.7	6.60	59.37	1.033337	1.087599	12,768,016	57,786	185,867	243,653	1.0194543	1.0638217
LINE TRANSF	1,677.2	25.79	5.93	1.019274	1.108562	10,616,800	225,927	13,551	239,478	1.0230771	1.0883716
SECONDARY	1,645.5	0.00	2.87	1.001745	1.110497	10,377,321	0	15,055	15,055	1.0014529	1.0999529
SERVICES	1,642.6	1.49	9.32	1.006624	1.117852	10,362,266	13,024	49,215	62,239	1.0060426	1.0965391
TOTAL SYSTEM	58.33	183.59	241.93			512,768	726,949	1,239,716			

DEVELOPMENT of LOSS FACTORS
UNADJUSTED
DEMAND

EXHIBIT 6

LOSS FACTOR LEVEL	CUSTOMER SALES MW	CALC LOSS TO LEVEL	SALES MW @ GEN	CUM EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	489.1	23.4	512.5	1.04775	0.95443
SUBTRANS SUBS	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS LINES	0.0	0.0	0.0	0.00000	0.00000
PRIM SUBS	0.0	0.0	0.0	0.00000	0.00000
PRIM LINES	301.5	26.4	327.9	1.08760	0.91946
SECONDARY	<u>1,631.8</u>	<u>192.3</u>	<u>1,824.1</u>	1.11785	0.89457
TOTALS	2,422.5	242.1	2,664.6		

DEVELOPMENT of LOSS FACTORS
UNADJUSTED
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH	CALC LOSS TO LEVEL	SALES MWH @ GEN	CUM EXPANSION FACTORS	
	a	b	c	d	1/d
BULK LINES	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0.00000	0.00000
TRANS LINES	3,402,775	128,893	3,531,668	1.03788	0.96350
SUBTRANS SUBS	0	0	0	0.00000	0.00000
SUBTRANS LINES	0	0	0	0.00000	0.00000
PRIM SUBS	0	0	0	0.00000	0.00000
PRIM LINES	1,907,564	121,744	2,029,308	1.06382	0.94001
SECONDARY	<u>10,300,027</u>	<u>994,356</u>	<u>11,294,382</u>	1.09654	0.91196
TOTALS	15,610,366	1,244,993	16,855,359		

ESTIMATED VALUES AT GENERATION

LOSS FACTOR AT VOLTAGE LEVEL	MW	MWH
BULK LINES	0.00	0
TRANS SUBS	0.00	0
TRANS LINES	512.50	3,531,668
SUBTRANS SUBS	0.00	0
SUBTRANS LINES	0.00	0
PRIM SUBS	0.00	0
PRIM LINES	327.94	2,029,308
SECONDARY	1,824.15	11,294,382
SUBTOTAL	2,664.58	16,855,359
ACTUAL ENERGY LESS THIR	2,661.35	16,718,140
MISSMATCH	3.23	137,219
% MISSMATCH	0.12%	0.82%

Adjusted Losses and Loss Factors by Facility

EXHIBIT 8

DEVELOPMENT of LOSS FACTORS
ADJUSTED
DEMAND

EXHIBIT 7

LOSS FACTOR LEVEL	CUSTOMER SALES MW a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MW @ GEN d	CUM EXPANSION FACTORS e	f=1/e
BULK LINES	0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
TRANS LINES	489.1	0.0	23.4	512.5	1.04775	0.95443
SUBTRANS SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
SUBTRANS LINES	0.0	0.0	0.0	0.0	0.00000	0.00000
PRIM SUBS	0.0	0.0	0.0	0.0	0.00000	0.00000
PRIM LINES	301.5	0.0	26.1	327.6	1.08658	0.92032
SECONDARY	<u>1,631.8</u>	<u>0.0</u>	<u>189.4</u>	<u>1,821.2</u>	1.11606	0.89601
TOTALS	2,422.5	0.0	238.9	2,661.4		

DEVELOPMENT of LOSS FACTORS
ADJUSTED
ENERGY

LOSS FACTOR LEVEL	CUSTOMER SALES MWH a	SALES ADJUST b	CALC LOSS TO LEVEL c	SALES MWH @ GEN d	CUM EXPANSION FACTORS e	f=1/e
BULK LINES	0	0	0	0	0.00000	0.00000
TRANS SUBS	0	0	0	0	0.00000	0.00000
TRANS LINES	3,402,775	0	128,893	3,531,668	1.03788	0.96350
SUBTRANS SUBS	0	0	0	0	0.00000	0.00000
SUBTRANS LINES	0	0	0	0	0.00000	0.00000
PRIM SUBS	0	0	0	0	0.00000	0.00000
PRIM LINES	1,907,564	0	111,508	2,019,072	1.05846	0.94477
SECONDARY	<u>10,300,027</u>	<u>0</u>	<u>867,373</u>	<u>11,167,400</u>	1.08421	0.92233
TOTALS	15,610,366	0	1,107,774	16,718,140		

ESTIMATED VALUES AT GENERATION

LOSS FACTOR AT VOLTAGE LEVEL	MW	MWH
BULK LINES	0.00	0
TRANS SUBS	0.00	0
TRANS LINES	512.50	3,531,668
SUBTRANS SUBS	0.00	0
SUBTRANS LINES	0.00	0
PRIM SUBS	0.00	0
PRIM LINES	327.63	2,019,072
SECONDARY	<u>1,821.22</u>	<u>11,167,400</u>
	2,661.35	16,718,140
ACTUAL ENERGY LESS THIR	2,661.35	16,718,140
MISSMATCH	0.00	0
% MISSMATCH	0.00%	0.00%

Adjusted Losses and Loss Factors by Facility

EXHIBIT 8

Unadjusted Losses by Segment

	MW	MWH
Service Drop Losses	10.83	62,822
Secondary Losses	2.87	15,196
Line Transformer Losses	31.78	241,721
Primary Line Losses	66.10	245,934
Distribution Substation Losses	9.22	69,167
<u>Transmission System Losses</u>	<u>121.28</u>	<u>610,153</u>
Total	242.08	1,244,993

Mismatch Allocation by Segment

	MW	MWH
Service Drop Losses	0.29	13,579
Secondary Losses	0.08	3,285
Line Transformer Losses	0.85	52,247
Primary Line Losses	1.77	53,158
Distribution Substation Losses	0.25	14,950
<u>Transmission System Losses</u>	<u>0.00</u>	<u>0</u>
Total	3.23	137,219

Adjusted Losses by Segment

	MW	MWH
Service Drop Losses	10.54082	49,243
Secondary Losses	2.79614	11,912
Line Transformer Losses	30.93061	189,474
Primary Line Losses	64.33214	192,776
Distribution Substation Losses	8.97202	54,217
<u>Transmission System Losses</u>	<u>121.27877</u>	<u>610,153</u>
Total	238.85050	1,107,774

Loss Factors by Segment

Retail Sales from Service Drops	1631.83	10,300,027
<u>Adjusted Service Drop Losses</u>	<u>10.54</u>	<u>49,243</u>
Input to Service Drops	1642.37	10,349,270
Service Drop Loss Factor	1.00646	1.00478
Output from Secondary	1642.37	10,349,270
<u>Adjusted Secondary Losses</u>	<u>2.80</u>	<u>11,912</u>
Input to Secondary	1645.17	10,361,182
Secondary Loss Factor	1.00170	1.00115
Output from Line Transformers	1645.17	10,361,182
<u>Adjusted Line Transformer Losses</u>	<u>30.93</u>	<u>189,474</u>
Input to Line Transformers	1676.10	10,550,655
Line Transformer Loss Factor	1.01880	1.01829
Retail Sales from Primary	301.53	1,907,564
Req. Whls Sales from Primary	0.00	0
<u>Input to Line Transformers</u>	<u>1676.10</u>	<u>10,550,655</u>
Output from Primary Lines	1977.63	12,458,219
<u>Adjusted Primary Line Losses</u>	<u>64.33</u>	<u>192,776</u>
Input to Primary Lines	2041.96	12,650,995
Primary Line Loss Factor	1.03253	1.01547
Output from Distribution Substations	2041.96	12,650,995
<u>Adjusted Distribution Substation Losses</u>	<u>8.97202</u>	<u>54,217</u>
Input to Distribution Substations	2050.93	12,705,212
Distribution Substation Loss Factor	1.00439	1.00429
Retail Sales at from Transmission	119.106	753,505
Req. Whls Sales from Transmission	67.73	70,195
Non-Req. Whls Sales from Transmission	302.309	2,579,075
Third Party Wheeling Losses	0.000	0
<u>Input to Distribution Substations</u>	<u>2050.93</u>	<u>12,705,212</u>
Output from Transmission	2,540.073	16,107,987
<u>Adjusted Transmission System Losses</u>	<u>121.27877</u>	<u>610,153</u>
Input to Transmission	2,661.351	16,718,140
Transmission System Loss Factor	1.04775	1.03788

Appendix C

Discussion of Hoebel Coefficient



COMMENTS ON HOEBEL COEFFICIENTS

The Hoebel constant represents an established industry standard relationship between peak losses and average losses and is used in a loss study to estimate energy losses from peak demand losses. H. F. Hoebel described this relationship in his article, "Cost of Electric Distribution Losses," Electric Light and Power, March 15, 1959. A copy of this article is attached.

Within any loss evaluation study, peak demand losses can readily be calculated given equipment resistance and approximate loading. Energy losses, however, are much more difficult to determine given their time-varying nature. This difficulty can be reduced by the use of an equation which relates peak load losses (demand) to average losses (energy). Once the relationship between peak and average losses is known, average losses can be estimated from the known peak load losses.

Within the electric utility industry, the relationship between peak and average losses is known as the loss factor. For definitional purposes, loss factor is the ratio of the average power loss to the peak load power loss, during a specified period of time. This relationship is expressed mathematically as follows:

$$\underline{(1) F_{LS} \approx A_{LS} \div P_{LS}}$$

where: F_{LS} = Loss Factor
 A_{LS} = Average Losses
 P_{LS} = Peak Losses

The loss factor provides an estimate of the degree to which the load loss is maintained throughout the period in which the loss is being considered. In other words, loss factor is the ratio of the actual kWh losses incurred to the kWh losses which would have occurred if full load had continued throughout the period under study.

Examining the loss factor expression in light of a similar expression for load factor indicates a high degree of similarity. The mathematical expression for load factor is as follows:

$$\underline{(2) F_{LD} \approx A_{LD} \div P_{LD}}$$

where: F_{LD} = Load Factor
 A_{LD} = Average Load
 P_{LD} = Peak Load

This load factor result provides an estimate of the degree to which the load loss is maintained throughout the period in which the load is being considered. Because of the similarities in definition, the loss factor is sometimes called the "load factor of losses." While the definitions are similar, a strict equating of the two factors cannot be made. There does exist, however, a relationship between these two factors which is dependent upon the shape of the load duration curve. Since resistive losses vary as the square of the load, it can be shown mathematically that the loss factor can vary between the extreme limits of load factor and load factor squared. The



relationship between load factor and loss factor has become an industry standard and is as follows:

$$\underline{(3) F_{LS} \approx H * F_{LD}^2 + (1-H) * F_{LD}}$$

where: F_{LS} = Loss Factor
 F_{LD} = Load Factor
 H = Hoebel Coeff

As noted in the attached article, the suggested value for H (the Hoebel coefficient) is 0.7. The exact value of H will vary as a function of the shape of the utility's load duration curve. In recent years, values of H have been computed directly for a number of utilities based on EEI load data. It appears on this basis, the suggested value of 0.7 should be considered a lower bound and that values approaching unity may be considered a reasonable upper bound. Based on experience, values of H have ranged from approximately 0.85 to 0.95. The standard default value of 0.9 is generally used.

Inserting the Hoebel coefficient estimate gives the following loss factor relationship using Equation (3):

$$\underline{(4) F_{LS} \approx 0.90 * F_{LD}^2 + 0.10 * F_{LD}}$$

Once the Hoebel constant has been estimated and the load factor and peak losses associated with a piece of equipment have been estimated, one can calculate the average, or energy losses as follows:

$$\underline{(5) A_{LS} \approx P_{LS} * [H * F_{LD}^2 + (1-H) * F_{LD}]}$$

where: A_{LS} = Average Losses
 P_{LS} = Peak Losses
 H = Hoebel Coefficient
 F_{LD} = Load Factor

Loss studies use this equation to calculate energy losses at each major voltage level in the analysis.

