













Technical Report NREL/TP-5600-51577 April 2011

Spring 2011 Composite Data Products ARRA Material Handling Equipment

J. Kurtz, K. Wipke, S. Sprik, T. Ramsden, C. Ainscough, G. Saur

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

> Available electronically at http://www.osti.gov/bridge Available for a processing fee to U.S. Department of Energy and its contractors, in paper, from: U.S. Department of Energy Office of Scientific and Technical Information P.O. Box 62 Oak Ridge, TN 37831-0062

phone: 865.576.8401 fax: 865.576.5728

email: mailto:reports@adonis.osti.gov

Available for sale to the public, in paper, from: U.S. Department of Commerce National Technical Information Service 5285 Port Royal Road Springfield, VA 22161 phone: 800.553.6847

fax: 703.605.6900

email: orders@ntis.fedworld.gov

online ordering: http://www.ntis.gov/help/ordermethods.aspx


Cover Photos: (left to right) PIX 16416, PIX 17423, PIX 16560, PIX 17613, PIX 17436, PIX 17721



Printed on paper containing at least 50% wastepaper, including 10% post consumer waste.



Spring 2011 Composite Data Products ARRA Material Handling Equipment




Jennifer Kurtz, Keith Wipke, Sam Sprik, Todd Ramsden, Chris Ainscough, Genevieve Saur


April 6th, 2011

TP-5600-51577


CDPARRA-MHE-01 Fuel Cell MHE Systems Deployed




CDPARRA-MHE-02 Fuel Cell System Operation Hours




CDPARRA-MHE-03 Fueling Events by Quarter




CDPARRA-MHE-04 Hydrogen Dispensed by Quarter




CDPARRA-MHE-05 Refueling Time of Day



CDPARRA-MHE-06 Histogram of Fueling Times



CDPARRA-MHE-07 Tank Pressure Level at Fueling







- 2. The outer arc is set at 30% total refuelings.
- 3. Full Pressure is either 3600 psi or 5000 psi.




CDPARRA-MHE-08 Operation Time between Fueling




CDPARRA-MHE-09 Histogram of Fueling Rates



CDPARRA-MHE-10 Histogram of Fueling Amounts




CDPARRA-MHE-11 Fuel Cell Operation Hours by Quarter




CDPARRA-MHE-12 Fuel Cell System Maintenance by Category

Fuel Cell System Maintenance By Category - ARRA All ARRA Sites Thru 2010Q4




CDPARRA-MHE-13


Fuel Cell System Scheduled and Unscheduled Maintenance by Category




CDPARRA-MHE-14 Average Fuel Cell System Maintenance by Quarter




CDPARRA-MHE-15 Operating Time at Fuel Cell Voltage Levels



CDPARRA-MHE-16 Operating Time at Fuel Cell Current Levels




CDPARRA-MHE-17 Operating Time at Fuel Cell Power Levels



CDP-MHE-18 Infrastructure Maintenance by Category


Infrastructure Maintenance By Category All Sites Thru 2010Q4






CDP-MHE-19

Infrastructure Scheduled & Unscheduled Maintenance by Category




CDP-MHE-20 Infrastructure Maintenance by Quarter

Average Infrastructure Site Quarterly Maintenance




CDPARRA-MHE-21 Average Daily Hydrogen Dispensed by Location

Average Daily Hydrogen Dispensed by Location - ARRA







CDPARRA-MHE-22 Average Daily Dispensing Operations by Site




CDPARRA-MHE-23 Average Daily Fuel Cell Operation Hours per Fleet




CDPARRA-MHE-24 Average Daily Fuel Cell Operation Hours per System





CDP-MHE-25

Infrastructure Safety Reports by Quarter




- 1) Near Miss is an event that under slightly different circumstances could have become an incident -unplanned H2 release insufficient to sustain a flame
- 2) Incident is an event that results in:
 - -a lost time accident and/or injury to personnel
 - -damage/unplanned downtime for project equipment, facilities or property
 - -impact to the public or environment
 - -any hydrogen release that unintentionally ignites or is sufficient to sustain a flame if ignited
 - -release of any volatile, hydrogen containing compound (other than the hydrocarbons uses as common fuels)



CDPARRA-MHE-26 Fuel Cell System Safety Reports by Quarter

Fuel Cell System Safety Reports by Quarter - ARRA




- 1) Near Miss is an event that under slightly different circumstances could have become an incident -unplanned H2 release insufficient to sustain a flame
- 2) Incident is an event that results in:
 - -a lost time accident and/or injury to personnel
 - -damage/unplanned downtime for project equipment, facilities or property
 - -impact to the public or environment
 - -any hydrogen release that unintentionally ignites or is sufficient to sustain a flame if ignited
 - -release of any volatile, hydrogen containing compound (other than the hydrocarbons uses as common fuels)



CDPARRA-MHE-27 Fuel Cell System Safety Reports by Severity and Type





An INCIDENT is an event that results in:

- a lost time accident and/or injury to personnel
- damage/unplanned downtime for project equipment, facilities or property
- impact to the public or environment
- any hydrogen release that unintentionally ignites or is sufficient to sustain a flame if ignited
- release of any volatile, hydrogen containing compound (other than the hydrocarbons used as common fuels)


A NEAR-MISS is:

- an event that under slightly different circumstances could have become an incident


, - unplanned H2 release insufficient to sustain a flame


Created: Mar-29-11 2:35 PM

CDP-MHE-28 Fuel Cell System Reliability Growth by Site for Quarter





CDP-MHE-29 Fuel Cell System Reliability Growth by Top 4 Categories





Average Vehicle Operating Hours






Average Vehicle Operating Hours


*IEC 61164 β

Created: Apr-05-11 4:40 PM


CDP-MHE-30 Fuel Cell System Mean Time Between Failure



CDP-MHE-31Fuel Cell System Mean Time Between Scheduled Maintenance



CDP-MHE-32 Site Operation Hours and Voltage Durability




- (1) Range bars created using one data point for each fleet. Some stacks have accumulated hours beyond 10% voltage degradation.
- (2) 10% voltage drop level is a DOE metric for assessing fuel cell performance.
- (3) Projections using field data and calculated at a high stack current.
- (4) 10% voltage drop is NOT an indication of an OEM's end-of-life criteria and projections do not address catastrophic stack failure.
- (5) Each site has one voltage projection value that is the weighted average of the site's fuel cell stack projections.



CDP-MHE-33

Fuel Cell Stack Voltage Durability as a Function of Voltage Drop Levels




- (1) 10% Voltage degradation is a DOE metric for assessing fuel cell performance not an indication of an OEM's end-of-life criteria.
- (2) Projections using field data and calculated at high stack current.
- (3) 25th and 75th percentiles spans the range of stack projection. The included stacks satisfy a minimum number of operation hours and weighting factor.
- (4) The projection curves display the sensitivity to percentage of voltage degradation, but the projections do not imply that all stacks will (or do) operate at these voltage degradation levels.
- (5) Each site has one voltage projection value that is the weighted average of the sites's fuel cell stack projections.



CDP-MHE-34 Fuel Cell Stack Power Degradation over Time


Max Fuel Cell Stack Power Degradation Over Operation






- 1) Normalized by fleet maximum power.
- 2) Each segment point is median FC power (+-100 hrs). Box not drawn if fewer than 3 points in segment.

CDPARRA-MHE-35 Dispensed Hydrogen by Day of Week





CDPARRA-MHE-37 Fuel Cell System Downtime



CDPARRA-MHE-40 Site Summary

MHE Deployment - ARRA






Marker size proportional to number of units.

Forklift Units (I,II,III)	0,26,72	0,14,0	35,0,0	25,0,0	45,14,2	0,36,100	40,0,0	0,25,70
Operation								
Shifts per Day	2	2	3	1-2	3	2	2	3
Hours per Shift	8-10	9.5	8	10	8	8-10	8	8
Days per Week	6	N/A	N/A	7	7	6	6	6



CDP-MHE-41 Infrastructure Safety Categories





An INCIDENT is an event that results in:

- a lost time accident and/or injury to personnel
- damage/unplanned downtime for project equipment, facilities or property
- impact to the public or environment
- any hydrogen release that unintentionally ignites or is sufficient to sustain a flame if ignited
- release of any volatile, hydrogen containing compound (other than the hydrocarbons used as common fuels)

:AR-MISS is

- an event that under slightly different circumstances could have become an incident

- unplanned H2 release insufficient to sustain a flame

NREL cdp_mhe_4

Created: Mar-09-11 2:26 PM

CDP-MHE-42 Amount of Hydrogen Dispensed by Day of Week

