



**Technical Report**  
NREL/TP-5600-58614  
May 2013

## Spring 2013 Composite Data Products – Backup Power

J. Kurtz, K. Wipke, S. Sprik, T. Ramsden, C. Ainscough,  
G. Saur, M. Post and M. Peters

## NOTICE

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

Available electronically at <http://www.osti.gov/bridge>  
Available for a processing fee to U.S. Department of Energy  
and its contractors, in paper, from:  
U.S. Department of Energy  
Office of Scientific and Technical Information  
P.O. Box 62  
Oak Ridge, TN 37831-0062  
phone: 865.576.8401  
fax: 865.576.5728  
email: <mailto:reports@adonis.osti.gov>


Available for sale to the public, in paper, from:  
U.S. Department of Commerce  
National Technical Information Service  
5285 Port Royal Road  
Springfield, VA 22161  
phone: 800.553.6847  
fax: 703.605.6900  
email: [orders@ntis.fedworld.gov](mailto:orders@ntis.fedworld.gov)  
online ordering: <http://www.ntis.gov/help/ordermethods.aspx>

Cover Photos: (left to right) PIX 16416, PIX 17423, PIX 16560, PIX 17613, PIX 17436, PIX 17721



Printed on paper containing at least 50% wastepaper, including 10% post consumer waste.

## Backup Power Fuel Cell Systems Deployed




NREL cdp\_bu\_01

Created: Apr-02-13 2:33 PM | Data Range: 2009Q3-2012Q4

- 1) Sites may have more than one FC system
- 2) Not all FC systems are supplying operation data

## Deployed kW Capacity for Backup Power



NREL cdp\_bu\_02


Created: Apr-02-13 2:33 PM | Data Range: 2009Q3-2012Q4

# CDP-BU-03

## Backup Power Deployments

State	kW	Sites
Arizona	84	16
California	576	124
Colorado	24	5
Connecticut	125	27
Florida	6	1
Georgia	50	1
Illinois	4	2
Indiana	50	16
Kentucky	22	4
Louisiana	35	7
Massachusetts	10	1
Michigan	168	41
Mississippi	5	1
New Jersey	173	38
New York	228	53
North Carolina	10	2
South Carolina	50	1
Texas	200	39
Utah	36	9

### Backup Power Deployments



Totals	1855	388
--------	------	-----




NREL cdp\_bu\_03

Created: Apr-03-13 11:16 AM | Data Range: 2009Q3-2012Q4

| Site Capacity (line height proportional to installed site kW capacity)


## Fuel Cell System Starts by Month




NREL cdp\_bu\_04

Created: Apr-03-13 11:03 AM | Data Range: 2009Q3-2012Q4

## Fuel Cell System Run Hours by Month



## Cumulative Hydrogen Consumed by Month




NREL cdp\_bu\_06

Created: Apr-03-13 9:52 AM | Data Range: 2009Q3-2012Q4




## Fuel Cell System Starts by Day of Week



NREL cdp\_bu\_07

Created: Apr-02-13 2:40 PM | Data Range: 2009Q3-2012Q4

## Fuel Cell System Starts by Time of Day




NREL cdp\_bu\_08

Created: Apr-02-13 2:41 PM | Data Range: 2009Q3-2012Q4

1) FC system conditioning is an automated operation for regular system checks; activated after long periods of no operation.

## Continuous Fuel Cell System Run Time




<sup>1</sup> Fuel cell operations less than 5 minutes apart have been concatenated due to battery interactions that may cause apparently intermittent operation.




## Unsuccessful Operation Categories

### Start Reliability



1788 out of 1796 successful starts


### Unsuccessful Operation Categories



8 failed operations




## Time Between System Starts



NREL cdp\_bu\_11


Created: Apr-02-13 2:42 PM | Data Range: 2009Q3-2012Q4

## System Start Ambient Temperature



NREL cdp\_bu\_12

Created: Apr-02-13 2:42 PM | Data Range: 2009Q3-2012Q4




NREL cdp\_bu\_13

Created: Apr-02-13 2:42 PM | Data Range: 2009Q3-2012Q4

# CDP-BU-14

## Site Capacity




NREL cdp\_bu\_14

Created: Apr-02-13 2:43 PM | Data Range: 2009Q3-2012Q4




# CDP-BU-15

## Backup Power Operation with Grid Outage from 01/2010 to 12/2012



# CDP-BU-16


## Operation Hours Per Month



NREL cdp\_bu\_16

Created: Apr-02-13 2:43 PM | Data Range: 2009Q3-2012Q4

## Average Starts Per Month




NREL cdp\_bu\_17

Created: Apr-02-13 2:43 PM | Data Range: 2009Q3-2012Q4

# CDP-BU-18

## Site Capacity

### Continuous System Run Time



NREL cdp\_bu\_18


Created: Apr-04-13 8:51 AM | Data Range: 2009Q3-2012Q4

- 1) Grid data from Electric Disturbance Event (OE-417) Annual Summaries 2002-2012
- 2) Fuel cell operations less than 5 minutes apart have been combined to address intermittent operation.
- 3) Does not include conditioning starts.

# CDP-BU-19

## Unit Locations


### FC Unit Locations - Backup Power



NREL cdp\_bu\_19

Created: Apr-03-13 11:57 AM | Data Range: 2009Q3-2012Q4


## Power Outages per Year



NREL cdp\_bu\_20

Created: Apr-02-13 2:43 PM | Data Range: 2009Q3-2012Q4

## Operation Hours vs. Calendar Days



NREL cdp\_bu\_21

Created: Apr-04-13 8:09 AM | Data Range: 2009Q3-2012Q4