




**Better
Buildings®**
U.S. DEPARTMENT OF ENERGY

Innovative Industrial Projects: Technologies and Practices that Save Water

May 11, 2016

Panelists

- Mark Dhennin
Director, Energy and Environment
Cummins, Inc.
- Sean West
EH&S Program Manager
United Technologies Corporation
- Muneer Chowdhury
Energy and Environmental Efficiency Manager
Bridgestone Americas, Inc.



**United
Technologies**

UTC Water Reduction Goals

May 11, 2016

Sean West

UNITED TECHNOLOGIES

Agenda

UTC at a glance

2015 Sustainability Goals

2020 Sustainability Goals

Absolute Water Reduction

Water Management Best Practice Implementation

UNITED TECHNOLOGIES

2015 REVENUE \$56.2B




Heating, ventilating, cooling & refrigeration systems



Security & fire protection services



Elevators, escalators, moving walkways, people movers & horizontal transportation systems



Industrial & aerospace systems



Aircraft engines, gas turbines & space propulsion systems

No technical data subject to the EAR or the ITAR

SUSTAINABILITY AT UTC

Driving sustainable performance



Our strategy is straightforward and effective:


Innovate to meet growing demand for sustainable products

Implement sustainable solutions in our operations

Encourage suppliers, customers and employees to achieve sustainable outcomes

UNITED TECHNOLOGIES

Manufacturing Sites Worldwide




ENVIRONMENTAL PROGRESS


Achieved 2015 goals

— Actual
— Goal


Greenhouse Gas Emissions (million tons)




Water Consumption (billion gallons)



Air Emissions (million pounds)



Industrial Process Waste (million pounds)



Goodrich data included as of 2013

This document does not contain any export controlled technical data.

UTC 2020 SUSTAINABILITY GOALS



2020 SUSTAINABILITY GOALS

MOVING THE WORLD FORWARD



¹ Programmatic reduction of 25% from 2015 levels for greenhouse gas emissions. ² Total level 1 mistake proofing to 25% by 2020. Reduction of 1.5x exposure to hazardous substances.

SINCE 1997, UNITED TECHNOLOGIES HAS **TRIPLED** THE SIZE OF OUR BUSINESS

WHILE REDUCING OUR GREENHOUSE GAS EMISSIONS BY **34%**

AND WATER CONSUMPTION BY **57%**

ENGINEERING GOALS

Implement *Design for Sustainability* during the development cycle of new products

Implement *Life-Cycle Analysis* during the development cycle of new products

SUPPLY CHAIN GOALS

INCENTIVIZING KEY SUPPLIERS TO IMPLEMENT

11 SPECIFIC SUSTAINABILITY MEASURES

ENVIRONMENT, HEALTH & SAFETY COMPLIANCE GOALS

- 0** Enforcement actions, non-compliance

- 100%** Inspections without enforcement actions

- 100%** Annual permit & program evaluations

- 100%** Passing compliance/assurance scores

Join the conversation
#NaturalLeader
 NaturalLeader.com UTC.com

No technical data subject to the EAR or the ITAR

2020 WATER REDUCTION GOAL

Absolute water reduction goal



Annual Target: annual increment 5% absolute reduction from baseline


Reporting Sites: Manufacturing, and non-manufacturing with annual energy/water spend > \$100,000

Baseline: 2015 water use amount

No technical data subject to the EAR or the ITAR

2020 WATER BEST PRACTICE GOAL

Implementation of Best Practices



Annual Target: Starting Q4-2016, 20% of business unit WMBP projects must be complete; Additional 20% each year 2017-2020

Reporting Sites: All subject to 2020 water use goal

Baseline: 2015 site water scarcity level, total water use

No technical data subject to the EAR or the ITAR

WATER MANAGEMENT BEST PRACTICE

Implementation matrix

	Large Sites > 1 Million Gal/year	Small Sites < 1 Million Gal/year
Stressed Regions Scarce Regions Extreme Scarce Regions	71 sites (20%) 563.9 million gallons (29%)	76 sites (22%) 28.45 million gallons (1.5%)
Abundant Regions Sufficient Regions	71 sites (20%) 1,339 million gallons (68%)	79 sites (23%) 27.5 million gallons (1.5%)

- Yellow** = All ten best practices required
Blue = Must have current water balance and leak management PLUS five additional best practices
Green = Must have current water balance and leak management

UTC MINIMUM BEST PRACTICES

Current water balance
Leak management

UTC ADDITIONAL BEST PRACTICES

Eliminate once-through cooling
Cooling tower management
Flow meters
Low flow fixtures and flow restrictors
Rinse tank overflow
Xeriscaping
Recycle Process wastewater
Rain water harvesting




Goal Attainment:

Credit given when BMP implemented across > 50% opportunities at site

No technical data subject to the EAR or the ITAR

WATER SCARCITY ANALYSIS

Water use by scarcity level – Water tool output



Extreme Scarcity	Scarcity	Stressed	Sufficient	Abundant
<500 (m3/person/year)	500-1000 (m3/person/year)	1001-1700 (m3/person/year)	1701-4000 (m3/person/year)	>4000 (m3/person/year)

No technical data subject to the EAR or the ITAR

UTC EH&S DATA COLLECTION

Documenting WMBP Implementation Status












Water Best Practice Status
Edit a Record

UniqueKey

Water Scarcity Classification


2015 Water Usage - Gals

Required Water Best Practices

Water Best Practice	Implementation Status 	Comments	
Cooling Tower Management	<input type="text" value="Not Started"/>	<input type="text" value="2018 project"/>	
Current Water Balance (Mandatory)	<input type="text" value="Complete"/>	<input type="text" value="URS Consulting completed report Jan 2016"/>	
Elimination of Once-Through Cooling	<input type="text" value="Greater Than 50% Complete"/>	<input type="text" value="Water cooled Air Compressor added to tower"/>	
Flow Meters	<input type="text" value="Not Started"/>	<input type="text" value="Reviewing meter specs"/>	
Leak Management (Mandatory)	<input type="text" value="Not Started"/>	<input type="text" value="Spring 2016 target date"/>	
Low Flow Fixtures and Flow Resistors	<input type="text" value="Complete"/>	<input type="text" value="42 fixtures complete"/>	
Rain Water Harvesting	<input type="text" value="Reviewed, Exemption Granted"/>	<input type="text" value="Landlord rejected project"/>	
Recycle Process Wastewater	<input type="text" value="Reviewed, Not Applicable"/>	<input type="text" value="no process wastewater"/>	
Rinse Tank Overflow	<input type="text" value="Reviewed, Not Applicable"/>	<input type="text" value="no rinse tanks on site"/>	
Xeriscaping	<input type="text" value="Not Started"/>	<input type="text" value="working with landscape contractor"/>	

UTC WATER GUIDANCE DOCUMENT

List of ten water management best practices


United Technologies

GLOBAL WATER CONSERVATION GUIDANCE DOCUMENT


Water use has always been an important part of conservation goals. From a global perspective, water supply necessitates that sustainability go beyond being inextricably linked to energy as potential to significantly impact how and where it is used. UTC has a successful history of implementing water conservation programs that have reduced water consumption 24% from 2.1 billion gallons in 1997 to 1.6 billion gallons in 2010. UTC has reduced water consumption 57% from 3.3 billion gallons in 2006 to 1.4 billion gallons in 2010. In addition to local water supply classification sites should be aware of other risk factors such as local water quality conditions. Water quality statistics typically published by water suppliers or municipalities. Other risk factors include rising cost and increased regulatory requirements on water quality. This guidance document provides details of UTC global water scarcity assessment and best practices for managing water risks for the corporation and its chain. You will also find case studies and event projects that have been successfully implemented at UTC sites.

TABLE OF CONTENTS

- Current state assessment
- Baseline consumption and water balance
- Continuous Improvement (key areas to focus)
- Required Actions
- Minimum expectations for best practices
- Case studies

BEST PRACTICES

- Water balance
- Leak management
- Eliminate once-through cooling
- Cooling tower management
- Flow meters
- Low flow fixtures and flow restrictors
- Rinse tank overflow
- Xeriscaping
- Recycle process wastewater
- Rain water harvesting


United Technologies

CURRENT STATE ASSESSMENT

Unlike greenhouse gas emissions, water issues need to be managed accordingly. Utilizing the Water Development (WBCSD) Water Tool, UTC was able to assess its water consumption relative to our global operations.


Regional water resources are classified by the WBCSD into three categories: *Abundant, Sufficient, Stressed*. UTC used to compare UTC sites with validated water availability on a watershed basis. It provided a baseline of UTC such as projected water availability (or scarcity) population growth patterns and industrial intensity.

According to WBCSD projections of future water use are in regions with Sufficient or Abundant water use) are in regions that are Stressed. Refer to Figure 1 below.


Fig. #1 (2010 data)

	Large Volume > 10 Million Gal		Medium Volume 1 Million - 10 Million Gal	
	# of Sites	Gallons	# of Sites	Gallons
Extreme Scarcity	6	102,330,695	15	1,177,808,100
Scarcity	4	114,558,951	14	1,177,808,100
Stressed	3	72,503,618	14	1,177,808,100
Sufficient	6	228,129,201	24	1,177,808,100
Abundant	15	655,285,741	49	1,177,808,100
No Data	0	0	3	1,177,808,100
Total	34	1,177,808,100	116	1,177,808,100

Since 2006, UTC's water consumption has declined by 24% in "Extremely Scarce" regions. If this trend continues, we may experience water shortages, increased regulatory requirements, and increased costs.


United Technologies

Cooling tower management program



In many cases, consumers of water can help track and manage water consumption. In many cases, consumers of water can help track and manage water consumption. In many cases, consumers of water can help track and manage water consumption.

Install flow meters


Installing flow meters on large process lines allows water consumers to help track and manage water consumption. Installing flow meters alone do not save water, they do monitor usage and can identify water leaks and system failures.

Install low flow fixtures and flow restrictors

Modern plumbing fixtures use significantly less water than older fixtures. Replacing old plumbing fixtures with new dual flush water closets, 0.125 gallon per flush (GPF) kitchen fixtures and low flow showerheads. The use of flow restrictors in the feed line to process equipment can help reduce water consumption. The use of flow restrictors in the feed line to process equipment can help reduce water consumption.

Reduce or eliminate rinse tank

It is a common practice to use rinse tanks. The water flow to rinse tanks should be controlled manually or automatically. Another option is to control water flow to rinse tanks. Conductivity sensors can measure the conductivity of the water and cycle the water accordingly.


United Technologies

MINIMUM EXPECTATIONS FOR BEST PRACTICES

Water Balance per Standard Practice 009.

A Water Balance shall be prepared that illustrates the volumetric flow rate of all water used including sources that are not defined as a Significant Water Source (e.g. sanitary, cafeteria, blow down from cooling towers and boilers and mop water) and all Significant Water Sources. The Water Balance shall also indicate where wastewater is treated and/or recycled. The volume of water discharge from all water sources at the facility shall be measured using influent and/or discharge water meters. The volume of water consumed (from all sources including public water supplies or on-site diversions) and discharged shall be evaluated annually to ensure that the sources of all significant changes are identified.

Water leak management program

All facilities will experience some water leaks. Leaks may range from a fraction of a percent up to several percents of total water use. Common locations to find leaks are in piping joints, restroom fixtures, pump seals, hose nozzles/shut-off valves, drinking fountains, processing equipment, and other locations. Eliminating leaks typically includes tightening or replacing fittings. Leaks can be identified via visual or auditory observation. Water fixtures and process equipment should be observed during both use and down time. All employees should be responsible for notifying maintenance personnel of leaks. Underground and under-the-floor leaks can be detected through a leak detection survey. If an underground leak is suspected, but not identified, facilities should consider having a leak detection survey conducted by a consulting or service firm.

Quantifying the volume of water lost through leaks is important for determining the potential water and cost savings of leak repair. One of the simplest methods to determine leak loss is the bucket and stopwatch method. A small drip also can be measured by the bucket and stopwatch method. Mathematical estimates of leaks also can be used.


Eliminate once-through cooling

For many years it was a common practice to use municipal water in once-through or single-pass cooling systems for various HVAC and process cooling applications. Single-pass cooling systems are ineffective and waste water. All single-pass cooling systems should be replaced with air-cooled or recirculating systems.


UTC 2015 ANNUAL REPORT

At UTC we measure our sustainability performance for current operations through key performance indicators. To learn more about our progress in protecting the environment and the health and safety of our employees and communities where we work, visit our [2020 Sustainability Goals](#) page.


GREENHOUSE GAS EMISSIONS
Million metric tons CO₂e




WORLDWIDE WATER CONSUMPTION
Billion gals




INDUSTRIAL PROCESS WASTE
Million lbs




NON-RECYCLED INDUSTRIAL PROCESS WASTE
Million lbs




NON-GREENHOUSE GAS EMISSIONS
Million lbs



LOST WORKDAY INCIDENT RATE
Cases/100 employees




TOTAL RECORDABLE INCIDENT RATE
Cases/100 employees



The increases in our 2013 environmental performance results reflect the addition of 100 former Goodrich sites to our EH&S management system.

WATER CONSUMPTION WORLDWIDE



Q&A

Sean West
EH&S Program Manager
Sean.west@utc.com
(860) 728-7619



Environment, Health & Safety

United Technologies Corporation

One Team, ne Planet.

BRIDGESTONE

Muneer Chowdhury

May 11, 2016

Bridgestone Americas' commitment to
helping ensure a healthy environment for current
and future generations to enjoy

- Founded in Japan in 1931, headquartered in Tokyo
- The world's largest tire and rubber company
- Manufactures tires and a broad range of diversified products, which includes Industrial Products, Building Products, Chemical Products and Sporting Goods.
- Products sold in more than 150 nations and territories around the world



Conveyer Belts



Seismic Isolation Rubber



Sporting Goods



High Performance film



Bicycles



Seat pads for automobiles
(Polyurethane foam)

Brief Background of Bridgestone Americas (BSAM)

- Nashville, Tennessee-based BSAM is the largest subsidiary of Bridgestone Corporation with 50,000 teammates in North and South America.
- BSAM and its subsidiaries develop, manufacture and market a wide range of Bridgestone, Firestone and associate brand tires to address the needs of a broad range of customers, including consumers, automotive and commercial vehicle original equipment manufacturers, and those in the agricultural, forestry and mining industries.
- The company is also engaged in retreading operations throughout the Western Hemisphere and produces air springs, roofing materials, and industrial fibers and textiles.
- BSAM also operates the world's largest chain of automotive tire and service centers.



► Tires for every need


we sell more than 8,000 different types and sizes of tires

- Passenger Cars, SUVs, Light Truck
- Trucks and Buses
- Agricultural
- Earth Moving
- Racing, Motor Cycle, Aircraft, and Metro



\$32

\$ 150,000



- **Water savings in Manufacturing process –
“Cooling tower installation project at Joliette Plant”**
- **Water savings by Rainwater Harvesting –
“ Rainwater Harvesting Project at Aiken ORR Plant”**
- **Water savings in facilities –
“Facilities fixtures upgrade at Warren and LaVergne
Plants”**

Joliette Plant



Current:

- The Joliette plant is one of the highest water consumption Plant in BSAM.
- Presently a process water circuit going to a cooling tower, but it provide services only for half of the plant.
- Major equipments of the power house like air compressors and dryers, as well as nitrogen exchanger are cooled with once through cooling process.


Proposed:

- Installation of a new cooling tower in the powerhouse area to provide a closed circuit cooling system that will reduce plant water consumption.
- Heat recuperated from the water will be used to preheat boiler feed water and combustion air, before going to the cooling water.

- The installation of the cooling tower to cool the powerhouse equipment in a closed loop circuit will reduce the plant water consumption by 60% that equals to 116.2 Million Gallons of Water.
- A saving of \$168, 490 per year.

Schematic flow Diagram

Conceptual diagram: cooling tower system for powerhouse equipment



Water savings details

Water saving potential,
once through flow that would be replaced by closed loop cooling system

Major equipment	MMGal/ year	MMGal/ year saved (including Delta syst.)
Purge tanks / Flash tank	10.0	10.0
Nitrogen exchanger	12.4	12.4
Compressor #1	15.6	9.4
Compressor #2	15.2	9.1
Compressor #3	9.0	5.4
Compressor #4	3.6	2.1
Dryerr #5	17.9	17.9
Compressor #5	43.8	43.8
Compressor #6	0.2	0.2
Compressor #7	0.3	0.3
Minor equipment		
Dryerr #1 et #2	7.3	7.3
Dryer #3 et #4	5.5	5.5
Nitrogen compressor	2.5	2.5
Nitrogen dryer	0.3	0.3
TOTAL potential water saving	Total flow saving	126.2
Tower make-up water	new usage	-10.0
TOTAL net potential water saving	Total net anticipated saving	116.2

2015 water unit cost (\$/Mgal) \$1.45 US \$1.89 canadian

TOTAL \$ saving	\$	168,490.00
------------------------	-----------	-------------------

Water usage in 2014	188.6
----------------------------	--------------

Percent anticipated saving	62%
-----------------------------------	------------



FXV Dual Air Intake

The FXV Dual Air Intake models provide many of the same features and benefits of the FXV, but on a much larger scale. It is the largest closed circuit cooling tower on the market, making it ideal for large projects where size matters.



Ideal for Large Projects



**Crossflow Design
Easiest to Maintain**



Easy Installation




Multi-cell FXV Dual Air Intake Installation

Aiken ORR Rain Water Harvesting




RAINWATER HARVESTING




**BOILERS
&
TOILETS**


**RAINWATER
POND**



AOR Rainwater Harvesting



Water from the green areas is collected and stored in a Firestone PondGard pond



Project Summary

- FR written for \$722,000
- Design Capacity of 100 GPM
- Savings at 50 GPM
 - \$81,547/yr
 - 26.8 million gallons
- Started-up 4/7/2015

Filter/Booster/Storage



- 100 Gpm Capacity
- 6000 gallon storage
- Ultraviolet Biocide Chamber
- Sand Filtration
- Mechanical redundancy with Service Water

Booster Pump Skid



- Currently provides supply water
 - 20 gpm to the boilers
 - Plant toilets
- Future
 - Cooling tower make-up
 - Curing hydraulic make-up

November 3, 2014

BRIDGESTONE
Your Journey, Our Passion



BRIDGESTONE
Your Journey, Our Passion

One Team,  One Planet.

November 25, 2014

BRIDGESTONE
Your Journey, Our Passion



BRIDGESTONE
Your Journey, Our Passion

One Team,  One Planet.

January 14, 2014



December 26, 2014

BRIDGESTONE
Your Journey, Our Passion



BRIDGESTONE
Your Journey, Our Passion

One Team,  One Planet.




Tank & Booster



UV Treatment Skid





Sink Area Before Renovation




Sink Area After Renovation



Sensor Equipped Faucets for Water Savings at our Rest rooms

Urinal Area Before Renovation

Original urinals – manual flush valve sticks causing wasted water and bathroom flooding



BRIDGESTONE

BRIDGESTONE
Your Journey, Our Passion

PASSION for EXCELLENCE



Touch-Free

Hygienic



**FALCON
WATERFREE
TECHNOLOGIES™**

This facility is committed to protecting and preserving our environment. By using this touch-free, completely hygienic Falcon Waterfree system, you are helping the environment to conserve an average of 40,000 gallons of fresh water per urinal, per year.

www.falconwaterfree.com

Auto Faucets



Auto Faucets Equipped

Water Savings projects Savings

- **Water savings in Manufacturing process –**
“Cooling tower installation project at Joliette Plant”
 - a. 116 Million Gallons of water savings per year
 - b. \$168,000 Savings per year
- **Water savings by Rainwater Harvesting –**
“Rainwater Harvesting Project at Aiken ORR Plant”
 - a. 27 Million Gallons of water savings per year
 - b. \$82,000 Savings per year
- **Water savings in facilities –**
“Facilities fixtures upgrade at Warren and LaVergne Plants”
 - a. 20 Million Gallons of water savings per year
 - b. \$60,000 Savings per year

Total Savings: 163 Million Gallons of Water and \$310,000/Year

Real pleasure for the opportunity

THANK YOU

Cummins Water Program

Mark Dhennin

Better Buildings Summit


May 2016




Cummins, Inc.

2015 Revenue: \$19.1 billion

55,000 employees, 190+ countries & territories



Engines



Power
Generation



Components



Distribution

2015 water consumption: 953 MG global; 494 MG U.S.

Envolve Cummins Priorities

FOCUS

ACTION AREAS

Reducing our carbon footprint.



New product fuel efficiency • facility GHG reduction • renewable energy • products-in-use fuel efficiency • logistics • remanufacturing

Using fewer natural resources.



Water reduction and neutrality • increased recycling • zero disposal • materials efficiency • packaging • advanced manufacturing

Partnering to solve complex problems.



Supplier and community collaboration • new technologies • metals and water availability • NGOs • governments

Water Stewardship at Cummins

External
Goals

Water Conservation

2020 Goal: Reduce water use intensity (normalized to labor hours worked) in our facilities by 33% as compared to a 2010 baseline.



Community Engagement

2020 Goal: Achieve water neutrality (off-set the water we use) for 15 facilities in water-scarce regions through community water projects.



Internal
Priorities


Risk Mitigation

Focus – Determine risks posed by water scarcity and mitigate commensurate with the exposure through business processes.




A
Complete
Approach



Segmenting Water Use



Make the Complex Simple




Prioritize




Consult

A screenshot of a 'Water Tool - Cost And Results Pass' dashboard. It features a table with columns for 'System/Component', 'Estimated Cost', 'Risk', and 'Company/Region'. Below this are sections for 'Energy/Process' and 'Process/Production' with their respective metrics and values.



Achieve



Expanding the Champion scope

Energy Champions

- Energy/GHG training
- Energy toolkit
- Best practice sharing
- Site energy teams



Environmental Champions

- Energy/GHG, water & waste training
- Energy, water & waste toolkits
- Best practice sharing
- Site environmental teams


- Holistic approach to environmental sustainability
- Utilize common, proven approaches and tools

Focus: Cummins Technical Center




- ➔ Opened in 1967
- ➔ 88 test cells and labs
 - ➔ 500 – 3,000 HP
- ➔ 1,100 employees
- ➔ 500,000 sq. ft.
- ➔ ISO 14001, ISO 50001, Superior Energy Performance – Platinum
- ➔ 68.8 million gallons of water consumed, 2015
- ➔ 722,000 MMBtu energy consumption, 2015
 - ➔ 42% Electricity, 37% Diesel, 20% Natural Gas, 1% Other





Cummins
Technical
Center:
Water Tree


Cummins Technical Center Macro Level Water Balance – Annual





Cummins Technical Center: Water Profile

Water Consumption (Millions of Gallons)




Largest Water Uses:

- Boilers – 38%
- Sanitary & Laboratories – 28%
- General process water cooling – 23%
- Bedplate washdown / test cell cleaning – 5%
- Chilled water system – 4%
- Other – 2%

Significant Efforts in Water Conservation:

- Test cell bedplate washdown
- Cooling tower water cycle improvements
 - From 2 cycles to 7
- Chemical management of process water
- Auditing and awareness

Water Management in a Research Environment



Leak Repairs and Auditing

- Maintenance team critical in fixing leaks
- Site communication on water conservation efforts led to a significant increase in employees reporting leaks
- One-pass cooling identified and addressed
- Test cell audits led to improved water valve placement, usage and control



CTC Energy/Water Deputies

- Operational team focusing on ground-level improvements
- Comprised of test cell operation experts, facilities engineering, operational and environmental management
- Harness team's technical expertise to implement improvement projects
- Critical in bedplate washdown project and others
- Just-Do-It attitude



Regenerative Dynamometers

- Do not require the use of process water to cool the dyno
- Much less water required in test cells
- Increases engine testing technical capabilities

Observations

