

US EPA ARCHIVE DOCUMENT



**TABLE 1F
AIR QUALITY APPLICATION SUPPLEMENT**

Permit No.:	TBD	Application Submittal Date:	July 7, 2014						
Company:	Lon C. Hill LP								
RN:	RN100215979	Facility Location:	3501 Callicoatte Rd, Corpus Christi, Texas						
City:	Corpus Christi	County:	Nueces						
Permit Unit I.D.:	TBD	Permit Name:	Lon C Hill Power Station						
Permit Activity:	<input checked="" type="checkbox"/> New Source	<input type="checkbox"/> Modification							
Complete for all Pollutants with a Project Emission Increase.	POLLUTANTS								
	Ozone		CO	PM ₁₀	PM _{2.5}	NO _x	SO ₂	Other ^[1] CO ₂ e	
	VOC	NO _x							
Nonattainment Potentially Applicable?								No	
PSD Potentially Applicable?									Yes
Existing site PTE (tpy)?									0.0
Proposed project emission increases (tpy from 2F ^[2])									2,517,769
Is the existing site a major source?									No
If not, is the project a major source by itself?									Yes
If site is major source, is project increase significant?									Yes
If netting required, estimated start of construction:			01-May-15						
5 years prior to start of construction contemporaneous			01-May-10						
Estimated start of operation period			01-Apr-17						
Net contemporaneous change, including proposed project, from Table 3F. (tpy)									2,517,769
Major NSR Applicable?	No	No	No	No	No	No	No	No	Yes
<i>Signature</i>			<i>Title</i>			<i>Date</i>			

[1] Other pollutants. [Pb, H₂S, TRS, H₂SO₄, Fluoride excluding HF, etc.]

[2] Sum of proposed emissions minus baseline emissions, increases only.

The representations made above and on the accompanying tables are true and correct to the best of my knowledge.

US EPA ARCHIVE DOCUMENT



**TABLE 2F
PROJECT EMISSION INCREASE**

Pollutant^[1]: CO₂e	Permit: TBD
Baseline Period: _____ to _____	

	Affected or Modified Facilities ^[2]		Permit No.	Actual Emissions ^[3]	Baseline Emissions ^[4]	Proposed Emissions ^[5]	Projected Actual Emissions	Difference (B-A) ^[6]	Correction ^[7]	Project Increase ^[8]
	FIN	EPN								
1	CC-101	STK-101	TBD		0.0	1,256,916		1,256,916		1,256,916
2	CC-102	STK-102	TBD		0.0	1,256,916		1,256,916		1,256,916
3	ABL-100	ABLSTK-100	TBD		0.0	2,779		2,779		2,779
4	EGEN-100	EGENSTK-100	TBD		0.0	77		76.7		76.7
5	FWP-100	FWPSTK-100	TBD		0.0	35		35.3		35.3
6	FUGNG-100	FUGNG-100	TBD		0.0	1,043		1,043		1,043
7	SF6-100	SF6-100	TBD		0.0	4.1		4.1		4.1
8										
9										
10										
Page Subtotal^[9]										2,517,769

[1] Individual Table 2F's should be used to summarize the project emission increase for each criteria pollutant
 [2] Emission Point Number as designated in NSR Permit or Emissions Inventory
 [3] All records and calculations for these values must be available upon request
 [4] Correct actual emissions for currently applicable rule or permit requirements, and periods of non-compliance. These corrections, as well as any MSS previously demonstrated under 30 TAC 101, should be explained in the Table 2F supplement
 [5] If projected actual emission is used it must be noted in the next column and the basis for the projection identified in the Table 2F supplement
 [6] Proposed Emissions (column B) minus Baseline Emissions (column A)
 [7] Correction made to emission increase for what portion could have been accommodated during the baseline period. The justification and basis for this estimate must be provided in the Table 2F supplement
 [8] Obtained by subtracting the correction from the difference. Must be a positive number.
 [9] Sum all values for this page.

**TABLE 3F
PROJECT CONTEMPORANEOUS CHANGES^[1]**

Company:		Lon C. Hill, LP								
Permit Application Number:					TBD					
Criteria Pollutant:					CO_{2e}					
		A			B					
Project Date ^[2]	Facility at Which Emission Change Occurred ^[3]		Permit No.	Project Name or Activity	Baseline Period (years)	Proposed Emissions (tons/year) ^[4]	Baseline Emissions (tons/year) ^[5]	Difference (A-B) ^[6]	Creditable Decrease or Increase ^[7]	
	FIN	EPN								
1	TBD	CC-101	STK-101	TBD	Unit 101 Combined Cycle (GT+HRSG)	NA	1,256,916	0.0	1,256,916	1,256,916
2	TBD	CC-102	STK-102	TBD	Unit 102 Combined Cycle (GT+HRSG)	NA	1,256,916	0.0	1,256,916	1,256,916
	TBD	ABL-100	ABLSTK-100	TBD	Auxiliary Boiler	NA	2,779	0.0	2,779	2,779
	TBD	EGEN-100	EGENSTK-100	TBD	Emergency Generator	NA	76.7	0.0	76.7	76.7
	TBD	FWP-100	FWPSTK-100	TBD	Firewater Pump	NA	35.3	0.0	35.3	35.3
3	TBD	FUGNG-100	FUGNG-100	TBD	Fugitive GHG	NA	1,043	0.0	1,043	1,043
4	TBD	SF6-100	SF6-100	TBD	Electrical Equipment Insulation Leaks	NA	4.1	0.0	4.1	4.1
5										
6										
Page Subtotal^[8]						2,517,769	0.0	2,517,769	2,517,769	
Summary of Contemporaneous Changes Total						2,517,769	0.0	2,517,769	2,517,769	

^[1] Individual Table 3F's should be used to summarize the project emission increase and net emission increase for each criteria pollutant.

^[2] The start of operation date for the modified or new facilities. Attach Table 4F for each project reduction claimed.

^[3] Emission Point No. as designated in NSR Permit or Emissions Inventory.

^[4] All records and calculations for these values must be available upon request.

^[5] All records and calculations for these values must be available upon request.

^[6] Proposed (column A) - Baseline (column B).

^[7] If portion of the decrease not creditable, enter creditable amount.

^[8] Sum all values for this page.

LON C HILL REDEVELOPMENT PROJECT
LON C. HILL, LP

Summary of GHG and CO₂ Sitewide Emission Rates

EPN	FIN	Name	GHG Mass Basis		CO ₂ e Emission Rate (tpy)
			Pollutant	Emission Rate (tpy)	
STK-101	CC-101	Unit 101 Combined Cycle (GT+HRSG)	CO ₂	1,255,634	1,256,916
			CH ₄	23.5	
			N ₂ O	2.3	
STK-102	CC-102	Unit 102 Combined Cycle (GT+HRSG)	CO ₂	1,255,634	1,256,916
			CH ₄	23.5	
			N ₂ O	2.3	
ABLSTK-100	ABL-100	Auxiliary Boiler	CO ₂	2,776	2,779
			CH ₄	0.05	
			N ₂ O	0.01	
EGENSTK-100	EGEN-100	Emergency Generator	CO ₂	76.5	77
			CH ₄	0.003	
			N ₂ O	0.001	
FWPSTK-100	FWP-100	Firewater Pump	CO ₂	35.2	35
			CH ₄	0.001	
			N ₂ O	0.0003	
FUGNG-100	FUGNG-100	Fugitive GHG	CH ₄	41.7	1,043
SF6-100	SF6-100	Electrical Equipment Insulation Leaks	SF ₆	0.0002	4.15
Total Sitewide Emission Rates				2,514,249	2,517,769

US EPA ARCHIVE DOCUMENT

LON C HILL REDEVELOPMENT PROJECT
LON C. HILL, LP

GHG Emission Rates per Unit Summary Table (Siemens SCC6-5000F)

Air Pollutant	Emission Factor (lb/MMBtu) ^{(1), (2)}	Heat Input (HHV) (MMBtu/yr) ⁽³⁾	GHG Emission Rate (tpy) ⁽⁴⁾	Global Warming Potential (100yr.) ⁽⁵⁾	CO ₂ e Emission Rate (tpy) ⁽⁶⁾
CO ₂	118.8	21,136,220	1,255,634	1	1,255,634
CH ₄	2.2E-03		23.5	25	588
N ₂ O	2.2E-04		2.3	298	694

Total GHG per Unit ⁽⁷⁾	1,255,660 tpy
Total CO ₂ e per Unit ⁽⁸⁾	1,256,916 tpy

GHG Emission Rates per Unit Summary Table (GE S207FA.04)

Air Pollutant	Emission Factor (lb/MMBtu) ^{(1), (2)}	Heat Input (HHV) (MMBtu/yr) ⁽³⁾	GHG Emission Rate (tpy) ⁽⁴⁾	Global Warming Potential (100yr.) ⁽⁵⁾	CO ₂ e Emission Rate (tpy) ⁽⁶⁾
CO ₂	118.8	19,711,384	1,170,989	1	1,170,989
CH ₄	2.2E-03		21.9	25	548
N ₂ O	2.2E-04		2.2	298	647

Total GHG per Unit ⁽⁷⁾	1,171,013 tpy
Total CO ₂ e per Unit ⁽⁸⁾	1,172,185 tpy

Notes:

- (1) CO₂ emission factor calculated per 40 CFR Part 75, Appendix G, Equation G-4, as referenced in §98.43(a), where:
 $CO_2 \text{ Emission Factor} = 1,040 \text{ scf/MMBtu} / 385 \text{ scf/lbmole} * 44 \text{ lb/lbmole} = 118.8 \text{ lb/MMBtu}$
 Carbon based F-factor, F_C: 1,040
 Standard Molar Volume: 385
 Molecular Weight CO₂, MW_{CO2}: 44
- (2) CH₄ and N₂O emission factors per 40 CFR 98, Subpart C, Table C-2 for natural gas fired units.
 $CH_4 \text{ Emission Factor} = 1.0E-03 \text{ kg/MMBtu} * 1 \text{ metric ton}/1,000 \text{ kg} * 1.1023 \text{ short ton} / \text{metric ton} * 2,000 \text{ lb}/\text{short ton} = 2.2E-03 \text{ lb/MMBtu}$
 $N_2O \text{ Emission Factor} = 1.0E-04 \text{ kg/MMBtu} * 1 \text{ metric ton}/1,000 \text{ kg} * 1.1023 \text{ short ton} / \text{metric ton} * 2,000 \text{ lb}/\text{short ton} = 2.2E-04 \text{ lb/MMBtu}$
 Where 1.1023 short ton/metric ton per 40 CFR 98, Subpart D, §98.43(a)(1)
- (3) Heat Input (HHV) maximum annual heat input for all operating scenarios evaluated for both Siemens SCC6-5000F and GE S207FA.04 including normal and MSS operation (8,760 hr/yr)
- (4) Emission Rate CO₂ (tpy) = Emission Factor CO₂ (lb/MMBtu) * Heat Input (MMBtu/yr) * 1ton/2,000 lb
 $CO_2 \text{ Emission Rate (Siemens SCC6-5000F)} = 118.8 \text{ lb/MMBtu} * 21,136,220 \text{ MMBtu/yr} * 1\text{ton}/2,000 \text{ lb} = 1,255,634 \text{ tpy}$
 Emission Rate CH₄ (tpy) = Emission Factor CH₄ (lb/MMBtu) * Heat Input (MMBtu/yr) * 1ton/2,000 lb + Purging CH₄ Emission Rate (tpy)
 Purging CH₄ Emission Rate (tpy) = Gas Turbine Purging CH₄ (tpy) + Duct Burner Purging CH₄ (tpy) + Pilot CH₄ (tpy)
 $CH_4 \text{ Emission Rate (Siemens SCC6-5000F)} = [2.2E-03 \text{ lb/MMBtu} * 21,136,220 \text{ MMBtu/yr} * 1\text{ton}/2,000 \text{ lb}] + 0.20 \text{ tpy} = 23.5 \text{ tpy}$
 $Purging CH_4 \text{ Emission Rate} = 0.16 \text{ tpy} + 0.04 \text{ tpy} + 0.001 \text{ tpy} = 0.20 \text{ tpy}$
 Emission Rate N₂O (tpy) = Emission Factor N₂O (lb/MMBtu) * Heat Input (MMBtu/yr) * 1ton/2,000 lb
 $N_2O \text{ Emission Rate (Siemens SCC6-5000F)} = 2.2E-04 \text{ lb/MMBtu} * 21,136,220 \text{ MMBtu/yr} * 1\text{ton}/2,000 \text{ lb} = 2.3 \text{ tpy}$
- (5) Global Warming potential per 40 CFR 98, Subpart A, Table A-1
- (6) CO₂e (tpy) = Mass Emission Rate (tpy) * Global Warming Potential
 $CH_4 \text{ as CO}_2\text{e (Siemens SCC6-5000F)} = 23.5 \text{ tpy} * 25 = 588 \text{ tpy}$
- (7) Total GHG emission rate per unit = Sum of GHG mass emission rates
 $Total GHG \text{ (Siemens SCC6-5000F)} = 1,255,634 + 23.5 + 2.3 = 1,255,660 \text{ tpy}$
- (8) Total CO₂e emission rate per unit = Sum of CO₂e emission rates
 $Total CO_2e \text{ (Siemens SCC6-5000F)} = 1,255,634 + 588 + 694 = 1,256,916 \text{ tpy}$

US EPA ARCHIVE DOCUMENT

LON C HILL REDEVELOPMENT PROJECT
LON C. HILL, LP

Fuel Purging

Occasionally during startup, shutdown, or maintenance activities, natural gas is purged to the atmosphere to reduce the header pressure. Fuel purging emissions are based on the Universal Ideal Gas Law, with the assumption that in one hour, the entire length of pipe is purged once and the purging takes place for every startup and shutdown of the units.

Parameter	Units	Gas Turbine	Duct Burner	Pilot
Line Diameter ⁽¹⁾	in	3.00	6.00	1.00
Line Length ⁽¹⁾	ft	10.00	5.00	5.00
Line Pressure ⁽¹⁾	psig	450	40	15
Line Temperature ⁽¹⁾	°F	125	42	42
CH ₄ MW ⁽²⁾	lb/lbmole	16.77	16.77	16.77
Line Volume ⁽³⁾	cf	0.49	0.98	0.03
CH ₄ Moles in Line ⁽⁴⁾	lbmole	0.04	0.01	0.0002
CH ₄ Pounds in Line ⁽⁵⁾	lb/purge	0.61	0.17	0.003
Annual No. of Purges per Unit ⁽⁶⁾	purges/yr	520	520	520
CH ₄ Annual Emission Rate ⁽⁷⁾	tpy	0.16	0.04	0.001

Notes:

- (1) Line characteristics per engineering knowledge.
- (2) Natural gas molecular weight (MW) per Natural Gas Fuel Analysis.
- (3) Line Volume = $\pi/4 * D^2 * L$
 Gas Turbine Line Volume = $\pi/4 * (3.00 \text{ inch} * 1\text{ft}/12\text{inch})^2 * 10.00 \text{ ft} = 0.49 \text{ cf}$
- (4) Universal Ideal Gas Law
 Gas Turbine Moles in Line = $n = P * V / (R * T) = (450 + 14.656) \text{ psia} * 0.49 \text{ cf} / (10.73 * (125 + 459.67) \text{ R}) = 0.036 \text{ lbmole}$
- (5) Pounds in Line (lb) = Moles in Line (lbmole) * Molecular Weight (lb/lbmole)
 Gas Turbine Pounds in Line = $0.036 \text{ lbmole} * 16.77 \text{ lb/lbmole} = 0.61 \text{ lb}$
- (6) Annual No. of Purges = Annual No. of Startups and Shutdowns
- (7) CH₄ Annual Emission Rate (tpy) = CH₄ Pounds in Line (lb/purge) * Annual No. of Purges (purges/yr) * 1ton/2,000lb
 GT CH₄ Annual Emission Rate per Unit = $0.61 \text{ lb/purge} * 520 \text{ purges/yr} * 1\text{ton}/2,000\text{lb} = 0.16 \text{ tpy}$

US EPA ARCHIVE DOCUMENT

LON C HILL REDEVELOPMENT PROJECT
LON C. HILL, LP

Auxiliary Boiler GHG Emission Rates Summary Table

Air Pollutant	Emission Factor (kg/MMBtu) ^{(1),(2)}	Heat Input (HHV) (MMBtu/yr) ⁽³⁾	GHG Emission Rate (tpy) ⁽⁴⁾	Global Warming Potential (100yr.) ⁽⁵⁾	CO ₂ e Emission Rate (tpy) ⁽⁶⁾
CO ₂	53.02	47,500	2,776	1	2,776
CH ₄	1.0E-03		0.05	25	1.31
N ₂ O	1.0E-04		0.01	298	1.56

Total GHG ⁽⁷⁾	2,776 tpy
Total CO ₂ e ⁽⁸⁾	2,779 tpy

Notes:

- (1) CO₂ emission factor per 40 CFR 98, Subpart C, Table C-1 for natural gas fired units.
- (2) CH₄ and N₂O emission factors per 40 CFR 98, Subpart C, Table C-2 for natural gas fired units.
- (3) Heat Input (HHV) (MMBtu/yr) = Design Heat Input (MMBtu/hr) * Annual Hours of Operation (hr/yr)
 $\text{Heat Input (HHV)} = 95.0 \text{ MMBtu/hr} * 500 \text{ hr/yr} = 47,500 \text{ MMBtu/yr}$
- (4) Emission Rate (tpy) = Emission Factor (kg/MMBtu) * Heat Input (MMBtu/yr) * 1 metric ton/1,000kg * 1.1023 short ton/metric ton
 $\text{CH}_4 \text{ Emission Rate} = 0.001 \text{ kg/MMBtu} * 47,500 \text{ MMBtu/yr} * 1 \text{ metric ton}/1,000\text{kg} * 1.1023 \text{ short ton}/\text{metric ton} = 0.05 \text{ tpy}$
 Where 1.1023 short ton/metric ton per 40 CFR 98, Subpart D, §98.43(a)(1)
- (5) Global Warming potential per 40 CFR 98, Subpart A, Table A-1
- (6) CO₂e (tpy) = Emission Rate (tpy) * Global Warming Potential
 $\text{CH}_4 \text{ as CO}_2\text{e} = 0.05 \text{ tpy} * 25 = 1.3 \text{ tpy}$
- (7) Total GHG emission rate = Sum of GHG emission rates
 $\text{Total GHG} = 2,776 + 0.05 + 0.01 = 2,776 \text{ tpy}$
- (8) Total CO₂e emission rate = Sum of CO₂e emission rates
 $\text{Total CO}_2\text{e} = 2,776 + 1.31 + 1.56 = 2,779 \text{ tpy}$

US EPA ARCHIVE DOCUMENT

LON C HILL REDEVELOPMENT PROJECT
LON C. HILL, LP

Emergency Generator GHG Emission Rates Summary Table

Air Pollutant	Emission Factor (kg/MMBtu) ^{(1),(2)}	Heat Input (HHV) (MMBtu/yr) ⁽³⁾	GHG Emission Rate (tpy) ⁽⁴⁾	Global Warming Potential (100yr.) ⁽⁵⁾	CO ₂ e Emission Rate (tpy) ⁽⁶⁾
CO ₂	73.96	938	76.47	1	76.5
CH ₄	3.0E-03		0.003	25	0.08
N ₂ O	6.0E-04		0.001	298	0.18

Total GHG ⁽⁷⁾	76 tpy
Total CO ₂ e ⁽⁸⁾	77 tpy

Notes:

- (1) CO₂ emission factors per 40 CFR 98, Subpart C, Table C-1 for Distillate Fuel Oil No. 2
- (2) CH₄ and N₂O emission factors per 40 CFR 98, Subpart C, Table C-2 for Petroleum (all fuel types in Table C-1)
- (3) Heat Input based on engineering knowledge.
- (4) Emission Rate (tpy) = Emission Factor (kg/MMBtu) * Heat Input (MMBtu/yr) * 1 metric ton/1,000kg * 1.1023 short ton/metric ton
 $CH_4 \text{ Emission Rate} = 0.003 \text{ kg/MMBtu} * 938 \text{ MMBtu/yr} * 1 \text{ metric ton}/1,000\text{kg} * 1.1023 \text{ short ton/metric ton} = 0.003 \text{ tpy}$
 Where 1.1023 short ton/metric ton per 40 CFR 98, Subpart D, §98.43(a)(1)
- (5) Global Warming potential per 40 CFR 98, Subpart A, Table A-1
- (6) CO₂e (tpy) = Emission Rate (tpy) * Global Warming Potential
 $CH_4 \text{ as CO}_2\text{e} = 0.003 \text{ tpy} * 25 = 0.1 \text{ tpy}$
- (7) Total GHG emission rate = Sum of GHG emission rates
 $Total \text{ GHG} = 76.5 + 0.003 + 0.001 = 76 \text{ tpy}$
- (8) Total CO₂e emission rate = Sum of CO₂e emission rates
 $Total \text{ CO}_2\text{e} = 76.5 + 0.08 + 0.18 = 77 \text{ tpy}$

US EPA ARCHIVE DOCUMENT

LON C HILL REDEVELOPMENT PROJECT
LON C. HILL, LP

Firewater Pump GHG Emission Rates Summary Table

Air Pollutant	Emission Factor (kg/MMBtu) ^{(1),(2)}	Heat Input (HHV) (MMBtu/yr) ⁽³⁾	GHG Emission Rate (tpy) ⁽⁴⁾	Global Warming Potential (100yr.) ⁽⁵⁾	CO ₂ e Emission Rate (tpy) ⁽⁶⁾
CO ₂	73.96	431.90	35.21	1	35.2
CH ₄	3.0E-03		0.001	25	0.04
N ₂ O	6.0E-04		0.0003	298	0.09

Total GHG ⁽⁷⁾	35 tpy
Total CO ₂ e ⁽⁸⁾	35 tpy

Notes:

- (1) CO₂ emission factors per 40 CFR 98, Subpart C, Table C-1 for Distillate Fuel Oil No. 2
- (2) CH₄ and N₂O emission factors per 40 CFR 98, Subpart C, Table C-2 for Petroleum (all fuel types in Table C-1)
- (3) Heat Input based on engineering knowledge.
- (4) Emission Rate (tpy) = Emission Factor (kg/MMBtu) * Heat Input (MMBtu/yr) * 1 metric ton/1,000kg * 1.1023 short ton/metric ton
 $CH_4 \text{ Emission Rate} = 0.003 \text{ kg/MMBtu} * 432 \text{ MMBtu/yr} * 1 \text{ metric ton}/1,000\text{kg} * 1.1023 \text{ short ton/metric ton} = 0.001 \text{ tpy}$
 Where 1.1023 short ton/metric ton per 40 CFR 98, Subpart D, §98.43(a)(1)
- (5) Global Warming potential per 40 CFR 98, Subpart A, Table A-1
- (6) CO₂e (tpy) = Emission Rate (tpy) * Global Warming Potential
 $CH_4 \text{ as CO}_2\text{e} = 0.001 \text{ tpy} * 25 = 0.04 \text{ tpy}$
- (7) Total GHG emission rate = Sum of GHG emission rates
 $Total \text{ GHG} = 35.2 + 0.001 + 0.0003 = 35 \text{ tpy}$
- (8) Total CO₂e emission rate = Sum of CO₂e emission rates
 $Total \text{ CO}_2\text{e} = 35.2 + 0.04 + 0.09 = 35 \text{ tpy}$

US EPA ARCHIVE DOCUMENT

LON C HILL REDEVELOPMENT PROJECT
LON C. HILL, LP

Fugitive GHG Emission Rates Summary Table

EPN	Air Pollutant	Weight % ⁽¹⁾	GHG Emission Rate (tpy) ⁽⁴⁾	Global Warming Potential (100yr.) ⁽³⁾	CO ₂ e Emission Rate (tpy) ⁽⁴⁾
FUGNG-100	CH ₄	91.84%	41.71	25	1,043

Notes:

- (1) Methane content (in wt%) per fuel analysis.
- (2) Annual Emission Rate (tpy) = Service Total Emission Rate (tpy) * CH₄ wt%
 $CH_4 \text{ Annual Emission Rate} = 45.42 \text{ tpy} * 91.84\% = 41.71 \text{ tpy}$
- (3) Global Warming potential per 40 CFR 98, Subpart A, Table A-1 [78 FR 71948, Nov. 29, 2013]
- (6) CO₂e (tpy) = Emission Rate (tpy) * Global Warming Potential
 $CH_4 \text{ as CO}_2\text{e} = 41.71 \text{ tpy} * 25 = 1,043 \text{ tpy}$

Natural Gas Service

Component Type	Component Service	Component Count (cpte) ⁽¹⁾	Emission Factor (lb/hr-cpte) ⁽²⁾	Hours in Service (hr/yr)	Control Efficiency (%) ⁽³⁾	Max. Hourly Emission Rate (lb/hr) ⁽⁴⁾	Annual Emission Rate (tpy) ⁽⁵⁾
Valves	Gas/Vapor	520	0.0089	8,760	0.0%	4.63	20.27
Flanges/Connectors	Gas/Vapor	1460	0.0029	8,760	0.0%	4.23	18.54
Compressors	Gas/Vapor	3	0.5027	8,760	0.0%	1.51	6.61
Service Total						10.37	45.42

Notes:

- (1) Component counts are based on preliminary design information and account for the 2 combined cycle units.
- (2) "SOCMI without ethylene" factors.
- (3) No control efficiency is claimed for natural gas service.
- (3) Max. Hourly Emission Rate (lb/hr) = Component Count (cpte) * Emission Factor (lb/hr-cpte) * (1 - Control Eff%)
 $Max. \text{ Hourly Emission Rate Valves in NG Service} = 520 \text{ cpte} * 0.0089 \text{ lb/hr-cpte} * (1 - 0.0\%) = 4.63 \text{ lb/hr}$
- (4) Annual Emission Rate (tpy) = Max. Hourly Emission Rate (lb/hr) * Hours in Service (hr/yr) * 1ton,2,000lb
 $Annual \text{ Emission Rate Valves in NG Service} = 4.63 \text{ lb/hr} * 8,760 \text{ hr/yr} * 1\text{ton}/2,000\text{lb} = 20.27 \text{ tpy}$

US EPA ARCHIVE DOCUMENT

LON C HILL REDEVELOPMENT PROJECT
LON C. HILL, LP

Electrical Equipment Insulation SF₆ Leaks Emission Rates Summary Table

EPN	Air Pollutant	GHG Emission Rate (tpy) ⁽⁴⁾	Global Warming Potential (100yr.) ⁽²⁾	CO ₂ e Emission Rate (tpy) ⁽³⁾
SF6-100	SF ₆	1.82E-04	22,800	4.15

Notes:

- (1) Annual SF₆ Emission Rate (tpy) = Sum [SF₆ Gas Hold by CB * Annual Leak Rate (%/yr)] * 1ton/2,000lb
 Annual SF₆ Emission Rate = [2GT * 24.25 lb/GT * 0.50% + 1 ST * 24.25 lb/ST * 0.50%] * 1 ton/2,000 lb = 1.82E-04 tpy
- (2) Global Warming potential per 40 CFR 98, Subpart A, Table A-1 [78 FR 71948, Nov. 29, 2013]
- (3) CO₂e (tpy) = Emission Rate (tpy) * Global Warming Potential
 SF₆ as CO₂e = 18.19E-05 tpy * 22,800 = 4.15 tpy

Electrical Equipment Characteristics

	GT Breakers	ST Breakers
No. of Breakers	2	1
GT Breaker Type ⁽¹⁾	TBD	TBD
GT Operating Mechanism ⁽¹⁾	TBD	TBD
SF ₆ Gas Hold by GCB ⁽¹⁾	24.25 lb	24.25 lb
Annual Leak Rate ⁽²⁾	0.50%	0.50%

Notes:

- (1) Gas insulated generator circuit breaker are part of an enclosed system. Per vendor data no SF₆ bleeding should occur. Generator circuit breaker SF₆ content is approximate 11 kg per breaker.
- (2) IEC Standard for new equipment leakage, as published on "SF₆ Leak Rates from High Voltage Circuit Breakers" U.S. EPA Investigates Potential Greenhouse Gas Emission Sources" (J. Blackman, et al.)