

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION**

320 West 4th Street, Suite 200, Los Angeles, CA 90013
(213) 576-6600 • Fax (213) 576-6660
<http://www.waterboards.ca.gov/losangeles/>

**U.S. ENVIRONMENTAL PROTECTION AGENCY
REGION IX**

75 Hawthorne Street, San Francisco, California 94105-3901
Phone (415) 947-8707 • Fax (415) 947-3545
<http://www.epa.gov/region09/>

**ORDER NO. R4-2010-0200
NPDES NO. CA0109991**

**WASTE DISCHARGE REQUIREMENTS AND
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT
FOR THE CITY OF LOS ANGELES, HYPERION TREATMENT PLANT
DISCHARGE TO THE PACIFIC OCEAN**

The following Discharger is subject to State waste discharge requirements and federal NPDES permit requirements, as set forth in this Order/Permit:

Table 1. Discharger Information

| | |
|--|-------------------------------|
| Discharger | City of Los Angeles |
| Name of Facility (and POTW) | Hyperion Treatment Plant |
| Facility (and POTW) Address | 12000 Vista del Mar Boulevard |
| | Playa del Rey, CA 90293 |
| | Los Angeles County |
| The U.S. Environmental Protection Agency and the Los Angeles Regional Water Quality Control Board have classified this discharge as a major discharge. | |

The discharge by the City of Los Angeles from the discharge points identified below is subject to State waste discharge requirements and federal NPDES permit requirements, as set forth in this Order/Permit:

Table 2. Discharge Location

| Discharge Point | Effluent Description | Discharge Point Latitude | Discharge Point Longitude | Receiving Water |
|-------------------------|------------------------------|---------------------------------|----------------------------------|------------------------|
| 001 | Secondary treated wastewater | 33° 55' 06" N | 118° 26' 51" W | Pacific Ocean |
| 002 (Y-shaped diffuser) | Secondary treated wastewater | 33° 54' 43" N | 118° 31' 17" W | Pacific Ocean |
| | | 33° 54' 02" N | 118° 31' 38" W | |

Table 3. Administrative Information for State Order

| | |
|---|---|
| This Order was adopted by the Los Angeles Regional Water Quality Control Board on: | November 4, 2010 |
| This Order shall become effective on: | December 24, 2010 |
| This Order shall expire on: | December 23, 2015 |
| The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than: | 180 days prior to the Order expiration date (Title 40, Code of Federal Regulations, part 122.21(d)) |

I, Samuel Unger, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on **November 4, 2010**.

Samuel Unger

Samuel Unger, Executive Officer

Table 4. Administrative Information for Federal Permit

| | |
|---|---|
| This Permit was issued by the U.S. Environmental Protection Agency, Region IX on: | |
| This Permit shall become effective on: | <i>DECEMBER 24, 2010</i> |
| This Permit shall expire on: | <i>DECEMBER 23, 2015</i> |
| The Discharger shall submit, in accordance with 40 CFR 122.21(d), a new application at least 180 days before: | 180 days prior to the Order expiration date (Title 40, Code of Federal Regulations, part 122.21(d)) |

I, Alexis Strauss, do hereby certify that this Permit with all attachments is a full, true, and correct copy of an NPDES permit issued by the U.S. Environmental Protection Agency, Region IX, on *22 November 2010*.

Alexis Strauss

Alexis Strauss, Water Division Director

Table of Contents

| | |
|--|----|
| I. Facility Information..... | 4 |
| II. Findings..... | 5 |
| III. Discharge Prohibitions..... | 20 |
| IV. Effluent Limitations, Performance Goals, and Discharge Specifications..... | 20 |
| V. Mass Emission Caps..... | 31 |
| VI. Receiving Water Limitations..... | 31 |
| VII. Provisions..... | 35 |
| VIII. Compliance Determination..... | 50 |

List of Tables

| | |
|--|----|
| Table 1. Discharger Information..... | 1 |
| Table 2. Discharge Location..... | 1 |
| Table 3. Administrative Information for State Order..... | 2 |
| Table 4. Administrative Information for Federal Permit..... | 2 |
| Table 5. Facility Information..... | 4 |
| Table 6. Basin Plan Beneficial Uses..... | 12 |
| Table 7. Ocean Plan Beneficial Uses..... | 13 |
| Table 8. Effluent Limitations and Performance Goals for Discharge Point 002..... | 21 |
| Table 9. Effluent Limitations for Discharge Point 001..... | 24 |

List of Attachments

| | |
|---|-----|
| Attachment A – Definitions..... | A-1 |
| Attachment B – Map..... | B-1 |
| Attachment C-1 – Flow Schematic..... | C-1 |
| Attachment C-2 – Map of Hyperion Service Area..... | C-2 |
| Attachment D – Standard Provisions..... | D-1 |
| Attachment E – Monitoring and Reporting Program (MRP)..... | E-1 |
| Attachment F – Fact Sheet..... | F-1 |
| Attachment G – Generic Toxicity Reduction Evaluation (TRE) Workplan (POTW)..... | G-1 |
| Attachment H – Biosolids and Sludge Management..... | H-1 |
| Attachment I – Pretreatment Program Requirements..... | I-1 |

I. FACILITY INFORMATION

The following Discharger is subject to the waste discharge requirements set forth in this Order/Permit:

Table 5. Facility Information

| | |
|---|--|
| Discharger | City of Los Angeles |
| Name of Facility | Hyperion Treatment Plant |
| Facility Address | 12000 Vista del Mar Boulevard |
| | Playa del Rey, CA 90293 |
| | Los Angeles County |
| Facility Contact, Title, and Phone | Steven Fan, Sanitation Wastewater Manager III, (310) 648-5168 |
| Mailing Address | Same as the Facility Address |
| Type of Facility | Publicly Owned Treatment Works |
| Facility Design Flow | 450 Million Gallons per Day (MGD) 30-day (monthly) average daily dry weather design capacity for secondary treatment and 850 MGD wet weather peak hydraulic capacity |

II. FINDINGS

The California Regional Water Quality Control Board, Los Angeles Region (hereinafter Regional Water Board) and U.S. Environmental Protection Agency, Region IX (hereinafter USEPA), find:

A. Consent Decree and Legal Issues

1. The operations and discharges from the Hyperion Treatment Plant and Hyperion collection system are also regulated under the following enforcement actions:
 - a. Amended Consent Decree entered on February 19, 1987, in United States and State of California v. City of Los Angeles, No. CV 77-3047-HP (C.D. Cal.);
 - b. Settlement Agreement, Los Angeles Superior Court Case No. C 665238, dated January 29, 1990, in State of California v. City of Los Angeles; and
 - c. Regional Water Board Cease and Desist Order 98-073 adopted on September 14, 1998, amended by Order No. 00-128 adopted on August 31, 2000.
2. In 1987, the City entered into an Amended Consent Decree (No. CV 77-3047-HP) with USEPA and the Regional Water Board. The Amended Consent Decree required the City under time schedules to undertake the following:
 - a. Eliminate the discharge of sewage sludge into the Pacific Ocean from Hyperion Treatment Plant by December 31, 1987 (status: completed);
 - b. Comply with interim effluent limits (status: interim limits are not applicable as of January 1, 1999);
 - c. Complete construction and begin operation of the Hyperion Energy Recovery System by June 30, 1989 (status: completed, but determined to be a technological failure and abandoned);
 - d. Achieve and thereafter maintain compliance with full secondary treatment at Hyperion Treatment Plant by December 31, 1998 (status: completed and achieved compliance before the deadline);
 - e. Prepare a storm water pollution reduction study and implement the recommended measures thereof (status: completed).
3. On June 7, 1991, the United States and the State of California filed a supplemental complaint under the existing Consent Decree CV 77-3047-HP (C.D. Cal.) for alleged pretreatment violations against the City. Settlement of the complaint had been concluded and modification to the Consent Decree was

entered into court records on August 7, 2000. The settlement requires the City to implement the Westside Water Recycling Extension Project and the Santa Monica Bay Storm Drain Low-Flow Diversion Project. The Santa Monica Urban Runoff Recycling Facility (SMURRF), completed in 2000, is owned and operated by the City of Santa Monica. As the first full-scale, dry-weather runoff recycling facility in the U.S., SMURRF reclaims dry-weather run-off from storm drains and treats the water for reuse in landscape irrigation and toilet flushing. Since the City of Los Angeles contributes about half of the runoff treated at SMURRF, the City of Los Angeles pays for half of the capital and operations and maintenance costs of SMURRF, pursuant to an agreement with the City of Santa Monica.

4. In October 1987, the California Attorney General, on behalf of the Regional Water Board, filed a complaint with the Los Angeles Superior Court (Case No. C 665238) for civil penalties regarding unpermitted discharges to Discharge Point 001 and raw sewage overflows to surface waters from the Hyperion collection system. A settlement agreement was entered into on January 29, 1990. In lieu of civil penalties, the City was required to implement 23 projects to improve and enhance its collection system and benefit the waters in the Greater Los Angeles Area. Twenty two of the 23 Settlement Agreement projects were completed. The remaining project deals with the Los Angeles Zoo Wastewater Treatment Facility. Two of the original three elements of the Zoo project (construction of the retention basin and pump station for collection of the Zoo's wastewater and diversion to the North Outfall Sewer force main) were completed in 1995. The City proposes to substitute Best Management Practices (BMPs) for the storm water peripheral drainage system, the third element of the original design concept. After reviewing the study, the Regional Water Board rejected the City's proposal because the proposed BMPs cannot achieve the objectives of the original Settlement Agreement. In a letter dated November 5, 2008, the Regional Water Board approved the Fremont High School Stormwater Improvements Project (Fremont Project) as a substitute for the remaining project, the Los Angeles Zoo Perimeter Drain System (PDS). The Regional Water Board agreed that the PDS has ceased to be necessary due to the completion of the North East interceptor Sewer and East Central Interceptor Sewer. The Fremont Project includes the implementation of the following five BMPs- Stormwater Diversion, Pollutant Settlement, Sediment Forebay, Dry Extended Detention/Retention Basin, and "Smart" (programmable) Irrigation System.
5. Sanitary sewer overflows (SSO) have been a recurring problem in certain areas of the City; in particular, in the South Central area, where sewers do not have adequate capacity to absorb inflow and infiltration that occurs during wet weather. For the entire City, between the wet weather period of February 3, 1998 through May 14, 1998, there were 99 separate sanitary overflows resulting in 44 million gallons of raw sewage released. On September 14, 1998, the Regional Water Board issued Cease and Desist Order (CDO) No. 98-073 to the City, amended by CDO No. 00-128 adopted on August 31, 2000. The CDO requires the City to provide adequate capacity to its wastewater collection system by constructing

additional sewer alignments and/or upgrading the existing sewer system over a seven-year period (1998 to 2005). Additionally, on August 5, 2004, the United States, the State of California, Santa Monica Baykeeper, a coalition of community groups and the City of Los Angeles lodged a settlement that would resolve the parties' Clean Water Act and Porter-Cologne Act litigation regarding the City of Los Angeles' SSOs and sewage odors. This settlement-underwent public review and comment. The Settlement Agreement and Final Order were filed on October 28, 2004, entered by the District Court on October 29, 2004, and are now being implemented. The Settlement Agreement and Final Order establish a ten-year program designed to reduce SSOs and sewage odors to the maximum extent feasible.

- B. Background.** The City of Los Angeles (hereinafter Discharger) is currently discharging pursuant to Order No. 2005-0020 and National Pollutant Discharge Elimination System (NPDES) Permit (CA0109991), which was adopted on April 7, 2005. The Discharger submitted a Report of Waste Discharge, dated October 27, 2009, and applied for an NPDES permit renewal to discharge up to 450 MGD of disinfected (Discharge Point 001) and undisinfected (Discharge Point 002) secondary-treated municipal wastewater from Hyperion Treatment Plant (hereinafter, HTP or Facility and its appurtenances), to the Pacific Ocean within Santa Monica Bay, a water of the United States. The application for the NPDES permit renewal and Report of Waste Discharge was deemed complete on December 23, 2009.

For the purposes of this Order/Permit, references to the "discharger" or "permittee" in applicable federal and State laws, regulations, plans, or policies are held to be equivalent to references to the Discharger herein.

- C. Facility Description.** The Discharger owns and operates its regional collection system and treatment facilities, the Hyperion Treatment Plant, and outfalls. The HTP is a publicly owned treatment works (POTW). In 2009, the HTP treated an average inflow of 312 MGD and discharged an average effluent flow of 275 MGD. Approximately 37 MGD of the secondary effluent was sent to West Basin Water Recycling Facility for advanced treatment and reuse.

The treatment system consists of primary and secondary treatments. Preliminary and primary wastewater treatments consist of screening, grit removal, and primary sedimentation with coagulation and flocculation. In secondary treatment, the primary effluent is biologically treated in a high purity oxygen-activated sludge process comprised of a cryogenic oxygen plant, nine secondary reactor modules and 36 secondary clarifiers. Each secondary reactor module is designed to handle 50 MGD of flow, which results in a total treatment capacity of 450 MGD producing secondary effluent. After clarification, secondary effluent is discharged into Santa Monica Bay. Discharge up to 325 MGD flows by gravity to the outfall, or is pumped at the Effluent Pumping Plant when flows exceed 325 MGD.

Solid fractions recovered from wastewater treatment processes include grit, primary screenings, primary sludge and skimmings, thickened waste activated sludge, digested sludge screenings and digester cleaning solids. The fine solids (grit, primary screenings, digested sludge screenings, digester cleaning solids) that consist of primary inorganic materials are hauled away to landfills. The remaining solid fractions (primary sludge and skimmings, thickened waste activated sludge) are anaerobically digested onsite. The digested solids are screened and dewatered using centrifuges. Since January 1, 2003, the Hyperion Treatment Plant has implemented full thermophilic digestion to generate Class A "EQ" biosolids. The biosolids (treated sewage sludge) are beneficially reused offsite for land application and composting projects. The digester gas is cleaned and a major part of the gas is currently exported to the Los Angeles Department of Water and Power's Scattergood Steam Generating Plant, located immediately adjacent to the Hyperion Treatment Plant. The exported digester gas is used as fuel in the generation of electricity. In return, the generating plant provides steam for digester heating for the Hyperion Treatment Plant. During interruption in the export of steam from the Scattergood Steam Generation Plant, digester gas can be used as fuel for in-plant boilers that provide steam to heat the anaerobic digesters. Any remaining non-exported digester gas may be flared, if necessary, and is regulated under a flare operation permit from the South Coast Air Quality Management District (AQMD). Attachment B provides a map of the area around the facility.

A schematic of the Hyperion Treatment Plant's wastewater flow is presented in Attachment C-1.

The HTP is part of a joint outfall system commonly known as the Hyperion Treatment System, which consists of the wastewater collection system, the Hyperion Treatment Plant and three upstream wastewater treatment plants: Donald C. Tillman Water Reclamation Plant (Tillman WRP), Los Angeles-Glendale Water Reclamation Plant (LAGWRP), and Burbank Water Reclamation Plant (Burbank WRP) (owned and operated by a contract city), and outfalls. The Hyperion Treatment System collects, treats, and disposes of sewage from the entire City (except the Wilmington-San Pedro Area, the strip north of San Pedro, and Watts) and from a number of cities and agencies (see Contract Cities and Agencies) under contractual agreements. The Contract Cities and Agencies operate their respective collection systems that are tributary to the City's main trunk lines. Some Contract Cities and Agencies also perform nondomestic source control activities. Approximately, 85% of the sewage and commercial/industrial wastewater comes from the City of Los Angeles. The remaining 15% comes from the Contract Cities and Agencies. The Hyperion Treatment System Service Area includes 6,138 miles of public sewers, 24 pump stations, 18 miles of force mains, 141,357 maintenance holes and serves a population of 3,954,000 in the City of Los Angeles and other Contract Agencies (see Attachment C-2, Map of Hyperion Treatment System Service Area).

Contract Cities and Agencies

- | | |
|--|---|
| a. Aneta Street Tax Zone | n. Federal Office Building |
| b. Army Reserve Center | o. City of Glendale |
| c. Army Reserve Training | p. Karl Holton Camp |
| d. Barrington Post Office | q. Las Virgenes Municipal Water District |
| e. City of Beverly Hills | r. Marina Del Rey |
| f. City of Burbank | s. City of San Fernando |
| g. California National Guard (Federal Avenue Armory) | t. City of Santa Monica |
| h. L.A. County Sanitation District #4 (W. Hollywood) | u. Terminal Island Treatment Service Area |
| i. L.A. County Sanitation District #5 (Inglewood) | v. Triunfo County Sanitation District |
| j. L.A. County Sanitation District #16 (Alhambra, Pasadena, S. Pasadena) | w. Universal City |
| k. L.A. County Sanitation District 27 (Sunset Mesa) | x. Veterans Memorial Park |
| l. City of Culver City | y. Veterans Administration - Sawtelle |
| m. City of El Segundo | z. West Los Angeles Community College |

Sludge from the City's two upstream plants (i.e., Tillman WRP and LAGWRP) is returned to the wastewater collection system and flows to the Hyperion Treatment Plant for treatment. Discharges from Tillman WRP and LAGWRP are regulated by Order No. R4-2010-0060 (NPDES No. CA0056227) and Order No. R4-2010-0059 (NPDES No. CA0053953), respectively. In addition, sludge generated from the Burbank WRP is returned to the City of Burbank sewer system for treatment at the Hyperion Treatment Plant. The influent to the Burbank WRP can be diverted/bypassed to the Hyperion Treatment Plant during periods of emergency. Discharges from the Burbank WRP are regulated under Order No. R4-2010-0058 (NPDES No. CA0055531).

Currently, the HTP accepts dry weather urban runoff that is diverted from storm drains into the City's collection system year-round via the low flow diversion (LFD) facilities except for storm events that generate greater than 0.1 inch of storm runoff and three days following the storm event, during which time LFD facilities are turned off. The City is currently upgrading the eight LFD facilities to equip the facilities with the necessary back up electrical, mechanical, telemetry, and the required pumping capacity to minimize down-time. The LFD facilities' operation are in accordance with the six-year schedule for bacteria concentration during winter dry weather, contained in the Santa Monica Bay Beaches Dry-weather Bacteria TMDL (Resolution No. 02-004 and Resolution No. 2002-022) adopted by the Regional Water Board.

Water Reclamation. A small fraction (approximately 37 MGD in 2009) of the HTP's secondary effluent is sent to West Basin Water Recycling Facility (West Basin Facility) for advanced treatment and reuse. The West Basin Municipal Water District (West Basin) operates the West Basin Facility in El Segundo. West Basin is

contractually entitled to receive up to 70 MGD of secondary effluent from HTP. West Basin Facility provides tertiary treatment and/or advanced treatments such as microfiltration and reverse osmosis (RO) to the Hyperion secondary effluent to produce Title 22 high purity recycled water. Title 22 recycled water is used for beneficial irrigation, industrial applications including cooling water and boiler feed water, and other purposes. The RO-treated recycled water is primarily injected into the West Coast Basin Barrier Project to control seawater intrusion.

The waste brine from West Basin Facility is discharged to the ocean through Hyperion's five-mile outfall (Discharge Point 002) via a waste brine line from West Basin Facility. Although the waste brine is discharged through Hyperion's outfall, it is regulated under separate waste discharge requirements and NPDES permit.

The Hyperion Treatment Plant ceased the irrigation use of in-plant chlorinated secondary treated wastewater in January 1999. Instead, the plant started using tertiary recycled water from West Basin Facility in August 1999.

Description of Outfalls. The Hyperion Treatment Plan has three ocean outfalls. However, only two outfall points (i.e., 001 and 002) are authorized discharge points for treated wastes to the Pacific Ocean. The three ocean outfalls are described as follows:

Discharge Point 001. This is commonly referred to as the "one-mile outfall". It is a 12-foot diameter outfall terminating approximately 5,364 feet (1.6 kilometers (km)) west-southwest of the treatment plant at a depth of approximately 50 feet (15 meters (m)) below the ocean surface (Latitude 33° 55.06', Longitude 118° 26.51'). This outfall is permitted for emergency discharge of chlorinated secondary treated effluent during extremely high flows, and preventative maintenance, such as routine opening and closing the outfall gate valve(s) for exercising and lubrication. However, during intense storms or storms associated with plant power outages, direct discharge of undisinfected storm water overflow from the HTP is also permitted at this outfall. This Order/Permit requires the City to notify the Regional Water Board and USEPA in advance of any planned preventative maintenance that results in discharges through Discharge Point 001.

Discharge Point 002. This is commonly referred to as the "five-mile outfall". It is a 12-foot diameter outfall terminating approximately 26,525 feet (8.1 km) west-southwest of the treatment plant at a depth of approximately 187 feet (57 m) below the ocean surface. This outfall is located north of Discharge Point 001 and ends in a "Y" shaped diffuser consisting of two 3,840-foot legs (Latitude 33° 54.72', Longitude 118° 31.29') (North terminus of wye structure – Latitude 33° 54.43', Longitude 118° 31.17'; South terminus of wye structure – Latitude 33° 54.02', Longitude 118° 31.38'). This is the only outfall permitted for the routine discharge of undisinfected secondary treated effluent.

Outfall No. 003. This is a 20-inch diameter outfall terminating approximately 35,572 feet (10.8 km) west of the treatment plant, at the head of a submarine canyon at a

depth of approximately 300 feet (91m) below the ocean surface (Latitude 33° 55.62' N, Longitude 118° 33.18' W). This outfall had been used to discharge sludge. Under the 1987 amended Consent Decree No. CV77-3047-HP, this outfall was deactivated in November 1987 when sludge discharge to the ocean was terminated.

Near the head of this outfall, a spool piece was removed and the discharge pipe was blind-flanged to prevent any possible discharge of sewage or sludge into the Pacific Ocean. This outfall has not been maintained since it was taken out of service. Any discharge from this outfall is prohibited.

- D. Legal Authorities.** This Order/Permit is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by USEPA and Chapter 5.5, Division 7 of the California Water Code (commencing with Section 13370). This Order shall serve as a jointly issued NPDES permit for point source discharges from this POTW to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the California Water Code (commencing with section 13260). Although Discharge Point 002 is beyond the limit of State-regulated ocean waters, effluent plume migration into State waters warrants joint regulation of the discharge by USEPA and the Regional Water Board.
- E. Background and Rationale for Requirements.** The Regional Water Board and USEPA developed the requirements in this Order/Permit based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for Order/Permit requirements, is hereby incorporated into this Order/Permit and constitutes part of the Findings for this Order/Permit. Attachments A through I are also incorporated into this Order/Permit.
- F. California Environmental Quality Act (CEQA).** Under California Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of the CEQA, Public Resources Code sections 21100-21177.
- G. Technology-based Effluent Limitations.** Section 301(b) of the CWA and implementing regulations at part 125.3, title 40 of the Code of Federal Regulations¹ (hereinafter 40 CFR), require that NPDES permits include limitations which meet applicable technology-based requirements, at minimum. The discharge authorized by this Order/Permit must meet minimum federal technology-based requirements for POTWs at 40 CFR 133. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet (Attachment F).
- H. Water Quality-Based Effluent Limitations.** Section 301(b) of the CWA and 40 CFR part 122.44(d) require that permits include limitations more stringent than applicable technology-based requirements where necessary to achieve water quality standards and State requirements. 40 CFR part 122.44(d)(1)(i) requires that permits

¹ All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated and will be abbreviated as "40 CFR part number".

include water quality-based effluent limitations (WQBELs) for all pollutants, which are or may be discharged at levels having the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives or criteria within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric objective or criterion for the pollutants, WQBELs must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed State criterion or policy interpreting the State’s narrative criterion, supplemented with other relevant information, as provided in 40 CFR part 122.44(d)(1)(vi). USEPA has applied CWA section 403(c) and 40 CFR part 125, Subpart M, following 40 CFR 122.

- I. **Los Angeles Water Quality Control Plan.** On June 13, 1994, the Regional Water Board adopted a water quality control plan for the Los Angeles Region (hereinafter Basin Plan), as amended, that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for the Pacific Ocean. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Basin Plan beneficial uses applicable to the Pacific Ocean are shown in Table 6:

Table 6. Basin Plan Beneficial Uses

| Discharge Point | Receiving Water | Beneficial Use(s) |
|-----------------|---|---|
| 001 | Dockweiler Beach (Hydrologic Unit 405.12) | <u>Existing:</u> Industrial service supply (IND), navigation (NAV), water contact recreation (REC-1), non-contact water recreation (REC-2), commercial and sport fishing (COMM), marine habitat (MAR), and wildlife habitat (WILD). <u>Potential:</u> Spawning, reproduction, and/or early development (SPWN). |
| | Pacific Ocean Nearshore Zone | <u>Existing:</u> IND, NAV, REC-1, REC-2, COMM, MAR, WILD, preservation of biological habitats (BIOL), RARE, migration of aquatic organisms (MIGR), SPWN, and SHELL. <u>Potential:</u> None. |
| 001, 002 | Pacific Ocean Offshore Zone | <u>Existing:</u> IND, NAV, REC-1, REC-2, COMM, MAR, WILD, RARE, MIGR, SPWN, and SHELL. <u>Potential:</u> None. |

Requirements of this Order/Permit implement the Basin Plan.

- J. Impaired Water Bodies on CWA 303(d) List.** On June 28, 2007, USEPA approved California’s 2006 section 303(d) List of Water Quality Limited Segments. The list (hereinafter referred to as the 303(d) list) identifies water bodies where water quality standards are not expected to be met after implementation of technology-based effluent limitations by point sources (water quality-limited water bodies).

Santa Monica Bay (Offshore and Nearshore) is on the 303(d) list for the following pollutants/stressors, from point and non-point sources: DDT (dichlorodiphenyltrichloroethane) (tissue & sediment), debris, fish consumption advisory, PCBs (polychlorinated biphenyls) (tissue & sediment), and sediment toxicity. This Order/Permit continues to prescribe WQBELS for DDT and PCBs, as described in Finding 54 of the 2005 Order/Permit.

- K. California Thermal Plan.** In 1972, the State Water Board adopted the *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (hereinafter Thermal Plan), as amended. This plan contains temperature objectives for coastal and inland surface waters. Requirements of this Order/Permit implement the Thermal Plan.
- L. California Ocean Plan.** In 1972, the State Water Board adopted the *Water Quality Control Plan for Ocean Waters of California, California Ocean Plan* (hereinafter Ocean Plan), as amended. The latest amendment became effective on February 14, 2006. The Ocean Plan is applicable, in its entirety, to point source discharges to the ocean waters of the State. Ocean Plan beneficial uses applicable to ocean waters of the State are shown in Table 7.

Table 7. Ocean Plan Beneficial Uses

| Discharge Point | Receiving Water | Beneficial Use(s) |
|-----------------|-----------------|--|
| 001, 002 | Pacific Ocean | IND, REC-1, REC-2, NAV, COMM, mariculture, preservation and enhancement of designated Areas of Special Biological Significance (ASBS), RARE, MAR, MIGR, SPWN, and SHELL. |

To protect the beneficial uses in ocean water, the Ocean Plan establishes water quality objectives and a program implementation. Requirements of this Order/Permit implement the Ocean Plan.

- M. Santa Monica Bay Restoration Plan.** The Hyperion Treatment Plant discharges to Santa Monica Bay, one of the most heavily used recreational areas in California. Recognizing the importance of the Bay as a national resource, the State of California and USEPA nominated and Congress included Santa Monica Bay in the National Estuary Program. This led to the formation of the Santa Monica Bay Restoration Project (currently named Santa Monica Bay Restoration Commission) that developed the Bay Restoration Plan (BRP), which serves as a blueprint for restoring and enhancing the Bay. The Regional Water Board plays a lead role in the implementation of the BRP. Three of the proposed priorities of the BRP are

reduction of pollutants of concern at the source (including municipal wastewater treatment plants), attainment of full secondary treatment at the City of Los Angeles' Hyperion Treatment Plant and the County Sanitation Districts of Los Angeles County's Joint Water Pollution Control Plant, and implementation of the mass emission approach for discharges of pollutants to the Bay.

- N. Alaska Rule.** USEPA has revised its regulation that specifies when new and revised State and Tribal water quality standards (WQS) become effective for CWA purposes (40 CFR part 131.21; 65 Fed. Reg. 24641 (April 27, 2000)). Under the revised regulation (hereinafter Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000 must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000 may be used for CWA purposes, whether or not approved by USEPA.
- O. Stringency of Requirements for Individual Pollutants.** This Order/Permit contains restrictions on individual pollutants that are no more stringent than required by the federal CWA. Individual pollutant restrictions consist of technology-based effluent limitations and water quality-based effluent limitations. The technology-based effluent limitations consist of restrictions on biochemical oxygen demand (5-day) (BOD₅), total suspended solids (TSS), and pH, and percent removal of BOD₅ and TSS, which implement the minimum, applicable federal technology-based requirements for POTWs. Also, effluent limitations consisting of restrictions on oil and grease, settleable solids, and turbidity more stringent than federal technology-based requirements are necessary to implement State treatment standards in Table A of the Ocean Plan. Water quality-based effluent limitations consisting of restrictions on copper, chlorine residual, ammonia (as nitrogen), acute toxicity, chronic toxicity, beryllium, chlordane, DDT, PAHs, PCBs, and TCDD equivalents have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. Collectively, restrictions on individual pollutants in this Order/Permit are no more stringent than required by the CWA.
- P. Antidegradation Policy.** 40 CFR part 131.12 requires that the State water quality standards include an antidegradation policy consistent with the federal antidegradation policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. This resolution incorporates the federal antidegradation policy, where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. As discussed in detail in the Fact Sheet (Attachment F), the permitted discharge is consistent with the antidegradation provisions of 40 CFR part 131.12 and State Water Board Resolution No. 68-16.

- Q. Anti-Backsliding Requirements.** CWA sections 402(o)/303(d) and 40 CFR part 122.44(l) prohibit backsliding and require effluent limitations, permit conditions, and standards in a reissued NPDES permit to be as stringent as those in the previous permit, with some exceptions where limitations and conditions may be relaxed. Some effluent limitations in this Order/Permit are less stringent than those in the previous Order/Permit. As discussed in detail in the Fact Sheet (Attachment F), this relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.

This Order/Permit is consistent with State and federal antidegradation policies in that it does not authorize a change in pollutant mass emission rates, nor does it authorize a relaxation in the manner of treatment of the discharge. Pollutant limit mass emission rates continue to be based on the design flow rate of the treatment plant under the 1994 permit of 420 MGD. Although the design flow rate of the treatment plant has increased to 450 MGD, this increase has been accompanied by a significant improvement in the level of treatment necessary to achieve full secondary treatment. As a result, both the quantity of discharged pollutants and quality of the discharge are expected to remain relatively constant or improve during this permit term, consistent with antidegradation policies. In conformance with reasonable potential analysis procedures identified in State Water Board and USEPA documents, effluent limitations for some constituents are not carried forward in this Order/Permit because there is not presently reasonable potential for the constituents to cause or contribute to an exceedance of water quality standards. Without reasonable potential, there is no longer a need to maintain prior WQBELs under NPDES regulations, antibacksliding provisions, and antidegradation policies. The accompanying monitoring and reporting program requires continued data collection and if monitoring data show reasonable potential for a constituent to cause or contribute to an exceedance of water quality standards, the Order/Permit will be reopened to incorporate WQBELs. Such an approach ensures that the discharge will adequately protect water quality standards for designated beneficial uses and conform with antidegradation policies and antibacksliding provisions.

- R. Endangered Species Act.** This Order/Permit does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the federal Endangered Species Act (16 U.S.C. sections 1531 to 1544). This Order/Permit requires compliance with effluent limitations, receiving water limitations, and other requirements to protect the beneficial uses of waters of the State. The Discharger is responsible for meeting all requirements of the applicable Endangered Species Act.
- S. Monitoring and Reporting.** 40 CFR part 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. California Water Code sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program

(Attachment E) establishes monitoring and reporting requirements to implement federal and State requirements.

- T. Standard and Special Conditions.** Standard Provisions that apply to all NPDES permits, in accordance with 40 CFR part 122.41, and additional provisions that apply to POTWs, in accordance with 40 CFR part 122.42, are provided in Attachment D. The Regional Water Board and USEPA have also included in this Order/Permit special provisions applicable to the Discharger. The rationale for the special provisions contained in this Order/Permit is provided in the Fact Sheet (Attachment F).
- U. Sanitary Sewer Overflows.** The State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order No. 2006-0003-DWQ (General Order) on May 2, 2006, as amended. The General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions. Furthermore, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating SSOs. The Discharger's collection system is part of the POTW that is subject to this Order/Permit. The Discharger must comply with both the General Order and this Order/Permit.
- V. Sewage Sludge/Biosolids Requirements.** Section 405 of the CWA and implementing regulations at 40 CFR 503 require that producers of sewage sludge/biosolids meet certain reporting, handling, and use or disposal requirements. The State has not been delegated the authority to implement this program; therefore, USEPA is the implementing agency. This Order/Permit contains sewage sludge/biosolids requirements pursuant to 40 CFR 503 that are applicable to the Discharger.
- W. Pretreatment.** In compliance with 40 CFR 403, the City developed a Pretreatment Program for POTWs owned and operated by the City. The City's Pretreatment Program was approved by USEPA on June 30, 1983. In 1989, USEPA delegated the authority to administer pretreatment programs in California to the State and Regional Water Boards. Thus, this Regional Water Board became the approval authority for pretreatment programs in Los Angeles and Ventura Counties.

This Order/Permit includes the City's approved Pretreatment Program and requires the City to continue implementation and control of the Program throughout the Hyperion Treatment Plant's service area, including contributing jurisdictions. The POTW, as Control Authority, may exercise its authority over the entire service area directly, as provided by state law, or may elect to enter into contracts or other multi-jurisdictional agreements with the contributing jurisdictions. In case the POTW elects to enter into inter-jurisdictional agreements, the POTW must ensure that discharges

received from entities outside of its political boundaries are regulated to the same extent as are the discharges from within its political boundaries.

The City applies one set of local limits to all discharges from the Hyperion Treatment Plant, Tillman WRP, and LAG WRP to the Hyperion Treatment System. Burbank WRP is also part of the Hyperion Treatment System.

- X. Federal Permit Renewal Contingency.** The Discharger's federal permit renewal is contingent upon determination by the U.S. Fish and Wildlife Service and NOAA National Marine Fisheries Service that the proposed discharge is consistent with the: (1) federal Endangered Species Act; (2) Magnuson-Stevens Fishery Conservation and Management Act (MSA); and (3) the Regional Water Board's certification/concurrence that the discharge will comply with applicable State water quality standards.

USEPA's reissuance of NPDES permit No. CA0109991 to the City of Los Angeles for Hyperion Treatment Plant is subject to requirements of MSA and ESA. In May 2010, USEPA requested updated information related to: (1) essential fish habitat and managed and associated species, and (2) threatened and endangered species and their designated critical habitats, in the vicinity of the Hyperion outfalls from the National Marine Fisheries Service and the U.S. Fish and Wildlife Service (collectively, the Services). Based on this and other relevant information, USEPA is currently evaluating whether there are effects on essential fish habitat and managed and associated species protected under the MSA or on threatened and endangered species and their designated critical habitats protected under the ESA. Based on the outcome of this analysis, USEPA may engage in consultation with the Services during, and subsequent to, this permit reissuance. USEPA may decide that changes to this permit are warranted based on the results of the completed consultation, and a reopener provision to this effect has been included in the Order/Permit.

Joint issuance of an NPDES permit which incorporates both federal requirements and State waste discharge requirements will serve as the State's concurrence that the discharge complied with State water quality standards. The California Coastal Commission has indicated that it is not necessary to obtain a consistency certification pursuant to the Coastal Zone Management Act for the issuance of a federal NPDES permit containing secondary treatment standards.

- Y. Performance Goals.** Chapter III, section F.2, of the 2005 Ocean Plan allows the Regional Water Board to establish more restrictive water quality objectives and effluent limitations than those set forth in the Ocean Plan as necessary for the protection of the beneficial uses of ocean waters.

Pursuant to this provision and to implement the recommendation of the Water Quality Advisory Task Force (*Working Together for an Affordable Clean Water Environment, A final report presented to the California Water Quality Control Board, Los Angeles Region by Water Quality Advisory Task Force, September 30, 1993*) that was adopted by the Regional Water Board on November 1, 1993, performance

goals that are more stringent than those based on Ocean Plan objectives are prescribed in this Order/Permit. This approach is consistent with the antidegradation policy in that it requires the Discharger to maintain its treatment level and effluent quality, recognizing normal variations in treatment efficiency and sampling and analytical techniques. However, this approach does not address substantial changes in treatment plant operations that could significantly affect the quality of the treated effluent.

The performance goals are based upon the actual performance of the HTP and are specified only as an indication of the treatment efficiency of the Facility. Performance goals are intended to minimize pollutant loading (primarily for toxics) while maintaining the incentive for future voluntary improvement of water quality, whenever feasible, without the imposition of more stringent limits based on improved performance. They are not considered as limitations or standards for the regulation of the discharge from the treatment facility. The Executive Officer may modify any of the performance goals if the Discharger requests and has demonstrated that the change is warranted. The methodology for calculating performance goals is described in the Fact Sheet (Attachment F).

Z. Mass Emission Benchmarks. To address the uncertainty due to potential increases in toxic pollutant loadings from the Hyperion Treatment Plant discharge to the marine environment during the five-year permit term and to establish a framework for evaluating the need for an antidegradation analysis to determine compliance with State and federal antidegradation requirements at the time of permit reissuance, 12-month average mass emission benchmarks have been established for effluent discharged through the 5-mile outfall (Discharge Point 002). These mass emission benchmarks are not enforceable water quality based effluent limitations. They may be re-evaluated and revised during the five-year permit term. The mass emission benchmarks (in metric tons per year; MT/yr) for the Hyperion Treatment Plant discharge were determined using January 1999 through June 2004 effluent concentrations and the Discharger's projected end-of-permit flow of 400 MGD. If only one effluent data point was detected or if all effluent data points were nondetect, the pollutant concentration associated with the maximum method detection limit from January 2003 to June 2004 was used to calculate the mass emission benchmark. If two or more effluent data points were detected, the pollutant concentration associated with the 95th percentile (calculated in accordance with Regional Water Board procedures) was used to calculate the mass emission benchmark. Exceptions to this are mass emission benchmarks for copper, lead, silver and zinc which are based directly on Mass Emission Caps for these pollutants of concern in Santa Monica Bay, established by the Regional Water Board. The methodology for calculating mass emission benchmarks is described in the Fact Sheet (Attachment F).

AA. Notification of Interested Parties. The Regional Water Board and USEPA have notified the Discharger and interested agencies and persons of their intent to jointly issue State Waste Discharge Requirements and a federal NPDES permit for the discharge and have provided an opportunity to submit their written comments and

recommendations by the close of the Regional Water Board/USEPA joint public hearing during the regularly scheduled Regional Water Board meeting on July 8th and 9th, 2010. Also, the Regional Water Board and USEPA have provided an opportunity to submit oral comments and recommendations at this joint public hearing. Details of these notifications are provided in the Fact Sheet and the joint public notice for this Order/Permit.

BB. Consideration of Public Comment. The Regional Water Board and USEPA heard and considered all written and oral comments pertaining to the discharge.

THEREFORE, IT IS HEREBY ORDERED that this Order/Permit supersedes Order No. R4-2005-0020, except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the California Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order/Permit.

III. DISCHARGE PROHIBITIONS

A. Ocean Plan Discharge Prohibitions

1. Discharge of any radiological, chemical or biological warfare agent or high-level radioactive waste into the ocean is prohibited.
2. Waste shall not be discharged to designated Areas of Special Biological Significance.
3. Pipeline discharge of sludge to the ocean is prohibited by federal law; the discharge of municipal and industrial waste sludge directly to the ocean, or into waste stream that discharges to the ocean is prohibited by the Ocean Plan. Discharge of sludge digester supernatant directly to the ocean, or to a waste stream that discharges to the ocean without further treatment, is prohibited. The treatment, use and disposal of sewage sludge shall be carried out in the manner found to have the least adverse impact on the total natural and human environment.
4. The bypassing of untreated wastes containing concentrations of pollutants in excess of those of Table A or Table B of the Ocean Plan to the ocean is prohibited.

B. The bypassing of untreated or partially treated wastes to the ocean is prohibited.

IV. EFFLUENT LIMITATIONS, PERFORMANCE GOALS, AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations and Performance Goals – Discharge Points 002 and 001

Effluent limitations for Discharge Points 002 and 001 are specified below. The discharge of an effluent with constituents in excess of effluent limitations is prohibited.

Performance goals for Discharge Point 002 are prescribed below. The listed performance goals are not enforceable effluent limitations or standards. The Discharger shall maintain, if not improve, its treatment efficiency. Any exceedance of the performance goals shall trigger an investigation into the cause of the exceedance. If the exceedance persists in three successive monitoring periods, the Discharger

shall submit a written report to the Regional Water Board and USEPA on the nature of the exceedance, the results of the investigation as to the cause of the exceedance, and the corrective actions taken or proposed corrective measures with timetable for implementation, if necessary.

1. Final Effluent Limitations and Performance Goals – Discharge Point 002

The Discharger shall maintain compliance with the following effluent limitations at Discharge Point 002, with compliance measured at Monitoring Location EFF-002 as described in the attached MRP.

Table 8. Effluent Limitations and Performance Goals for Discharge Point 002
(Footnotes are specified on pages 29 and 30 of this Order/Permit.)

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|----------------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| Major Wastewater Constituents | | | | | | | |
| Biochemical Oxygen Demand 5-day @ 20°C ⁶ | mg/L | 30 | 45 | -- | -- | -- | -- |
| | lbs/day | 113,000 | 169,000 | -- | -- | -- | -- |
| Total Suspended Solids ⁶ | mg/L | 30 | 45 | -- | -- | -- | -- |
| | lbs/day | 113,000 | 169,000 | -- | -- | -- | -- |
| pH ^{5,6,7} | standard units | -- | -- | -- | 6.0 | 9.0 | -- |
| Oil and Grease ⁷ | mg/L | 25 | 40 | -- | -- | 75 | -- |
| | lbs/day | 93,800 | 150,000 | -- | -- | -- | -- |
| Settleable Solids ⁷ | ml/L | 1.0 | 1.5 | -- | -- | 3.0 | -- |
| Turbidity ⁷ | NTU | 75 | 100 | -- | -- | 225 | -- |
| Marine Aquatic Life Toxicants⁸ | | | | | | | |
| Arsenic ^{9,10} | µg/L | -- | -- | -- | -- | -- | 3.5 |
| Cadmium ^{9,10} | µg/L | -- | -- | -- | -- | -- | 2.0 |
| Chromium (VI) ^{9,10} | µg/L | -- | -- | -- | -- | -- | 2.5 |
| Copper ^{9,10} | µg/L | -- | -- | -- | -- | -- | 25 |
| Lead ^{9,10} | µg/L | -- | -- | -- | -- | -- | 10 |
| Mercury ^{9,10} | µg/L | -- | -- | -- | -- | -- | 0.02 |
| Nickel ^{9,10} | µg/L | -- | -- | -- | -- | -- | 3 |
| Selenium ^{9,10} | µg/L | -- | -- | -- | -- | -- | 1.6 |
| Silver ^{9,10} | µg/L | -- | -- | -- | -- | -- | 2.2 |
| Zinc ^{9,10} | µg/L | -- | -- | -- | -- | -- | 31 |
| Cyanide ¹⁰ | µg/L | -- | -- | -- | -- | -- | 5 |
| Chlorine Residual ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| Ammonia as N ¹⁰ | mg/L | -- | -- | -- | -- | -- | 44.1 |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|-------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| Phenolic compounds (non-chlorinated) ¹⁰ | µg/L | -- | -- | -- | -- | -- | 2 |
| Phenolic compounds (chlorinated) ¹⁰ | µg/L | -- | -- | -- | -- | -- | 2 |
| Endosulfan ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.04 |
| HCH ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.015 |
| Endrin ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.025 |
| Acute toxicity | TUa | -- | -- | 2.8 | -- | -- | -- |
| Chronic toxicity | TUc | -- | -- | 84 | -- | -- | -- |
| Radioactivity | | | | | | | |
| Gross alpha | pCi/L | -- | -- | -- | -- | -- | 9.72 |
| Gross beta | pCi/L | -- | -- | -- | -- | -- | 27.5 |
| Combined Radium 226 & Radium-228 | pCi/L | -- | -- | -- | -- | -- | -- |
| Tritium | pCi/L | -- | -- | -- | -- | -- | -- |
| Strontium-90 | pCi/L | -- | -- | -- | -- | -- | -- |
| Uranium | pCi/L | -- | -- | -- | -- | -- | -- |
| Human Health Toxicants – Non Carcinogens⁸ | | | | | | | |
| Acrolein ¹⁰ | µg/L | -- | -- | -- | -- | -- | 20 |
| Antimony ^{9,10} | µg/L | -- | -- | -- | -- | -- | 1.5 |
| Bis(2-chloroethoxy) methane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.5 |
| Bis(2-chloroisopropyl) ether ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.5 |
| Chlorobenzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.6 |
| Chromium (III) ¹⁰ | µg/L | -- | -- | -- | -- | -- | 1 |
| Di-n-butyl-phthalate ¹⁰ | µg/L | -- | -- | -- | -- | -- | 5 |
| Dichlorobenzenes ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.6 |
| Diethyl phthalate ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.6 |
| Dimethyl phthalate ¹⁰ | µg/L | -- | -- | -- | -- | -- | 2.7 |
| 2-Methyl-4,6-dinitrophenol ¹⁰ | µg/L | -- | -- | -- | -- | -- | 4 |
| 2,4-Dinitrophenol ¹⁰ | µg/L | -- | -- | -- | -- | -- | 2.1 |
| Ethyl benzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.8 |
| Fluoranthene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.2 |
| Hexachlorocyclopentadiene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 29 |
| Nitrobenzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.5 |
| Thallium ^{9,10} | µg/L | -- | -- | -- | -- | -- | 0.1 |
| Toluene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.6 |
| Tributyltin ¹⁰ | ng/L | -- | -- | -- | -- | -- | 9.6 |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|---------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| 1,1,1-Trichloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.5 |
| Human Health Toxicants – Carcinogens⁸ | | | | | | | |
| Acrylonitrile ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.4 |
| Aldrin ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.0019 |
| Benzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.35 |
| Benzidine ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.0059 |
| Beryllium ¹⁰ | µg/L | -- | -- | -- | -- | -- | 1 |
| Bis(2-chloroethyl) ether ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.45 |
| | lbs/day | -- | -- | -- | -- | -- | 1.6 |
| Bis(2-ethylhexyl) phthalate ¹⁰ | µg/L | -- | -- | -- | -- | -- | 5 |
| Carbon tetrachloride ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.45 |
| Chlordane | µg/L | 0.0019 | -- | -- | -- | -- | -- |
| | lbs/day | 0.0067 | -- | -- | -- | -- | -- |
| Chlorodibromomethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.25 |
| Chloroform ¹⁰ | µg/L | -- | -- | -- | -- | -- | 8.7 |
| DDT | µg/L | 0.014 | -- | -- | -- | -- | -- |
| | lbs/day | 0.049 | -- | -- | -- | -- | -- |
| 1,4-Dichlorobenzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 2.0 |
| 3,3'-Dichlorobenzidine ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.55 |
| 1,2-Dichloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.5 |
| 1,1-Dichloroethylene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.6 |
| Bromodichloromethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.3 |
| Dichloromethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 6.5 |
| 1,3-Dichloropropene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.45 |
| Dieldrin ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.0034 |
| 2,4-Dinitrotoluene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.4 |
| 1,2-Diphenylhydrazine ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.3 |
| Halomethanes ¹⁰ | µg/L | -- | -- | -- | -- | -- | 1.05 |
| Heptachlor ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.0043 |
| Heptachlor epoxide ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.0017 |
| Hexachlorobenzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.018 |
| Hexachlorobutadiene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.35 |
| Hexachloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.35 |
| Isophorone ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.35 |
| N-Nitrosodimethylamine ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.85 |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|---------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| N-Nitrosodi-N-propylamine ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.65 |
| N-Nitrosodiphenylamine ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.45 |
| PAHs ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.70 |
| PCBs | µg/L | 0.0020 | -- | -- | -- | -- | -- |
| | lbs/day | 0.0070 | -- | -- | -- | -- | -- |
| TCDD equivalents | pg/L | 0.33 | -- | -- | -- | -- | -- |
| | lbs/day | 1.2x E-6 | -- | -- | -- | -- | -- |
| 1,1,2,2-Tetrachloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.55 |
| Tetrachloroethylene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.5 |
| Toxaphene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.018 |
| Trichloroethylene ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.4 |
| 1,1,2-Trichloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.25 |
| 2,4,6-Trichlorophenol ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.45 |
| Vinyl chloride ¹⁰ | µg/L | -- | -- | -- | -- | -- | 0.35 |

2. Final Effluent Limitations – Discharge Point 001

The Discharger shall maintain compliance with the following effluent limitations at Discharge Point 001, with compliance measured at Monitoring Location EFF-001, as described in the attached MRP.

Table 9. Effluent Limitations for Discharge Point 001
(Footnotes are specified on pages 29 and 30 of this Order/Permit.)

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|----------------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| Major Wastewater Constituents | | | | | | | |
| Biochemical Oxygen Demand 5-day @ 20°C ⁶ | mg/L | 30 | 45 | -- | -- | -- | -- |
| | lbs/day | 113,000 | 169,000 | -- | -- | -- | -- |
| Total Suspended Solids ⁶ | mg/L | 30 | 45 | -- | -- | -- | -- |
| | lbs/day | 113,000 | 169,000 | -- | -- | -- | -- |
| pH ^{5,6,7} | standard units | -- | -- | -- | 6.0 | 9.0 | -- |
| Oil and Grease ⁷ | mg/L | 25 | 40 | -- | -- | 75 | -- |
| | lbs/day | 93,800 | 150,000 | -- | -- | -- | -- |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|--|---------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| Settleable Solids ⁷ | ml/L | 1.0 | 1.5 | -- | -- | 3.0 | -- |
| Turbidity ⁷ | NTU | 75 | 100 | -- | -- | 225 | -- |
| Marine Aquatic Life Toxicants⁸ | | | | | | | |
| Arsenic ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Cadmium ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Chromium (VI) ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Copper ^{9,10} | µg/L | 16 | -- | 140 | -- | 160 | -- |
| | lbs/day | 56 | -- | 490 | -- | 560 | -- |
| Lead ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Mercury ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Nickel ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Selenium ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Silver ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Zinc ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Cyanide ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Chlorine Residual | µg/L | 28 | -- | 112 | -- | 840 | -- |
| | lbs/day | 98 | -- | 320 | -- | 2900 | -- |
| Ammonia as N | mg/L | 8.4 | -- | 34 | -- | 84 | -- |
| | lbs/day | 29,000 | -- | 120,000 | -- | 290,000 | -- |
| Phenolic compounds (non-chlorinated) ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Phenolic compounds (chlorinated) ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Endosulfan ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| HCH ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Endrin ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Acute toxicity | TUa | -- | -- | -- | -- | -- | -- |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|---------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| Chronic toxicity | TUc | -- | -- | 13 | -- | -- | -- |
| Radioactivity | | | | | | | |
| Gross alpha | pCi/L | -- | -- | -- | -- | -- | -- |
| Gross beta | pCi/L | -- | -- | -- | -- | -- | -- |
| Combined Radium 226 & Radium-228 | pCi/L | -- | -- | -- | -- | -- | -- |
| Tritium | pCi/L | -- | -- | -- | -- | -- | -- |
| Strontium-90 | pCi/L | -- | -- | -- | -- | -- | -- |
| Uranium | pCi/L | -- | -- | -- | -- | -- | -- |
| Human Health Toxicants – Non Carcinogens⁸ | | | | | | | |
| Acrolein ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Antimony ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Bis(2-chloroethoxy) methane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Bis(2-chloroisopropyl) ether ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Chlorobenzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Chromium (III) ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Di-n-butyl-phthalate ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Dichlorobenzenes ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Diethyl phthalate ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Dimethyl phthalate ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 2-Methyl-4,6-dinitrophenol ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 2,4-Dinitrophenol ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Ethyl benzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Fluoranthene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Hexachlorocyclopentadiene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|---------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| Nitrobenzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Thallium ^{9,10} | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Toluene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Tributyltin ¹⁰ | ng/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 1,1,1-Trichloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Human Health Toxicants – Carcinogens⁸ | | | | | | | |
| Acrylonitrile ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Aldrin ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Benzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Benzidine ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Beryllium | µg/L | 0.46 | -- | -- | -- | -- | -- |
| | lbs/day | 1.6 | -- | -- | -- | -- | -- |
| Bis(2-chloroethyl) ether ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Bis(2-ethylhexyl) phthalate ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Carbon tetrachloride ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Chlordane | µg/L | 0.0003 | -- | -- | -- | -- | -- |
| | lbs/day | 0.0011 | -- | -- | -- | -- | -- |
| Chlorodibromomethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Chloroform ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| DDT | µg/L | 0.0024 | -- | -- | -- | -- | -- |
| | lbs/day | 0.0084 | -- | -- | -- | -- | -- |
| 1,4-Dichlorobenzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 3,3'-Dichlorobenzidine ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 1,2-Dichloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|---------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 1,1-Dichloroethylene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Bromodichloromethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Dichloromethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 1,3-Dichloropropene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Dieldrin ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 2,4-Dinitrotoluene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 1,2-Diphenylhydrazine ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Halomethanes ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Heptachlor ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Heptachlor epoxide ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Hexachlorobenzene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Hexachlorobutadiene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Hexachloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Isophorone ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| N-Nitrosodimethylamine ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| N-Nitrosodi-N-propylamine ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| N-Nitrosodiphenylamine ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| PAHs | µg/L | 0.12 | -- | -- | -- | -- | -- |
| | lbs/day | 0.43 | -- | -- | -- | -- | -- |
| PCBs | µg/L | 0.00030 | -- | -- | -- | -- | -- |
| | lbs/day | 0.0084 | -- | -- | -- | -- | -- |
| TCDD equivalents | pg/L | 0.055 | -- | -- | -- | -- | -- |
| | lbs/day | 1.93xE-7 | -- | -- | -- | -- | -- |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | | Performance Goals ² |
|---|---------|-------------------------------------|----------------|----------------------------|-----------------------|------------------------------------|--------------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Minimum | Instantaneous Maximum ⁵ | Average Monthly |
| 1,1,2,2-Tetrachloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Tetrachloroethylene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Toxaphene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Trichloroethylene ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 1,1,2-Trichloroethane ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| 2,4,6-Trichlorophenol ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |
| Vinyl chloride ¹⁰ | µg/L | -- | -- | -- | -- | -- | -- |
| | lbs/day | -- | -- | -- | -- | -- | -- |

Footnotes:

¹ Effluent limitations for conventional, nonconventional, and toxic pollutants were calculated based on effluent limitations in *Table A* and water quality objectives in *Table B* of the Ocean Plan. The minimum dilution ratios used to calculate effluent limitations for nonconventional and toxic pollutants based on water quality objectives in *Table B* of the Ocean Plan are 84:1 (i.e., 84 parts seawater to one part effluent) and 13:1 for Discharge Points 002 and 001, respectively. The calculations of mass emission rates are shown in the accompanying Fact Sheet.

The mass emission rates are based on the average design flow rate (420 MGD) of the Hyperion Treatment Plant in the 1994 permit: lbs/day = 0.00834 x Ce (effluent concentration in ug/L) x Q (flow rate in MGD). During storm events when flow exceeds the dry weather design capacity, the mass emission rate limitations shall not apply.

² The performance goals are based upon the actual performance data of Hyperion Treatment Plant and are specified only as an indication of the treatment efficiency of the plant. They are not considered effluent limitations or standards for the treatment plant. Hyperion Treatment Plant shall make best efforts to maintain, if not improve, the effluent quality at the level of these performance goals. The Executive Officer and USEPA may modify any of the performance goals if the City requests and has demonstrated that the change is warranted.

³ See section VIII of this Order/Permit and Attachment A for definition of terms.

⁴ The maximum daily effluent concentration limitation shall apply to flow-weighted 24-hour composite samples. It may apply to grab samples if the collection of composite samples for those constituents is not appropriate because of the instability of the constituents.

⁵ The instantaneous maximum effluent limitations shall apply to grab sample results.

⁶ The effluent limitations are based on secondary treatment standards, 40 CFR 133.102.

⁷ Based on Ocean Plan Table A effluent limitations.

- ⁸ Effluent limitations for these constituents are based on Ocean Plan Table B objectives using initial dilution ratios of 84 and 13 parts of seawater to 1 part effluent for Discharge Points 002 and 001, respectively.
- ⁹ Represents total recoverable metal value.
- ¹⁰ These constituents did not show reasonable potential to exceed Ocean Plan Table B objectives; therefore, no numerical water quality-based effluent limits are prescribed.
-

3. Percent Removal: For BOD₅20°C and total suspended solids, the arithmetic mean values, by weight, for effluent samples collected in a period of 30 consecutive calendar days shall not exceed 15 percent of the arithmetic mean of values, by weight, for influent samples collected at approximately the same time during the same period.
4. The temperature of wastes discharged shall not exceed 100°F.
5. Radioactivity: Not to exceed limits specified in Title 17, Division 1, Chapter 5, Subchapter 4, Group 3, Article 3, Section 30253 of the California Code of Regulations. Reference to section 30253 is prospective, including future changes to any incorporated provisions of federal law, as the changes take effect.
6. The Discharger shall ensure that bacterial concentrations in the effluent discharged from Discharge Points 001 and 002 do not result in an exceedance of the Hyperion Treatment Plant's waste load allocation of zero (0) days exceedance of single sample numeric limits or geometric mean limits (based on Basin Plan bacteria objectives for marine waters designated REC-1, see Section VI.A.1.b) at shoreline compliance points, as specified in Regional Water Board Resolution Nos. 2002-004 and 2002-022.
7. Waste discharged to the ocean must be essentially free of:
 - a. Material that is floatable or will become floatable upon discharge.
 - b. Settleable material or substances that may form sediments which will degrade benthic communities or other aquatic life.
 - c. Substances that will accumulate to toxic levels in marine waters, sediments or biota.
 - d. Substances that significantly decrease the natural light to benthic communities and other marine life.
 - e. Materials that result in aesthetically undesirable discoloration of the ocean surface.
8. Interim Effluent Limitations – Not Applicable

B. Land Discharge Specifications – Not Applicable

C. Reclamation Specifications – Not Applicable

V. MASS EMISSION CAPS

A comprehensive plan of action for the protection and management of Santa Monica Bay, known as the Santa Monica Bay Restoration Plan (SMBRP), was approved by Governor Pete Wilson in December 1994 and USEPA Administrator Carol Browner in 1995. Since that time, mass emission caps have been applied to four pollutants of concern identified by the SMBRP (copper, lead, silver, and zinc) that are causing or could cause deterioration of designated beneficial uses in Santa Monica Bay. Caps are set at 1995 allowable mass emission rates. The Discharger should make best efforts to discharge these pollutants of concern below cap values. The Executive Officer and USEPA may modify any of the mass emission cap values if the City requests and demonstrates that the change is warranted.

The mass emission caps are based on an average flow rate of 347 MGD and the average concentration of the pollutant of concern in 1995. If performance data showed nondetectable levels, one half of the detection limit was used to calculate an average concentration. Mass emission cap calculations are shown in the Fact Sheet.

| <u>Parameter</u> | <u>Mass Emission Cap (lbs/year)</u> |
|------------------|-------------------------------------|
| Copper | 41,100 |
| Lead | 2,700 |
| Silver | 5,500 |
| Zinc | 59,100 |

VI. RECEIVING WATER LIMITATIONS

The Discharger shall not cause a violation of the following water quality objectives. Compliance with these water quality objectives shall be determined by samples collected at stations representative of the area within the waste field where initial dilution is completed.

A. Surface Water Limitations

1. Bacterial Characteristics

a. USEPA Primary Recreation Criteria in Federal Waters

Ocean waters beyond the outer limit of the territorial sea shall not exceed the following 304(a)(1) criteria for *Enterococcus* density beyond the zone of initial dilution in areas where primary contact recreation, as defined in

USEPA guidance, occurs. USEPA describes the “primary contact recreation” use as protective when the potential for ingestion of, or immersion in, water is likely. Activities usually include swimming, water-skiing, skin-diving, surfing, and other activities likely to result in immersion. (Water Quality Standards Handbook, EPA-823-B-94-005a, 1994, p. 2-2.)

30-day Geometric Mean (per 100 ml): 35.

Single Sample Maximum (per 100 ml): 104 for designated bathing beach; 158 for moderate use; 276 for light use; and 501 for infrequent use.

b. State/Regional Water Boards Water Contact Standards

- i. Within a zone bounded by the shoreline and a distance of 1,000 feet from the shoreline or the 30-foot depth contour, whichever is further from the shoreline, and in areas outside this zone used for water contact sports, as determined by the Regional Water Board (i.e., waters designated as REC-1), but including all kelp beds, the following bacterial objectives shall be maintained throughout the water column.

30-day Geometric Mean Limits

- a. Total coliform density shall not exceed 1,000/100 ml.
- b. Fecal coliform density shall not exceed 200/100 ml.
- c. *Enterococcus* density shall not exceed 35/100 ml.

Single Sample Maximum Limits (SSM)

- a. Total coliform density shall not exceed 10,000/100 ml.
- b. Fecal coliform density shall not exceed 400/100 ml.
- c. *Enterococcus* density shall not exceed 104/100 ml.
- d. Total coliform density shall not exceed 1,000/100 ml, when the fecal coliform/total coliform ratio exceeds 0.1.

If any of the single sample limits are exceeded, the Regional Water Board may require repeat sampling on a daily basis until the sample falls below the single sample limit in order to determine the persistence of the exceedance. When repeat sampling is required because of an exceedance of any single sample limit, values from all samples collected during that 30-day period will be used to calculate the geometric mean.

- c. The Initial Dilution Zone for any wastewater outfall shall be excluded from designation as kelp beds for purposes of bacterial standards. Adventitious assemblages of kelp plants on waste discharge structures (e.g., outfall pipes and diffusers) do not constitute kelp beds for purposes of bacterial standards.
- d. California Department of Public Health² (CDPH) Standards

California Department of Public Health (CDPH) has established minimum protective bacteriological standards for coastal waters adjacent to public beaches and for public water-contact sports areas in ocean waters. These standards are found in the California Code of Regulations, title 17, section 7958, and they are identical to the objectives contained in subsection b, above. When a public beach or public water-contact sports area fails to meet these standards, CDPH or the local public health officer may post with warning signs or otherwise restrict use of the public beach or public water-contact sports area until the standards are met. The CDPH regulations impose more frequent monitoring and more stringent posting and closure requirements on certain high-use public beaches that are located adjacent to a storm drain that flows in the summer.

For beaches not covered under AB 411 regulations (this incorporation by reference is prospective including future changes to the incorporated provisions as changes take effect), CDPH imposes the same standards as contained in title 17, California Code of Regulations, and requires weekly sampling but allows the county health officer more discretion in making posting and closure decisions.

- e. Shellfish Harvesting Standards. At all areas where shellfish may be harvested for human consumption, as determined by the Regional Water Board, the following bacterial objectives shall be maintained throughout the water column: The median total coliform density shall not exceed 70 per 100 ml, and not more than 10 percent of the samples shall exceed 230 per 100 ml.

2. Physical Characteristics

The waste discharged shall not:

- a. Cause floating particulates and oil and grease to be visible;
- b. Cause aesthetically undesirable discoloration of the ocean surface;

² Formerly, California Department of Health Services.
Limitations and Discharge Requirements
(May 20, 2010; Revised: October 12, 2010 & November 4, 2010)

- c. Significantly reduce the transmittance of natural light at any point outside the initial dilution zone; and
- d. Change the rate of deposition of inert solids and the characteristics of inert solids in ocean sediments such that benthic communities are degraded.

3. Chemical Characteristics

The waste discharged shall not:

- a. Cause the dissolved oxygen concentration at any time to be depressed more than 10 percent from that which occurs naturally, as a result of the discharge of oxygen demanding waste materials;
- b. Change the pH of the receiving waters at any time more than 0.2 units from that which occurs naturally as a result of the discharge pH;
- c. Cause the dissolved sulfide concentration of waters in and near sediments to be significantly increased above that present under natural conditions;
- d. Cause the concentration of substances set forth in Chapter II, Table B of the Ocean Plan, in marine sediments to be increased to levels that would degrade indigenous biota;
- e. Cause the concentration of organic materials in marine sediments to be increased to levels that would degrade marine life; and
- f. Contain nutrients at levels that will cause objectionable aquatic growth or degrade indigenous biota.

4. Biological Characteristics

The waste discharged shall not:

- a. Degrade marine communities, including vertebrate, invertebrate, and plant species;
- b. Alter the natural taste, odor, and color of fish, shellfish, or other marine resources used for human consumption; and
- c. Cause the concentration of organic materials in fish, shellfish, or other marine resources used for human consumption to bioaccumulate to levels that are harmful to human health.

5. Radioactivity

Discharge of radioactive waste shall not degrade marine life.

VII. PROVISIONS

A. Standard Provisions

1. The Discharger shall comply with all Standard Provisions included in Attachment D of this Order/Permit.
2. The Discharger shall comply with the following Regional Water Board provisions:
 - a. Neither the treatment nor the discharge of pollutants shall create pollution, contamination, or nuisance as defined by section 13050 of the California Water Code.
 - b. Odors, vectors, and other nuisances of sewage or sludge origin beyond the limits of the treatment plant site or the sewage collection system due to improper operation of facilities, as determined by the Regional Water Board, are prohibited.
 - c. All facilities used for collection, transport, treatment, or disposal of wastes shall be adequately protected against damage resulting from overflow, washout, or inundation from a storm or flood having a recurrence interval of once in 100 years.
 - d. Collection, treatment, and disposal systems shall be operated in a manner that precludes public contact with wastewater.
 - e. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer of the Regional Water Board and USEPA.
 - f. The provisions of this Order/Permit are severable. If any provision of this order is found invalid, the remainder of this Order shall not be affected.
 - g. Nothing in this Order/Permit shall be construed to preclude the institution of any legal action or relieve the Discharger from any responsibilities, liabilities or penalties established pursuant to any applicable State law or regulation under authority preserved by section 510 of the CWA.
 - h. Nothing in this Order/Permit shall be construed to preclude the institution of any legal action or relieve the Discharger from any responsibilities, liabilities or penalties to which the discharger is or may be subject to under section 311 of the CWA.

- i. The Discharger must comply with the lawful requirements of municipalities, counties, drainage districts, and other local agencies regarding discharges of storm water to storm drain systems or other water courses under their jurisdiction; including applicable requirements in municipal storm water management program developed to comply with NPDES permits issued by the Regional Water Board to local agencies.
- j. Discharge of wastes to any point other than specifically described in this Order/Permit is prohibited, and constitutes a violation thereof.
- k. The Discharger shall comply with all applicable effluent limitations, national standards of performance, toxic effluent standards, and all federal regulations established pursuant to sections 301, 302, 303(d), 304, 306, 307, 316, 403, and 405 of the Federal CWA and amendments thereto.
- l. These requirements do not exempt the operator of the waste disposal facility from compliance with any other laws, regulations, or ordinances which may be applicable; they do not legalize this waste disposal facility, and they leave unaffected any further restraints on the disposal of wastes at this site which may be contained in other statutes or required by other agencies.
- m. Oil or oily material, chemicals, refuse, or other pollutionable materials shall not be stored or deposited in areas where they may be picked up by rainfall and carried off of the property and/or discharged to surface waters. Any such spill of such materials shall be contained and removed immediately.
- n. A copy of these waste discharge specifications shall be maintained at the discharge facility so as to be available at all times to operating personnel.
- o. If there is any storage of hazardous or toxic materials or hydrocarbons at this facility and if the facility is not manned at all times, a 24-hour emergency response telephone number shall be prominently posted where it can easily be read from the outside.
- p. The Discharger shall file with the Regional Water Board a report of waste discharge at least 120 days before making any material change or proposed change in the character, location or volume of the discharge.
- q. In the event of any change in name, ownership, or control of these waste disposal facilities, the discharger shall notify the Regional Water Board and USEPA of such change and shall notify the succeeding owner or operator of the existence of this Order/Permit by letter, copy of which shall be forwarded to the Regional Water Board and USEPA.

- r. The California Water Code (CWC) provides that any person who violates a waste discharge requirement or a provision of the CWC is subject to civil penalties of up to \$5,000 per day, \$10,000 per day, or \$25,000 per day of violation, or when the violation involves the discharge of pollutants, is subject to civil penalties of up to \$10 per gallon per day or \$25 per gallon per day of violation; or some combination thereof, depending on the violation, or upon the combination of violations.

Violation of any of the provisions of the NPDES program or of any of the provisions of this Order/Permit may subject the violator to any of the penalties described herein, or any combination thereof, at the discretion of the prosecuting authority; except that only one kind of penalty may be for each kind of violation.

- s. Under CWC section 13387, any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this order, including monitoring reports or reports of compliance or noncompliance, or who knowingly falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained in this order is subject to a fine of not more than \$25,000 or imprisonment of not more than two years, or both. For a second conviction, such a person shall be punished by a fine of not more than \$25,000 per day of violation, or by imprisonment of not more than four years, or by both.
- t. The discharge of any waste resulting from the combustion of toxic or hazardous wastes to any waste stream that ultimately discharges to waters of the United States is prohibited, unless specifically authorized elsewhere in this Order/Permit.
- u. The Discharger shall notify the Executive Officer and USEPA in writing no later than 6 months prior to planned discharge of any chemical, other than the products previously reported to the Executive Officer and USEPA, which may be toxic to aquatic life. Such notification shall include:
 - 1. Name and general composition of the chemical,
 - 2. Frequency of use,
 - 3. Quantities to be used,
 - 4. Proposed discharge concentrations, and
 - 5. USEPA registration number, if applicable.

3. The Discharger shall comply with the following USEPA Region 9 Standard Provisions:
- a. The following condition has been established to enforce applicable requirements of the Resource Conservation and Recovery Act. POTWs may not receive hazardous waste by truck, rail, or dedicated pipe except as provided under 40 CFR 270. Hazardous wastes are defined at 40 CFR 261 and include any mixture containing any waste listed under 40 CFR 261.31 through 261.33. The Domestic Sewage Exclusion (40 CFR 261.4) applies only to wastes mixed with domestic sewage in a sewer leading to a POTW and not to mixtures of hazardous wastes and sewage or septage delivered to the treatment plant by truck.
 - b. Transfers by Modification: Except as provided in 40 CFR 122.61(b), this Permit may be transferred by the Discharger to a new owner or operator only if the Permit has been modified or revoked and reissued (under 40 CFR 122.62(b)(2)), or a minor modification made (under 40 CFR 122.63(d)), to identify the new permittee and incorporate such other requirements as may be necessary under the CWA. (40 CFR 122.61(a).)
 - c. Automatic Transfers: As an alternative to transfers under 40 CFR 122.61(a), this Permit may be automatically transferred to a new permittee if: the notice includes a written agreement between the Discharger and new permittee containing a specific date for transfer of permit responsibility, coverage, and liability between them; and the Water Division Director does not notify the Discharger and the proposed new permittee of his/her intent to modify or revoke and reissue the Permit. A modification under this paragraph may also be a minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the written agreement between the Discharger and the new permittee. (40 CFR 122.61(b).)
 - d. Minor Modification of Permits: Upon the consent of the Discharger, the Water Division Director may modify the Permit to make the corrections or allowances for changes in the permitted activity listed under 40 CFR 122.63(a) through (g), without following the procedures of 40 CFR 124. Any permit modification not processed as a minor modification under 40 CFR 122.63 must be made for cause and with 40 CFR 124 draft permit and public notice as required in 40 CFR 122.62. (40 CFR 122.63.)
 - e. Termination of Permits: The causes for terminating a permit during its term, or for denying a permit renewal application are found at 40 CFR 122.64(a)(1) through (4). (40 CFR 122.64.)
 - f. Availability of Reports: Except for data determined to be confidential under 40 CFR 2, all reports prepared in accordance with the terms of this Order/Permit shall be available for public inspection at the offices of the Regional Water Board and USEPA. As required by the CWA, permit

applications, permits, and effluent data shall not be considered confidential. (Pursuant to CWA section 308.)

- g. **Removed Substances:** Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering navigable waters. (Pursuant to CWA section 301.)
- h. **Severability:** The provisions of this Order/Permit are severable, and if any provision of this Order/Permit or the application of any provision of this Order/Permit to any circumstance is held invalid, the application of such provision to other circumstances and the remainder of this Order/Permit shall not be affected thereby. (Pursuant to CWA section 512.)
- i. **Civil and Criminal Liability:** Except as provided in standard conditions on Bypass and Upset, nothing in this Order/Permit shall be construed to relieve the Discharger from civil or criminal penalties for noncompliance. (Pursuant to CWA section 309.)
- j. **Oil and Hazardous Substances Liability:** Nothing in this Order/Permit shall be construed to preclude the institution of any legal action or relieve the Discharger from any responsibilities, liabilities, or penalties to which the Discharger is or may be subject under CWA section 311.
- k. **State or Tribal Law:** Nothing in this Order/Permit shall be construed to preclude the institution of any legal action or relive the operator from any responsibilities, liabilities, or penalties established pursuant to any applicable State or Tribal law or regulation under authority preserved by CWA section 510.

B. Monitoring and Reporting Program (MRP) Requirements

- 1. The Discharger shall comply with the MRP, and future revisions thereto, in Attachment E of this Order/Permit.
- 2. Reports required to be submitted to the Regional Water Board and USEPA shall be sent to:

California Regional Water Quality Control Board
Los Angeles Region
320 West 4th Street, Suite 200
Los Angeles, CA 90013
Attention: Information Technology Unit

U.S. EPA, Region 9
ATTN: NPDES Data Team (WTR-1)
75 Hawthorne Street

San Francisco, CA 94105-3901

Notifications and report required to be provided to the Regional Water Board shall be made to:

Telephone – (213) 576-6616
Facsimile – (213) 576-6660

Notifications and report required to be provided to USEPA shall be made to:

Telephone – (415) 972-3577
Facsimile – (415) 947-3545

3. After notification by the State or Regional Water Board or USEPA, the Discharger may be required to electronically submit self-monitoring reports. Until such time as electronic submissions of self-monitoring reports is required, the Discharger shall submit discharge monitoring reports (DMRs) in accordance with the requirements described in this Order/Permit.

DMRs must be signed and certified as required by the Standard Provisions of this Order/Permit (Attachment D). The Discharger shall submit the original DMR and one copy of the DMR to:

| Standard Mail | FedEx/UPS/ Other Private Carriers |
|--|--|
| State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000 | State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA 95814 |

The Discharger shall submit one copy of the DMR to:

U.S. EPA, Region 9
ATTN: NPDES Data Team (WTR-1)
75 Hawthorne Street
San Francisco, CA 94105-3901

All discharge monitoring results should be reported on the official USEPA pre-printed DMR forms (USEPA Form 3320-1). Forms that are self-generated must be approved by USEPA.

C. Special Provisions

1. Reopener Provisions

- a. This Order/Permit may be reopened and modified to incorporate new limits based on future reasonable potential analyses to be conducted

based on on-going monitoring data collected by the Discharger and evaluated by the Regional Water Board and USEPA.

- b. This Order/Permit may be reopened and modified to incorporate new mass emission rates based on the current Hyperion Treatment Plant's design capacity of 450 MGD provided that the Discharger requests and conducts an antidegradation analysis to demonstrate that the change is warranted.
- c. This Order/Permit may be reopened and modified, in accordance with the provisions set forth in 40 CFR 122 and 124, to incorporate requirements for the implementation of the watershed protection management approach.
- d. This Order/Permit may be modified, in accordance with the provisions set forth in 40 CFR 122 and 124, to include new MLs.
- e. This Order/Permit may be reopened and modified to revise effluent limitations as a result of future Basin Plan Amendments or the adoption of a TMDL for Santa Monica Bay Watershed Management Areas.
- f. The Regional Water Board or USEPA may modify or revoke and reissue this Order/Permit if present or future investigations demonstrate that the discharge(s) governed by this Order/Permit will cause, have the potential to cause, or will contribute to adverse impacts on water quality and/or beneficial uses of the receiving waters.
- g. This Order/Permit may be modified, revoked, and reissued or terminated in accordance with the provisions of 40 CFR 122.44, 122.62 to 122.64, 125.62, and 125.64. Causes for taking such actions include, but are not limited to, failure to comply with any condition of this Order/Permit, endangerment to human health or the environment resulting from the permitted activity, or acquisition of newly obtained information which would have justified the application of different conditions if known at the time of Order/Permit adoption and issuance. The filing of a request by the Discharger for an Order/Permit modification, revocation, and issuance or termination, or a notification of planned changes or anticipated noncompliances does not stay any condition of this Order/Permit.
- h. This Order/Permit may be modified, or revoked and reissued, based on the results of Magnuson-Stevens Fishery Conservation and Management Act and/or Endangered Species Act section 7 consultation(s) with the National Marine Fisheries Service and/or the U.S. Fish and Wildlife Service.
- i. This Order/Permit may be reopened and modified by the Regional Water Board and USEPA to incorporate conforming monitoring requirements and

schedule dates for implementation of the Comprehensive Monitoring Program for Santa Monica Bay (Santa Monica Bay Restoration Commission, January 2007).

- j. The Regional Water Board may reopen this Order to consider making conforming changes to Order No. R4-2010-XXXX in the event the USEPA issues a version of NPDES Permit No. CA0109991 that contains revisions based on its consideration of comments which are timely submitted.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

a. Treatment Plant Capacity

The Discharger shall submit a written report to the Regional Water Board Executive Officer and USEPA Director within 90 days after the “30-day (monthly) average” daily dry-weather flow equals or exceeds 75 percent of the 30-day (monthly) average daily dry weather design capacity (i.e., 450 MGD) of waste treatment and/or disposal facilities subject to this Order/Permit. The Discharger’s senior administrative officer shall sign a letter, which transmits the report and certifies that the Discharger’s policy-making body is adequately informed of the report contents. The report shall include the following:

1. Daily average flow for the calendar month, the date on which the maximum daily flow (peak flow) occurred, and the rate of that maximum flow.
2. The Discharger’s best estimate of when the monthly average daily dry-weather flow will equal or exceed the design capacity of the POTW.
3. The Discharger’s plans to provide additional capacity for waste treatment and/or disposal facilities before the waste flow exceeds the capacity of the POTW. This requirement can be satisfied by referencing and attaching to the report relevant portions of the wastewater planning documents developed in response to this requirement that provide a roadmap for infrastructure and program upgrades and strategies to meet projected increases in the Discharger’s wastewater treatment capacity.

3. Best Management Practices and Pollution Prevention

- a. Storm Water Pollution Prevention Plan (SWPPP) – The HTP is regulated under the State Water Board Water Quality Order No. 97-03-DWQ, NPDES General Permit No. CAS000001 (General Permit), WDRs for Discharge of Storm Water Associated with Industrial Activities Excluding Construction Activities.

b. Spill Clean-Up Contingency Plan (SCCP)

The Discharger shall maintain an SCCP for Hyperion Treatment Plant and its sanitary sewage collection system in an up-to-date condition and shall amend the SCCP whenever there is a change (e.g., in the design, construction, operation, or maintenance of the sewage system or sewage facilities) which materially affects the potential for spills. The Discharger shall review and amend the SCCP as appropriate after each spill from Hyperion Treatment Plant or in the service area of the Facility. Upon request of the Regional Water Board or USEPA, the Discharge shall submit the SCCP and any amendments to the Regional Water Board and USEPA. The Discharger shall ensure that the up-to-date SCCP is readily available to the sewage system personnel at all times and that the sewage system personnel are familiar with it.

Within six months of the adoption of this Order/Permit, the Discharger shall submit an SCCP, which provides the most applicable containment, cleanup and monitoring of sewer spills or overflows that reach water bodies, including dry channels and beach sands, that considers the information developed by the Sanitation Districts of Los Angeles County's efforts to develop a statewide approach, to the Regional Water Board Executive Officer and USEPA.

c. Pollutant Minimization Program

Reporting protocols in the Monitoring and Reporting Program, Attachment E, describe sample results that are to be reported as Detected but Not Quantified (DNQ) or Not Detected (ND). Definitions for a reported Minimum Level (ML) and Method Detection Limit (MDL) are provided in the Ocean Plan. These reporting protocols and definitions are used in determining the need to conduct a Pollution Minimization Program, as follows:

The Discharger shall develop and conduct a Pollutant Minimization Program (PMP) as further described below when there is evidence (e.g., sample results reported as DNQ when the effluent limitation is less than the MDL, sample results from analytical methods more sensitive than those methods required by this Order/Permit, presence of whole effluent toxicity, health advisories for fish consumption, results of benthic or aquatic organism tissue sampling) that a pollutant is present in the effluent above an effluent limitation and either:

1. The concentration of the pollutant is reported as DNQ and the effluent limitation is less than the reported ML; or

2. The concentration of the pollutant is reported as ND and the effluent limitation is less than the MDL.

The goal of the PMP shall be to reduce all potential sources of a pollutant through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost-effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to California Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

The PMP shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board and USEPA:

1. An annual review and semi-annual monitoring of potential sources of the reportable priority pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling;
2. Quarterly monitoring for the reportable priority pollutant(s) in the influent to the wastewater treatment system;
3. Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutant(s) in the effluent at or below the effluent limitation;
4. Implementation of appropriate cost-effective control measures for the reportable priority pollutant(s), consistent with the control strategy; and
5. An annual status report that shall be sent to the Regional Water Board and USEPA including:
 - a. All PMP monitoring results for the previous year;
 - b. A list of potential sources of the reportable pollutant(s);
 - c. A summary of all actions undertaken pursuant to the control strategy; and
 - d. A description of actions to be taken in the following year.

4. Construction, Operation and Maintenance Specifications

- a. Wastewater treatment facilities subject to this Order/Permit shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to Chapter 3, Subchapter 14, Title 23 of the California Code of Regulations (section 13625 of the California Water Code).
- b. The Discharger shall maintain in good working order a sufficient alternate power source for operating the wastewater treatment and disposal facilities. All equipment shall be located to minimize failure due to moisture, liquid spray, flooding, and other physical phenomena. The alternate power source shall be designed to permit inspection and maintenance and shall provide for periodic testing. If such alternate power source is not in existence, the Discharger shall halt, reduce, or otherwise control all discharges upon the reduction, loss, or failure of the primary source of power.
- c. Emergency Power Facilities

The Discharger shall provide standby or emergency power facilities and/or storage capacity or other means so that in the event of plant upset or outage due to power failure or other cause, discharge of raw or inadequately treated sewage does not occur.

5. Special Provisions for Municipal Facilities (POTWs Only)

- a. Sludge (Biosolids) Requirements – Refer to Attachment H
- b. Pretreatment Program Requirements – Refer to Attachment I
- c. Spill Reporting Requirements for POTWs
 1. Initial Notification

This requirement is an appropriate mechanism to ensure that the agencies that have first responder duties are notified in a timely manner in order to protect public health and beneficial uses. For spills, overflows, and bypasses from its POTW, the Discharger shall make notifications as required below:

- a. In accordance with the requirements of Health and Safety Code section 5411.5, the Discharger shall provide notification to the local health officer or the director of environmental health with jurisdiction over the affected water body of any unauthorized release of sewage or other waste that causes, or probably will cause, a discharge to any waters of the State as soon as

possible, but not later than two (2) hours after becoming aware of the release.

- b. In accordance with the requirements of Water Code section 13271, the Discharger shall provide notification to the California Emergency Management Agency (Cal EMA) of the release of reportable amounts of hazardous substances or sewage that causes, or probably will cause, a discharge to any waters of the State as soon as possible, but not later than two (2) hours after becoming aware of the release. The California Code of Regulations, Title 23, section 2250, defines a reportable amount of sewage as being 1,000 gallons. The phone number for reporting releases to Cal EMA is (800) 852-7550.
- c. The Discharger shall notify the Regional Water Board of any unauthorized release of sewage from its POTW that causes, or probably will cause, a discharge to any waters of the State as soon as possible, but not later than **two (2)** hours after becoming aware of the release. This initial notification does not need to be made if the Discharger has notified Cal EMA and the local health officer or the director of environmental health with jurisdiction over the affected water body. The phone number for reporting releases of sewage to the Regional Water Board is (213) 576-6657. The phone numbers for after hours and weekend reporting of releases of sewage to the Regional Water Board are (213) 305-2284 and (213) 305-2253.

At a minimum the following information shall be provided to the Regional Water Board:

1. The location, date and time of the release.
2. The waters of the State that received or will receive the discharge.
3. An estimate of the amount of sewage or other waste released and the amount that reached waters of the State at the time of notification.
4. If ongoing, the estimated flow rate of the release at the time of the notification.
5. The name, organization, phone number, and email address of the reporting representative.

2. Monitoring

For spills, overflows, and bypasses reported under section VII.C.5.c.1, the Discharger shall monitor as required below:

To define the geographical extent of the impact, the Discharger shall obtain grab samples (if feasible, accessible, and safe): (1) for all spills, overflows, or bypasses of any volume that reach any waters of the State; and (2) for all spills, overflows, or bypasses of 1,000 gallons or more. The Discharger shall analyze the samples for total and fecal coliforms or *E. coli*, *Enterococcus*, and relevant pollutants of concern, upstream and downstream of the point of entry of the spill (if feasible, accessible, and safe). This monitoring shall be done on a daily basis from time the spill is known until the results of two consecutive sets of bacteriological monitoring indicate the return to the background level or the County Department of Public Health authorizes cessation of monitoring.

3. Twenty-four (24) Hour Reporting

The Regional Water Board initial notification required under section VII.C.5.c.1, above shall be followed by:

a. As soon as possible, but not later than **twenty-four (24) hours** after becoming aware of an unauthorized discharge of sewage or other waste from its POTW to any waters of the State or of 1,000 gallons or more, the Discharger shall submit a report to the Regional Water Board by email at aanijielo@waterboards.ca.gov and the USEPA by telephone at (415) 972-3577 or facsimile at (415) 947-3545. If the discharge is 1,000 gallons or more, this report shall certify that the Cal EMA has been notified of the discharge in accordance with Water Code section 13271 and section VII.C.5.c.1. This report shall also certify that the local health officer or director of environmental health with jurisdiction over the affected water body has been notified of the discharge in accordance with Health and Safety Code section 5411.5 and section VII.C.5.c.1. This report shall also include at a minimum the following information:

- (i) Agency, NPDES No., Order No., and MRP CI No., if applicable.
- (ii) The location, date and time of the discharge.
- (iii) The waters of the State that received the discharge.

- (iv) A description of the level of treatment of the sewage or other waste discharged.
 - (v) An initial estimate of the amount of sewage or other waste released and the amount that reached waters of the State.
 - (vi) The Cal EMA control number and the date and time that notification of the incident was provided to the Cal EMA.
 - (vii) The name of the local health officer or director of environmental health notified (if contacted directly), the date and time of notification, and the method of notification (e.g., phone, fax, email).
- b. A preliminary written report is due five (5) working days after disclosure of the incident reported under section VII.C.5.c.3.a (submission to the Regional Water Board and USEPA of the log number of the SSO Database entry shall satisfy this requirement for a preliminary written report). Within 30 days after submitting this preliminary written report, the Discharger shall submit the final written report to the Regional Water Board and USEPA. The final written report shall document the information required in section VII.C.5.c.4, below, and in the Standard Provisions of this Order/Permit. The Executive Officer for just cause can grant an extension for submittal of the final written report to the Regional Water Board.
- c. The Discharger shall include a certification in the annual summary report (due according to the schedule in the Monitoring and Reporting Program) stating that the sewer system emergency equipment, including alarm systems, backup pumps, standby power generators, and other critical emergency pump station components are maintained and tested in accordance with the Discharger's Preventative Maintenance Plan (PMP). Any deviations from or modifications to the PMP shall be discussed.

4. Records

The Discharger shall develop and maintain a record of all spills, overflows, or bypasses of raw or partially treated sewage from its POTW. This record shall be made available to the Regional Water Board and USEPA upon request and a summary shall be included in the annual summary report. The records shall contain:

- a. The date and time of each spill, overflow, or bypass;

- b. The location of each spill, overflow, or bypass (including latitude and longitude);
- c. The estimated volume of each spill, overflow, or bypass including gross volume, amount recovered and not recovered, and monitoring results required by section VII.C.5.c.2;
- d. The cause of each spill, overflow, or bypass;
- e. Whether each spill, overflow, or bypass entered a waters of the State and, if so, the name of the water body and whether it entered via a storm drain or other man-made conveyance;
- f. Mitigation measures implemented;
- g. Corrective measures implemented or proposed to be implemented to prevent/minimize future occurrences; and
- h. The mandatory information included in SSO online reporting for finalizing and certifying the SSO report for each spill, overflow, or bypass under the SSO WDR.

5. Activities Coordination

In addition, the Regional Water Board and USEPA expect that the POTW will coordinate its compliance activities for consistency and efficiency with other entities that have responsibilities under: this NPDES permit, including the Pretreatment Program; an MS4 NPDES permit that may contain spill prevention, sewer maintenance and reporting requirements; or the SSO WDR.

6. Consistency with Statewide General Waste Discharge Requirements For Sanitary Sewer Systems (SSO WDR)

The Clean Water Act prohibits the discharge of pollutants from a point source to waters of the United States unless authorized under a NPDES permit. (33 U.S.C. §§1311, 1342.). The State Water Board adopted Statewide General Waste Discharge Requirements for Sanitary Sewer Systems, (Order No. 2006-0003-DWQ) on May 2, 2006, to provide a consistent, Statewide regulatory approach to address Sanitary Sewer Overflows (SSOs). The SSO WDR requires public agencies that own or operate sanitary sewer systems to develop and implement sewer system management plans and report all SSOs to the State Water Board's online SSO Database.

The requirements contained in this Order/Permit in Sections VII.C.3.b (Spill Clean-Up Contingency Plan), VII.C.4 (Construction, Operation

and Maintenance Specifications), and VI.C.5.c (Spill Reporting Requirements for POTWs) are intended to be consistent with the requirements of the SSO WDR and as outlined in the State Water Board letter dated September 9, 2008 (Modification to Monitoring and Reporting Program). The Regional Water Board recognizes that there may be some overlap between the provisions of this Order/Permit and SSO WDR requirements. The requirements of the SSO WDR are considered the minimum thresholds (see Finding 11 of Order No. 2006-0003-DWQ). The Regional Water Board will accept the documentation prepared by the Discharger under the SSO WDR for compliance purposes as satisfying the requirements in sections VII.C.3.b, VII.C.4, and VII.C.5.c provided that any additional or more stringent provisions enumerated in this Order/Permit are addressed.

Regardless of the coverage obtained under the SSO WDR, the Discharger's collection system is part of the Publicly Owned Treatment Works that is subject to this Order/Permit. As such, pursuant to federal regulations, the Discharger must properly operate and maintain its collection system (40 CFR 122.41(e)), report any non-compliance (40 CFR 122.41(l)(6) and (7)), and mitigate any discharge from the collection system in violation of this Order/Permit (40 CFR 122.41(d)).

6. Other Special Provisions – Not Applicable
7. Compliance Schedules – Not Applicable

VIII. COMPLIANCE DETERMINATION

Compliance with effluent limitations for reportable pollutants shall be determined using sample reporting protocols defined in the MRP.

A. General

Compliance with effluent limitations for reportable pollutants shall be determined using sample reporting protocols defined in the MRP.

1. Compliance with Effluent Limitations expressed as Single Constituents

Dischargers are out of compliance with the effluent limitation if the concentration of the pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reported Minimum Level.

2. Compliance with Effluent Limitations expressed as Sum of Several Constituents

Dischargers are out of compliance with an effluent limitation which applies to the sum of a group of chemicals (e.g., PCB's) if the sum of the individual pollutant concentrations is greater than the effluent limitation. Individual pollutants of the group will be considered to have a concentration of zero if the constituent is reported as "Not Detected" (ND) or "Detected, but Not Quantified" (DNQ).

3. Multiple Sample Data Reduction

The concentration of the pollutant in the effluent may be estimated from the result of a single sample analysis or by a measure of central tendency (arithmetic mean, geometric mean, median, etc.) of multiple sample analyses when all sample results are quantifiable (i.e., greater than or equal to the reported Minimum Level). When one or more sample results are reported as ND or DNQ, the central tendency concentration of the pollutant shall be the median (middle) value of the multiple samples, where DNQ is lower than a quantified value and ND is lower than DNQ. If, in an even number of samples, one or both of the middle values is ND or DNQ, the median will be the lower of the two middle values.

4. Sufficient sampling and analysis shall be required to determine compliance with the effluent limitation. If the analytical result of any single sample (daily discharge) monitored monthly, quarterly, semiannually, or annually, exceeds the AMEL, the Discharger shall increase sampling frequency to weekly until compliance with the AMEL is demonstrated. All analytical results shall be reported as specified in Section VIII—Compliance Determination.

5. Average Monthly Effluent Limitation (AMEL)

If the average (or when applicable, the median determined by subsection 3 above for multiple sample data reduction) of daily discharges over a calendar month exceeds the AMEL for a given parameter, an alleged violation will be flagged and the Discharger will be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). However, an alleged violation of the AMEL will be considered

one violation for the purpose of assessing mandatory minimum penalties. The average of daily discharges over a calendar month that exceeds the AMEL for a parameter will be considered out of compliance for that month only. If only a single sample (daily discharge) is taken over a calendar month and the analytical result for that sample exceeds the AMEL, the Discharger will be considered out of compliance for that month. If no sample (daily discharge) is taken over a calendar month, no compliance determination can be made for that month with respect to effluent violation determination, but compliance determination can be made for that month with respect to reporting violation determination.

6. Average Weekly Effluent Limitation (AWEL)

If the average of daily discharges over a calendar week exceeds the AWEL for a given parameter, an alleged violation will be flagged and the Discharger will be considered out of compliance for each day of that week for that parameter (e.g., resulting in seven days of non-compliance). However, an alleged violation of the AWEL will be considered one violation for the purpose of assessing mandatory minimum penalties. The average of daily discharges over a calendar week that exceeds the AWEL for a parameter will be considered out of compliance for that week only. If only a single sample (daily discharge) is taken over a calendar week and the analytical result for that sample exceeds the AWEL, the Discharger will be considered out of compliance for that week. If no sample (daily discharge) is taken over a calendar week, no compliance determination can be made for that week with respect to effluent violation determination, but compliance determination can be made for that week with respect to reporting violation determination.

A calendar week will begin on Sunday and end on Saturday. Partial calendar weeks at the end of the calendar month will be carried forward to the next month in order to calculate and report a consecutive seven-day average value on Saturday.

7. Maximum Daily Effluent Limitation (MDEL)

If a daily discharge on a calendar day exceeds the MDEL for a given parameter, an alleged violation will be flagged and the Discharger will be considered out of compliance for that day for that parameter. If no sample (daily discharge) is taken over a calendar day, no compliance determination can be made for that day with respect to effluent violation determination, but compliance determination can be made for that day with respect to reporting violation determination.

8. Instantaneous Minimum Effluent Limitation

If the analytical result of a single grab sample exceeds (is lower than) the instantaneous minimum effluent limitation for a given parameter, an alleged violation will be flagged and the Discharger will be considered out of compliance for that single sample for that parameter. Non-compliance for each single grab sample will be considered separately (e.g., the analytical results of two grab samples taken over a calendar day that are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

9. Instantaneous Maximum Effluent Limitation

If the analytical result of a single grab sample exceeds (is higher than) the instantaneous maximum effluent limitation for a given parameter, an alleged violation will be flagged and the Discharger will be considered out of compliance for that single sample for that parameter. Non-compliance for each single grab sample will be considered separately (e.g., the analytical results of two grab samples taken over a calendar day that both are higher than the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

10. Percent Removal

A percentage expression of the removal efficiency across a treatment plant for a given pollutant parameter, as determined from the 30-day average values of the raw wastewater influent pollutant concentrations to the facility and the 30-day average values of the effluent pollutant concentrations for a given time period.

Daily discharge percent removal is calculated using the following equation:
Percent Removal (%) = $[1 - (C_{\text{Effluent}} \div C_{\text{Influent}})] \times 100\%$

11. Mass and Concentration Limitations

Compliance with mass effluent limitations and concentration effluent limitations for the same parameter shall be determined separately. When the concentration for a parameter in a sample is reported as ND or DNQ, the corresponding mass emission rate determined using that sample concentration shall also be reported as ND or DNQ.

12. Mass Emission Rate

The daily discharge mass emission rate for any calendar day is calculated using the following equations:

$$\text{Daily Discharge mass emission rate (lb/day)} = \frac{8.337}{N} \sum_{i=1}^N Q_i C_i$$

$$\text{Daily Discharge mass emission rate (kg/day)} = \frac{3.785}{N} \sum_{i=1}^N Q_i C_i$$

in which “N” is the number of samples taken over any calendar day. If grab samples are taken, “Ci” is the constituent concentration (mg/L) and “Qi” is the flow rate (MGD) associated with each “N” grab sample. If composite samples are taken, “Ci” is the constituent concentration (mg/L) in each composite sample and “Qi” is the average flow rate (MGD) during the period over which sample compositing occurs.

The daily discharge concentration of a constituent shall be determined from the flow-weighted average of the same constituent in the combined waste stream using the following equations:

$$\text{Daily discharge concentration} = \frac{1}{Q_t} \sum_{i=1}^N Q_i C_i$$

in which “N” is the number of component waste streams. “Ci” is the constituent concentration (mg/L) and “Qi” is the flow rate (MGD) associated with each “N” component waste stream. “Qt” is the total flow rate of the combined waste stream.

13. Bacterial Standards and Analyses

The geometric mean used for determining compliance with bacterial standards is calculated using the following equation:

$$\text{Geometric Mean} = (C_1 \times C_2 \times \dots \times C_n)^{1/n}$$

where n is the number of days samples were collected during the period and C is the concentration of bacteria (MPN/100 mL or CFU/100 mL) found on each day of sampling.

For bacterial analyses, sample dilutions should be performed so the expected range of values is bracketed (for example, with multiple tube fermentation method or membrane filtration method, 2 to 16,000 per 100 ml for total and fecal coliform, at a minimum, and 1 to 1000 per 100 ml for *Enterococcus*). The detection method used for each analysis shall be reported with the results of the analysis.

Detection methods used for coliforms (total and fecal) and *Enterococcus* shall be those presented in Table 1A of 40 CFR 136 (revised revised July 1, 2009),

unless alternate methods have been approved by USEPA pursuant to 40 CFR 136 or improved methods have been determined by the Executive Officer and/or USEPA.

14. Single Operational Upset

A single operational upset (SOU) that leads to simultaneous violations of more than one pollutant parameter shall be treated as a single violation and limits the Discharger's liability in accordance with the following conditions:

A single operational upset is broadly defined as a single unusual event that temporarily disrupts the usually satisfactory operation of a system in such a way that it results in violation of multiple pollutant parameters.

A Discharger may assert SOU to limit liability only for those violations which the Discharger submitted notice of the upset as required in Attachment D – Standard Provisions.

For purpose outside of CWC section 13385(h) and (i), determination of compliance and civil liability (including any more specific definition of SOU, the requirements for Dischargers to assert the SOU limitation of liability, and the manner of counting violations) shall be in accordance with USEPA Memorandum "Issuance of Guidance Interpreting Single Operational Upset" (September 27, 1989).

For purpose of CWC section 13385(h) and (i), determination of compliance and civil liability (including any more specific definition of SOU, the requirements for Dischargers to assert the SOU limitation of liability, and the manner of counting violations) shall be in accordance with CWC section 13385(f)(2).

ATTACHMENT A – DEFINITIONS

Acute Toxicity:

a. Acute Toxicity (TUa)

Expressed in Toxic Units Acute (TUa)

$$TUa = \frac{100}{96\text{-hr LC } 50\%}$$

b. Lethal Concentration 50% (LC 50)

LC 50 (percent waste giving 50% survival of test organisms) shall be determined by static or continuous flow bioassay techniques using standard marine test species as specified in Ocean Plan Appendix III, Chapter II. If specific identifiable substances in wastewater can be demonstrated by the discharger as being rapidly rendered harmless upon discharge to the marine environment, but not as a result of dilution, the LC 50 may be determined after the test samples are adjusted to remove the influence of those substances.

When it is not possible to measure the 96-hour LC 50 due to greater than 50 percent survival of the test species in 100 percent waste, the toxicity concentration shall be calculated by the expression:

$$TUa = \frac{\log(100 - S)}{1.7}$$

where:

S = percentage survival in 100% waste. If S > 99, TUa shall be reported as zero.

Areas of Special Biological Significance (ASBS): are those areas designated by the State Water Board as ocean areas requiring protection of species or biological communities to the extent that alteration of natural water quality is undesirable. All Areas of Special Biological Significance are also classified as a subset of STATE WATER QUALITY PROTECTION AREAS.

Average Monthly Effluent Limitation (AMEL) means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month. (40 CFR 122.2.)

Average Weekly Effluent Limitation (AWEL) means the highest allowable average of “daily discharges” over a calendar week (Sunday through Saturday), calculated as the sum of all “daily discharges” measured during a calendar week divided by the number of “daily discharges” measured during that week. (40 CFR 122.2.)

Chlordane shall mean the sum of chlordane-alpha, chlordane-gamma, chlordene-alpha, chlordene-gamma, nonachlor-alpha, nonachlor-gamma, and oxychlordane.

Chronic Toxicity: This parameter shall be used to measure the acceptability of waters for supporting a healthy marine biota until improved methods are developed to evaluate biological response.

a. Chronic Toxicity (TUc)

Expressed as Toxic Units Chronic (TUc)

$$TUc = \frac{100}{NOEL}$$

b. No Observed Effect Level (NOEL)

The NOEL is expressed as the maximum percent effluent or receiving water that causes no observable effect on a test organism, as determined by the result of a critical life stage toxicity test listed in Ocean Plan Appendix III.

Composite Sample, for flow rate measurements, means the arithmetic mean of no fewer than eight individual measurements taken at equal intervals for 24 hours or for the duration of discharge, whichever is shorter.

Composite sample, for other than flow rate measurements, means:

- a. No fewer than eight individual sample portions taken at equal time intervals for 24 hours, or the duration of the discharge, whichever is shorter. The volume of each individual sample portion shall be directly proportional to the discharge flow rate at the time of sampling; or,
- b. No fewer than eight individual sample portions taken of equal time volume taken over a 24 hour period. The time interval between each individual sample portion shall vary such that the volume of the discharge between each individual sample portion remains constant.

The compositing period shall equal the specified sampling period, or 24 hours, if no period is specified.

For a composite sample, if the duration of the discharge is less than 24 hours but greater than 8 hours, at least eight flow-weighted individual sample portions shall be taken during the duration of the discharge and composited. For a discharge duration of 8 hours or less, eight individual "grab samples" may be substituted and composited.

The composite sample result shall be reported for the calendar day during which composite sampling ends.

Daily Discharge means the “discharge of a pollutant” measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the “daily discharge” is calculated as the average measurement of the pollutant over the day. (40 CFR 122.2.)

DDT shall mean the sum of 4,4'DDT, 2,4'DDT, 4,4'DDE, 2,4'DDE, 4,4'DDD, and 2,4'DDD.

Degrade. Degradation shall be determined by comparison of the waste field and reference site(s) for characteristic species diversity, population density, contamination, growth anomalies, debility, or supplanting of normal species by undesirable plant and animal species. Degradation occurs if there are significant differences in any of three major biotic groups, namely, demersal fish, benthic invertebrates, or attached algae. Other groups may be evaluated where benthic species are not affected, or are not the only ones affected.

Detected, but Not Quantified (DNQ) means sample results less than the reported Minimum Level, but greater than or equal to the laboratory's MDL.

Dichlorobenzenes shall mean the sum of 1,2- and 1,3-dichlorobenzene.

Downstream Ocean Waters shall mean waters downstream with respect to ocean currents.

Dredged Material: Any material excavated or dredged from the navigable waters of the United States, including material otherwise referred to as “spoil”.

Enclosed Bays are indentations along the coast, which enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. This definition includes but is not limited to: Humboldt Bay, Bodega Harbor, Tomales Bay, Drakes Estero, San Francisco Bay, Morro Bay, Los Angeles Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay.

Endosulfan shall mean the sum of endosulfan-alpha and -beta and endosulfan sulfate.

Estuaries and Coastal Lagoons are waters at the mouths of streams that serve as mixing zones for fresh and ocean waters during a major portion of the year. Mouths of streams that are temporarily separated from the ocean by sandbars shall be considered as estuaries. Estuarine waters will generally be considered to extend from a bay or the open ocean to the upstream limit of tidal action but may be considered to extend seaward if significant mixing of fresh and salt water occurs in the open coastal waters. The waters described by this definition include but are not limited to the Sacramento-San Joaquin Delta as defined by section 12220 of the California Water Code, Suisun Bay, Carquinez Strait downstream to Carquinez Bridge, and appropriate areas of the Smith, Klamath, Mad, Eel, Noyo, and Russian Rivers.

Grab Sample means an individual sample collected during a period of time not to exceed 15 minutes. Grab samples shall be collected during normal peak loading conditions for the parameter of interest, which may or may not occur during hydraulic peaks.

Halomethanes shall mean the sum of bromoform, bromomethane (methyl bromide) and chloromethane (methyl chloride).

HCH shall mean the sum of the alpha, beta, gamma (lindane) and delta isomers of hexachlorocyclohexane.

Initial Dilution is the process that results in the rapid and irreversible turbulent mixing of wastewater with ocean water around the point of discharge.

For a submerged buoyant discharge, characteristic of most municipal and industrial wastes that are released from the submarine outfalls, the momentum of the discharge and its initial buoyancy act together to produce turbulent mixing. Initial dilution in this case is completed when the diluting wastewater ceases to rise in the water column and first begins to spread horizontally.

For shallow water submerged discharges, surface discharges, and non-buoyant discharges, characteristic of cooling water wastes and some individual discharges, turbulent mixing results primarily from the momentum of discharge. Initial dilution, in these cases, is considered to be completed when the momentum induced velocity of the discharge ceases to produce significant mixing of the waste, or the diluting plume reaches a fixed distance from the discharge to be specified by the Regional Water Board, whichever results in the lower estimate for initial dilution.

Instantaneous Maximum Effluent Limitation: the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum effluent limitation).

Instantaneous Minimum Effluent Limitation: the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum effluent limitation).

Kelp Beds, for purposes of the bacteriological standards of the Ocean Plan, are significant aggregations of marine algae of the genera Macrocystis and Nereocystis. Kelp beds include the total foliage canopy of Macrocystis and Nereocystis plants throughout the water column.

Mariculture is the culture of plants and animals in marine waters independent of any pollution source.

Material: (a) In common usage: (1) the substance or substances of which a thing is made or composed (2) substantial; (b) For purposes of the Ocean Plan relating to waste disposal, dredging and the disposal of dredged material and fill, MATERIAL means matter of any kind or description which is subject to regulation as waste, or any material dredged from the navigable waters of the United States. See also, DREDGED MATERIAL.

Maximum Daily Effluent Limitation (MDEL) means the highest allowable “daily discharge”. (40 CFR Part 122.2.)

MDL (Method Detection Limit) is the minimum concentration of a substance that can be measured and reported with 99% confidence that the analyte concentration is greater than zero, as defined in 40 CFR part 136, Appendix B.

Minimum Level (ML) is the concentrations at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method-specified sample weights, volumes and processing steps have been followed.

Natural Light: Reduction of natural light may be determined by the Regional Water Board by measurement of light transmissivity or total irradiance, or both, according to the monitoring needs of the Regional Water Board.

Not Detected (ND) means those sample results less than the laboratory’s MDL.

Ocean Waters are the territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. If a discharge outside the territorial waters of the State could affect the quality of the waters of the State, the discharge may be regulated to assure no violation of the Ocean Plan will occur in ocean waters.

PAHs (polynuclear aromatic hydrocarbons) shall mean the sum of acenaphthylene, anthracene, 1,2-benzanthracene (benzo[a]anthracene), 3,4-benzofluoranthene (benzo[b]fluoranthene), benzo[k]fluoranthene, 1,12-benzoperylene (benzo[ghi]perylene), benzo[a]pyrene, chrysene, dibenzo[ah]anthracene, fluorene, indeno[1,2,3-cd]pyrene, phenanthrene and pyrene.

PCBs (polychlorinated biphenyls) shall mean the sum of chlorinated biphenyls whose analytical characteristics resemble those of Aroclor-1016, Aroclor-1221, Aroclor-1232, Aroclor-1242, Aroclor-1248, Aroclor-1254 and Aroclor-1260.

Pollutant Minimization Program (PMP) means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a pollutant through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, in order to maintain the effluent concentration at or below the effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to

California Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements in Ocean Plan section III.C.9.

Publicly Owned Treatment Works. The term Publicly Owned Treatment Works or POTW means a treatment works as defined by section 212 of the Act, which is owned by a State or municipality (as defined by section 502(4) of the Act). This definition includes any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage or industrial wastes of a liquid nature. It also includes sewers, pipes and other conveyances only if they convey wastewater to a POTW Treatment Plant. The term also means the municipality which has jurisdiction over the Indirect Discharges to and the discharges from such treatment works. (40 CFR 403.3(q).)

Reported Minimum Level is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in their permit. The MLs included in this permit correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board in accordance with Ocean Plan section III.C.5. The ML is based on the proper application of method-specific analytical procedures and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the reported ML. (See Ocean Plan section III.C.6.)

Shellfish are organisms identified by the California Department of Health Services as shellfish for public health purposes (i.e., mussels, clams and oysters).

Significant Difference is defined as a statistically significant difference in the means of two distributions of sampling results at the 95 percent confidence level.

Six-month Median Effluent Limitation: the highest allowable moving median of all “daily discharges” for any 180-day period.


State Water Quality Protection Areas (SWQPAs) are non-terrestrial marine or estuarine areas designated to protect marine species or biological communities from an undesirable alteration in natural water quality. All AREAS OF SPECIAL BIOLOGICAL SIGNIFICANCE (ASBS) that were previously designated by the State Water Board in Resolutions 74-28, 74-32, and 75-61 are now also classified as a subset of State Water Quality Protection Areas and require special protections afforded by the Ocean Plan.

TCDD Equivalentents shall mean the sum of the concentrations of chlorinated dibenzodioxins (2,3,7,8-CDDs) and chlorinated dibenzofurans (2,3,7,8-CDFs) multiplied by their respective toxicity factors, as shown in the table below.

| Isomer Group | Toxicity Equivalence Factor |
|---------------------|-----------------------------------|
| 2,3,7,8-tetra CDD | 1.0 |
| 2,3,7,8-penta CDD | 0.5 |
| 2,3,7,8-hexa CDDs | 0.1 |
| 2,3,7,8-hepta CDD | 0.01 |
| octa CDD | 0.001 |
| | |
| 2,3,7,8 tetra CDF | 0.1 |
| 1,2,3,7,8 penta CDF | 0.05 |
| 2,3,4,7,8 penta CDF | 0.5 |
| 2,3,7,8 hexa CDFs | 0.1 |
| 2,3,7,8 hepta CDFs | 0.01 |
| octa CDF | 0.001 |

Water Reclamation: The treatment of wastewater to render it suitable for reuse, the transportation of treated wastewater to the place of use, and the actual use of treated wastewater for a direct beneficial use or controlled use that would not otherwise occur.


ATTACHMENT B – MAP



Attachment B – Map
(May 20, 2010; Revised: October 12, 2010 & November 4, 2010)

ATTACHMENT C-1 – FLOW SCHEMATIC

Hyperion Treatment Plant
Process Flow Diagram



Annual Average Flow Data*

| Ref. Pt. | Flow (MGD) | Ref. Pt. | Flow (MGD) | Ref. Pt. | Flow (MGD) | Ref. Pt. | Flow (MGD) | Ref. Pt. | Flow (MGD) | Ref. Pt. | Flow (MGD) | Ref. Pt. | Flow (MGD) |
|----------|------------|----------|------------|----------|------------|----------|------------|----------|------------|----------|------------|----------|------------|
| 1 | 306 | 5 | 0 | 9 | 406 | 13 | 6.7 | 17 | 99 | 21 | 1.9 | 25 | 3.13 |
| 2 | 309 | 6 | 1.31 | 10 | 306 | 14 | 4.7 | 18 | 8.9 | 22 | 2.32 | 26 | 2.86 |
| 3 | 321 | 7 | 94 | 11 | 31.9 | 15 | 263 | 19 | 8.5 | 23 | N/A | 27 | N/A |
| 4 | 97 | 8 | 321 | 12 | 274 | 16 | 268 | 20 | 0.42 | 24 | ND | 28 | ND |

*Annual Average Flow Data From October 2008 to September 2009 (MPR)

City of Los Angeles- Bureau of Sanitation
Regulatory Affairs Division

April 22, 2010

ATTACHMENT D – STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order/Permit. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 CFR part 122.41(a))
2. The Discharger shall comply with effluent standards or prohibitions established under section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order/Permit has not yet been modified to incorporate the requirement. (40 CFR part 122.41(a)(1))

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order/Permit. (40 CFR part 122.41(c))

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order/Permit that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR part 122.41(d))

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order/Permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order/Permit. (40 CFR part 122.41(e))

E. Property Rights

1. This Order/Permit does not convey any property rights of any sort or any exclusive privileges. (40 CFR part 122.41(g))
2. The issuance of this Order/Permit does not authorize any injury to persons or property or invasion of other private rights, or any infringement of State or local law or regulations. (40 CFR part 122.5(c))

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 CFR part 122.41(i); California Water Code (CWC) § 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order/Permit (40 CFR part 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order/Permit (40 CFR part 122.41(i)(2));
3. Inspect and photograph at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order/Permit (40 CFR part 122.41(i)(3)); and
4. Sample or monitor at reasonable times for the purposes of assuring Order/Permit compliance or as otherwise authorized by the CWA or the CWC, any substances or parameters at any location. (40 CFR part 122.41(i)(4))

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR part 122.41(m)(1)(i))
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 CFR part 122.41(m)(1)(ii))

2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5. (40 CFR part 122.41(m)(2))
3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board and USEPA may take enforcement action against a Discharger for bypass, unless (40 CFR part 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR part 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass, which occurred during normal periods of equipment downtime or preventive maintenance (40 CFR part 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Regional Water Board and USEPA as required under Standard Provisions – Permit Compliance I.G.5 below. (40 CFR part 122.41(m)(4)(i)(C))
4. The Regional Water Board and USEPA may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board and USEPA determine that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3. (40 CFR part 122.41(m)(4)(ii))
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 CFR part 122.41(m)(3)(i))
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E (24-hour notice). (40 CFR part 122.41(m)(3)(ii))

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed

treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR part 122.41(n)(1))

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR part 122.41(n)(2))
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR part 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 CFR part 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 CFR part 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR part 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR part 122.41(n)(3)(iv))
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 CFR part 122.41(n)(4))

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order/Permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order/Permit condition. (40 CFR part 122.41(f))

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order/Permit after the expiration date of this Order/Permit, the Discharger must apply for and obtain a new Order/Permit. (40 CFR part 122.41(b))

C. Transfers

This Order/Permit is not transferable to any person except after notice to the Regional Water Board and USEPA. The Regional Water Board and USEPA may require modification or revocation and reissuance of the Order/Permit to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and CWC. (See 40 CFR part 122.61; in some cases, modification or revocation and reissuance is mandatory.) (40 CFR part 122.41(l)(3).)

III. STANDARD PROVISIONS – MONITORING

- A.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR part 122.41(j)(1))
- B.** Monitoring results must be conducted according to test procedures under 40 CFR part 136 or, in the case of sludge use or disposal, approved under 40 CFR part 136 unless otherwise specified in 40 CFR part 503 unless other test procedures have been specified in the Order/Permit. (40 CFR part 122.41(j)(4))

IV. STANDARD PROVISIONS – RECORDS

- A.** Except for records of monitoring information required by this Order/Permit related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order/Permit, and records of all data used to complete the application for this Order/Permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer or USEPA Water Division Director at any time. (40 CFR part 122.41(j)(2).) It is recommended that the Discharger maintain the results of all analyses indefinitely.
- B. Records of monitoring information shall include:**
 - 1. The date, exact place, and time of sampling or measurements (40 CFR part 122.41(j)(3)(i));

2. The individual(s) who performed the sampling or measurements (40 CFR part 122.41(j)(3)(ii));
3. The date(s) analyses were performed (40 CFR part 122.41(j)(3)(iii));
4. The individual(s) who performed the analyses (40 CFR part 122.41(j)(3)(iv));
5. The analytical techniques or methods used (40 CFR part 122.41(j)(3)(v)); and
6. The results of such analyses. (40 CFR part 122.41(j)(3)(vi))

C. Claims of confidentiality for the following information will be denied (40 CFR part 122.7(b)):

1. The name and address of any permit applicant or Discharger (40 CFR part 122.7(b)(1)); and
2. Permit applications, permits and effluent data. (40 CFR part 122.7(b)(2))

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA, within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order/Permit or to determine compliance with this Order/Permit. The Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA, upon request, copies of records required to be kept by this Order/Permit. (40 CFR part 122.41(h); CWC § 13267)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5. See 40 CFR § 122.22.
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR part 122.22(a)(3))

3. All reports required by this Order/Permit and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2, or by a duly authorized representative of that person. A person is a duly authorized representative only if (40 CFR §122.22(b):
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 (40 CFR part 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR part 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board, State Water Board, and USEPA. (40 CFR part 122.22(b)(3))
4. If an authorization under Standard Provisions – Reporting V.B.3 is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 must be submitted to the Regional Water Board, State Water Board, and USEPA prior to or together with any reports, information, or applications to be signed by an authorized representative. (40 CFR part 122.22(c))
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 CFR part 122.22(d))

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified elsewhere in this Order/Permit. (40 CFR part 122.41(l)(4))

2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board, State Water Board, or USEPA for reporting results of monitoring of sludge use or disposal practices. (40 CFR part 122.41(l)(4)(i))
3. If the Discharger monitors any pollutant more frequently than required by this Order/Permit using test procedures approved under 40 CFR part 136 or, in the case of sludge use or disposal, approved under 40 CFR part 136 unless otherwise specified in 40 CFR part 503, or as specified in this Order/Permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board or USEPA. (40 CFR part 122.41(l)(4)(ii))
4. Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this Order/Permit. (40 CFR part 122.41(l)(4)(iii))

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order/Permit, shall be submitted no later than 14 days following each schedule date. (40 CFR part 122.41(l)(5))

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided to the Regional Water Board within 5 days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR § 122.41(l)(6)(i))
2. The following shall be included as information that must be reported within 24 hours under this paragraph (See 40 CFR § 122.41(g)) (40 CFR part 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in the Order/Permit (See 40 CFR part 122.41(g))
 - b. Any upset that exceeds any effluent limitation in this Order/Permit. (40 CFR part 122.41(l)(6)(ii)(B))

- c. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in the Order/Permit to be reported within 24 hours (See 40 CFR 122.44(g).) (40 CFR 122.41(6)(ii)(C).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours (40 CFR part 122.41(l)(6)(iii)).

F. Planned Changes

The Discharger shall give notice to the Regional Water Board and USEPA as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when (40 CFR part 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR part 122.29(b) (40 CFR part 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the Order/Permit, nor to notification requirements under 40 CFR § 122.42(a)(1) (see Additional Provisions — Notification Levels VII.A.1). (40 CFR part 122.41(l)(1)(ii))
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of Order/Permit conditions that are different from or absent in the Order/Permit, including notification of additional use or disposal sites not reported during the Order/Permit application process or not reported pursuant to an approved land application plan. (40 CFR part 122.41(l)(1)(iii))

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board and USEPA of any planned changes in the permitted facility or activity that may result in noncompliance with General Order/Permit requirements. (40 CFR part 122.41(l)(2))

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E, at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR part 122.41(l)(7))

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in an Order/Permit application, or submitted incorrect information in an Order/Permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 CFR part 122.41(l)(8))

VI. STANDARD PROVISIONS – ENFORCEMENT

- A. The Regional Water Board is authorized to enforce the terms of this Order/Permit under provisions of the California Water Code including, but not limited to, sections 13385, 13386, and 13387.
- B. The CWA provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The CWA provides that any person who *negligently* violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both. Any person who *knowingly* violates such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions (40 CFR 122.41(a)(2)).

- C.** Any person may be assessed an administrative penalty by the Administrator for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000. (40 CFR 122.41(a)(3)).
- D.** The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both. (40 CFR 122.41(j)(5))
- E.** The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both. (40 CFR 122.41(k)(2)).

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board and USEPA of the following (40 CFR part 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to section 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR part 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order/Permit. (40 CFR part 122.42(b)(2))
3. For the purposes of this paragraph, adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR part 122.42(b)(3))

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Table of Contents

| | |
|--|------|
| Attachment E – Monitoring and Reporting Program (MRP) | E-3 |
| I. General Monitoring Provisions | E-3 |
| II. Monitoring Locations | E-6 |
| III. Influent Monitoring Requirements | E-10 |
| A. Monitoring Locations INF-001, INF-002, INF-003, INF-004, and INF-005 | E-10 |
| IV. Effluent Monitoring Requirements | E-12 |
| A. Monitoring Locations - EFF-001 and EFF-002 | E-12 |
| V. Whole Effluent Toxicity Testing Requirements | E-19 |
| A. Acute Toxicity Testing for Discharge Point 002 | E-19 |
| B. Chronic Toxicity Testing for Discharge Points 002 and 001 | E-20 |
| C. Quality Assurance | E-21 |
| D. Accelerated Monitoring | E-22 |
| E. Preparation of an Initial Investigation TRE Workplan | E-23 |
| F. Steps in Toxicity Reduction Evaluation (TRE) and Toxicity Identification Evaluation (TIE) | E-23 |
| G. Ammonia Removal | E-24 |
| H. Reporting | E-25 |
| VI. Receiving Water Monitoring Requirements | E-27 |
| A. Inshore Water Quality Monitoring | E-27 |
| B. Offshore Water Quality Monitoring | E-28 |
| C. Benthic Infauna and Sediment Chemistry Monitoring | E-30 |
| D. Fish and Invertebrate (Trawl and Rig Fishing) Monitoring | E-34 |
| E. Kelp Bed Monitoring | E-40 |
| VII. Other Monitoring Requirements | E-42 |
| A. Special Study - Constituents of Emerging Concern in Effluent | E-42 |
| B. Special Study - Nutrient Loading and Receiving Water Impacts | E-45 |
| C. Outfall and Diffuser Inspection | E-45 |
| D. Biosolids and Sludge Management | E-45 |
| E. Hauling Reports | E-49 |
| VIII. Reporting Requirements | E-46 |
| A. General Monitoring and Reporting Requirements | E-46 |
| B. Self Monitoring Reports (SMRs) and Discharge Monitoring Reports (DMRs) | E-51 |
| C. Other Reports | E-53 |

List of Tables

| | |
|---|------|
| Table 1. Monitoring Station Locations | E-7 |
| Table 2. Influent Monitoring | E-10 |
| Table 3. Effluent Monitoring | E-13 |
| Table 4. 12-Month Average Effluent Mass Emission Benchmarks | E-16 |
| Table 5. Inshore Monitoring Stations | E-27 |
| Table 6. Inshore Microbiological Monitoring Requirements | E-27 |
| Table 7. Offshore Monitoring Stations | E-28 |

Attachment E – MRP E-1

May 20, 2010; (Revised: October 12, 2010 & November 4, 2010)

| | | |
|-----------|--|------|
| Table 8. | Offshore Water Quality Monitoring Requirements | E-29 |
| Table 9. | Additional Offshore Water Quality Monitoring Requirements..... | E-29 |
| Table 10. | Benthic Infauna, Sediment Chemistry, and Trawl Monitoring Stations | E-31 |
| Table 11. | Benthic Infauna and Sediment Chemistry Monitoring Requirements..... | E-32 |
| Table 12. | Local Demersal Fish and Macroinvertebrate Monitoring Stations..... | E-34 |
| Table 13. | Local Bioaccumulation Sampling Zones | E-36 |
| Table 14. | Local Bioaccumulation Monitoring Requirements | E-36 |
| Table 15. | Local Seafood Safety Survey Zones..... | E-38 |
| Table 16. | Local Seafood Safety Monitoring Requirements..... | E-38 |
| Table 17. | Effluent Monitoring of CECs..... | E-43 |
| Table 18. | Monitoring Periods and Reporting Schedule | E-51 |

List of Figures

| | | |
|-----------|---|------|
| Figure 1. | Offshore Water Quality Station Locations..... | E-55 |
| Figure 2. | Offshore Benthic Sediments and Macrofauna Station Locations for Fixed Stations plus Year 1 Random Stations..... | E-56 |
| Figure 3. | Offshore Benthic Sediments and Macrofauna Station Locations for Fixed Stations plus Year 2 Random Station..... | E-57 |
| Figure 4. | Trawl Station Locations Including Fixed Stations and Example of a Combined Array of Year 1 and Year 2 Stations..... | E-58 |
| Figure 5. | Local Seafood Survey Zones as Defined by SMBRC Seafood Tissue Monitoring Design. | E-59 |

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

The Code of Federal Regulations¹ (CFR) at 40 CFR 122.48 requires that all NPDES permits specify monitoring and reporting requirements. CWC sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A. NPDES compliance monitoring focuses on the effects of a specific point source discharge. Generally, it is not designed to assess impacts from other sources of pollution (e.g., nonpoint source runoff, aerial fallout) or to evaluate the current status of important ecological resources in the water body. The scale of existing compliance monitoring programs does not match the spatial and, to some extent, temporal boundaries of the important physical and biological processes in the ocean. In addition, the spatial coverage provided by compliance monitoring programs is less than ten percent of the nearshore ocean environment. Better technical information is needed about status and trends in ocean waters to guide management and regulatory decisions, to verify the effectiveness of existing programs, and to shape policy on marine environmental protection.
- B. The Regional Water Board and USEPA, working with other groups, have developed a comprehensive basis for effluent and receiving water monitoring appropriate to large publicly owned treatment works (POTWs) discharging to waters of the Southern California Bight. This effort has culminated in the publication by the Southern California Coastal Water Research Project (SCCWRP) of the Model Monitoring Program guidance document (Schiff, K.C., J.S. Brown and S.B. Weisberg. 2001. *Model Monitoring Program for Large Ocean Dischargers in Southern California*. SCCWRP Tech. Rep. #357. Southern California Coastal Water Research Project, Westminster, CA. 101 pp.). This guidance provides the principles, framework and recommended design for effluent and receiving water monitoring elements that have guided development of the monitoring program described below.
- C. In July 2000, the Santa Monica Bay Restoration Project (SMBRP) published “An Assessment of the Compliance Monitoring System in Santa Monica Bay” to set forth recommendations and priorities for compliance monitoring in Santa Monica Bay. This report reasoned that a reduced level of receiving water monitoring is justified for large POTWs discharging to Santa Monica Bay due to improvements in effluent quality and associated decreases in receiving water impacts. Like the Model Monitoring Plan developed by SCCWRP, SMBRP recommendations are focused on

¹ All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated and will be abbreviated as “40 CFR part number”.

providing answers to management questions and allowing a reduction in POTW receiving water monitoring where discharge effects are well understood. The monitoring plan set forth here has been guided by SMBRP recommendations.

D. The conceptual framework for the Model Monitoring Program has three components that comprise a range of spatial and temporal scales: (1) core monitoring; (2) regional monitoring; and (3) special studies.

1. Core monitoring is local in nature and focused on monitoring trends in quality and effects of the point source discharge. This includes effluent monitoring as well as some aspects of receiving water monitoring. In the monitoring program described below, these core components are typically referred to as local monitoring.

2. Regional monitoring is focused on questions that are best answered by a region-wide approach that incorporates coordinated survey design and sampling techniques. The major objective of regional monitoring is to collect information required to assess how safe it is to swim in the ocean, how safe it is to eat seafood from the ocean, and whether the marine ecosystem is being protected. Key components of regional monitoring include elements to address pollutant mass emission estimations, public health concerns, monitoring of trends in natural resources, assessment of regional impacts from all contaminant sources, and protection of beneficial uses. The final design of regional monitoring programs is developed by means of steering committees and technical committees comprised of participating agencies and organizations and is not specified in this Order/Permit. Instead, for each regional component, the degree and nature of participation of the Discharger is specified. For this Order/Permit, these levels of effort are based upon past participation of the Discharger in regional monitoring programs.

The Discharger shall participate in regional monitoring activities coordinated by the SCCWRP or any other appropriate agency approved by the Regional Water Board and USEPA. The procedures and time lines for the Regional Water Board and USEPA approval shall be the same as detailed for special studies, below.

3. Special studies are focused on refined questions regarding specific effects or development of monitoring techniques and are anticipated to be of short duration and/or small scale, although multiyear studies also may be needed. Questions regarding effluent or receiving water quality, discharge impacts, ocean processes in the area of the discharge, or development of techniques for monitoring the same, arising out of the results of core or regional monitoring, may be pursued through special studies. These studies are by nature ad hoc and cannot be typically anticipated in advance of the five-year permit cycle.

The Discharger, the Regional Water Board and USEPA shall consult annually to determine the need for special studies. Each year, the Discharger shall

submit proposals for any proposed special studies to the Regional Water Board and USEPA by December 31st for the following year's monitoring effort (July through June). The following year, detailed scopes of work for proposals, including reporting schedules, shall be presented by the Discharger at a Spring Regional Water Board meeting, to obtain the Regional Water Board approval and to inform the public. Upon approval by the Regional Water Board and USEPA, the Discharger shall implement its special study or studies.

- E. Bight Regional Monitoring.** Regular regional monitoring for the Southern California Bight has been established, occurring at five-year intervals, and is coordinated through SCCWRP with discharger agencies and numerous other entities. The fourth regional monitoring program (Bight '08) occurred primarily during summer 2008. The next (fifth) regional monitoring program (Bight '13) is expected to take place during 2013. While participation in regional monitoring programs is required under this Order/Permit, revisions to the Discharger's monitoring program at the direction of the Regional Water Board and USEPA may be necessary to accomplish the goals of regional monitoring or to allow the performance of special studies to investigate regional or site-specific water issues of concern. These revisions may include a reduction or increase in the number of parameters to be monitored, the frequency of monitoring, or the number and size of samples to be collected. Such changes may be authorized by the Regional Water Board Executive Officer and USEPA Director upon written notification to the Discharger.

Discharger participation in regional monitoring programs is required as a condition of this Order/Permit. The Discharger shall complete collection and analysis of samples in accordance with the schedule established by the Steering Committee directing the Bight-wide regional monitoring surveys. The level of participation shall be similar to that provided by the Discharger in previous regional surveys conducted in 1994, 1998, 2003, and 2008.

- F. Bay Comprehensive Monitoring Program.** The Santa Monica Bay Restoration Commission adopted a new comprehensive monitoring program for Santa Monica Bay in April 2007. This new monitoring program, developed by the Commission's Technical Advisory Committee, culminates efforts that began in the mid 1990s with the identification of key management questions and monitoring priorities. It lays out new monitoring designs for five major habitats within the Bay:

- Pelagic Ecosystem
- Soft Bottom Ecosystem
- Hard Bottom Ecosystem
- Rocky and Sandy Intertidal
- and Wetlands.

Design for each habitat includes a core motivating question, a number of related objectives, specific monitoring approaches, indicators, data products, and sampling designs detailing number and locations of stations, sampling frequency, and measurements to be collected. The Bay Monitoring Program also includes an

implementation plan that includes a detailed schedule, cost estimates for individual Program elements, and recommendations on the Program's management structure, including data management and assessment strategies.

The Bay Monitoring Program is designed to be implemented in part through modifications to existing receiving water monitoring programs for major NPDES dischargers into coastal ocean waters. Some elements of this monitoring program already have been implemented, for example, through establishment of periodic Bight-wide regional monitoring surveys (Southern California Bight Pilot Project '94, Bight '98, Bight '03, and Bight '08) and kelp bed monitoring. However, other elements of the program have yet to be implemented.

SMBRC, USEPA, the Regional Water Board, the Discharger, affected NPDES permit holders, and other interested agencies and stakeholders will develop plans to collaboratively fund these elements of the program and determine each party's level of participation. It is anticipated that funding for the program from the City of Los Angeles will be supplied through a combination of modifications to the Hyperion Treatment Plant's Monitoring and Reporting Program, including redirection of existing effort and new monitoring efforts relevant to the Hyperion Treatment Plant's discharge. Redirection of existing monitoring requirements and/or the imposition of additional monitoring efforts conducted under the terms of this Order/Permit are subject to a public hearing before the Regional Water Board and public notice by USEPA. This Order/Permit may be reopened and modified by the Regional Water Board and USEPA to incorporate conforming monitoring requirements and schedule dates for implementation of the Comprehensive Monitoring Program for Santa Monica Bay (Santa Monica Bay Restoration Commission, January 2007).

Each year, at a Spring Regional Water Board meeting, the Discharger shall provide an informational report summarizing to date its contributing activities towards coordinated implementation of the Comprehensive Monitoring Program for Santa Monica Bay (SMBRC, January 2007).

- G.** This monitoring program for Hyperion Treatment Plant is comprised of requirements to demonstrate compliance with the conditions of the NPDES permit, ensure compliance with State water quality standards, and mandate participation in regional monitoring and/or area-wide studies.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order/Permit:

Table 1. Monitoring Station Locations

| Influent and Effluent Monitoring Stations | | | | | | | | | |
|---|------------------|---------------------------------|-------------------|--|----------------|------------------|--------|-------------------|--------|
| Discharge Point Name | | Monitoring Location Name | | Monitoring Location Description | | | | | |
| Influent Monitoring Station | | | | | | | | | |
| -- | | INF-001 | | North Outfall Relief Sewer - Sampling stations shall be established at each point of inflow to the sewage treatment plant and shall be located upstream of any in-plant return flows and where representative samples of the influent can be obtained. (33.93061°N, 118.43317°W) | | | | | |
| -- | | INF-002 | | North Central Outfall Sewer - Sampling stations shall be established at each point of inflow to the sewage treatment plant and shall be located upstream of any in-plant return flows and where representative samples of the influent can be obtained. (33.9306°N, 118.43326°W) | | | | | |
| -- | | INF-003 | | Central Outfall Sewer - Sampling stations shall be established at each point of inflow to the sewage treatment plant and shall be located upstream of any in-plant return flows and where representative samples of the influent can be obtained. (33.93033°N, 118.43353°W) | | | | | |
| -- | | INF-004 | | North Outfall Sewer - Sampling stations shall be established at each point of inflow to the sewage treatment plant and shall be located upstream of any in-plant return flows and where representative samples of the influent can be obtained. (33.92782°N, 118.43331°W) | | | | | |
| -- | | INF-005 | | Coastal Interceptor Sewer - Sampling stations shall be established at each point of inflow to the sewage treatment plant and shall be located upstream of any in-plant return flows and where representative samples of the influent can be obtained. (33.92746°N, 118.44318°W) | | | | | |
| Effluent Monitoring Station | | | | | | | | | |
| 001 | | EFF-001 | | Sampling station shall be located downstream of any in-plant return flows but before entering the discharge tunnel where representative samples of the effluent discharged through Discharge Point 001 can be obtained. (33.92417°N, 118.4314°W) | | | | | |
| 002 | | EFF-002 | | Sampling station shall be located downstream of any in-plant return flows but before entering the discharge tunnel where representative samples of the effluent discharged through Discharge Point 002 can be obtained. (33.92527°N, 118.43195°W) | | | | | |
| Receiving Water Monitoring Stations | | | | | | | | | |
| Inshore Water Quality Monitoring Stations | | | | | | | | | |
| Station | Latitude* | | Longitude* | | Station | Latitude* | | Longitude* | |
| RW-IS-01 | 33 | 59.833 | 118 | 48.067 | RW-IS-07 | 33 | 58.550 | 118 | 28.317 |
| RW-IS-02 | 34 | 00.950 | 118 | 46.967 | RW-IS-08 | 33 | 57.567 | 118 | 27.583 |
| RW-IS-03 | 34 | 01.717 | 118 | 44.117 | RW-IS-09 | 33 | 56.900 | 118 | 27.133 |
| RW-IS-04 | 34 | 01.833 | 118 | 40.383 | RW-IS-10 | 33 | 56.283 | 118 | 26.817 |
| RW-IS-05 | 34 | 02.050 | 118 | 34.833 | RW-IS-11 | 33 | 50.000 | 118 | 23.850 |
| RW-IS-06 | 34 | 00.201 | 118 | 29.923 | | | | | |
| <p>Note: IS-01 to IS-11 shall be sampled at a distance of 100 ft from the shoreline or at the 30-ft depth contour, whichever is further from shore (except that station IS-11 is located at King Harbor in Redondo Beach).</p> <p>* Given in decimal minutes.</p> | | | | | | | | | |

| Offshore Water Quality Monitoring Stations | | | | | | | | | | |
|---|------------------|--------|-------------------|--------|--|----------------|------------------|--------|-------------------|--------|
| Station | Latitude* | | Longitude* | | | Station | Latitude* | | Longitude* | |
| RW-OS-3201 | 33 | 51.250 | 118 | 24.367 | | RW-OS-3604** | 33 | 56.416 | 118 | 30.586 |
| RW-OS-3202 | 33 | 50.917 | 118 | 25.067 | | RW-OS-3605** | 33 | 55.666 | 118 | 32.133 |
| RW-OS-3203 | 33 | 50.717 | 118 | 25.583 | | RW-OS-3606** | 33 | 55.000 | 118 | 33.500 |
| RW-OS-3204** | 33 | 50.217 | 118 | 26.433 | | RW-OS-3701 | 33 | 59.166 | 118 | 29.166 |
| RW-OS-3205** | 33 | 49.433 | 118 | 27.817 | | RW-OS-3702 | 33 | 58.800 | 118 | 30.000 |
| RW-OS-3206 | 33 | 49.666 | 118 | 29.567 | | RW-OS-3703 | 33 | 58.450 | 118 | 30.600 |
| RW-OS-3301 | 33 | 53.583 | 118 | 25.633 | | RW-OS-3704** | 33 | 58.000 | 118 | 31.533 |
| RW-OS-3302 | 33 | 53.350 | 118 | 26.183 | | RW-OS-3705** | 33 | 57.216 | 118 | 33.216 |
| RW-OS-3303 | 33 | 53.133 | 118 | 26.800 | | RW-OS-3706** | 33 | 56.550 | 118 | 34.500 |
| RW-OS-3304** | 33 | 52.767 | 118 | 27.417 | | RW-OS-3801 | 34 | 2.000 | 118 | 35.000 |
| RW-OS-3305** | 33 | 52.100 | 118 | 29.600 | | RW-OS-3802 | 34 | 1.550 | 118 | 35.250 |
| RW-OS-3306** | 33 | 51.067 | 118 | 31.633 | | RW-OS-3803 | 34 | 0.350 | 118 | 35.833 |
| RW-OS-3401 | 33 | 54.150 | 118 | 25.950 | | RW-OS-3804** | 33 | 59.600 | 118 | 36.250 |
| RW-OS-3402 | 33 | 54.000 | 118 | 26.833 | | RW-OS-3805** | 33 | 58.333 | 118 | 36.850 |
| RW-OS-3403 | 33 | 54.066 | 118 | 27.600 | | RW-OS-3806 | 33 | 57.366 | 118 | 37.416 |
| RW-OS-3404** | 33 | 53.816 | 118 | 28.116 | | RW-OS-3901 | 34 | 1.650 | 118 | 43.000 |
| RW-OS-3405** | 33 | 53.233 | 118 | 30.383 | | RW-OS-3902 | 34 | 1.166 | 118 | 43.000 |
| RW-OS-3406** | 33 | 52.750 | 118 | 32.133 | | RW-OS-3903 | 34 | 0.666 | 118 | 43.000 |
| RW-OS-3501 | 33 | 55.883 | 118 | 26.883 | | RW-OS-3904** | 33 | 59.850 | 118 | 43.000 |
| RW-OS-3502 | 33 | 55.666 | 118 | 27.616 | | RW-OS-3905 | 33 | 57.616 | 118 | 43.000 |
| RW-OS-3503 | 33 | 55.433 | 118 | 28.350 | | RW-OS-3906 | 33 | 56.566 | 118 | 43.000 |
| RW-OS-3504** | 33 | 55.000 | 118 | 29.650 | | RW-OS-4001 | 33 | 59.716 | 118 | 48.316 |
| RW-OS-3505** | 33 | 54.550 | 118 | 31.516 | | RW-OS-4002 | 33 | 59.300 | 118 | 48.316 |
| RW-OS-3506** | 33 | 54.000 | 118 | 32.983 | | RW-OS-4003** | 33 | 58.833 | 118 | 48.316 |
| RW-OS-3601 | 33 | 57.584 | 118 | 27.975 | | RW-OS-4004 | 33 | 57.500 | 118 | 48.316 |
| RW-OS-3602 | 33 | 57.333 | 118 | 28.666 | | RW-OS-4005 | 33 | 55.683 | 118 | 48.316 |
| RW-OS-3603 | 33 | 56.966 | 118 | 29.416 | | RW-OS-4006 | 33 | 54.750 | 118 | 48.316 |

* Given in decimal minutes.
** Discrete stations of the Central Bight Cooperative Water Quality Survey.

| Benthic and Trawl Monitoring Stations | | | | | | | | | |
|--|------------------|--------|-------------------|--------|--------------------------------------|------------------|--------|-------------------|--------|
| Station | Latitude* | | Longitude* | | Station | Latitude* | | Longitude* | |
| <u>FIXED GRID STATIONS</u> | | | | | RW-FA-10 | 33 | 53.132 | 118 | 30.983 |
| RW-A-1 (T) | 33 | 59.183 | 118 | 30.117 | RW-FA-11 | 33 | 53.594 | 118 | 30.105 |
| RW-A-2 | 33 | 55.117 | 118 | 26.883 | RW-FA-12 | 33 | 53.870 | 118 | 29.438 |
| RW-A-3 (T) | 33 | 52.050 | 118 | 25.000 | RW-FA-13 | 33 | 54.398 | 118 | 34.130 |
| RW-B-1 | 34 | 00.417 | 118 | 42.933 | RW-FA-14 | 33 | 54.874 | 118 | 28.602 |
| RW-B-3 | 34 | 00.350 | 118 | 35.833 | RW-FA-15 | 33 | 55.073 | 118 | 33.387 |
| RW-B-5 | 33 | 57.983 | 118 | 31.533 | RW-FA-16 | 33 | 55.966 | 118 | 30.050 |
| RW-B-6 | 33 | 56.467 | 118 | 30.567 | RW-FA-17 | 33 | 56.086 | 118 | 33.208 |
| RW-B-7 | 33 | 55.283 | 118 | 29.500 | RW-FA-18 | 33 | 56.612 | 118 | 29.351 |
| RW-B-8 | 33 | 53.800 | 118 | 28.450 | RW-FA-19 | 33 | 56.671 | 118 | 32.167 |
| RW-B-10 | 33 | 50.483 | 118 | 24.940 | RW-FA-20 | 33 | 57.157 | 118 | 31.470 |
| RW-C-1 (T) | 33 | 59.833 | 118 | 43.050 | RW-Random1A (T)** | 33 | 54.874 | 118 | 28.602 |
| RW-C-3 (T) | 33 | 59.383 | 118 | 36.033 | RW-Random2A (T)** | 33 | 52.397 | 118 | 29.837 |
| RW-C-5 | 33 | 57.167 | 118 | 33.233 | RW-Random3A (T)** | 33 | 51.451 | 118 | 28.185 |
| RW-C-6 (T) | 33 | 55.683 | 118 | 32.083 | <u>YEAR 2 RANDOM STATIONS</u> | | | | |
| RW-C-7 | 33 | 53.583 | 118 | 32.250 | RW-NB-1 | 33 | 54.325 | 118 | 33.022 |
| RW-C-8 | 33 | 52.750 | 118 | 31.417 | RW-NB-2 | 33 | 54.490 | 118 | 30.105 |
| RW-D-1 (Benthic) | 33 | 54.700 | 118 | 33.000 | RW-NB-3 | 33 | 54.883 | 118 | 32.057 |
| RW-D-1T (T)** | 33 | 54.805 | 118 | 32.215 | RW-NB-4 | 33 | 54.905 | 118 | 30.594 |
| RW-E-1 | 33 | 59.057 | 118 | 42.867 | RW-NB-5 | 33 | 55.261 | 118 | 32.981 |
| RW-E-3 | 33 | 58.317 | 118 | 36.867 | RW-NB-6 | 33 | 55.620 | 118 | 29.888 |
| RW-E-6 | 33 | 55.700 | 118 | 33.417 | RW-NB-7 | 33 | 55.670 | 118 | 31.887 |
| RW-E-10 | 33 | 49.405 | 118 | 27.880 | RW-NB-8 | 33 | 56.212 | 118 | 30.826 |
| RW-Z-1 | 33 | 54.883 | 118 | 31.500 | RW-FB-9 | 33 | 52.493 | 118 | 31.105 |
| RW-Z-2 (T) | 33 | 54.450 | 118 | 31.467 | RW-FB-10 | 33 | 53.017 | 118 | 29.854 |
| RW-Z-3 (T)** | 33 | 54.005 | 118 | 30.395 | RW-FB-11 | 33 | 53.087 | 118 | 33.191 |
| RW-Z-4 (T)** | 33 | 55.282 | 118 | 30.579 | RW-FB-12 | 33 | 53.249 | 118 | 30.759 |
| <u>YEAR 1 RANDOM STATIONS</u> | | | | | RW-FB-13 | 33 | 53.282 | 118 | 29.015 |
| RW-NA-1 | 33 | 53.396 | 118 | 31.190 | RW-FB-14 | 33 | 53.616 | 118 | 33.900 |
| RW-NA-2 | 33 | 54.054 | 118 | 30.907 | RW-FB-15 | 33 | 54.194 | 118 | 28.841 |
| RW-NA-3 | 33 | 54.199 | 118 | 32.025 | RW-FB-16 | 33 | 55.102 | 118 | 29.375 |
| RW-NA-4 | 33 | 55.061 | 118 | 30.380 | RW-FB-17 | 33 | 56.220 | 118 | 33.825 |
| RW-NA-5 | 33 | 55.167 | 118 | 31.114 | RW-FB-18 | 33 | 56.407 | 118 | 29.231 |
| RW-NA-6 | 33 | 56.041 | 118 | 31.636 | RW-FB-19 | 33 | 56.690 | 118 | 31.871 |
| RW-FA-7 | 33 | 52.397 | 118 | 29.837 | RW-FB-20 | 33 | 56.858 | 118 | 30.287 |
| RW-FA-8 | 33 | 52.675 | 118 | 32.650 | RW-Random1B (T)** | 33 | 56.220 | 118 | 33.825 |
| RW-FA-9 | 33 | 52.981 | 118 | 29.263 | RW-Random2B (T)** | 33 | 56.407 | 118 | 29.231 |
| | | | | | RW-Random3B (T)** | 33 | 53.017 | 118 | 29.854 |
| * Given in decimal minutes. | | | | | | | | | |
| ** Trawl site only. | | | | | | | | | |
| (T) Trawl stations. | | | | | | | | | |

III. INFLUENT MONITORING REQUIREMENTS

(Footnotes are specified on pages E-15 and E-16 of this Order/Permit.)

Influent monitoring is required to:

- Determine compliance with NPDES permit conditions.
- Assess treatment plant performance.
- Assess effectiveness of the Pretreatment Program.

A. Monitoring Locations INF-001, INF-002, INF-003, INF-004, and INF-005

1. The Discharger shall monitor influent to the Facility at INF-001, INF-002, INF-003, INF-004, and INF-005 as follows. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level:

Table 2. Influent Monitoring

| Influent Monitoring Program | | | | |
|--|----------|--------------------------|---|---------------------------------|
| Parameter | Units | Sample Type ¹ | Minimum Sampling Frequency ² | Required Analytical Test Method |
| Flow | MGD | Recorder/totalizer | Continuous ³ | 4 |
| BOD ₅ 20°C | mg/L | 24-hr composite | Daily | 4 |
| Suspended solids | mg/L | 24-hr composite | Daily | 4 |
| pH | pH units | Grab | Weekly | 4 |
| Oil and grease | mg/L | Grab ⁵ | Weekly | 4 |
| TOC (total organic carbon) | mg/L | 24-hr composite | Monthly | 4 |
| Cyanide | µg/L | Grab | Monthly | 4 |
| Organic nitrogen | mg/L | 24-hr composite | Quarterly | 4 |
| Radioactivity (including gross alpha, gross, beta, combined radium-226 & radium-228, tritium, strontium-90 and uranium) ⁶ | pCi/L | 24-hr composite | Monthly | 4 |
| Total phosphorus (as P) | mg/L | 24-hr composite | Quarterly | 4 |
| Tributyltin | ng/L | 24-hr composite | Quarterly | 4 |
| Aldrin | µg/L | 24-hr composite | Quarterly | 4 |
| Chlordane and related compounds ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| DDT ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Dieldrin | µg/L | 24-hr composite | Quarterly | 4 |
| Endosulfan ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Endrin | µg/L | 24-hr composite | Quarterly | 4 |
| HCH ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Heptachlor | µg/L | 24-hr composite | Quarterly | 4 |
| Heptachlor epoxide | µg/L | 24-hr composite | Quarterly | 4 |
| PCBs ⁷ | µg/L | 24-hr composite | Quarterly | 4 |

| Influent Monitoring Program | | | | |
|---|-------|--------------------------|---|---------------------------------|
| Parameter | Units | Sample Type ¹ | Minimum Sampling Frequency ² | Required Analytical Test Method |
| Toxaphene | µg/L | 24-hr composite | Quarterly | 4 |
| 2,4-Dinitrophenol | µg/L | 24-hr composite | Quarterly | 4 |
| 2,4,6-Trichlorophenol | µg/L | 24-hr composite | Quarterly | 4 |
| 4,6-Dinitro-2-methylphenol | µg/L | 24-hr composite | Quarterly | 4 |
| Phenolic compounds (chlorinated) ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Phenolic compounds (non-chlorinated) ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Bis(2-chloro-ethoxy) methane | µg/L | 24-hr composite | Quarterly | 4 |
| Bis(2-chloro-isopropyl) ether | µg/L | 24-hr composite | Quarterly | 4 |
| Di-n-butylphthalate | µg/L | 24-hr composite | Quarterly | 4 |
| Dichlorobenzenes ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Diethylphthalate | µg/L | 24-hr composite | Quarterly | 4 |
| Dimethylphthalate | µg/L | 24-hr composite | Quarterly | 4 |
| Fluoranthene | µg/L | 24-hr composite | Quarterly | 4 |
| Hexachlorocyclopentadiene | µg/L | 24-hr composite | Quarterly | 4 |
| Isophorone | µg/L | 24-hr composite | Quarterly | 4 |
| Nitrobenzene | µg/L | 24-hr composite | Quarterly | 4 |
| Benidine | µg/L | 24-hr composite | Quarterly | 4 |
| Bis(2-chloroethyl) ether | µg/L | 24-hr composite | Quarterly | 4 |
| Bis(2-ethylhexyl) phthalate | µg/L | 24-hr composite | Quarterly | 4 |
| 1,4-Dichlorobenzene | µg/L | 24-hr composite | Quarterly | 4 |
| 3,3-Dichlorobenzidine | µg/L | 24-hr composite | Quarterly | 4 |
| 2,4-Dinitrotoluene | µg/L | 24-hr composite | Quarterly | 4 |
| 1,2-Diphenylhydrazine | µg/L | 24-hr composite | Quarterly | 4 |
| Hexachlorobenzene | µg/L | 24-hr composite | Quarterly | 4 |
| Hexachlorobutadiene | µg/L | 24-hr composite | Quarterly | 4 |
| Hexachloroethane | µg/L | 24-hr composite | Quarterly | 4 |
| N-Nitrosodimethylamine | µg/L | 24-hr composite | Quarterly | 4 |
| N-Nitrosodi-n-propylamine | µg/L | 24-hr composite | Quarterly | 4 |
| N-Nitrosodiphenylamine | µg/L | 24-hr composite | Quarterly | 4 |
| PAHs ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| TCDD equivalents ^{7, 12} | pg/L | 24-hr composite | Quarterly | 4 |
| Acrolein | µg/L | Grab | Quarterly | 4 |
| Acrylonitrile | µg/L | Grab | Quarterly | 4 |
| Benzene | µg/L | Grab | Quarterly | 4 |
| Carbon tetrachloride | µg/L | Grab | Quarterly | 4 |
| Chlorobenzene | µg/L | Grab | Quarterly | 4 |
| Chlorodibromomethane | µg/L | Grab | Quarterly | 4 |
| Chloroform | µg/L | Grab | Quarterly | 4 |
| Dichlorobromomethane | µg/L | Grab | Quarterly | 4 |
| Dichloromethane | µg/L | Grab | Quarterly | 4 |
| 1,1-Dichloroethylene | µg/L | Grab | Quarterly | 4 |

| Influent Monitoring Program | | | | |
|----------------------------------|-------|--------------------------|---|---------------------------------|
| Parameter | Units | Sample Type ¹ | Minimum Sampling Frequency ² | Required Analytical Test Method |
| 1,2-Dichloroethane | µg/L | Grab | Quarterly | 4 |
| 1,3-Dichloropropene | µg/L | Grab | Quarterly | 4 |
| Ethylbenzene | µg/L | Grab | Quarterly | 4 |
| Halomethanes ⁷ | µg/L | Grab | Quarterly | 4 |
| Methyl-tert-butyl-ether | µg/L | Grab | Quarterly | 4 |
| Toluene | µg/L | Grab | Quarterly | 4 |
| 1,1,2,2-Tetrachloroethane | µg/L | Grab | Quarterly | 4 |
| 1,1,1-Trichloroethane | µg/L | Grab | Quarterly | 4 |
| 1,1,2-Trichloroethane | µg/L | Grab | Quarterly | 4 |
| Tetrachloroethylene | µg/L | Grab | Quarterly | 4 |
| Trichloroethylene | µg/L | Grab | Quarterly | 4 |
| Vinyl chloride | µg/L | Grab | Quarterly | 4 |
| Antimony | µg/L | 24-hr composite | Quarterly | 4 |
| Arsenic | µg/L | 24-hr composite | Quarterly | 4 |
| Beryllium | µg/L | 24-hr composite | Quarterly | 4 |
| Cadmium | µg/L | 24-hr composite | Monthly | 4 |
| Chromium (III) | µg/L | Grab | Monthly | 4 |
| Copper | µg/L | 24-hr composite | Monthly | 4 |
| Hexavalent chromium ⁹ | µg/L | Grab | Monthly | 4 |
| Lead | µg/L | 24-hr composite | Monthly | 4 |
| Mercury ¹³ | µg/L | 24-hr composite | Monthly | 4 |
| Nickel | µg/L | 24-hr composite | Monthly | 4 |
| Selenium | µg/L | 24-hr composite | Monthly | 4 |
| Silver | µg/L | 24-hr composite | Monthly | 4 |
| Thallium | µg/L | 24-hr composite | Quarterly | 4 |
| Zinc | µg/L | 24-hr composite | Monthly | 4 |

IV. EFFLUENT MONITORING REQUIREMENTS

(Footnotes are specified on pages E-15 and E-16 of this Order/Permit.)

Effluent monitoring is required to:

- Determine compliance with NPDES permit conditions and water quality standards.
- Assess plant performance, identify operational problems and improve plant performance.
- Provide information on wastewater characteristics and flows for use in interpreting water quality and biological data.

A. Monitoring Locations - EFF 001 and EFF 002

1. The Discharger shall monitor effluent at EFF-001 and EFF-002 as follows. If more than one analytical test method is listed for a given parameter, the

Discharger must select from the listed methods and corresponding Minimum Level:

Table 3. Effluent Monitoring

| Effluent Monitoring Program | | | | |
|---|----------------|--------------------------|--|---------------------------------|
| Parameter | Units | Sample Type ¹ | Minimum Sampling Frequency ^{2,10} | Required Analytical Test Method |
| Flow | MGD | Recorder/totalizer | Continuous ³ | 4 |
| BOD ₅ 20 ⁰ C | mg/L | 24-hr composite | Daily | 4 |
| Suspended solids | mg/L | 24-hr composite | Daily | 4 |
| pH | pH unit | Grab | Weekly | 4 |
| Oil and grease | mg/L | Grab ⁵ | Weekly | 4 |
| Temperature ¹¹ | ⁰ C | Continuous | Continuous | 4 |
| Total Organic Carbon | mg/L | 24-hr composite | Monthly | 4 |
| Settleable solids | mL/L | Grab ⁵ | Daily | 4 |
| Total residual chlorine (Discharge Point 001 only) | mg/L | Grab | Daily | 4 |
| Dissolved Oxygen | mg/L | Grab | Weekly | 4 |
| Turbidity | NTU | Grab and 24-hr composite | Weekly | 4 |
| Ammonia nitrogen | mg/L | 24-hr composite | Weekly | 4 |
| Toxicity, Acute | TUa | 24-hr composite | Monthly | 4 |
| Toxicity, Chronic | TUc | 24-hr composite | Monthly | 4 |
| Cyanide | µg/L | grab | Monthly | 4 |
| Nitrate nitrogen | mg/L | 24-hr composite | Quarterly | 4 |
| Organic nitrogen | mg/L | 24-hr composite | Quarterly | 4 |
| Radioactivity (including gross alpha, gross beta, combined radium-226 & radium-228, tritium, strontium-90 and uranium) ⁶ | pCi/L | 24-hr composite | Monthly | 4 |
| Total phosphorus (as P) | mg/L | 24-hr composite | Quarterly | 4 |
| Tributyltin | ng/L | 24-hr composite | Quarterly | 4 |
| Aldrin | µg/L | 24-hr composite | Quarterly | 4 |
| Chlordane and related compounds ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| DDT ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Dieldrin | µg/L | 24-hr composite | Quarterly | 4 |
| Endosulfan ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Endrin | µg/L | 24-hr composite | Quarterly | 4 |
| HCH ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Heptachlor | µg/L | 24-hr composite | Quarterly | 4 |
| Heptachlor epoxide | µg/L | 24-hr composite | Quarterly | 4 |
| PCBs ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| PCB congeners ⁸ | µg/L | 24-hr composite | Annually | 4 |
| Toxaphene | µg/L | 24-hr composite | Quarterly | 4 |
| 2,4-Dinitrophenol | µg/L | 24-hr composite | Quarterly | 4 |

| Effluent Monitoring Program | | | | |
|---|-------|--------------------------|--|---------------------------------|
| Parameter | Units | Sample Type ¹ | Minimum Sampling Frequency ^{2,10} | Required Analytical Test Method |
| 2,4,6-Trichlorophenol | µg/L | 24-hr composite | Quarterly | 4 |
| 4,6-Dinitro-2-methylphenol | µg/L | 24-hr composite | Quarterly | 4 |
| Phenolic compounds (chlorinated) ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Phenolic compounds (non-chlorinated) ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Bis(2-chloro-ethoxy) methane | µg/L | 24-hr composite | Quarterly | 4 |
| Bis(2-chloro-isopropyl) ether | µg/L | 24-hr composite | Quarterly | 4 |
| Di-n-butylphthalate | µg/L | 24-hr composite | Quarterly | 4 |
| Dichlorobenzenes ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| Diethylphthalate | µg/L | 24-hr composite | Quarterly | 4 |
| Dimethylphthalate | µg/L | 24-hr composite | Quarterly | 4 |
| Fluoranthene | µg/L | 24-hr composite | Quarterly | 4 |
| Hexachlorocyclopentadiene | µg/L | 24-hr composite | Quarterly | 4 |
| Isophorone | µg/L | 24-hr composite | Quarterly | 4 |
| Nitrobenzene | µg/L | 24-hr composite | Quarterly | 4 |
| Benzidine | µg/L | 24-hr composite | Quarterly | 4 |
| Bis(2-chloroethyl) ether | µg/L | 24-hr composite | Quarterly | 4 |
| Bis(2-ethylhexyl) phthalate | µg/L | 24-hr composite | Quarterly | 4 |
| 1,4-Dichlorobenzene | µg/L | 24-hr composite | Quarterly | 4 |
| 3,3-Dichlorobenzidine | µg/L | 24-hr composite | Quarterly | 4 |
| 2,4-Dinitrotoluene | µg/L | 24-hr composite | Quarterly | 4 |
| 1,2-Diphenylhydrazine | µg/L | 24-hr composite | Quarterly | 4 |
| Hexachlorobenzene | µg/L | 24-hr composite | Quarterly | 4 |
| Hexachlorobutadiene | µg/L | 24-hr composite | Quarterly | 4 |
| Hexachloroethane | µg/L | 24-hr composite | Quarterly | 4 |
| N-Nitrosodimethylamine | µg/L | 24-hr composite | Quarterly | 4 |
| N-Nitrosodi-n-propylamine | µg/L | 24-hr composite | Quarterly | 4 |
| N-Nitrosodiphenylamine | µg/L | 24-hr composite | Quarterly | 4 |
| PAHs ⁷ | µg/L | 24-hr composite | Quarterly | 4 |
| TCDD equivalents ^{7,12} | pg/L | 24-hr composite | Quarterly | 4 |
| Acrolein | µg/L | Grab | Quarterly | 4 |
| Acrylonitrile | µg/L | Grab | Quarterly | 4 |
| Benzene | µg/L | Grab | Quarterly | 4 |
| Carbon tetrachloride | µg/L | Grab | Quarterly | 4 |
| Chlorobenzene | µg/L | Grab | Quarterly | 4 |
| Chlorodibromomethane | µg/L | Grab | Quarterly | 4 |
| Chloroform | µg/L | Grab | Quarterly | 4 |
| Dichlorobromomethane | µg/L | Grab | Quarterly | 4 |
| Dichloromethane | µg/L | Grab | Quarterly | 4 |
| 1,1-Dichloroethylene | µg/L | Grab | Quarterly | 4 |
| 1,2-Dichloroethane | µg/L | Grab | Quarterly | 4 |
| 1,3-Dichloropropene | µg/L | Grab | Quarterly | 4 |

| Effluent Monitoring Program | | | | |
|----------------------------------|-------|--------------------------|--|---------------------------------|
| Parameter | Units | Sample Type ¹ | Minimum Sampling Frequency ^{2,10} | Required Analytical Test Method |
| Ethylbenzene | µg/L | Grab | Quarterly | 4 |
| Halomethanes ⁷ | µg/L | Grab | Quarterly | 4 |
| Methyl-tert-butyl-ether | µg/L | Grab | Quarterly | 4 |
| Toluene | µg/L | Grab | Quarterly | 4 |
| 1,1,2,2-Tetrachloroethane | µg/L | Grab | Quarterly | 4 |
| 1,1,1-Trichloroethane | µg/L | Grab | Quarterly | 4 |
| 1,1,2-Trichloroethane | µg/L | Grab | Quarterly | 4 |
| Tetrachloroethylene | µg/L | Grab | Quarterly | 4 |
| Trichloroethylene | µg/L | Grab | Quarterly | 4 |
| Vinyl chloride | µg/L | Grab | Quarterly | 4 |
| Antimony | µg/L | 24-hr composite | Quarterly | 4 |
| Arsenic | µg/L | 24-hr composite | Monthly | 4 |
| Beryllium | µg/L | 24-hr composite | Quarterly | 4 |
| Cadmium | µg/L | 24-hr composite | Monthly | 4 |
| Chromium (III) | µg/L | Grab | Monthly | 4 |
| Copper | µg/L | 24-hr composite | Monthly | 4 |
| Hexavalent chromium ⁹ | µg/L | Grab | Monthly | 4 |
| Lead | µg/L | 24-hr composite | Monthly | 4 |
| Mercury ¹³ | µg/L | 24-hr composite | Monthly | 4 |
| Nickel | µg/L | 24-hr composite | Monthly | 4 |
| Selenium | µg/L | 24-hr composite | Monthly | 4 |
| Silver | µg/L | 24-hr composite | Monthly | 4 |
| Thallium | µg/L | 24-hr composite | Quarterly | 4 |
| Zinc | µg/L | 24-hr composite | Monthly | 4 |

Footnotes for Influent and Effluent Monitoring Program:

- ¹ For 24-hour composite samples, if the duration of the discharge is less than 24 hours but greater than 8 hours, at least eight flow-weighted samples shall be obtained during the discharge period and composited. For discharge durations of less than eight hours, individual grab samples may be substituted. A grab sample is an individual sample collected in less than 15 minutes.
- ² For the influent and effluent, weekly and monthly sampling shall be arranged so that each day of the week is represented over a seven week or month period. The schedule should be repeated every seven weeks or months.
- ³ When continuous monitoring of flow is required, total daily flow and peak daily flow (24-hr basis) shall be reported.
- ⁴ Pollutants shall be analyzed using: the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board, the State Water Board and USEPA Region 9. For any pollutant whose effluent limitation is lower than all the minimum levels (MLs) specified in Appendix II of the Ocean Plan, the analytical method with the lowest ML must be selected.

- 5 Oil and grease and settleable solids monitoring shall consist of a single grab sample at peak flow over a 24-hour period.
- 6 Analyze these radiochemicals by the following USEPA methods: method 900.0 for gross alpha and gross beta, method 903.0 or 903.1 for radium-226, method 904.0 for radium-228, method 906.0 for tritium, method 905.0 for strontium-90, and method 908.0 for uranium. Analysis for combined radium-226 & 228 shall be conducted only if gross alpha or gross beta results for the same sample exceed 15 pCi/L or 50 pCi/L, respectively. If radium-226 & 228 exceeds the stipulated criteria, then analyze for tritium, strontium-90, and uranium.
- 7 See Attachment A for definition of terms.
- 8 To facilitate interpretation of sediment/fish tissue data and TMDL development, PCB congeners whose analytical characteristics resemble those of PCB-18, 28, 37, 44, 49, 52, 66, 70, 74, 77, 81, 87, 99, 101, 105, 110, 114, 118, 119, 123, 126, 128, 138, 149, 151, 153, 156, 157, 158, 167, 168, 169, 170, 177, 180, 183, 187, 189, 194, 201, and 206 shall be individually quantified.
- 9 Discharger may, at its option, meet the hexavalent chromium limitation by analyzing for total chromium rather than hexavalent chromium.
- 10 For Discharge Point 001, the minimum frequency of analysis shall be once per discharge day, but no more than one analysis need be done during the indicated sampling period; however, total chlorine residual shall be monitored daily, and acute toxicity shall not be monitored. During routine maintenance activities, sampling and analyses are not required, except for total chlorine residuals.
- 11 For Discharge Point 002, sampling shall be continuous, and the maximum daily temperature shall be reported.
- 12 USEPA Method 1613 shall be used to analyze TCDD equivalents.
- 13 USEPA Method 1631E, with a quantitation level of 0.5 ng/L, shall be used to analyze total mercury.

B. Mass Emission Benchmarks

The following Mass Emission Benchmarks, in metric tons per year (MT/yr), have been established for the discharge through the 5-mile outfall (Discharge Point 002). The Discharger shall monitor and report the mass emission rate for all constituents that have mass emission benchmarks. For each constituent, the 12-month average mass emission rate and the concentration and flow used to calculate that mass emission rate shall be reported in the annual pretreatment report and the annual receiving water monitoring report.

Table 4. 12-Month Average Effluent Mass Emission Benchmarks

| Ocean Plan Constituent | 12-month Average Mass Emission Benchmarks (MT/yr) |
|----------------------------|---|
| Marine Aquatic Life | |
| Arsenic | 1.9 |
| Cadmium | 0.88 |
| Chromium VI | 4.6 |
| Chromium (total) | N/A |

| Ocean Plan Constituent | 12-month Average Mass Emission Benchmarks (MT/yr) |
|--------------------------------------|--|
| Copper | 13 |
| Lead | 2.1 |
| Mercury | 0.19 |
| Nickel | 8.3 |
| Selenium | 0.94 |
| Silver | 1.2 |
| Zinc | 22 |
| Cyanide | 4.6 |
| Total chlorine residual | N/A |
| Ammonia as N | 20,100 |
| Acute toxicity | N/A |
| Chronic toxicity | N/A |
| Phenolic compounds (non-chlorinated) | 3 |
| Phenolic compounds (chlorinated) | 0.5 |
| Endosulfan | 0.004 |
| Endrin | 0.004 |
| HCH | 0.02 |
| Radioactivity | N/A |
| Human Health (noncarcinogens) | |
| Acrolein | 1 |
| Antimony | 3 |
| Bis(2-cl-ethoxy) methane | 0.03 |
| Bis(2-cl-isopropyl) ether | 0.03 |
| Chlorobenzene | 0.066 |
| Chromium (III) | 3.6 |
| Di-n-butyl phthalate | 2.2 |
| Dichlorobenzenes (BNA) | 1 |
| Diethyl phthalate | 0.03 |
| Dimethyl phthalate | 0.15 |
| 2-methyl-4,6-dinitrophenol | 0.2 |
| 2,4-dinitrophenol | 0.12 |
| Ethyl benzene | 0.066 |
| Fluoranthene | 0.03 |
| Hexachlorocyclopentadiene | 1.6 |
| Nitrobenzene | 0.03 |

| Ocean Plan Constituent | 12-month Average Mass Emission Benchmarks (MT/yr) |
|--|---|
| Thallium | 4.3 |
| Toluene | 0.25 |
| Tributyltin | N/A |
| 1,1,1-trichloroethane | 0.099 |
| Human Health Protection (carcinogens) | |
| Acrylonitrile | 0.17 |
| Aldrin | N/A |
| Benzene | 0.12 |
| Benzidine | N/A |
| Beryllium | 0.006 |
| Bis(2-chloroethyl) ether | 0.05 |
| Bis(2-ethylhexyl) phthalate | 3.8 |
| Carbon tetrachloride | 0.083 |
| Chlordane | N/A |
| Chlorodibromomethane | 2.2 |
| Chloroform | 3.6 |
| DDT, total | N/A |
| 1,4-dichlorobenzene (BNA) | 7.7 |
| 3,3'-dichlorobenzidine | N/A |
| 1,2-dichloroethane | 0.03 |
| 1,1-dichloroethylene | 0.072 |
| Dichlorobromomethane | 0.83 |
| Methylene chloride | 12 |
| 1,3-dichloropropene | 0.17 |
| Dieldrin | N/A |
| 2,4-dinitrotoluene | 0.04 |
| 1,2-diphenylhydrazine | 0.03 |
| Halomethanes | 1.2 |
| Heptachlor | N/A |
| Heptachlor epoxide | N/A |
| Hexachlorobenzene | N/A |
| Hexachlorobutadiene | 0.04 |
| Hexachloroethane | 0.04 |
| Isophorone | 3.2 |
| N-nitrosodimethylamine | 0.094 |

| Ocean Plan Constituent | 12-month Average Mass Emission Benchmarks (MT/yr) |
|---------------------------|---|
| N-nitrosodi-n-propylamine | 0.072 |
| N-nitrosodiphenylamine | 0.05 |
| PAHs | N/A |
| PCBs | N/A |
| TCDD equivalents | N/A |
| 1,1,2,2-tetrachloroethane | 0.1 |
| Tetrachloroethylene | 3.2 |
| Toxaphene | N/A |
| Trichloroethylene | 0.094 |
| 1,1,2-trichloroethane | 0.094 |
| 2,4,6-trichlorophenol | 0.05 |
| Vinyl chloride | 0.094 |

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. Acute Toxicity Testing for Discharge Point 002

1. Methods and Test Species

The Discharger shall conduct 96-hour static renewal acute toxicity tests on flow-weighted 24-hour composite effluent samples. When conducting toxicity tests in accordance with the specified chronic test methods manual, if daily observations of mortality make it possible to also calculate acute toxicity for the desired exposure period and the dilution series for the toxicity test includes the acute IWC, such method may be used to estimate the 96-hour LC50.

The presence of acute toxicity shall be estimated as specified in *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (EPA 821-R-02-012, 2002), with preference for West Coast vertebrate and invertebrate species.

2. Frequency

a. Screening - The Discharger shall conduct the first acute toxicity test screening for three consecutive months beginning in 2011. Re-screening is required every 24 months. The Discharger shall re-screen with a marine vertebrate species and a marine invertebrate species and continue to monitor with the most sensitive species. If the first suite of re-screening tests demonstrate that the same species is the most sensitive, then the re-

screening does not need to include more than one suite of tests. If a different species is the most sensitive or if there is ambiguity, then the Discharger shall proceed with suites of screening tests for a minimum of three, but not to exceed five, suites.

- b. Regular toxicity tests - After the screening period, monitoring shall be conducted monthly using the most sensitive marine species.

3. Toxicity Units

The acute toxicity of the effluent shall be expressed and reported in Acute Toxic Units, TU_a, where,

$$TU_a = \frac{100}{LC50}$$

The Lethal Concentration, 50 Percent (LC50) is expressed as the estimate of the percent effluent concentration that causes death in 50% of the test population in the time period prescribed by the toxicity test.

B. Chronic Toxicity Testing for Discharge Points 002 and 001

1. Methods and Test Species

The Discharger shall conduct critical life stage chronic toxicity tests on flow-weighted, 24-hour composite effluent samples. The presence of chronic toxicity shall be estimated as specified in *Short Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms* (EPA/600/R-95/136, 1995). When a chronic toxicity test method that incorporates a 96-hour acute toxicity endpoint is used to monitor toxicity at the chronic IWC in effluent discharged from Discharge Point 002, the 96-hour acute toxicity statistical endpoint may also be reported as LC50 and TU_a, along with other chronic toxicity test results required by this Order/Permit.

2. Frequency

Screening - The Discharger shall conduct the first chronic toxicity test screening for three consecutive months beginning in 2011. Re-screening is required every 24 months. The Discharger shall re-screen with a marine vertebrate species, a marine invertebrate species, and a marine alga species and continue to monitor with the most sensitive species. If the first suite of re-screening tests demonstrate that the same species is the most sensitive, then the re-screening does not need to include more than one suite of tests. If a different species is the most sensitive or if there is ambiguity, then the Discharger shall proceed with suites of screening tests for a minimum of three, but not to exceed five, suites.

Regular toxicity tests - After the screening period, monitoring shall be conducted monthly using the most sensitive marine species.

3. Toxicity Units

The chronic toxicity of the effluent shall be expressed and reported in Chronic Toxic Units, TU_c, where,

$$TU_c = \frac{100}{NOEC}$$

The No Observable Effect Concentration (NOEC) is expressed as the maximum percent effluent concentration that causes no observable effect on test organisms, as determined by the results of a critical life stage toxicity test.

C. Quality Assurance

1. Concurrent testing with a reference toxicant shall be conducted. Reference toxicant tests shall be conducted using the same test conditions as the effluent toxicity tests (e.g., same test duration, etc).
2. If either the reference toxicant test or effluent test does not meet all test acceptability criteria (TAC) as specified in the test methods manual (EPA-821-R-02-012 and/or EPA/600/R-95/136), then the Discharger must re-sample and re-test within 14 days.
3. Control and dilution water should be receiving water or laboratory water, as appropriate, as described in the manual. If the dilution water used is different from the culture water, a second control using culture water shall be used.
4. A series of at least five dilutions and a control shall be tested. The dilution series shall include the instream waste concentration (IWC) and two dilutions above and two below the IWC. The chronic IWCs for Discharge Points 001 and 002 are 7.1% and 1.1% effluent, respectively. 7.1% is the result of 1 divided by 14, which is sum of dilution credit 13 plus 1. 1.1% is the result of 1 divided by 85, which is sum of dilution credit 84 plus 1. The acute IWC for Discharge Point 002 is 35.7% effluent.
5. Following Paragraph 10.2.6.2 of USEPA's chronic freshwater test methods manual (EPA/821/R-02/013, 2002), all chronic toxicity test results from the multi-concentration tests required by this Order/Permit must be reviewed and reported according to USEPA guidance on the evaluation of concentration-response relationships found in Method Guidance and Recommendations for Whole Effluent Toxicity (WET) Testing (40 CFR 136) (EPA/821/B-00-004, 2000).
6. Because this Order/Permit requires sublethal hypothesis testing endpoints from test methods in Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms (EPA/600/R-95/136, 1995), within-test variability must be reviewed for acceptability and a variability criterion (upper %MSD bound) must be

applied, as directed under each test method. Based on this review, only accepted effluent toxicity test results shall be reported on the DMR form. If excessive within-test variability invalidates a test result, then the Discharger must resample and retest within 14 days.

7. If the discharged effluent is chlorinated, then chlorine shall not be removed from the effluent sample prior to toxicity testing without written approval by the permitting authority.
8. pH drift during the toxicity test may contribute to artifactual toxicity when pH-dependent toxicants (e.g., ammonia, metals) are present in an effluent. To determine whether or not pH drift during the toxicity test is contributing to artifactual toxicity, the Discharger shall conduct three sets of parallel toxicity tests, in which the pH of one treatment is controlled at the pH of the effluent and the pH of the other treatment is not controlled, as described in section 11.3.6.1 of the test methods manual, Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms (EPA/821/R-02/013, 2002). Toxicity is confirmed to be artifactual and due to pH drift when no toxicity above the chronic WET permit limit or trigger is observed in the treatments controlled at the pH of the effluent. If toxicity is confirmed to be artifactual and due to pH drift, then, following written approval by the permitting authority, the Discharger may use the procedures outlined in section 11.3.6.2 of the test methods manual to control sample pH during the toxicity test.

D. Accelerated Monitoring

If the effluent toxicity test result exceeds the toxicity limitation, then the Discharger shall immediately implement accelerated toxicity testing that consists of six additional tests, approximately every two weeks, over a 12-week period. Effluent sampling for the first test of the six additional tests shall commence within five days of the test results exceeding the toxicity limitation.

1. If all results of the six additional tests are in compliance with the toxicity limitation, then the Discharger may resume regular monthly testing.
2. If the result of any of the six additional tests exceeds the toxicity limitation, then the Discharger shall continue to monitor once every two weeks until six consecutive biweekly tests are in compliance. At that time, the Discharger may resume regular monthly testing.
3. If the results of any two of the six additional tests (any two tests in the 12-week period) exceed the toxicity limitation, then the Discharger shall implement the initial investigation Toxicity Reduction Evaluation (TRE) Workplan.

4. If implementation of the initial investigation TRE workplan (see item E, below) indicates the source of toxicity (e.g., a temporary plant upset, etc.), then the Discharger shall return to the regular testing frequency.

E. Preparation of an Initial Investigation TRE Workplan

The Discharger shall prepare and submit a copy of the Discharger's Initial Investigation Toxicity Reduction Evaluation (TRE) workplan to the Regional Water Board Executive Officer for approval and USEPA within 90 days of the effective date of this Order/Permit. If the Executive Officer does not disapprove the workplan within 60 days, the workplan shall become effective. The Discharger shall use USEPA manual EPA/833B-99/002 (municipal), or most current version, as guidance. At a minimum, the workplan must contain the provisions in Attachment G. This workplan shall describe the steps the Discharger intends to follow if toxicity is detected, and should include, at a minimum:

1. A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
2. A description of the facility's methods of maximizing in-house treatment efficiency and good housekeeping practices and a list of all chemicals used in the operation of the facility; and
3. If a Toxicity Identification Evaluation (TIE) is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor). See MRP section V.F.3 for guidance manuals.

F. Steps in Toxicity Reduction Evaluation (TRE) and Toxicity Identification Evaluation (TIE)

1. If results of the implementation of the Initial Investigation TRE Workplan indicate the need to continue the TRE/TIE, then Discharger shall expeditiously develop a more detailed TRE Workplan for submittal to the Executive Officer and USEPA within 15 days of completion of the initial investigation TRE. The detailed workplan shall include, but not be limited to:
 - a. Further actions to investigate and identify the cause of toxicity;
 - b. Actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
 - c. A schedule for these actions.
2. The following section summarizes the stepwise approach used in conducting the TRE:

- a. Step 1 includes basic data collection.
 - b. Step 2 evaluates optimization of the treatment system operation, facility housekeeping, and selection and use of in-plant process chemicals.
 - c. If Steps 1 and 2 are unsuccessful, Step 3 implements a Toxicity Identification Evaluation (TIE) and employment of all reasonable efforts using currently available TIE methodologies. The objective of the TIE shall be to identify the substance or combination of substances causing the observed toxicity.
 - d. Assuming successful identification or characterization of the toxicant(s), Step 4 evaluates final effluent treatment options.
 - e. Step 5 evaluates in-plant treatment options.
 - f. Step 6 consists of confirmation once a toxicity control method has been implemented.
3. The Discharger may initiate a Toxicity Identification Evaluation (TIE) as part of a TRE to identify the causes of toxicity using the same species and test method and, as guidance, USEPA test method manuals; Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures (EPA/600/6-91/003, 1991); Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity (EPA/600/R-92/080, 1993); Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity (EPA/600/R-92/081, 1993); and Marine Toxicity Identification Evaluation (TIE): Phase I Guidance Document (EPA/600/R-96-054, 1996).
 4. If a TRE/TIE is initiated prior to completion of the accelerated testing required in section V.D. of this program, then the accelerated testing schedule may be terminated, or used as necessary in performing the TRE/TIE, as determined by the Executive Officer and USEPA.

G. Ammonia Removal

1. Except with prior approval from the Regional Water Board Executive Officer and USEPA, ammonia shall not be removed from bioassay samples. The Discharger must demonstrate the effluent toxicity is caused by ammonia *because of increasing test pH* when conducting the toxicity test. It is important to distinguish the potential toxic effects of ammonia from other pH sensitive chemicals, such as certain heavy metals, sulfide, and cyanide. The following may be steps to demonstrate that the toxicity is caused by ammonia and not other toxicants before the Executive Officer and USEPA would allow for control of pH in the test.

- a. There is consistent toxicity in the effluent, and the maximum pH in the toxicity test is in the range to cause toxicity due to increased pH.
 - b. Chronic ammonia concentrations in the effluent are greater than 4 mg/L total ammonia.
 - c. Conduct graduated pH tests as specified in the toxicity identification evaluation methods. For example, mortality should be higher at pH 8 and lower at pH 6.
 - d. Treat the effluent with a zeolite column to remove ammonia. Mortality in the zeolite treated effluent should be lower than the non-zeolite treated effluent. Then add ammonia back to the zeolite-treated samples to confirm toxicity due to ammonia.
2. When it has been demonstrated that toxicity is due to ammonia because of increasing test pH, pH may be controlled, using appropriate procedures which do not significantly alter the nature of the effluent, after submitting a written request to the Executive Officer and USEPA and receiving written permission expressing approval from the Executive Officer and USEPA.

H. Reporting

The Discharger shall submit a full report of the toxicity test results, including any accelerated testing conducted during the month, as required by this Order/Permit. Test results shall be reported in Acute Toxic Units (TUa) or Chronic Toxic Units (TUc), as required, with the self-monitoring report (SMR) and the discharge monitoring report (DMR) for the month in which the test is conducted.

If an initial investigation indicates the source of toxicity and accelerated testing is unnecessary, pursuant to section V.D, then those results also shall be submitted with the DMR and SMR for the period in which the investigation occurred.

1. The full report shall be received by the Regional Water Board and USEPA by the 15th day of the second month following sampling.
2. A full laboratory report for all toxicity testing shall be submitted as an attachment to the SMR and DMR for the month in which the toxicity test was conducted and shall also include: the toxicity test results reported according to the test methods manual chapter on report preparation and test review; the dates of sample collection and initiation of each toxicity test; all results for effluent parameters monitored concurrently with the toxicity test(s); and progress reports on TRE/TIE investigations. Routine reporting shall include, at a minimum, as applicable for each toxicity test:
 - a. sample collection date(s)

- b. test initiation date
 - c. test species
 - d. end point values for each dilution (e.g. number of young, growth rate, percent survival)
 - e. LC_{50} value(s) in percent effluent
 - f. TU_a value(s) $\left(TU_a = \frac{100}{LC50}\right)$
 - g. NOEC value(s) in percent effluent
 - h. TU_c values $\left(TU_c = \frac{100}{NOEC}\right)$
 - i. Mean percent mortality (+standard deviation) after 96 hours in 100% effluent (if applicable)
 - j. IC/EC₂₅ value(s) in percent effluent
 - k. NOEC and LOEC (Lowest Observable Effect Concentration) values for reference toxicant test(s)
 - l. Available water quality measurements for each toxicity test (e.g., pH, dissolved oxygen, temperature, conductivity, hardness, salinity, ammonia).
3. The Discharger shall provide a compliance summary that includes a summary table of toxicity data from at least eleven of the most recent effluent samples for toxicity testing.
 4. The Discharger shall notify the Regional Water Board and USEPA of any exceedance of a toxicity limitation, in writing, within 14 days after the receipt of the test results. The notification will describe actions the Discharger has taken or will take to investigate and correct the cause(s) of toxicity. It may also include a status report on any actions required by the permit, with a schedule for actions not yet completed. If no actions have been taken, the reasons shall be given.

VI. RECEIVING WATER MONITORING REQUIREMENTS

(Footnotes are specified on page E-41 of this Order/Permit.)

A. Inshore Water Quality Monitoring

This monitoring addresses the question: “Are Ocean Plan and Basin Plan objectives for bacteria being met?” Data collected at inshore stations provide the means to determine whether bacteriological objectives for water contact and shellfish harvesting are being met in the area of greatest potential for water contact and shellfish harvesting activities most proximal to the points of discharge.

1. The Discharger shall monitor the following 11 inshore stations:

Table 5. Inshore Monitoring Stations

| Inshore Monitoring Stations | | | | | | | | | | |
|-----------------------------|-----------|--------|------------|--------|--|----------|-----------|--------|------------|--------|
| Station | Latitude* | | Longitude* | | | Station | Latitude* | | Longitude* | |
| RW-IS-01 | 33 | 59.833 | 118 | 48.067 | | RW-IS-07 | 33 | 58.550 | 118 | 28.317 |
| RW-IS-02 | 34 | 00.950 | 118 | 46.967 | | RW-IS-08 | 33 | 57.567 | 118 | 27.583 |
| RW-IS-03 | 34 | 01.717 | 118 | 44.117 | | RW-IS-09 | 33 | 56.900 | 118 | 27.133 |
| RW-IS-04 | 34 | 01.833 | 118 | 40.383 | | RW-IS-10 | 33 | 56.283 | 118 | 26.817 |
| RW-IS-05 | 34 | 02.050 | 118 | 34.833 | | RW-IS-11 | 33 | 50.000 | 118 | 23.850 |
| RW-IS-06 | 34 | 00.201 | 118 | 29.923 | | | | | | |

Note: IS-01 to IS-11 shall be sampled at a distance of 100 ft from the shoreline or at the 30-ft depth contour, whichever is further from shore (except that station IS-11 is located at King Harbor in Redondo Beach).
* Given in decimal minutes.

Eleven inshore water quality sampling stations shall be sampled at a distance of 1000 feet from the shoreline or at the 30-foot depth contour, whichever is further from shore (except that station IS-11 is located at King Harbor in Redondo Beach). The stations shall be designated and located as shown in Table 5.

2. Parameters to be monitored at the 11 stations are as follows:

Table 6. Inshore Microbiological Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|---------------------|-------------------------|------------------------------|--------------------------------|---------------------------------|
| Total coliform | CFU/100 mL or MPN/100mL | Grab at surface and midwater | Annually (summer) ¹ | 15 |
| Fecal coliform | CFU/100 mL or MPN/100mL | Grab at surface and midwater | Annually (summer) ¹ | 15 |
| <i>Enterococcus</i> | CFU/100 mL or MPN/100mL | Grab at surface and midwater | Annually (summer) ¹ | 15 |

B. Offshore Water Quality Monitoring

This monitoring addresses the compliance questions: “Are Ocean Plan and Basin Plan objectives for physical and chemical parameters and bacteria being met?” Water quality data collected provide the information necessary to demonstrate compliance with the water quality standards. In addition, data collected by the City of Los Angeles contribute to the Central Bight Cooperative Water Quality Survey. This regionally coordinated survey provides integrated water quality surveys on a quarterly basis and covers more than 200 kilometers of coast in Ventura, Los Angeles, Orange, and San Diego Counties, from the nearshore to approximately 10 kilometers offshore. This cooperative program contributes to a regional understanding of seasonal patterns in water column structure. The regional view provides context for determining the significance and causes of locally observed patterns in the area of wastewater outfalls.

1. The Discharger shall monitor the following 54 offshore stations (Figure 1):

Table 7. Offshore Monitoring Stations

| Offshore Monitoring Stations | | | | | | | | | | |
|------------------------------|-----------|--------|------------|--------|--|--------------|-----------|--------|------------|--------|
| Station | Latitude* | | Longitude* | | | Station | Latitude* | | Longitude* | |
| RW-OS-3201 | 33 | 51.250 | 118 | 24.367 | | RW-OS-3604** | 33 | 56.416 | 118 | 30.586 |
| RW-OS-3202 | 33 | 50.917 | 118 | 25.067 | | RW-OS-3605** | 33 | 55.666 | 118 | 32.133 |
| RW-OS-3203 | 33 | 50.717 | 118 | 25.583 | | RW-OS-3606** | 33 | 55.000 | 118 | 33.500 |
| RW-OS-3204** | 33 | 50.217 | 118 | 26.433 | | RW-OS-3701 | 33 | 59.166 | 118 | 29.166 |
| RW-OS-3205** | 33 | 49.433 | 118 | 27.817 | | RW-OS-3702 | 33 | 58.800 | 118 | 30.000 |
| RW-OS-3206 | 33 | 49.666 | 118 | 29.567 | | RW-OS-3703 | 33 | 58.450 | 118 | 30.600 |
| RW-OS-3301 | 33 | 53.583 | 118 | 25.633 | | RW-OS-3704** | 33 | 58.000 | 118 | 31.533 |
| RW-OS-3302 | 33 | 53.350 | 118 | 26.183 | | RW-OS-3705** | 33 | 57.216 | 118 | 33.216 |
| RW-OS-3303 | 33 | 53.133 | 118 | 26.800 | | RW-OS-3706** | 33 | 56.550 | 118 | 34.500 |
| RW-OS-3304** | 33 | 52.767 | 118 | 27.417 | | RW-OS-3801 | 34 | 2.000 | 118 | 35.000 |
| RW-OS-3305** | 33 | 52.100 | 118 | 29.600 | | RW-OS-3802 | 34 | 1.550 | 118 | 35.250 |
| RW-OS-3306** | 33 | 51.067 | 118 | 31.633 | | RW-OS-3803 | 34 | 0.350 | 118 | 35.833 |
| RW-OS-3401 | 33 | 54.150 | 118 | 25.950 | | RW-OS-3804** | 33 | 59.600 | 118 | 36.250 |
| RW-OS-3402 | 33 | 54.000 | 118 | 26.833 | | RW-OS-3805** | 33 | 58.333 | 118 | 36.850 |
| RW-OS-3403 | 33 | 54.066 | 118 | 27.600 | | RW-OS-3806 | 33 | 57.366 | 118 | 37.416 |
| RW-OS-3404** | 33 | 53.816 | 118 | 28.116 | | RW-OS-3901 | 34 | 1.650 | 118 | 43.000 |
| RW-OS-3405** | 33 | 53.233 | 118 | 30.383 | | RW-OS-3902 | 34 | 1.166 | 118 | 43.000 |
| RW-OS-3406** | 33 | 52.750 | 118 | 32.133 | | RW-OS-3903 | 34 | 0.666 | 118 | 43.000 |
| RW-OS-3501 | 33 | 55.883 | 118 | 26.883 | | RW-OS-3904** | 33 | 59.850 | 118 | 43.000 |
| RW-OS-3502 | 33 | 55.666 | 118 | 27.616 | | RW-OS-3905 | 33 | 57.616 | 118 | 43.000 |
| RW-OS-3503 | 33 | 55.433 | 118 | 28.350 | | RW-OS-3906 | 33 | 56.566 | 118 | 43.000 |
| RW-OS-3504** | 33 | 55.000 | 118 | 29.650 | | RW-OS-4001 | 33 | 59.716 | 118 | 48.316 |
| RW-OS-3505** | 33 | 54.550 | 118 | 31.516 | | RW-OS-4002 | 33 | 59.300 | 118 | 48.316 |
| RW-OS-3506** | 33 | 54.000 | 118 | 32.983 | | RW-OS-4003** | 33 | 58.833 | 118 | 48.316 |
| RW-OS-3601 | 33 | 57.584 | 118 | 27.975 | | RW-OS-4004 | 33 | 57.500 | 118 | 48.316 |
| RW-OS-3602 | 33 | 57.333 | 118 | 28.666 | | RW-OS-4005 | 33 | 55.683 | 118 | 48.316 |
| RW-OS-3603 | 33 | 56.966 | 118 | 29.416 | | RW-OS-4006 | 33 | 54.750 | 118 | 48.316 |

* Given in decimal minutes.
** Discrete stations of the Central Bight Cooperative Water Quality Survey.

2. Parameters to be monitored at the 54 offshore stations are as follows:

Table 8. Offshore Water Quality Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|----------------------------------|-------------------------|---|----------------------------|---------------------------------|
| Dissolved oxygen | mg/L | continuous profile ³ | quarterly | 15 |
| Water temperature | °C | continuous profile ³ | quarterly | 15 |
| Salinity | ppt | continuous profile ³ | quarterly | 15 |
| Transmissivity | % transmission | continuous profile ³ or Beam C | quarterly | 15 |
| Chlorophyll a | µg/L | continuous profile ³ | quarterly | 15 |
| pH | pH units | continuous profile ³ | quarterly | 15 |
| Ammonia | µg/L | discrete sampling at specified depth ² | quarterly | 15 |
| Fecal coliform | CFU/100 mL or MPN/100mL | discrete sampling at specified depth ² | quarterly | 15 |
| Total coliform | CFU/100 mL or MPN/100mL | discrete sampling at specified depth ² | quarterly | 15 |
| <i>Enterococcus</i> | CFU/100 mL or MPN/100mL | discrete sampling at specified depth ² | quarterly | 15 |
| Visual observations ⁴ | --- | --- | quarterly | 15 |

3. Sampling Design - Fifty-four offshore water quality stations shall be sampled quarterly by a CTD profiler (see Figure 1). Water quality methods and protocols shall follow those described in the most current edition of the Field Operations Manual for Marine Water Column, Benthic, and Trawl Monitoring in Southern California. Visual observations shall be recorded at each station.

Concurrent with the CTD profiling survey, discrete samples shall be collected quarterly at all 21 offshore discrete sampling stations for ammonia and fecal coliform, total coliform and *Enterococcus* at fixed depths of 1, 15, 30, and 45 meters (or as deep as practical for those stations located in depths less than 45 m) as noted in Table 7.

4. Whenever there is any discharge to the 1-mile outfall (Discharge Point 001), the following additional offshore sampling shall be conducted at Station A-2 (see Benthic and Trawl Stations table in Benthic Sediments Monitoring under Table 1 and Figure 2) and two additional stations within approximately 50 meters of the discharge point:

Table 9. Additional Offshore Water Quality Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|-------------------------|-------------------------|------------------------------------|----------------------------|---------------------------------|
| Total chlorine residual | mg/L | Grab ^{2,5} | Once per discharge day | 15 |
| Fecal coliform | CFU/100 mL or MPN/100mL | Surface & bottom grab ⁶ | Once per discharge day | 15 |
| Total coliform | CFU/100 mL or MPN/100mL | Surface & bottom grab ⁶ | Once per discharge day | 15 |

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|---------------------|-------------------------|------------------------------------|----------------------------|---------------------------------|
| <i>Enterococcus</i> | CFU/100 mL or MPN/100mL | Surface & bottom grab ⁶ | Once per discharge day | 15 |

C. Benthic Infauna and Sediment Chemistry Monitoring

1. Local Benthic Trends Survey

This survey addresses the question: “Are benthic conditions under the influence of the discharge changing over time?” The data collected are used for regular assessment of trends in sediment contamination and biological response along a fixed grid of sites within the influence of the discharge.

- a. Sampling Design - Benthic infauna and sediment chemistry monitoring stations in Table 10 shall be sampled in summer (July – September) for the parameters in Table 11. Separate samples shall be collected for benthic infauna and sediment chemistry.

Forty-four benthic monitoring stations (24 fixed stations plus one set of 20 random stations) shall be sampled annually for benthic infauna community analysis⁷. Random station sets A and B shall be sampled in alternate years. The entire contents of each sample shall be passed through a 1.0 millimeter screen to retain the benthic organisms. Sampling methods and protocols shall follow those described in the most current edition of the Field Operations Manual for Marine Water Column, Benthic, and Trawl Monitoring in Southern California.

Table 10. Benthic Infauna, Sediment Chemistry, and Trawl Monitoring Stations

| Benthic and Trawl Monitoring Stations | | | | | | | |
|---------------------------------------|-----------|------------|-------------------------------|-----------|------------|--|--|
| Station | Latitude* | Longitude* | Station | Latitude* | Longitude* | | |
| FIXED GRID STATIONS | | | | | | | |
| RW-A-1 (T) | 33 59.183 | 118 30.117 | RW-FA-10 | 33 53.132 | 118 30.983 | | |
| RW-A-2 | 33 55.117 | 118 26.883 | RW-FA-11 | 33 53.594 | 118 30.105 | | |
| RW-A-3 (T) | 33 52.050 | 118 25.000 | RW-FA-12 | 33 53.870 | 118 29.438 | | |
| RW-B-1 | 34 00.417 | 118 42.933 | RW-FA-13 | 33 54.398 | 118 34.130 | | |
| RW-B-3 | 34 00.350 | 118 35.833 | RW-FA-14 | 33 54.874 | 118 28.602 | | |
| RW-B-5 | 33 57.983 | 118 31.533 | RW-FA-15 | 33 55.073 | 118 33.387 | | |
| RW-B-6 | 33 56.467 | 118 30.567 | RW-FA-16 | 33 55.966 | 118 30.050 | | |
| RW-B-7 | 33 55.283 | 118 29.500 | RW-FA-17 | 33 56.086 | 118 33.208 | | |
| RW-B-8 | 33 53.800 | 118 28.450 | RW-FA-18 | 33 56.612 | 118 29.351 | | |
| RW-B-10 | 33 50.483 | 118 24.940 | RW-FA-19 | 33 56.671 | 118 32.167 | | |
| RW-C-1 (T) | 33 59.833 | 118 43.050 | RW-FA-20 | 33 57.157 | 118 31.470 | | |
| RW-C-3 (T) | 33 59.383 | 118 36.033 | RW-Random1A (T)** | 33 54.874 | 118 28.602 | | |
| RW-C-5 | 33 57.167 | 118 33.233 | RW-Random2A (T)** | 33 52.397 | 118 29.837 | | |
| RW-C-6 (T) | 33 55.683 | 118 32.083 | RW-Random3A (T)** | 33 51.451 | 118 28.185 | | |
| RW-C-7 | 33 53.583 | 118 32.250 | YEAR 2 RANDOM STATIONS | | | | |
| RW-C-8 | 33 52.750 | 118 31.417 | RW-NB-1 | 33 54.325 | 118 33.022 | | |
| RW-C-9A (T) | 33 51.283 | 118 26.283 | RW-NB-2 | 33 54.490 | 118 30.105 | | |
| RW-D-1 (Benthic) | 33 54.700 | 118 33.000 | RW-NB-3 | 33 54.883 | 118 32.057 | | |
| RW-D-1T (T)** | 33 54.805 | 118 32.215 | RW-NB-4 | 33 54.905 | 118 30.594 | | |
| RW-E-1 | 33 59.057 | 118 42.867 | RW-NB-5 | 33 55.261 | 118 32.981 | | |
| RW-E-3 | 33 58.317 | 118 36.867 | RW-NB-6 | 33 55.620 | 118 29.888 | | |
| RW-E-6 | 33 55.700 | 118 33.417 | RW-NB-7 | 33 55.670 | 118 31.887 | | |
| RW-E-10 | 33 49.405 | 118 27.880 | RW-NB-8 | 33 56.212 | 118 30.826 | | |
| RW-Z-1 | 33 54.883 | 118 31.500 | RW-FB-9 | 33 52.493 | 118 31.105 | | |
| RW-Z-2 (T) | 33 54.450 | 118 31.467 | RW-FB-10 | 33 53.017 | 118 29.854 | | |
| RW-Z-3 (T)** | 33 54.005 | 118 30.395 | RW-FB-11 | 33 53.087 | 118 33.191 | | |
| RW-Z-4 (T)** | 33 55.282 | 118 30.579 | RW-FB-12 | 33 53.249 | 118 30.759 | | |
| YEAR 1 RANDOM STATIONS | | | RW-FB-13 | 33 53.282 | 118 29.015 | | |
| RW-NA-1 | 33 53.396 | 118 31.190 | RW-FB-14 | 33 53.616 | 118 33.900 | | |
| RW-NA-2 | 33 54.054 | 118 30.907 | RW-FB-15 | 33 54.194 | 118 28.841 | | |
| RW-NA-3 | 33 54.199 | 118 32.025 | RW-FB-16 | 33 55.102 | 118 29.375 | | |
| RW-NA-4 | 33 55.061 | 118 30.380 | RW-FB-17 | 33 56.220 | 118 33.825 | | |
| RW-NA-5 | 33 55.167 | 118 31.114 | RW-FB-18 | 33 56.407 | 118 29.231 | | |
| RW-NA-6 | 33 56.041 | 118 31.636 | RW-FB-19 | 33 56.690 | 118 31.871 | | |
| RW-FA-7 | 33 52.397 | 118 29.837 | RW-FB-20 | 33 56.858 | 118 30.287 | | |
| RW-FA-8 | 33 52.675 | 118 32.650 | RW-Random1B (T)** | 33 56.220 | 118 33.825 | | |
| RW-FA-9 | 33 52.981 | 118 29.263 | RW-Random2B (T)** | 33 56.407 | 118 29.231 | | |
| | | | RW-Random3B (T)** | 33 53.017 | 118 29.854 | | |

* Given in decimal minutes.
** Trawl site only.
(T) Trawl stations.

For benthic infauna community analysis, the following determinations shall be made at each station, where appropriate: Identification of all organisms to lowest possible taxon; community structure analysis⁷; mean, range, standard deviation, and 95% confidence limits, if appropriate, for value determined in the community analysis. The Discharger shall

conduct additional statistical analyses to determine temporal and spatial trends in the marine environment.

Forty-four benthic monitoring stations (24 fixed stations plus one set of 20 random stations) shall also be sampled annually for Grain Size (sufficiently detailed to calculate percent weight in relation to phi size) and TOC; random station sets A and B shall be sampled in alternate years. Four benthic monitoring stations (RW- C1, C6, Z2, and E6) shall be sampled annually for Dissolved Sulfides. Nine benthic monitoring stations (RW- Z2, C1, C3, C6, C7, RW-C8, C9a, D1, and E6) shall be sampled annually for selected priority pollutants and compounds on the local 303(d) list; see Table 11. All 64 benthic monitoring stations (24 fixed stations plus both sets of 20 random stations) shall be sampled in year five of the Order/Permit for selected priority pollutants and compounds on the local 303(d) list; see Table 11.

Table 11. Benthic Infauna and Sediment Chemistry Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|---|----------|---|----------------------------|---------------------------------|
| Benthic Infauna | -- | 0.1 square meter Van Veen grab | Annually | 15 |
| Grain Size | Phi size | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Total organic carbon | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Dissolved Sulfides | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters, porewater) | Annually | 15 |
| Organic nitrogen | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Priority Pollutants for Sediment Chemistry | | | | |
| Arsenic | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Cadmium | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Chromium | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Copper | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Lead | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Mercury | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Nickel | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Silver | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Zinc | mg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Total DDT ¹³ | µg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| DDT derivatives ⁸ | µg/kg | 0.1 square meter Van Veen grab (upper 2 | Annually | 15 |

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|--------------------------------|-------|--|----------------------------|---------------------------------|
| | | centimeters) | | |
| Total PCB ¹⁴ | µg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| PCB derivatives ⁹ | µg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |
| Compounds on local 303(d) list | µg/kg | 0.1 square meter Van Veen grab (upper 2 centimeters) | Annually | 15 |

2. Local Benthic Mapping Survey

- a. Sampling Design - The benthic monitoring station array utilized was designed as a fixed station/random station combination, incorporating 24 stations from the old sampling array and two sets of 20 newly designated randomly positioned stations. These stations shall be sampled in alternate years for the purposes of monitoring benthic infaunal community and sediment chemistry changes resulting from the implementation of full secondary treatment at Hyperion Treatment Plant. The goal is to develop a better depiction of any impact footprint resulting from the discharge using a probabilistic monitoring approach.
- b. The Discharger shall evaluate monitoring data collected between January 1999 and December 2009 using a fixed station/random station combination, and any other relevant data, to assess the mapping ability of this benthic station array. The goal is to determine if the spatial coverage is appropriate to adequately delineate any changes and describe the extent of the footprint of any impacts. Following the analysis, the station array will be assessed and any recommendations for change will be submitted to the Regional Water Board Executive Officer and USEPA.

3. Regional Benthic Survey

This regional survey addresses the questions: 1) "What is the extent, distribution, magnitude and trend of ecological change in soft-bottom benthic habitats within the Southern California Bight?"; and 2) "What is the relationship between biological response and contaminant exposure?" The data collected will be used to assess the condition of the sea-floor environment and the health of biological communities in the Bight.

Sampling Design - A regional survey of benthic conditions within the Southern California Bight took place in 2008 (Bight '08). The final survey design was determined cooperatively by participants represented on the Regional Steering Committee. The Discharger provided support to the Bight '08 benthic survey by participating in or performing the following activities:

Participation on the Steering Committee
 Participation on relevant Technical Committees (e.g., Information Management, Field Methods & Logistics, Benthos, and Chemistry)
 Field sampling at sea
 Infaunal sample analysis
 Sediment chemistry analysis
 Data management

This level of participation was consistent with that provided by the Discharger during the 2008, 2003, 1998, and 1994 Regional Benthic Surveys. The next regional survey is expected to take place in 2013 and the Discharger’s level of participation shall be consistent with that provided in previous surveys.

D. Fish and Macroinvertebrate (Trawl and Rig Fishing) Monitoring

1. Local Demersal Fish and Macroinvertebrates Survey

This survey addresses the question: “Is the health of demersal fish and epibenthic invertebrate communities in the vicinity of the discharge changing over time?” The data collected are used for regular assessment of temporal trends in community structure along an array of sites within the influence of the discharge. Data will also be collected on trash and debris to contribute to the SMBRP’s Sources and Loadings program.

Sampling Design - Ten trawl monitoring stations (7 fixed stations plus one set of 3 random stations; see Table 12) shall be sampled in winter (January – March) and summer (July – September) for demersal fish and epibenthic invertebrates, using 10-minute otter trawls. Random station sets A and B shall be sampled in alternate years. Sampling methods and protocols shall follow those described in the most current edition of the Field Operations Manual for Marine Water Column, Benthic, and Trawl Monitoring in Southern California.

Table 12. Local Demersal Fish and Macroinvertebrates Monitoring Stations

| Trawl Monitoring Stations | | | | | |
|---------------------------|-----------|------------|-------------------------------|-----------|------------|
| Station | Latitude* | Longitude* | Station | Latitude* | Longitude* |
| FIXED GRID STATION | | | YEAR 1 RANDOM STATIONS | | |
| RW-C-1 (T) | 33 59.833 | 118 43.050 | RW-Random1A (T)** | 33 54.874 | 118 28.602 |
| RW-C-3 (T) | 33 59.383 | 118 36.033 | RW-Random2A (T)** | 33 52.397 | 118 29.837 |
| RW-C-6 (T) | 33 55.683 | 118 32.083 | RW-Random3A (T)** | 33 51.451 | 118 28.185 |
| RW-Z-2 (T) | 33 54.450 | 118 31.467 | YEAR 2 RANDOM STATIONS | | |
| RW-Z-3 (T)** | 33 54.005 | 118 30.395 | RW-Random1B (T)** | 33 56.220 | 118 33.825 |
| RW-Z-4 (T)** | 33 55.282 | 118 30.579 | RW-Random2B (T)** | 33 56.407 | 118 29.231 |
| RW-D-1T (T)** | 33 54.805 | 118 32.215 | RW-Random3B (T)** | 33 53.017 | 118 29.854 |

* Given in decimal minutes.
 ** Trawl site only.
 (T) Trawl stations.

All organisms captured shall be identified to the lowest possible taxon and counted. Fish shall be size-classed. Wet-weight biomass shall be estimated for all species. Each individual captured shall be examined for the presence of externally evident signs of disease or anomaly. Estimates of type, quantity, and weight of trash and debris in each trawl shall be made. Community analysis¹⁰ shall be conducted for fish and macroinvertebrates at each station. Mean, range, standard deviation, and 95% confidence limits, if appropriate, shall be reported for the values determined in the community analysis. The Discharger shall conduct additional statistical analyses to determine temporal and spatial trends in the marine environment.

2. Regional Demersal Fish and Macroinvertebrates Survey

This survey addresses the questions: 1) “What is the extent, distribution, magnitude and trend of ecological change in demersal fish and epibenthic invertebrate communities within the Southern California Bight?” and 2) “What is the relationship between biological response and contaminant exposure?” The data collected will be used to assess the condition of the sea-floor environment and health of biological resources in the Bight.

Sampling Design - A regional survey of trawl-caught demersal fish and epibenthic invertebrates within the Southern California Bight took place in 2008 (Bight '08). The final survey design was determined cooperatively by the participants as represented in the Regional Steering Committee. The Discharger provided support to the Bight '08 survey by participating in or performing the following activities:

- Participation on the Steering Committee
- Participation on relevant Technical Committees (e.g., Information Management, Field Methods & Logistics, Fish & Invertebrates)
- Field sampling at sea
- Data management

This level of participation was consistent with that provided by the Discharger during the 2008, 2003, and 1998 Regional Surveys. The next regional survey is expected to take place in 2013 and the Discharger’s level of participation shall be consistent with that provided in previous surveys.

3. Bioaccumulation and Seafood Safety Monitoring

a. Local Bioaccumulation Trends Survey

This survey addresses the question: “Are fish tissue contamination levels in the vicinity of the outfall changing over time?” The data collected are used for regular assessment of temporal trends in honeyhead turbot tissue.

Sampling Design - Three survey sites (Table 13) shall be sampled annually for the parameters in Table 14. The composite sample for muscle tissue and the composite sample for liver tissue for a survey site can be taken from any station within that survey site.

Table 13. Local Bioaccumulation Sampling Zones

| Station Type | Monitoring Location Name | Monitoring Location Description |
|----------------|--------------------------|--|
| Bottom Station | RW-BA-Z4 | Zone 4 (south Santa Monica Bay) - Inshore of the 150 meter depth contour and between a line bearing 235° magnetic off the south end of the Redondo Beach Pier and a line bearing 240° magnetic off the south entrance of Marina Del Rey. This zone includes the Redondo Piers, the north rim of the Redondo Canyon, Short Bank, and the 1, 5, and 7-mile Hyperion outfalls. |
| Bottom Station | RW-BA-Z5 | Zone 5 (north Santa Monica Bay) - Inshore of the 150-meter depth contour and between a line bearing 240° magnetic off the south entrance of Marina del Rey and a line bearing 180° magnetic off Point Dume. This zone includes the Santa Monica beaches, Venice and Santa Monica Piers, Paradise Cove and most of Point Dume Canyon. |
| Bottom Station | RW-BA-NF | Nearfield - A 2-km radius around the 5-mile outfall (Discharge Point 002). |

Table 14. Local Bioaccumulation Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|------------|-------|--|----------------------------|---------------------------------|
| % moisture | % | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| % lipid | % | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| Arsenic | µg/kg | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| Selenium | µg/kg | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|------------------------------|-------|--|----------------------------|---------------------------------|
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| Mercury | µg/kg | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| Total DDT ¹³ | µg/kg | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| DDT derivatives ⁸ | µg/kg | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| Total PCB ¹⁴ | µg/kg | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| PCB derivatives ⁹ | µg/kg | Composite of <u>liver tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |
| | | Composite of <u>muscle tissue</u> from 10 individuals of <u>hornyhead turbot</u> | annually | 15 |

b. Local Seafood Safety Survey

This survey addresses the questions: 1) “Where seafood consumption advisories exist locally, do tissue concentrations of contaminants continue to exceed the Advisory Tissue Concentration (ATC)?”; and 2) “What are tissue contaminant trends relative to the ATC in other species and for other contaminants not currently subject to local consumption advisories?”

The data collected will be used to provide information necessary for the management of local seafood consumption advisories.

Sampling Design - A regionally coordinated survey covering Santa Monica Bay employing the sampling design proposed by the Santa Monica Bay Restoration Commission (SMBRC). During years one, three, and five of this Order/Permit, two survey sites (Table 15) shall be sampled annually

(late summer/early fall)—focusing on a consistent size class of fish—for the parameters in Table 16. The composite sample for muscle tissue for a survey site can be taken from any station within that survey site.

Table 15. Local Seafood Safety Survey Zones

| Station Type | Monitoring Location Name | Monitoring Location Description |
|----------------|--------------------------|--|
| Bottom Station | RW-BA-Z4 | Zone 4 (south Santa Monica Bay) - Inshore of the 150 meter depth contour and between a line bearing 235° magnetic off the south end of the Redondo Beach Pier and a line bearing 240° magnetic off the south entrance of Marina Del Rey. This zone includes the Redondo Piers, the north rim of the Redondo Canyon, Short Bank, and the 1, 5, and 7-mile Hyperion outfalls. |
| Bottom Station | RW-BA-Z5 | Zone 5 (north Santa Monica Bay) - Inshore of the 150-meter depth contour and between a line bearing 240° magnetic off the south entrance of Marina del Rey and a line bearing 180° magnetic off Point Dume. This zone includes the Santa Monica beaches, Venice and Santa Monica Piers, Paradise Cove and most of Point Dume Canyon. |

One species from each of five groups of fish (rockfish, kelpbass, sandbass, surfperches and croakers) shall be sampled from each of the two zones in years one, three and five. For rockfishes, scorpionfish (*Scorpaena guttata*) is the preferred species, followed by bocaccio (*Sebastes paucispinis*) and then by any other abundant and preferably benthic rockfish species. For surfperches, black perch (*Embiotoca jacksoni*) is the preferred species, followed by white seaperch (*Phanerodon furcatus*) and then by walleye surfperch (*Hyperprosopon argenteum*).

Sampling should take place within the same season of the year (preferably late summer/early fall) and should focus upon a consistent size class of fish. All tissue samples shall be analyzed for:

Table 16. Local Seafood Safety Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|------------|-------|---|----------------------------------|---------------------------------|
| % moisture | % | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |
| % lipid | % | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |
| Arsenic | µg/kg | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |
| Selenium | µg/kg | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|------------------------------|-------|---|----------------------------------|---------------------------------|
| Mercury | µg/kg | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |
| Total DDT ¹³ | µg/kg | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |
| DDT derivatives ⁸ | µg/kg | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |
| Total PCB ¹⁴ | µg/kg | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |
| PCB derivatives ⁹ | µg/kg | Composite of muscle tissue from 10 individuals of each of 5 species ¹⁰ | Annually during years 1, 3 and 5 | 15 |

c. Regional Seafood Safety Survey

This regional survey addresses the question: “Are seafood tissue levels within the Southern California Bight below levels that ensure public safety?” The data collected will be used to assess levels of contaminants in the edible tissue of commercial or recreationally important fish within the Bight relative to Advisory Tissue Concentrations.

Sampling Design - A regional survey of edible tissue contaminant levels in fish within the Southern California Bight shall be conducted at least once every ten years, encompassing a broader set of sampling sites and target species than those addressed in the local seafood survey. The objective is to determine whether any unexpected increases or decreases in contaminant levels have occurred in non-target species and/or at unsampled sites. The final survey design may be determined cooperatively by participants represented on a Regional Steering Committee or by the State of California’s Office of Environmental Health and Hazard Assessment. The Discharger shall provide support to a Regional Seafood Safety Survey by participating in or performing the following activities:

- Participation on a Steering Committee
- Participation on relevant Technical Committees (e.g., Information Management, Field Methods & Logistics, and Chemistry)
- Field sampling at sea
- Tissue chemical analysis
- Data management

The Discharger’s participation shall be consistent with that provided by the Discharger to similar regional bioaccumulation surveys.

d. Regional Bioaccumulation Survey

This regional survey addresses the question: "Are fish body burdens within the Southern California Bight a health risk to higher trophic levels in the marine food web?" The data collected will be used to estimate health risk to marine birds, mammals and wildlife from the consumption of fish tissue.

Sampling Design - A regional survey of whole fish body burdens of contaminants within the Southern California Bight took place in 2008 (Bight '08). The final survey design was determined cooperatively by participants represented on the Regional Steering Committee. The Discharger provided support to the Bight '08 Bioaccumulation Survey by participating in or performing the following activities:

- Participation on the Steering Committee
- Participation on relevant Technical Committees (e.g., Information Management, Field Methods & Logistics, and Chemistry)
- Field sampling at sea
- Tissue chemical analysis

This level of participation was consistent with that provided by the Discharger to the 2008, 2003, and 1998 Regional Bioaccumulation/Predator Risk Survey. The next regional survey is expected to occur in 2013 and the Discharger's level of participation shall be consistent with that provided in previous surveys.

E. Kelp Bed Monitoring

This regional survey is to address the question: "Is the extent of kelp beds in the Southern California Bight changing over time and are some beds changing at rates different than others?" The data collected in this regional survey will be used to assess status and trends in kelp bed health and spatial extent. The regional nature of the survey will allow the status of beds local to the discharge to be compared to regional trends.

The Discharger shall participate in the Central Region Kelp Survey Consortium (CRKSC) Monitoring Program to conduct regional kelp bed monitoring in Southern California coastal waters. The CRKSC design is based upon quarterly measures of kelp canopy extent using aerial imaging. The Discharger shall provide up to \$10,000 per year in financial support to the CRKSC (annual level of support will depend on the number of participants in the program). The Discharger shall participate in the regional management and technical committees responsible for the development of the survey design and the assessment of kelp bed resources in the Bight.

Participation in this survey provides data to the SMBRC's Kelp Beds program.

Footnotes for Receiving Water Monitoring Program:

- 1 The annual sample shall be taken in the summer quarter.
 - 2 Discrete sampling for ammonia nitrogen, fecal coliform, total coliform, *Enterococcus*, and total residual chlorine shall be done below the surface within 1 m (3.1 ft) and at 15.0 m (49.2 ft), 30.0 m (98.4 ft), and 45.0 m (147.6 ft) (or as deep as practical for those stations located in depths less than 45 m).
 - 3 Depth profile measurements will be obtained using multiple sensors to measure parameters through the entire water column (from the surface to as close to the bottom as practicable).
 - 4 Receiving Water Observations of water color, turbidity, odor, and unusual or abnormal amounts of floating or suspended matter in the water or on the beach, rocks and jetties, or beach structures shall be made and recorded at stations. The character and extent of such matter shall be described. The dates, times and depths of sampling and these observations shall also be reported.
 - 5 The "Daily Maximum" value shall be reported during periods of discharge.
 - 6 Bottom sampling shall be done within 2.0 m (6.6 ft) of the seabed.
 - 7 Community analysis of benthic infauna shall include number of species, number of individuals per species, total numerical abundance per station, benthic response index (BRI) and biological indices, plus utilize appropriate regression analyses, parametric and nonparametric statistics, and multivariate techniques or other appropriate analytical techniques.
 - 8 At a minimum, 4,4'-DDT, 2,4'-DDT, 4,4'-DDE, 2,4'-DDE, 4,4'-DDD, and 2,4'-DDD.
 - 9 At a minimum, chlorinated biphenyl congeners whose analytical characteristics resemble those of PCB-18, 28, 37, 44, 49, 52, 66, 70, 74, 77, 81, 87, 99, 101, 105, 110, 114, 118, 119, 123, 126, 128, 138, 149, 151, 153, 156, 157, 158, 167, 168, 169, 170, 177, 180, 183, 187, 189, 194, 201, and 206 shall be individually quantified.
 - 10 Community analysis of fish and macroinvertebrates shall include wet weight of fish and macroinvertebrate species (when combined weight of individuals of one species exceed 0.1 kg), standard length of each individual fish, number of species, number of individuals per species, total numerical abundance per station, number of individuals in each 1-cm size class for each species of fish, species abundance per trawl and per station, and biological indices, plus utilize appropriate regression analyses, parametric and nonparametric techniques, and multivariate techniques or other appropriate analytical techniques.
 - 11 Where appropriate, individuals collected for both local bioaccumulation trends or local seafood safety comprising the smallest 10 percent by weight shall not be used as part of the composite sample. Individuals for tissue analysis shall be randomly selected from the remaining organisms. It may not be possible to collect the required number of fish every year at each zone. If fish of the target size are absent in a given zone, additional sampling effort need not be attempted. If target size fish are present in a given zone, one additional sampling event shall be conducted to attempt to collect the necessary number of individuals.
 - 12 Tissue samples removed from individuals shall be of uniform weight.
 - 13 Total DDT means the sum of 4,4'-DDT, 2,4'-DDT, 4,4'-DDE, 2,4'-DDE, 4,4'-DDD and 2,4'-DDD.
 - 14 Total PCBs (polychlorinated biphenyls) mean the sum of chlorinated biphenyls whose analytical characteristics resemble those of Aroclor-1016, Aroclor-1221, Aroclor-1232, Aroclor-1242, Aroclor-1248, Aroclor-1254 and Aroclor-1260.
 - 15 Pollutants shall be analyzed using: the analytical methods described in 40 CFR part 136; where no methods are specified for a given pollutant, by methods approved by this Regional Water Board, State Water Board, and USEPA Region 9.
-

VII. OTHER MONITORING REQUIREMENTS

A. Special Study – Constituents of Emerging Concern in Effluent

Background

Advancements in analytical technology over the last decade have dramatically increased the number of chemicals that can be detected and greatly decreased the concentrations at which chemicals can be detected. This new ability to detect trace levels of chemical concentrations has expanded the existing understanding of the kinds of contaminants present in water and wastewater. Many man-made chemicals, particularly pesticides, pharmaceuticals and personal care products, have been found in waters across the United States.

Collectively, these compounds are referred to as Emerging Constituents (ECs) or Constituents of Emerging Concern (CECs) because their presence is starting to be revealed by rapid advances in analytical technology. Despite recent improvements in analytical science, there is still scarcity of data and lack of robust methodologies for measuring most CECs. CECs are part of the unregulated chemicals, for which no water quality standards or State notification levels have been established.

Recent publications and media reports on CECs have increased public awareness of the issue, providing an impetus for CEC investigations around the country, including local efforts by the City of Los Angeles and Southern California Coastal Water Research Project (SCCWRP). For instance, starting in 2005, the City of Los Angeles has been conducting a special study as part of Order No. 2005-0020, and results suggest that the presence of natural and synthetic estrogen hormones has caused feminization of male fish (hornyhead turbot) in Santa Monica Bay, especially near the Hyperion Treatment Plant outfall. In January 2010, SCCWRP convened a workshop where 50 scientists, water quality managers, and stakeholders discussed and collaborated on developing an effective CEC monitoring and management strategy that is protective of water quality. Anticipated outcomes of this workshop include recommended lists of CECs for monitoring in recycled water (for groundwater concerns) by the end of 2010, and for monitoring in ambient waters, including ocean waters, by the summer of 2011.

In recent years, this Regional Water Board has incorporated monitoring of a select group of CECs into the NPDES permits issued to POTWs.

CEC Special Study Requirements

1. The Discharger shall initiate an investigation of CECs by conducting a special study. Specifically, within 6 months of the effective date of this Order/Permit, the Discharger shall develop a CEC Special Study Work Plan (Work Plan) and submit it for Regional Water Board Executive Officer and USEPA Director approval. Immediately upon approval of the Work Plan, the Discharger shall fully implement the Work Plan.

This Work Plan shall include, but not be limited to, the following:

- a. Identification of CECs to be monitored in the effluent, sample type (e.g., 24-hour composite), sampling frequency, and sampling methodology. Table 17 identifies the minimum parameters to be monitored.

Table 17. Effluent Monitoring of CECs

| Parameter ² | Units | Sample Type | Minimum Sampling Frequency | Analytical Test Method and (Minimum Level, units) |
|---|-------|----------------|----------------------------|---|
| 17 α -Ethinyl Estradiol | ng/L | To be proposed | Annually | To be proposed |
| 17 β -Estradiol | ng/L | To be proposed | Annually | To be proposed |
| Estrone | ng/L | To be proposed | Annually | To be proposed |
| Bisphenol A | ng/L | To be proposed | Annually | To be proposed |
| Nonylphenol and nonylphenol polyethoxylates | ng/L | To be proposed | Annually | To be proposed |
| Octylphenol | ng/L | To be proposed | Annually | To be proposed |
| Polybrominated diphenyl ethers | ng/L | To be proposed | Annually | To be proposed |
| Acetaminophen | ng/L | To be proposed | Annually | To be proposed |
| Amoxicillin | ng/L | To be proposed | Annually | To be proposed |
| Azithromycin | ng/L | To be proposed | Annually | To be proposed |
| Carbamazepine | ng/L | To be proposed | Annually | To be proposed |
| Ciprofloxacin | ng/L | To be proposed | Annually | To be proposed |
| Dilantin | ng/L | To be proposed | Annually | To be proposed |
| Gemfibrozil | ng/L | To be proposed | Annually | To be proposed |
| Ibuprofen | ng/L | To be proposed | Annually | To be proposed |
| Lipitor | ng/L | To be proposed | Annually | To be proposed |
| Sulfamethoxazole | ng/L | To be proposed | Annually | To be proposed |
| Trimethoprim | ng/L | To be proposed | Annually | To be proposed |
| Salicylic acid | ng/L | To be proposed | Annually | To be proposed |
| Triclosan | ng/L | To be proposed | annually | To be proposed |
| DEET | ng/L | To be proposed | Annually | To be proposed |
| Caffeine | ng/L | To be proposed | Annually | To be proposed |
| Iodinated contrast media (i.e., iopromide) | ng/L | To be proposed | Annually | To be proposed |
| Fire retardants (e.g., TCEP) | ng/L | To be proposed | Annually | To be proposed |

Once the SCCWRP's recommended list of CEC monitoring in ambient waters, including ocean waters, is finalized, the above list of minimum parameters to be monitored by the Discharger and the sampling frequency may be re-evaluated and modified by the Executive Officer and Director. At such time, upon request by the Executive Officer and Director, the Discharger shall monitor the requested CEC parameters at the specified frequency. In the Work Plan, the Discharger may also propose, for consideration and approval by the Executive Officer and Director, surrogate or indicator CECs that may contribute towards a better understanding of CECs in its effluent.

² Given the evolving state of research, science, and policy involving CECs, the Regional Water Board Executive Officer and USEPA Director may add or remove CECs from the monitoring and reporting program.

Sample Type - The Discharger shall propose in the Work Plan the appropriate sample type for each type of constituent.

Sampling Period - At minimum, the Discharger shall monitor the specified CECs once per year. The Work Plan shall propose the appropriate sampling month or quarter for each year, consistent with the goals of the analyses. The rationale for selecting the particular sampling month or quarter shall be explained in the Work Plan.

Analytical Test Methodology and QA/QC - The Discharger shall review and consider all available analytical test methodologies and appropriate QA/QC procedures, including but not limited to those listed in USEPA Methods 1694 and 1698 or utilized by the U.S. Geologic Survey, California Department of Public Health, or other federal or State agencies. Based on its review, the Discharger shall propose the most appropriate analytical methodology, considering sensitivity, accuracy, availability, and cost.

- b. Characterization of existing CEC data (data collected previous to Special Study). The Discharger shall propose a characterization of all existing CEC data (associated with its effluent or receiving water) that have been collected for various purposes in the past. At minimum, the characterization shall include:
- an identification of all CECs monitored to date (outside of this Special Study);
 - monitoring duration, frequency, and date(s) (for example, from 2000-present, annually);
 - analytical methodologies employed;
 - RL, MLs, and MDLs achieved for each methodology used; and
 - temporal/seasonal trend analyses (using both statistical and graphical demonstration) of CEC data, over time and by season.
- c. Evaluation of CEC data collected as part of this Special Study. The Discharger shall propose an evaluation of CEC data (associated with its effluent) to be collected as part of this special study. At minimum, the characterization shall include:
- an identification of CECs that have been monitored;
 - monitoring duration, frequency, and date(s);
 - RL, MLs and MDLs achieved for each methodology used;
 - a brief update on any improvements (or change) in the analytical methodologies and associated RL, MLs and MDLs achieved for each methodology used; and

- temporal/seasonal trend analyses (using both statistical and graphical demonstration) of CEC data collected as part of this special study.
2. Reporting - By April 15th of each year (starting April 15, 2012), the Discharger shall submit to the Regional Water Board Executive Officer and USEPA Director an annual report summarizing the monitoring results from the previous calendar year. Each annual report shall include a compilation of effluent monitoring data of CECs listed in the approved Work Plan, MLs, sample type, analytical methodology used, sampling date/time, QA/QC information, and an evaluation of cumulative CEC data collected to date as part of this special study (see above for further details on CEC data evaluation). In addition, the first annual report due April 15, 2012 shall include a characterization of existing CEC data, i.e., all data collected outside of this special study (see above for further details on existing CEC data characterization).

B. Special Study – Nutrient Loading and Receiving Water Impacts

By November 4, 2011, consistent with the logistics described in section I.D.3 of the MRP, the Discharger shall propose, as a special study, a summary assessment of existing nutrient data (both effluent and receiving water) collected under the Order/Permit during the period of secondary treatment and quantify the resulting effects, if any, of the discharge on receiving water quality for dissolved oxygen, pH, and percent transmission.

C. Outfall and Diffuser Inspection

This survey answers the question: “Are the outfall structures in serviceable condition ensuring their continued safe operation?” The data collected will be used for a periodic assessment of the integrity of the outfall pipes and ballasting system.

Each ocean outfall (001 and 002) shall be externally inspected a minimum of once a year. Inspections shall include general observations and photographic/videographic records of the outfall pipes and adjacent ocean bottom. The pipes shall be visually inspected by a diver, manned submarine, or remotely operated vehicle. A summary report of the inspection findings shall be provided. This written report, augmented with videographic and/or photographic images, will provide a description of the observed condition of the discharge pipes from shallow water to their respective termini.

D. Biosolids and Sludge Management

The Discharger must comply with all Clean Water Act and regulatory requirements of 40 CFR 257, 258, 501, and 503, including all applicable monitoring, record keeping, and reporting requirements. The Discharger must comply with the requirements in Attachment H of this Order/Permit.

E. Hauling Reports

1. In the event wastes are transported to a different disposal site during the reporting period, the following shall be reported:
 - a. Types of wastes and quantity of each type;
 - b. Name and either the address or the State registration number for each hauler of wastes (or the method of transport if other than by hauling); and
 - c. Location of the final point(s) of disposal for each type of wastes.
2. If no wastes are transported off site during the reporting period, a statement to that effect shall be submitted.

VIII. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. The Discharger shall inform the Regional Water Board and USEPA well in advance of any proposed construction or maintenance or modification to the POTW that could potentially affect compliance with applicable requirements.
3. If the Discharger monitors (other than for process/operational control, startup, research, or equipment testing) any influent, effluent, or receiving water constituent more frequently than required by this Order/Permit using approved analytical methods, the results of those analyses shall be included in the monitoring report. These results shall be reflected in the calculation of the average (or median) used in demonstrating compliance with this Order/Permit.
4. The date and time of sampling (as appropriate) shall be reported with the analytical values determined.
5. Influent and effluent analyses shall be performed on different days of the week during each month. Quarterly influent and effluent analyses shall be performed during the months of January, April, July, and October. Semiannual influent and effluent analyses shall be performed during the months of January and July. Annual influent and effluent analyses shall be performed during the month of July. Should there be instances when monitoring cannot be done during these specified months, the Discharger must notify the Regional Water Board and USEPA, state the reason why the monitoring cannot be conducted, and obtain approval from the Regional Water Board Executive Officer and USEPA for an alternate schedule. Results of quarterly, semiannual, and

annual analyses shall be reported by the 15th of the second month following the analysis.

6. Pollutants shall be analyzed using the analytical methods described in 40 CFR 136 or where no methods are specified for a particular pollutant, by methods approved by the Regional Water Board Executive Officer, in consultation with the State Water Board's Quality Assurance Program, and USEPA. For any analyses performed for which no procedure is specified in USEPA guidelines or in the MRP, the constituent or parameter analyzed and the method or procedure used must be specified in the monitoring report.
7. The laboratory conducting analyses shall be certified by the California Department of Public Health Environmental Laboratory Accreditation Program (ELAP), in accordance with CWC section 13176, or approved by the Regional Water Board Executive Officer, in consultation with the State Water Board's Quality Assurance Program, and USEPA for that particular parameter and must include quality assurance/quality control (QA/QC) data in their reports. A copy of the laboratory certification shall be provided each time a new/renewal certification is obtained from ELAP and must be submitted with the annual summary report. Each monitoring report must affirm in writing that: "All analyses were conducted at a laboratory certified for such analyses by the California Department of Public Health, or approved by the Regional Water Board Executive Officer (in consultation with the State Water Board's Quality Assurance Program) and USEPA, and in accordance with current USEPA guideline procedures or as specified in this MRP."
8. Water/wastewater samples must be analyzed within allowable holding time limits as specified in 40 CFR 136.3. All QA/QC analyses must be run on the same dates that samples are actually analyzed. The Discharger shall retain the QA/QC documentation in its files and make available for inspection and/or submit this documentation when requested by the Regional Water Board and/or USEPA. Proper chain of custody procedures must be followed and a copy of this documentation shall be submitted with the monthly report.
9. The Discharger shall calibrate and perform maintenance procedures on all monitoring instruments to insure accuracy of measurements.
10. The Discharger shall report with each sample result in the monitoring reports: the analytical method used, the Method Detection Limit (MDL) as determined by the procedure in 40 CFR 136, and the Reporting Level (RL) [the applicable minimum level (ML) or reported Minimum Level (RML)] for each pollutant. The MLs are those published by the State Water Board in Appendix II of the 2005 Ocean Plan. The ML represents the lowest quantifiable concentration in a sample based on the proper application of all method-based analytical procedures and the absence of any matrix interference. When all specific analytical steps are followed and after appropriate application of method specific factors, the ML also represents the lowest standard in the calibration

curve for that specific analytical technique. When there is deviation from the analytical method for dilution or concentration of samples, other factors are applied to the ML depending on the sample preparation. The resulting value is the reported Minimum Level.

11. The Discharger shall select the analytical method that provides an ML lower than the effluent limitation or performance goal established for a given parameter or where no such requirement exists, the lowest applicable water quality objective in the Ocean Plan. If the effluent limitation, performance goal, or the lowest applicable water quality objective is lower than all the MLs in Appendix II of the 2005 Ocean Plan, the Discharger must select the method with the lowest ML for compliance purposes. The Discharger shall include in the annual summary reports a list of the analytical methods and MLs employed for each test.
12. Non-detect levels reported for the Hyperion effluent are generally higher than effluent limitations or water quality objectives for DDT, chlordane, PCBs and PAHs. Therefore, the Discharger shall strive for lower analytical detection levels than those specified in Appendix II of the 2005 Ocean Plan to facilitate pollutant load quantification for future DDT and PCBs TMDLs.
13. The Discharger shall instruct its laboratories to establish calibration standards so that the ML (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve. In accordance with section 14 below, the Discharger's laboratory may employ a calibration standard lower than the ML in Appendix II of the 2005 Ocean Plan.
14. Upon request by the Discharger, the Regional Water Board, in consultation with the State Water Board's Quality Assurance Program and/or USEPA, may establish an ML that is not contained in Appendix II of the 2005 Ocean Plan, to be included in the Discharger's NPDES permit, in any of the following situations:
 - a. When the pollutant under consideration is not included in Appendix II;
 - b. When the Discharger agrees to use a test method that is more sensitive than those specified in 40 CFR 136 (most recent revision);
 - c. When the Discharger agrees to use an ML lower than those listed in Appendix II;
 - d. When the Discharger demonstrates that the calibration standard matrix is sufficiently different from that used to establish the ML in Appendix II and proposes an appropriate ML for their matrix; or

- e. When the Discharger uses a method whose quantification practices are not consistent with the definition of an ML. Examples of such methods are the USEPA-approved method 1613 for dioxins and furans, method 1624 for volatile organic substances, and method 1625 for semi-volatile organic substances. In such cases, the Discharger, Regional Water Board, State Water Board and USEPA shall agree on a lowest quantifiable limit, and that limit will substitute for the ML for reporting and compliance determination purposes.
15. The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:
 - a. Sample results greater than or equal to the reported ML shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
 - b. Sample results less than the reported ML, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported. For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc.").
 - c. Sample results less than the laboratory's MDL shall be reported as "Not Detected" or ND.
 16. For bacterial analyses, sample dilutions should be performed so the expected range of values is bracketed (for example, with multiple tube fermentation method or membrane filtration method, 2 to 16,000 per 100 ml for total and fecal coliforms, at a minimum; and 1 to 1000 per 100 ml for *Enterococcus*). The detection methods used for each analysis shall be reported with the results of the analyses. Detection methods used for coliforms (total and fecal) and *Enterococcus* shall be those presented in Table 1A of 40 CFR 136 (most recent revision).
 17. Records and reports of marine monitoring surveys conducted to meet receiving water monitoring requirements shall include, at a minimum, the following information:
 - a. A description of climatic and receiving water characteristics at the time of sampling (weather observations, unusual or abnormal amounts of floating debris, discoloration, wind speed and direction, swell or wave action, time of sampling or measurements, tidal stage and height, etc.).

- b. The date, exact place and description of sampling stations, including differences unique to each station (e.g., date, time, station location, depth, and sample type).
 - c. A list of the individuals participating in field collection of samples or data and description of the sample collection and preservation procedures used in the various surveys.
 - d. A description of the specific method used for laboratory analysis, the date(s) the analyses were performed and the individuals participating in these analyses.
 - e. An in-depth discussion of the results of the survey. All tabulations and computations shall be explained.
18. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with this Order/Permit.
 19. The Discharger shall attach a cover letter to the monitoring reports. The information contained in the cover letter shall clearly identify violations of the Order/Permit; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
 20. All reports must be submitted to the Regional Water Board and USEPA, signed and certified as required by the Standard Provisions (Attachment D), to the addresses listed below. (Reference the reports to Compliance File No. CI-1492 to facilitate routing to the appropriate staff and file.)

California Regional Water Quality Control Board
Los Angeles Region
320 W. 4th Street, Suite 200
Los Angeles, CA 90013
Attention: Information Technology Unit

Regional Administrator
United States Environmental Protection Agency, Region IX
NPDES Data Team (WTR-1)
75 Hawthorne Street
San Francisco, CA 94105

B. Self Monitoring Reports (SMRs) and Discharge Monitoring Reports (DMRs)

1. At any time during the term of this Order/Permit, the State or Regional Water Board may notify the Discharger to electronically submit Self-Monitoring Reports (SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit hard copy SMRs. The CIWQS web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. The Discharger shall report in the SMR/DMR the results for all monitoring specified in this Order/Permit. The Discharger shall submit monthly SMRs/DMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order/Permit. If the Discharger monitors any pollutant more frequently than required by this Order/Permit, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the monitoring reports.
3. Monitoring periods and reporting for required monitoring shall be completed according to the following schedule, except where specific monitoring periods and reporting dates are required elsewhere in this Order/Permit:

Table 18. Monitoring Periods and Reporting Schedule

| Sampling Frequency | Monitoring Period Begins On... | Monitoring Period | Monitoring Report Due Date |
|--------------------|--|--|---|
| Continuous | Order/Permit effective date | All | By the 15 th day of the second month after the month of sampling |
| Hourly | Order/Permit effective date | Hourly | By the 15 th day of the second month after the month of sampling |
| Daily | Order/Permit effective date | (Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling | By the 15 th day of the second month after the month of sampling |
| Weekly | Sunday following Order/Permit effective date (or on Order/Permit effective date if that date is Sunday) | Sunday through Saturday | By the 15 th day of the second month after the month of sampling |
| Monthly | First day of calendar month following Order/Permit effective date (or on Order/Permit effective date if that date is first day of month) | 1 st day of calendar month through last day of calendar month | By the 15 th day of the second month after the month of sampling |

| Sampling Frequency | Monitoring Period Begins On... | Monitoring Period | Monitoring Report Due Date |
|--------------------|---|---|---|
| Quarterly | Closest of January 1, April 1, July 1, or October 1 following (or on) Order/Permit effective date | January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31 | May 15 August 15 November 15 February 15 |
| Semiannually | Closest of January 1 or July 1 following (or on) Order/Permit effective date | January 1 through June 30 July 1 through December 31 | August 15 February 15 |
| Annually | January 1 following (or on) Order/Permit effective date | January 1 through December 31 | February 15 |

4. The Discharger shall submit hard copy SMRs in accordance with the following requirements:
 - a. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment.
 - b. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the address listed below. (Reference the reports to Compliance File No. CI-1492 to facilitate routing to the appropriate staff and file.)

California Regional Water Quality Control Board
 Los Angeles Region
 320 West 4th Street, Suite 200
 Los Angeles, CA 90013
 Attention: Information Technology Unit

5. The Discharger shall submit hard copy DMRs in accordance with the following requirements:
 - a. As described in section VIII.B.1 above, at any time during the term of this Order/Permit, the State or Regional Water Board may notify the Discharger to electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.
 - b. DMRs must be signed and certified as required by the Standard Provisions (Attachment D). The Discharger shall submit the original DMR and one copy of the DMR to the State Water Board address listed below. The Discharger shall submit one copy of the DMR to the USEPA address listed below:

| Standard Mail | FedEx/UPS/Other Private Carriers |
|--|--|
| State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000 | State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA 95814 |
| U.S. EPA, Region 9 ATTN: NPDES Data Team (WTR-1) 75 Hawthorne Street San Francisco, CA 94105-3901 | |

- c. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated must be approved by USEPA.

C. Other Reports

1. Annual Summary Report

By April 15 of each year, the Discharger shall submit an annual summary report containing a discussion of the previous year's influent/effluent analytical results, as well as graphical and tabular summaries of the monitoring analytical data. The data shall be submitted to the Regional Water Board and USEPA on hard copy and a CD-ROM disk or other appropriate electronic medium. The submitted data must be IBM compatible, preferably using Microsoft Excel software. The Discharger shall discuss the compliance record and any corrective actions taken or planned that may be needed to bring the discharge into full compliance with Order/Permit requirements.

The first annual report shall be due April 15, 2011, covering the sampling period from January 2010 – December 2010.

2. Receiving Water Monitoring Report

An annual summary of the receiving water monitoring data collected during each sampling year (January – December) shall be prepared and submitted so that it is received by the Regional Board and USEPA by August 1 of the following year.

By August 1 of every other year, a detailed receiving water monitoring biennial assessment report of the data collected during the two previous calendar sampling years (January – December) shall be prepared and submitted to the Regional Water Board and USEPA. This report shall include an annual data summary and shall also include an in-depth analysis of the biological, chemical, and physical data following recommendations in the Model Monitoring Program guidance document (Schiff, K.C., J.S. Brown and S.B. Weisberg. 2001. *Model Monitoring Program for Large Ocean Dischargers in Southern California*).

SCCWRP Tech. Rep. #357. SCCWRP, Westminster, CA. 101 pp.). Data shall be tabulated, summarized, and graphed where appropriate, analyzed, interpreted, and generally presented in such a way as to facilitate ready understanding of its significance. Spatial and temporal trends shall be examined and compared. The relation of physical and chemical parameters to biological parameters shall be evaluated. See, also, section IV.H of this Monitoring and Reporting Program. All receiving water monitoring data shall be submitted in accordance with the data submittal formats developed for the Southern California Bight Regional Monitoring Surveys.

The first biennial assessment report shall be due August 1, 2011, covering sampling periods of January – December 2009 and January – December 2010. Subsequent reports shall be due August 1, 2013, and August 1, 2015, to cover sampling periods of January 2011 – December 2012 and January 2013 – December 2014, respectively.

3. Outfall Inspection Report

By August 1 of each year, a summary report of the outfall Inspection findings for the previous calendar year shall be prepared and submitted to the Regional Water Board and USEPA. This written report, augmented with videographic and/or photographic images, shall provide a description of the observed external condition of the discharge pipes from shallow water to their respective termini.

The first summary report shall be due August 1, 2011, covering the monitoring period from January 2010 – December 2010.

4. Database Management System

The Regional Water Board and State Water Resources Control Board are developing a database compliance monitoring management system. The Discharger may be required to submit all monitoring and annual summary reports electronically in a specified format when this system becomes fully operational.

Figure 1. Offshore Water Quality Station Locations




Figure 2. Offshore Benthic Sediments and Macrofauna Station Locations for Fixed Stations plus Year 1 Random Stations




Figure 3. Offshore Benthic Sediments and Macrofauna Station Locations for Fixed Stations plus Year 2 Random Stations




Figure 4. Trawl Station Locations Including Fixed Stations and Example of a Combined Array of Year 1 and Year 2 Stations





Figure 5. Local Seafood Survey Zones as Defined by SMBRC Seafood Tissue Monitoring Design



ATTACHMENT F – FACT SHEET

Table of Contents

| | |
|--|------|
| Attachment F – Fact Sheet | F-2 |
| I. Permit Information..... | F-2 |
| II. Background - Consent Decree and Legal Issues..... | F-3 |
| III. Facility Description..... | F-5 |
| IV. Applicable Plans, Policies, and Regulations | F-16 |
| V. Rationale for Effluent Limitations and Discharge Specifications | F-24 |
| VI. Performance Goals | F-42 |
| VII. Rationale for Receiving Water Limitations | F-44 |
| VIII. Mass Emission Caps | F-44 |
| IX. Rationale for Monitoring and Reporting Requirements | F-45 |
| X. Rationale for Provisions | F-48 |
| XI. Public Participation | F-50 |

List of Tables

| | |
|--|------|
| Table 1. Facility Information..... | F-2 |
| Table 2. Description of the Outfalls..... | F-8 |
| Table 3a. Historic Effluent Limitations and Monitoring Data (Conventional and Non-conventional Pollutants).. | F-10 |
| Table 3b. Historic Effluent Limitations and Monitoring Data (Toxic Pollutants)..... | F-10 |
| Table 4. Basin Plan Beneficial Uses of the Applicable Receiving Waters..... | F-17 |
| Table 5. Ocean Plan Beneficial Uses | F-18 |
| Table 6. Summary of Technology-based Effluent Limitations for Secondary Treatment Facility by USEPA at 40 CFR part 133.102 | F-25 |
| Table 7. Summary of Technology-based Effluent Limitations for POTWs established by the Ocean Plan (2005) | F-25 |
| Table 8. Summary of Technology-based Effluent Limitations - Discharge Points 001 and 002.. | F-26 |
| Table 9. Pollutants with Background Seawater Concentrations | F-31 |
| Table 10. Ocean Plan Water Quality Objectives (C _o) for Copper and Ammonia..... | F-31 |
| Table 11. Summary of Final Effluent Limitations Discharge Point 002 | F-34 |
| Table 12. Summary of Final Effluent Limitations Discharge Point 001 | F-38 |

ATTACHMENT F – FACT SHEET

As described in section II of this Order/Permit, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order/Permit.

This Order/Permit has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order/Permit that are specifically identified as “not applicable” have been determined not to apply to this Discharger. sections or subsections of this Order/Permit not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table 1. Facility Information

| | |
|---|---|
| WDID | 4B190106002 |
| Discharger | City of Los Angeles |
| Name of Facility | Hyperion Treatment Plant |
| Facility Address | 12000 Vista del Mar Boulevard |
| | Playa del Rey, CA 90293 |
| | Los Angeles County |
| Facility Contact, Title and Phone | Steven Fan, Sanitation Wastewater Manager III, (310) 648-5168 |
| Authorized Person to Sign and Submit Reports | Steven Fan, Sanitation Wastewater Manager III, (310) 648-5168 |
| Mailing Address | Public Works Building, Bureau of Sanitation 1149 S. Broadway, 9 th Floor Los Angeles, CA 90015 |
| Billing Address | same |
| Type of Facility | POTW |
| Major or Minor Facility | Major |
| Threat to Water Quality | 1 |
| Complexity | A |
| Pretreatment Program | Yes |
| Reclamation Requirements | None |
| Facility Design Flow | 450 (in million gallons per day) |
| Watershed | Santa Monica Bay Watershed Management Area |
| Receiving Water | Pacific Ocean |
| Receiving Water Type | Ocean waters |

- A.** The City of Los Angeles (hereinafter Discharger) is the owner and operator of Hyperion Treatment Plant (hereinafter, HTP or Facility and its appurtenances), a municipal publicly owned treatment works (POTW). USEPA and the Regional Water Board have classified the Hyperion Treatment Plant as a major discharger. It has a Threat to Water Quality and Complexity rating of 1-A pursuant to California Code of Regulations (CCR), Title 23, section 2200.

For the purposes of this Order/Permit, references to the “discharger” or “permittee” in applicable federal and State laws, regulations, plans, or policies are held to be equivalent to references to the Discharger herein.

- B.** The Hyperion Treatment Plant discharges wastewater to the Pacific Ocean, a water of the United States, and is currently regulated by Order R4-2005-0020 (NPDES No. CA0109991), which was issued on April 11, 2005 and expired on May 14, 2010. The terms and conditions of the current Order/Permit have been automatically continued and remain in effect until new Waste Discharge Requirements (WDRs) and National Pollutant Discharge Elimination System (NPDES) permit are issued pursuant to this Order/Permit.
- C.** The Discharger submitted a Report of Waste Discharge, dated October 27, 2009, and applied for renewal of its WDR and NPDES permit to discharge up to 450 MGD of secondary-treated wastewater from the Hyperion Treatment Plant. The application was deemed complete on December 23, 2009. A site visit was conducted on October 7, 2010, to observe operations and to collect additional data to develop permit limitations and conditions.

II. BACKGROUND - CONSENT DECREE AND LEGAL ISSUES

- A.** The operations and discharges from the Hyperion Treatment Plant and Hyperion collection system are also regulated under the following enforcement actions:
1. Amended Consent Decree entered on February 19, 1987, in United States and State of California v. City of Los Angeles, No. CV 77-3047-HP (C.D. Cal.);
 2. Settlement Agreement, Los Angeles Superior Court Case No. C 665238, dated January 29, 1990, in State of California v. City of Los Angeles; and
 3. Regional Water Board Cease and Desist Order 98-073 adopted on September 14, 1998, amended by Order No. 00-128 adopted on August 31, 2000.
- B.** In 1987, the City entered into an Amended Consent Decree (No. CV 77-3047-HP) with USEPA and the Regional Water Board. The Amended Consent Decree required the City under time schedules to undertake the following:

1. Eliminate the discharge of sewage sludge into the Pacific Ocean from Hyperion Treatment Plant by December 31, 1987 (status: completed);
 2. Comply with interim effluent limitations (status: interim limits are not applicable as of January 1, 1999);
 3. Complete construction and begin operation of the Hyperion Energy Recovery System by June 30, 1989 (status: completed, but determined to be a technological failure and abandoned);
 4. Achieve and thereafter maintain compliance with full secondary treatment at Hyperion Treatment Plant by December 31, 1998 (status: completed and achieved compliance before the deadline);
 5. Prepare a storm water pollution reduction study and implement the recommended measures thereof (status: completed).
- C. On June 7, 1991, the United States and the State of California filed a supplemental complaint under the existing Consent Decree CV 77-3047-HP (C.D. Cal.) for alleged pretreatment violations against the City. Settlement of the complaint had been concluded and modification to the Consent Decree was entered into court records on August 7, 2000. The settlement requires the City to implement the Westside Water Recycling Extension Project and the Santa Monica Bay Storm Drain Low-Flow Diversion Project. The Santa Monica Urban Runoff Recycling Facility (SMURRF), completed in 2000, is owned and operated by the City of Santa Monica. As the first full-scale, dry-weather runoff recycling facility in the U.S., SMURRF reclaims dry-weather run-off from storm drains and treats the water for reuse in landscape irrigation and toilet flushing. Since the City of Los Angeles contributes about half of the runoff treated at SMURRF, the City of Los Angeles pays for half of the capital and operations and maintenance costs of SMURRF, pursuant to an agreement with the City of Santa Monica.
- D. In October 1987, the California Attorney General, on behalf of the Regional Water Board, filed a complaint with the Los Angeles Superior Court (Case No. C 665238) for civil penalties regarding unpermitted discharges to Discharge Point 001 and raw sewage overflows to surface waters from the Hyperion collection system. A settlement agreement was entered into on January 29, 1990. In lieu of civil penalties, the City was required to implement 23 projects to improve and enhance its collection system and benefit the waters in the Greater Los Angeles Area. Twenty two of the 23 Settlement Agreement projects were completed. The remaining project deals with the Los Angeles Zoo Wastewater Treatment Facility. Two of the original three elements of the Zoo project (construction of the retention basin and pump station for collection of the Zoo's wastewater and diversion to the North Outfall Sewer force main) were completed in 1995. The City proposes to substitute Best Management Practices (BMPs) for the stormwater peripheral drainage system, the third element of the original design concept. After reviewing the study, the Regional Water Board rejected the

City's proposal because the proposed BMPs cannot achieve the objectives of the original Settlement Agreement. In a letter dated November 5, 2008, the Regional Water Board approved the Fremont High School Stormwater Improvements Project (Fremont Project) as a substitute for the remaining project, the Los Angeles Zoo Perimeter Drain System (PDS). The Regional Water Board agreed that the PDS has ceased to be necessary due to the completion of the North East interceptor Sewer and East Central Interceptor Sewer. The Fremont Project includes the implementation of the following five BMPs: Stormwater Diversion, Pollutant Settlement, Sediment Forebay, Dry Extended Detention/Retention Basin, and "Smart" (programmable) Irrigation System.

- E. Sanitary sewer overflows (SSO) have been a recurring problem in certain areas of the City; in particular, in the South Central area, where sewers do not have adequate capacity to absorb inflow and infiltration that occurs during wet weather. For the entire City, between the wet weather period of February 3, 1998 through May 14, 1998, there were 99 separate sanitary overflows resulting in 44 million gallons of raw sewage released. On September 14, 1998, the Regional Water Board issued Cease and Desist Order (CDO) No. 98-073 to the City, amended by CDO No. 00-128 adopted on August 31, 2000. The CDO requires the City to provide adequate capacity to its wastewater collection system by constructing additional sewer alignments and/or upgrading the existing sewer system over a seven-year period (1998 to 2005). Additionally, on August 5, 2004, the United States, the State of California, Santa Monica Baykeeper, a coalition of community groups and the City of Los Angeles lodged a settlement that would resolve the parties' Clean Water Act and Porter-Cologne Act litigation regarding the City of Los Angeles' SSOs and sewage odors. This settlement underwent public review and comment. The Settlement Agreement and Final Order was filed on October 28, 2004 and entered by the District Court on October 29, 2004, and is now being implemented. The Settlement Agreement and Final Order establish a ten-year program designed to reduce SSOs and sewage odors to the maximum extent feasible.

III. FACILITY DESCRIPTION

A. Description of Wastewater and Biosolids Treatment or Controls

The Discharger owns and operates the Hyperion Treatment Plant located at 12000 Vista del Mar Boulevard, Playa Del Rey, California. The plant has a 30-day (monthly) average daily dry weather design treatment capacity of 450 million gallons per day (MGD) and a wet weather peak hydraulic capacity of approximately 850 MGD. In 2009, the HTP treated an average effluent flow of 312 MGD and discharged an average of 275 MGD. Approximately 37 MGD of the secondary effluent was sent to West Basin Water Recycling Facility for advanced treatment and reuse.

The HTP is part of a joint outfall system commonly known as the Hyperion Treatment System, which consists of the wastewater collection system, the Hyperion Treatment Plant and three upstream wastewater treatment plants: Donald C. Tillman Water Reclamation Plant (Tillman WRP), Los Angeles-Glendale Water Reclamation Plant (LAGWRP), Burbank Water Reclamation Plant (Burbank WRP) (owned and operated by a contract city), and outfalls. The Hyperion Treatment System collects, treats, and disposes of sewage from the entire City (except the Wilmington-San Pedro Area, the strip north of San Pedro, and Watts) and from a number of cities and agencies under contractual agreements. Approximately, 85% of the sewage and commercial/industrial wastewater comes from the City of Los Angeles. The remaining 15% comes from the Contract Cities and Agencies. There are approximately four million people in the Hyperion Treatment System Service Area.

The HTP started treating dry weather runoff from the low flow diverters (LFDs) year-round in November 2009.

Sludge from the City's two upstream plants (Tillman WRP and LAGWRP) is returned to the wastewater collection system and flows to the Hyperion Treatment Plant for treatment. Discharges from Tillman WRP and LAGWRP are regulated by Order No. R4-2010-0060 (NPDES No. CA0056227) and Order No. R4-2010-0059 (NPDES No. CA0053953), respectively. In addition, sludge generated from the Burbank WRP is also returned to the City of Burbank sewer system for treatment at the Hyperion Treatment Plant. The influent to the Burbank WRP can be diverted/bypassed to the Hyperion Treatment Plant during periods of emergency. Discharges from the Burbank WRP are regulated under R4-2010-0058 (NPDES No. CA0055531).

The Hyperion Treatment Plant has provided full secondary treatment since December 1998. Preliminary and primary wastewater treatments consist of screening, grit removal, and primary sedimentation with coagulation and flocculation. In secondary treatment, the primary effluent is biologically treated in a high purity oxygen activated sludge process comprised of a cryogenic oxygen plant, nine secondary reactor modules and 36 secondary clarifiers. Each secondary reactor module is designed to handle 50 MGD of flow which results in a total treatment capacity of 450 MGD producing secondary effluent. After clarification, undisinfected secondary effluent is discharged into Santa Monica Bay through a five mile submerged outfall pipe. Discharge up to 325 MGD flows by gravity to the outfall, or is pumped at the Effluent Pumping Plant when flows exceed 325 MGD.

Solid fractions recovered from wastewater treatment processes include grit, primary screenings, primary sludge and skimmings, thickened waste activated sludge, digested sludge screenings and digester cleaning solids. The fine solids (grit, primary screenings, digested sludge screenings, digester cleaning solids) that consist of primarily inorganic materials are hauled away to landfills. The remaining solid fractions (primary sludge and skimmings, thickened waste activated sludge) are anaerobically digested onsite. The digested solids are screened and dewatered

using centrifuges. Since January 1, 2003, the Hyperion Treatment Plant has implemented full thermophilic digestion to generate Class A "EQ" biosolids. The biosolids (treated sewage sludge) are beneficially reused offsite for land application and composting projects. The digester gas is cleaned and a major part of the gas is currently exported to the Los Angeles Department of Water and Power's Scattergood Steam Generating Plant, located immediately adjacent to the Hyperion Treatment Plant. The exported digester gas is used as fuel in the generation of electricity. In return, the generating plant provides steam for digester heating for the Hyperion Treatment Plant. During interruptions in the export of steam from the Scattergood Steam Generation Plant, digester gas can be used as fuel for in-plant boilers that provide steam to heat the anaerobic digesters. Any remaining non-exported digester gas may be flared, if necessary, and is regulated under a flare operation permit from the South Coast Air Quality Management District (AQMD).

The Hyperion Treatment Plant has an industrial wastewater Pretreatment Program which is approved by USEPA and the Regional Water Board. The City continues to implement the Pretreatment Program throughout the Hyperion Treatment Plant's service area. However, since Contract Cities and Agencies operate their respective collection systems that are tributary to the City's main trunk lines, some contract cities and agencies also perform certain nondomestic source control activities, e.g., Fats, Oils, and Grease (FOG) program.

The Hyperion Treatment Plant collects and treats in-plant storm water runoff except that, during intense storms, undisinfected storm water overflows may be discharged through Outfall 001. This storm water discharge is regulated under the State Water Board's *NPDES General Permit No. CAS00001 and Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities* contained in Order No. 97-03-DWQ, adopted on April 17, 1997. The City has developed and implemented a *Storm Water Pollution Prevention Plan* as required by the general permit.

Water Reclamation. A small fraction (approximately 37 MGD in 2009) of the HTP's secondary effluent is sent to West Basin Water Recycling Facility (West Basin Facility) for advanced treatment and reuse. The West Basin Municipal Water District (West Basin) operates the West Basin Facility in El Segundo. West Basin is contractually entitled to receive up to 70 MGD of secondary effluent from HTP. West Basin Facility provides tertiary treatment and/or advanced treatments such as microfiltration and reverse osmosis (RO) to the Hyperion secondary effluent to produce Title 22 and high purity recycled water. Title 22 recycled water is used for beneficial irrigation, industrial applications including cooling water and boiler feed water, and other purposes. The RO-treated recycled water is primarily injected into the West Coast Basin Barrier Project to control seawater intrusion.

The waste brine from West Basin Facility is discharged to the ocean through Hyperion’s five-mile outfall (Discharge Point 002) via a waste brine line from West Basin Facility. Although the waste brine is discharged through Hyperion’s outfall, it is regulated under separate waste discharge requirements and NPDES permit.

The Hyperion Treatment Plant ceased the irrigation use of in-plant chlorinated secondary treated wastewater in January 1999. Instead, the plant started using tertiary recycled water from West Basin Facility in August 1999.

B. Discharge Points and Receiving Waters

The HTP has three ocean outfalls. However, only two outfalls (i.e., 001 and 002) are authorized discharge points for discharging treated wastes to the Pacific Ocean. The three ocean outfalls are described as follows:

1. Discharge Points 001 and 002

Table 2. Description of the Outfalls

| Discharge Point No. | 001 | 002 |
|---|--------------------------------|---|
| Diameter of Pipe at Discharge Terminus (feet) | 12 | 12 |
| Outfall Distance Offshore (feet) | 5,364 | 26,525 (including Y-shaped diffuser with two 3,840-ft legs) |
| Discharge Depth Below Surface Water (feet) | 50 | 187 |
| Latitude and Longitude | 33° 55.06' N, 118° 26.51' W | 33° 54.72' N, 118° 31.29' W (Outfall at start of wye structure) 33° 54.43' N, 118° 31.17' W (North terminus of wye structure) 33° 54.02' N, 118° 31.38' W (South terminus of wye structure) |

Discharge Point 001

Discharge Point 001 is commonly referred to as the “one-mile outfall”. It is a 12-foot diameter outfall terminating approximately 5,364 feet (1.6 kilometers (km)) west-southwest of the treatment plant at a depth of approximately 50 feet (15 meters (m)) below the ocean surface (Latitude 33° 55.06’ N, Longitude 118° 26.51’ W). This outfall is permitted for emergency discharge of chlorinated secondary treated effluent during extremely high flows, and preventative maintenance, such as routine opening and closing the outfall gate valve(s) for exercising and lubrication. However, during intense storms or storms associated with plant power outages, direct discharge of undisinfected storm water overflow is also permitted at this outfall. This Order/Permit requires the City to notify the Regional Water Board and USEPA in advance of any planned preventative maintenance that results in discharges through Discharge Point 001.

The ocean water in this area is not listed as impaired under the 2006 Clean Water Act (CWA) section 303(d) List.

Discharge Point 002

Discharge Point 002 is commonly referred to as the “five-mile outfall”. It is a 12-foot diameter outfall terminating approximately 26,525 feet (8.1 km) west-southwest of the treatment plant at a depth of approximately 187 feet (57m) below the ocean surface. This outfall is located north of Discharge Point 001 and ends in a “Y” shaped diffuser consisting of two 3,840-foot legs (Latitude 33° 54.72’ N, Longitude: 118° 31.29’ W) (North terminus of wye structure – Latitude 33° 54.43’ N, Longitude 118° 31.71’ W; South terminus of wye structure – Latitude 33° 54.02’ N, Longitude 118° 31.38’ W). This is the only outfall permitted for the routine discharge of undisinfected secondary treated effluent.

2. Outfall No. 003

This is a 20-inch diameter outfall terminating approximately 35,572 feet (10.8 km) west of the treatment plant, at the head of a submarine canyon at a depth of approximately 300 feet (91m) below the ocean surface (Latitude 33° 55.62’ N, Longitude 118° 33.18’ W). This outfall had been used to discharge sludge. Under the 1987 amended Consent Decree No. CV77-3047-HP, this outfall was deactivated in November 1987 when sludge discharge to the ocean was terminated. Near the head of this outfall, a spool piece was removed and the discharge pipe was blind-flanged to prevent any possible discharge of sewage or sludge into the Pacific Ocean. This outfall has not been maintained since it was taken out of service. Any discharge from this outfall is prohibited.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Effluent limitations contained in the existing Order/Permit for discharges from Discharge Points EFF-002 and EFF-001 and representative monitoring data from the term of the previous Order/Permit are as follows:

Table 3a. Historic Effluent Limitations and Monitoring Data (Conventional and Non-conventional Pollutants)

| Parameter | Units | Effluent Limitation in Order R4-2005-0020 | | | Monitoring Data (From July 2005 – July 2009) | | |
|--------------------------------------|-----------|---|----------------|---------------|--|----------------------------------|-------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Highest Average Monthly Discharge | Highest Average Weekly Discharge | Highest Daily Discharge |
| Conventional/Non-Conventional | | | | | | | |
| BOD | mg/L | 30 | 45 | -- | 24 | 26.4 | 38 |
| Total Suspended Solids | mg/L | 30 | 45 | -- | 12 | 15 | 24 |
| Oil & Grease | mg/L | 25 | 40 | 75 | 13 | 22 | 38 |
| Settleable Solids | mL/L | 1.0 | 1.5 | 3.0 | <0.1 | 0.3 | 1.5 |
| Total Coliform | MPN/100mL | -- | -- | -- | 119323 | 160000 | 160000 |
| Fecal Coliform | MPN/100mL | -- | -- | -- | 60940 | 160000 | 160000 |
| <i>Enterococcus</i> | MPN/100mL | -- | -- | -- | 3746 | 16000 | 16000 |
| Nitrate-N | mg/L | -- | -- | -- | 0.22 | -- | -- |
| Nitrite-N | mg/L | -- | -- | -- | 0.92 | -- | -- |
| pH | pH Unit | 6.0 – 9.0 | | | 7.4 | 7.5 | 7.6 |
| Temperature | °C | | | | 29 | 29 | 29 |
| Turbidity | NTU | 75 | 100 | 225 | 11.7 | 13.6 | 18.8 |

Table 3b. Historic Effluent Limitations and Monitoring Data (Toxic Pollutants)

| Parameter | Units | Effluent Limitation in Order No. R4-2005-0020 | | | Monitoring Data (From July 2005 – July 2009) | | | |
|---------------------------------------|-------|---|---------------|-----------------------|--|-------------------|------------------|------------------|
| | | Average Monthly | Maximum Daily | Instantaneous Maximum | Minimum Nondetect | Maximum Nondetect | Minimum Detected | Maximum Detected |
| Marine Aquatic Life Protection | | | | | | | | |
| Arsenic (As) | µg/L | -- | -- | -- | <1 | <1 | 1.1 | 3.5 |
| Cadmium (Cd) | µg/L | -- | -- | -- | <0.01 | <0.4 | -- | -- |
| Chromium VI (Cr VI) | µg/L | -- | -- | -- | <0.5 | <2 | -- | -- |
| Chromium Total (Cr) | µg/L | -- | -- | -- | <0.5 | <10 | -- | -- |
| Copper (Cu)* | µg/L | 16 | 140 | 160 | -- | -- | 12.9 | 28 |
| Lead (Pb) | µg/L | -- | -- | -- | <0.5 | <3 | -- | -- |

| Parameter | Units | Effluent Limitation in Order No. R4-2005-0020 | | | Monitoring Data (From July 2005 – July 2009) | | | |
|---|-------|---|---------------|-----------------------|--|-------------------|------------------|------------------|
| | | Average Monthly | Maximum Daily | Instantaneous Maximum | Minimum Nondetect | Maximum Nondetect | Minimum Detected | Maximum Detected |
| Mercury (Hg) | µg/L | -- | -- | -- | <0.004 | <0.022 | -- | -- |
| Nickel (Ni) | µg/L | -- | -- | -- | <20 | <20 | 7.95 | 21.8 |
| Selenium (Se) | µg/L | -- | -- | -- | <1 | <1 | 1 | 1.6 |
| Silver (Ag) | µg/L | -- | -- | -- | <0.2 | <0.25 | 0.57 | 2.24 |
| Zinc (Zn) | µg/L | -- | -- | -- | <20 | <20 | 15.8 | 118 |
| Cyanide* | µg/L | 14 | 56 | 140 | <4 | <4 | 5 | 5 |
| Total Residual Chlorine* | mg/L | 28 | 112 | 840 | <0.1 | <0.1 | 0.1 | 0.3 |
| Ammonia-N* | mg/L | 8.4 | 34 | 84 | -- | -- | 33.7 | 41.8 |
| Acute Toxicity** | TUa | -- | 2.8 | 2-- | -- | -- | 0.59 | 3 |
| Chronic Toxicity* | TUc | -- | 13 | -- | -- | -- | 10 | 142.9 |
| Chronic Toxicity** | TUc | -- | 84 | -- | -- | -- | 10 | 142.9 |
| Non-Chlorinated Phenolic Compounds | µg/L | -- | -- | -- | <0.21 | <2 | -- | -- |
| Chlorinated Phenolic Compounds | µg/L | -- | -- | -- | <0.4 | <5 | -- | -- |
| Endosulfan | µg/L | -- | -- | -- | <0.002 | <0.008 | -- | -- |
| Endrin | µg/L | -- | -- | -- | <0.001 | <0.007 | -- | -- |
| HCH* | µg/L | 0.056 | 0.11 | 0.17 | <0.002 | <0.003 | -- | -- |
| Human Health Toxicants – Non Carcinogens | | | | | | | | |
| Acrolein | µg/L | -- | -- | -- | <0.61 | <1.96 | -- | -- |
| Antimony | µg/L | -- | -- | -- | <0.5 | <0.5 | 0.84 | 1.53 |
| Bis (2-Chloroethoxy) methane | µg/L | -- | -- | -- | <0.05 | <0.05 | -- | -- |
| Bis (2-Chloroisopropyl) ether | µg/L | -- | -- | -- | <0.05 | <0.35 | -- | -- |
| Chlorobenzene | µg/L | -- | -- | -- | <0.06 | <0.15 | -- | -- |
| Chromium III (Cr) | µg/L | -- | -- | -- | <0.5 | <10 | -- | -- |
| Di-n-Butyl Phthalate | µg/L | -- | -- | -- | <0.15 | <10 | -- | -- |
| Dichlorobenzene | µg/L | -- | -- | -- | <0.06 | <2 | -- | -- |
| Diethyl phthalate | µg/L | -- | -- | -- | <0.06 | <2 | -- | -- |
| Dimethyl phthalate | µg/L | -- | -- | -- | <0.08 | <0.27 | -- | -- |
| 4,6-dinitro-2-methylphenol | µg/L | -- | -- | -- | <0.4 | <0.49 | -- | -- |
| 2,4-dinitrophenol* | µg/L | 56 | -- | -- | <0.08 | <0.130 | -- | -- |
| Ethylbenzene | µg/L | -- | -- | -- | <0.08 | <0.17 | -- | -- |
| Fluoranthene | µg/L | -- | -- | -- | <0.0047 | <0.2 | -- | -- |

| Parameter | Units | Effluent Limitation in Order No. R4-2005-0020 | | | Monitoring Data (From July 2005 – July 2009) | | | |
|---|-------|---|---------------|-----------------------|--|-------------------|------------------|------------------|
| | | Average Monthly | Maximum Daily | Instantaneous Maximum | Minimum Nondetect | Maximum Nondetect | Minimum Detected | Maximum Detected |
| Hexachlorocyclopentadiene | µg/L | -- | -- | -- | <2.42 | <2.9 | -- | -- |
| Nitrobenzene | µg/L | -- | -- | -- | <0.05 | <0.33 | -- | -- |
| Thallium | µg/L | -- | -- | -- | <0.01 | <1 | -- | -- |
| Toluene | µg/L | -- | -- | -- | <0.08 | <2 | -- | -- |
| Tributyltin* | µg/L | 0.02 | -- | -- | <1 | <1 | -- | -- |
| Tributyltin** | µg/L | 0.12 | -- | -- | <1 | <1 | -- | -- |
| 1,1,1-trichloroethane | µg/L | -- | -- | -- | <0.05 | <0.29 | -- | -- |
| Human Health Toxicants - Carcinogens | | | | | | | | |
| Acrylonitrile* | µg/L | 1.4 | -- | -- | <0.08 | <0.96 | -- | -- |
| Aldrin | µg/L | -- | -- | -- | <0.003 | <0.09 | -- | -- |
| Benzene | µg/L | -- | -- | -- | <0.07 | <0.22 | -- | -- |
| Benzidine | µg/L | -- | -- | -- | <1.52 | <5 | -- | -- |
| Beryllium (Be)* | µg/L | 0.46 | -- | -- | <0.04 | <2 | -- | -- |
| Bis (2-Chloroethyl) ether* | µg/L | 0.63 | -- | -- | <0.09 | <0.32 | -- | -- |
| Bis(2-ethylhexyl)-phthalate* | µg/L | 49 | -- | -- | <1 | <5 | -- | -- |
| Carbon tetrachloride | µg/L | -- | -- | -- | <0.09 | <0.34 | -- | -- |
| Chlordane* | µg/L | 0.0003 | -- | -- | <0.003 | <0.09 | -- | -- |
| Chlordane** | µg/L | 0.0019 | -- | -- | <0.003 | <0.09 | -- | -- |
| Chlorodibromomethane | µg/L | -- | -- | -- | <2 | <2 | 2.16 | 2.16 |
| Chloroform | µg/L | -- | -- | -- | -- | -- | 2.05 | 8.65 |
| DDT* | µg/L | 0.0024 | -- | -- | <0.002 | <0.006 | -- | -- |
| DDT** | µg/L | 0.014 | -- | -- | <0.002 | <0.006 | -- | -- |
| 1,4-Dichlorobenzene | µg/L | -- | -- | -- | <0.07 | <1 | 1.25 | 2.05 |
| 3,3'-Dichlorobenzidine | µg/L | -- | -- | -- | <0.11 | <1.79 | -- | -- |
| 1,2-dichloroethane | µg/L | -- | -- | -- | <0.03 | <0.1 | -- | -- |
| 1,1-dichloroethylene | µg/L | -- | -- | -- | <0.12 | <0.2 | -- | -- |
| Dichlorobromomethane | µg/L | -- | -- | -- | <2 | <2 | -- | -- |
| Dichloromethane | µg/L | -- | -- | -- | <0.12 | <2 | 2.13 | 6.49 |
| 1,3-dichloropropene | µg/L | -- | -- | -- | <0.09 | <0.15 | -- | -- |
| Dieldrin | µg/L | -- | -- | -- | <0.0009 | <0.005 | -- | -- |
| 2,4-Dinitrotolulene | µg/L | -- | -- | -- | <0.08 | <0.13 | -- | -- |

| Parameter | Units | Effluent Limitation in Order No. R4-2005-0020 | | | Monitoring Data (From July 2005 – July 2009) | | | |
|---------------------------|-------|---|---------------|-----------------------|--|-------------------|------------------|------------------|
| | | Average Monthly | Maximum Daily | Instantaneous Maximum | Minimum Nondetect | Maximum Nondetect | Minimum Detected | Maximum Detected |
| 1,2-Diphenylhydrazine | µg/L | | -- | -- | <0.06 | <0.21 | -- | -- |
| Halomethanes | µg/L | -- | -- | -- | <0.21 | <2 | -- | -- |
| Heptachlor | µg/L | | -- | -- | <0.001 | <0.007 | -- | -- |
| Heptachlor epoxide | µg/L | | -- | -- | <0.001 | <0.003 | -- | -- |
| Hexachlorobenzene | µg/L | | -- | -- | <0.07 | <0.18 | -- | -- |
| Hexachlorobutadiene | µg/L | -- | -- | -- | <0.07 | <0.17 | -- | -- |
| Hexachloroethane | µg/L | -- | -- | -- | <0.07 | <0.17 | -- | -- |
| Isophorone | µg/L | -- | -- | -- | <0.07 | <1 | -- | -- |
| N-Nitrosodimethylamine | µg/L | -- | -- | -- | <0.17 | <0.5 | -- | -- |
| N-Nitrosodi-N-propylamine | µg/L | 5.3 | -- | -- | <0.13 | <0.36 | -- | -- |
| N-Nitrosodiphenylamine | µg/L | -- | -- | -- | <0.09 | <0.86 | -- | -- |
| PAH* | µg/L | 0.123 | -- | -- | <0.0037 | <0.36 | -- | -- |
| PAH** | µg/L | 0.748 | -- | -- | <0.0037 | <0.36 | -- | -- |
| PCBs* | µg/L | 0.0003 | -- | -- | <0.07 | <0.49 | -- | -- |
| PCBs** | µg/L | 0.002 | -- | -- | <0.07 | <0.49 | -- | -- |
| TCDD equivalents* | pg/L | 0.055 | -- | -- | <1 | <1 | -- | -- |
| TCDD equivalents** | pg/L | 0.33 | -- | -- | <1E | <1 | -- | -- |
| 1,1,2,2-tetrachloroethane | µg/L | -- | -- | -- | <0.11 | <0.19 | -- | -- |
| Tetrachloroethylene | µg/L | -- | -- | -- | <0.1 | <2 | 2.37 | 4.03 |
| Toxaphene | µg/L | | -- | -- | <0.02 | <0.1 | -- | -- |
| Trichloroethylene | µg/L | -- | -- | -- | <0.08 | <0.18 | -- | -- |
| 1,1,2-trichloroethane | µg/L | -- | -- | -- | <0.05 | <0.2 | -- | -- |
| 2,4,6-Trichlorophenol | µg/L | -- | -- | -- | <0.09 | <0.45 | -- | -- |
| Vinyl chloride | µg/L | -- | -- | -- | <0.07 | <0.22 | -- | -- |

* Indicates effluent limitations for Discharge Point 001.

** Indicates effluent limitations for Discharge Point 002.

< Indicates that the pollutant was not detected at that concentration level.

-- Indicates not applicable.

D. Compliance Summary

Monitoring data from 2005 to 2009 indicate that the Discharger has consistently complied with the effluent limitations of Order No. R4-2005-0020, except for the following exceedances:

Settleable Solids

- Daily maximum limitation of 3.0 ml/L on April 7, 2005.
- Weekly average limitation of 1.5 ml/L on April 9, 2005.
- Daily maximum limitation of 3.0 ml/L on July 16, 2009.

Ammonia as N - Daily maximum limitation of 34 mg/L on November 29, 2006.

Acute toxicity - Daily maximum acute toxicity limitation of 2.8 TUa on March 12, 2008. An acute topsmelt toxicity test conducted on a 24-hour composite sample collected on March 11, 2008 (and analyzed on March 12, 2008) resulted in an exceedance of the effluent limitation in Order No. R4-2005-0020. This triggered the initiation of accelerated testing, a requirement of Order No. R4-2005-0020. The Discharger conducted all six additional tests, which were in compliance with the toxicity limitation. The Discharger has since resumed regular monthly testing.

Sanitary Sewer Overflows (SSO) and Spills - The Discharger has reported a number of spills and/or overflows in the HTP service area over the years. City of Los Angeles reported that, between January 2007 and April 2010, there was a total of 557 SSOs and spills in the Hyperion Service Area (totaling 524,450 gallons of spill, of which 183,847 gallons were recovered). Only one SSO incident, estimated at 1,700 gallons, was related to wet weather. Appropriate enforcement is being evaluated by the Regional Water Board and USEPA.

Discharge to Discharge Point 001 - During the planned maintenance of the one-mile gates, secondary treated effluent was discharged through the Discharge Point 001 (one-mile outfall), on the following dates: July 21, 2005, August 29, 2005, May 2 and 24, 2007, February 12, 2008, May 21, 2008, August 20, 2008, January 13, 2009, April 28, 2009. In addition, from November 28 - 30, 2006, during a planned maintenance inspection of Discharge Point 002 (five-mile outfall), secondary treated effluent was discharged through the Outfall Discharge Point 001. The Discharger conducted the necessary notifications to the Regional Water Board and USEPA, appropriate sampling and monitoring was conducted as required by the Order No. R4-2005-0020.

E. Discharge Plume

The City has conducted offshore water quality monitoring in Santa Monica Bay since 1987.

The movement of the Hyperion Treatment Plant's wastewater plume is dictated by the depth of the thermocline or stratification and the direction and strength of highly variable currents in Santa Monica Bay. Under typical conditions, the plume is detected within 2 km (6,562 ft) of the outfall terminus of Discharge Point 002, although it has been detected as far as 8 km (2,6247 ft) away from the outfall. Also, the plume has almost always been detected below the thermocline at a depth ranging from 10 m (33 ft) to 55 m (180 ft). Infrequently, during winter storm conditions, the plume has been detected at the surface in the vicinity of the outfall. On rare occasions, it has been impossible to detect the plume.

As the waters of Santa Monica Bay approach the shore, the thermocline intersects the rising sea bottom. This point is typically 1000 m (3,281 ft) or more offshore and is the theoretical limit of the approach of the plume to the shoreline. The plume has never been detected less than 2.5 km (8,202 ft) from shore, at the 45 m (148 ft) depth contour.

The City has conducted shoreline and nearshore/inshore water quality monitoring in Santa Monica Bay since the late 1940s. The monitoring results indicated that effluent from the five-mile outfall does not reach the shoreline and that elevated bacterial counts are associated with runoff from storm drains and discharges from piers. The direct impacts of the discharge from the one-mile outfall on shoreline water quality have not been studied due to the lack of routine discharge. However, it is expected to be minimal because effluent discharged from the one-mile outfall is disinfected and the volume of the discharge is usually less than five million gallons, occurring at most once per quarter. This discharge is intended for conducting a functional test of equipment.

Shoreline monitoring requirements have been transferred to the monitoring program of the municipal storm water for the City (Order No. 01-182, NPDES No. CAS004001) adopted by this Regional Water Board on December 13, 2001.

F. Receiving Water Description

The receiving water into which Hyperion Treatment Plant discharges is part of the Santa Monica Bay watershed. The watershed is home to unique wetland, sand dune, and open ocean ecosystems that support a rich diversity of wildlife and serve as migration stopovers for marine mammals and birds. The Bay and its beaches are invaluable recreational resources and important sources of revenue for the region. The Bay is heavily used for fishing, swimming, surfing, diving, and other activities classified as water contact and noncontact recreation.

Over the years, the beneficial uses of the Bay have been impaired to various degrees due to pollution, resource over-exploitation, and habitat destruction. The primary problems of concern include acute health risk associated with swimming in runoff-contaminated surfzone waters, chronic (cancer) risk associated with consumption of certain sport fish species in areas impacted by DDT and PCB contamination, pollutant loading from point sources, urban runoff, and other nonpoint sources in light of projected population increases and their impacts on marine ecosystem, health of fishery resources, and degradation of natural habitats, and population decline of key species. (Santa Monica Bay Restoration Commission. 2004. "State of the Bay: 2004 Progress and Challenges", 45 pages; Santa Monica Bay Restoration Project. 1998. "Taking the Pulse of the Bay - State of the Bay 1998").

Section 403 of the Clean Water Act (CWA) requires dischargers to comply with specific Ocean Discharge Criteria established to address impacts on marine resources, including fisheries and endangered species. The City of Los Angeles submitted a report on May 29, 2003, to demonstrate compliance with the section 403 Ocean Discharge Criteria. Based upon an evaluation of previous receiving water monitoring data and reports from other agencies, the City concluded that no unreasonable degradation of the marine environment is occurring with the current discharge receiving full secondary treatment and compliance with applicable water quality standards achieved.

G. Planned Changes

The Discharger has no significant planned changes.

IV. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the proposed Order/Permit are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order/Permit is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and Chapter 5.5, Division 7 of the California Water Code (CWC) (commencing with Section 13370). It shall serve as a NPDES permit for point source discharges from this facility to surface waters. This Order/Permit also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, Chapter 4, Division 7 of the California Water Code (commencing with Section 13260). Although Discharge Point 002 is beyond the limit of State-regulated ocean waters, effluent plume migration into State waters warrants joint regulation of the discharge by USEPA and the Regional Water Board.

B. California Environmental Quality Act (CEQA)

Under California Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100 through 21177.

C. State and Federal Regulations, Policies, and Plans

1. **Los Angeles Water Quality Control Plan.** On June 13, 1994, the Regional Water Board adopted a water quality control plan for the Los Angeles Region (hereinafter Basin Plan), as amended, that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for the Pacific Ocean. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63 which established State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Basin Plan beneficial uses applicable to the Pacific Ocean are as follows:

Table 4. Basin Plan Beneficial Uses of the Applicable Receiving Waters

| Discharge Point | Receiving Water | Beneficial Use(s) |
|-----------------|--|---|
| 001, 002 | Dockweiler Beach (Hydrologic Unit 405.12) | <u>Existing:</u> Industrial service supply (IND), navigation (NAV), water contact recreation (REC-1), non-contact water recreation (REC-2), commercial and sport fishing (COMM), marine habitat (MAR), and wildlife habitat (WILD). <u>Potential:</u> Spawning, reproduction, and/or early development (SPWN). |
| | Pacific Ocean Nearshore Zone | <u>Existing:</u> IND, NAV, REC-1, REC-2, COMM, MAR, WILD, preservation of biological habitats (BIOL), RARE, migration of aquatic organisms (MIGR), SPWN, and SHELL. <u>Potential:</u> None. |
| | Pacific Ocean Offshore Zone | <u>Existing:</u> IND, NAV, REC-1, REC-2, COMM, MAR, WILD, RARE, MIGR, SPWN, and SHELL. <u>Potential:</u> None. |

Requirements of this Order/Permit implement the Basin Plan. The Basin Plan relies primarily on the requirements of *the Water Quality Control Plan for Ocean Waters of California* (Ocean Plan) for protection of the beneficial uses of the State ocean waters. The Basin Plan, however, may contain additional water quality objectives applicable to the Discharger.

2. **California Thermal Plan.** In 1972, the State Water Board adopted the *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (hereinafter Thermal Plan), as amended. This plan contains temperature objectives for coastal and inland surface waters. Requirements of this Order/Permit implement the Thermal Plan.
3. **California Ocean Plan.** In 1972, the State Water Board adopted the *Water Quality Control Plan for Ocean Waters of California, California Ocean Plan* (hereinafter Ocean Plan), as amended. The latest amendment became effective on February 14, 2006. The Ocean Plan is applicable, in its entirety, to point source discharges to the ocean waters of the State. Ocean Plan beneficial uses applicable to ocean waters of the State are shown in Table 5.

Table 5. Ocean Plan Beneficial Uses

| Discharge Point | Receiving Water | Beneficial Use(s) |
|-----------------|-----------------|---|
| 001, 002 | Pacific Ocean | IND, REC-1, REC-2, NAV, COMM, mariculture, preservation and enhancement of designated Area of Special Biological Significance (ASBS), RARE, MAR, MIGR, SPWN, and SHELL. |

To protect the beneficial uses in ocean water, the Ocean Plan establishes water quality objectives and a program implementation. Requirements of this Order/Permit implement the Ocean Plan.

4. **Santa Monica Bay Restoration Plan.** The Hyperion Treatment Plant discharges to Santa Monica Bay, one of the most heavily used recreational areas in California. Recognizing the importance of the Bay as a national resource, the State of California and USEPA nominated and Congress included Santa Monica Bay in the National Estuary Program. This led to the formation of the Santa Monica Bay Restoration Project (currently named Santa Monica Bay Restoration Commission) that developed the Bay Restoration Plan (BRP) which serves as a blueprint for restoring and enhancing the Bay. The Regional Water Board plays a lead role in the implementation of the BRP. Three of the proposed priorities of the BRP are reduction of pollutants of concern at the source (including municipal wastewater treatment plants), attainment of full secondary treatment at the City of Los Angeles' Hyperion Treatment Plant and the County Sanitation Districts of Los Angeles County's Joint Water Pollution Control Plant, and implementation of the mass emission approach for discharges of pollutants to the Bay.
5. **Alaska Rule.** USEPA has revised its regulation that specifies when new and revised State and Tribal water quality standards (WQS) become effective for CWA purposes (40 CFR part 131.21; 65 Fed. Reg. 24641 (April 27, 2000)). Under the revised regulation (hereinafter Alaska Rule), new and revised

standards submitted to USEPA after May 30, 2000 must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000 may be used for CWA purposes, whether or not approved by USEPA.

6. **Stringency of Requirements for Individual Pollutants.** This Order/Permit contains restrictions on individual pollutants that are no more stringent than required by the federal CWA. Individual pollutant restrictions consist of technology-based effluent limitations and water quality-based effluent limitations. The technology-based effluent limitations consist of restrictions on biochemical oxygen demand (5-day) (BOD₅), total suspended solids (TSS), and pH, and percent removal of BOD₅ and TSS, which implement the minimum, applicable federal technology-based requirements for POTWs. Also, effluent limitations consisting of restrictions on oil and grease, settleable solids, and turbidity more stringent than federal technology-based requirements are necessary to implement State treatment standards in Table A of the Ocean Plan. Water quality-based effluent limitations consisting of restrictions on copper, chlorine residual, ammonia (as nitrogen), acute toxicity, chronic toxicity, beryllium, chlordane, DDT, PAHs, PCBs, and TCCD equivalents have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. Collectively, restrictions on individual pollutants in this Order/Permit are no more stringent than required by the CWA.
7. **Antidegradation Policy.** Title 40 of the Code of Federal Regulations¹ Part 131.12 requires that the State water quality standards include an antidegradation policy consistent with the federal antidegradation policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. This resolution incorporates the federal antidegradation policy, where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. As discussed in detail in the Fact Sheet (Attachment F), the permitted discharge is consistent with the antidegradation provisions of 40 CFR part 131.12 and State Water Board Resolution No. 68-16.
8. **Anti-Backsliding Requirements.** CWA sections 402(o)/303(d) and 40 CFR part 122.44(l) prohibit backsliding and require effluent limitations, permit conditions, and standards in a reissued NPDES permit to be as stringent as those in the previous permit, with some exceptions where limitations and conditions may be relaxed. Some effluent limitations in this Order/Permit are

¹ All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated and will be abbreviated as "40 CFR part number".

less stringent than those in the previous Order/Permit. As discussed in detail in the Fact Sheet (Attachment F), this relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.

This Order/Permit is consistent with State and federal antidegradation policies in that it does not authorize a change in pollutant mass emission rates, nor does it authorize a relaxation in the manner of treatment of the discharge. Pollutant limit mass emission rates continue to be based on the design flow rate of the treatment plant under the 1994 permit of 420 MGD. Although the design flow rate of the treatment plant has increased to 450 MGD, this increase has been accompanied by a significant improvement in the level of treatment necessary to achieve full secondary treatment. As a result, both the quantity of discharged pollutants and quality of the discharge are expected to remain relatively constant or improve during this permit term, consistent with antidegradation policies. In conformance with reasonable potential analysis procedures identified in State Water Board and USEPA documents, effluent limitations for some constituents are not carried forward in this Order/Permit because there is not presently reasonable potential for the constituents to cause or contribute to an exceedance of water quality standards. Without reasonable potential, there is no longer a need to maintain prior WQBELs under NPDES regulations, antidegradation provisions, and antidegradation policies. The accompanying monitoring and reporting program requires continued data collection and if monitoring data show reasonable potential for a constituent to cause or contribute to an exceedance of water quality standards, the Order/Permit will be reopened to incorporate WQBELs. Such an approach ensures that the discharge will adequately protect water quality standards for designated beneficial uses and conform with antidegradation policies and antidegradation provisions.

9. **Endangered Species Act.** This Order/Permit does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the federal Endangered Species Act (16 U.S.C. sections 1531 to 1544). This Order/Permit requires compliance with effluent limitations, receiving water limitations, and other requirements to protect the beneficial uses of waters of the State. The Discharger is responsible for meeting all requirements of the applicable Endangered Species Act
10. **Monitoring and Reporting Requirements.** 40 CFR part 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. California Water Code sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (Attachment E) establishes monitoring and reporting requirements to implement federal and State requirements.

11. **Federal Permit Renewal Contingency.** The Discharger's federal permit renewal is contingent upon determination by the U.S. Fish and Wildlife Service and NOAA National Marine Fisheries Service that the proposed discharge is consistent with the: (1) federal Endangered Species Act; (2) Magnuson-Stevens Fishery Conservation and Management Act (MSA); and (3) the Regional Water Board's certification/concurrence that the discharge will comply with applicable State water quality standards.

USEPA's reissuance of NPDES No. CA0109991 to the City of Los Angeles for Hyperion Treatment Plant is subject to requirements of MSA and ESA. In May 2010, USEPA requested updated information related to: (1) essential fish habitat and managed and associated species, and (2) threatened and endangered species and their designated critical habitats, in the vicinity of the Hyperion outfalls from the National Marine Fisheries Service and the U.S. Fish and Wildlife Service (collectively, the Services). Based on this and other relevant information, USEPA is currently evaluating whether there are effects on essential fish habitat and managed and associated species protected under the MSA, or on threatened and endangered species and their designated critical habitats protected under the ESA. Based on the outcome of this analysis, USEPA may engage in consultation with the Services during, and subsequent to, this permit reissuance. USEPA may decide that changes to this permit are warranted based on the results of the completed consultation, and a reopener provision to this effect has been included in the Order/Permit.

Joint issuance of an NPDES permit which incorporates both federal requirements and State waste discharge requirements will serve as the State's concurrence that the discharge complied with State water quality standards. The California Coastal Commission has indicated that it is not necessary to obtain a consistency certification pursuant to the Coastal Zone Management Act for the issuance of a federal NPDES permit containing secondary treatment standards.

D. Impaired Water Bodies on CWA 303(d) List

On June 28, 2007, the USEPA approved the State's 2006 303(d) List of Water Quality Limited Segments (hereinafter 303(d) list). The 303(d) list identifies water bodies where water quality standards are not expected to be met after implementation of technology-based effluent limitations by point sources (water quality limited water bodies).

Santa Monica Bay (Offshore and Nearshore) is on the 303(d) list for the following pollutants/stressors from point and non-point sources: DDT (tissue & sediment, centered on Palos Verdes Shelf), PCBs (tissue & sediment), sediment toxicity, debris, and fish consumption advisory. Santa Monica Bay Beaches Total maximum daily loads (TMDLs) for DDT, PCBs, sediment toxicity, and fish consumption

advisory have not been scheduled. A TMDL for Santa Monica Bay Nearshore Debris TMDL is under development. Santa Monica Bay Beaches Bacteria TMDLs were approved by USEPA in 2003, as described in the following section.

E. Other Plans, Policies and Regulations

1. **Secondary Treatment Regulations.** 40 CFR part 133 establishes the minimum levels of effluent quality to be achieved by secondary treatment at publicly owned treatment works. These technology-based effluent limitations, established by USEPA, are incorporated into this Order/Permit except where more stringent limitations are required by other applicable plans, policies, or regulations.
2. **Storm Water.** See Fact Sheet.
3. **Sanitary Sewer Overflows.** The State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order No. 2006-0003-DWQ (General Order) on May 2, 2006. The amended General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions. Furthermore, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating SSOs. The requirements contained in this Order/Permit are generally consistent with the requirements in the SSO WDR. The Discharger's collection system is part of the POTW that is subject to this Order/Permit. The Discharger must comply with both the General Order and this Order/Permit.
4. **Pretreatment.** Section 402 of the CWA and implementing regulations at 40 CFR 403 establish pretreatment requirements for POTWs which receive pollutants from non-domestic users. This Order/Permit contains pretreatment program requirements pursuant to 40 CFR 403 that are applicable to the Discharger.
5. **Sewage Sludge/Biosolids Requirements.** Section 405 of the CWA and implementing regulations at 40 CFR 503 require that producers of sewage sludge/biosolids meet certain reporting, handling, and use or disposal requirements. The State has not been delegated the authority to implement this program; therefore, USEPA is the implementing agency. This Order/Permit contains sewage sludge/biosolids requirements pursuant to 40 CFR 503 that are applicable to the Discharger.
6. **Watershed Management.** This Regional Water Board has been implementing a Watershed Management Approach (WMA) to address water quality protection in Los Angeles and Ventura Counties. The approach is in accordance with

USEPA guidance on *Watershed Protection: A Project Focus* (EPA 841-R-95-003, August 1995). The objective is to provide a comprehensive and integrated strategy resulting in water resource protection, enhancement and restoration, while balancing economic and environmental impacts within a hydrologically defined drainage basin or watershed. The Management Approach emphasizes cooperative relationships between regulatory agencies, the regulated community, environmental groups, and other stakeholders in the watershed to achieve the greatest environmental improvements with the resources available. This Order/Permit and the accompanying *Monitoring and Reporting Program* (Attachment E) fosters implementation of this approach. The *Monitoring and Reporting Program* requires the Discharger to participate in regional monitoring programs in the Southern California Bight.

7. **Santa Monica Bay Beaches Bacteria Total Maximum Daily Loads (TMDLs).** The Regional Water Board has adopted two TMDLs to reduce bacteria at Santa Monica Bay beaches during dry and wet weather. The Regional Water Board adopted the Dry Weather and Wet Weather TMDLs on January 24, 2002 and December 12, 2002, respectively (Resolution Nos. 2002-004 and 2002-022). These TMDLs were approved by the State Water Board, State OAL and USEPA Region 9 and became effective on July 15, 2003. Since their approval, these TMDLs have been incorporated into the Los Angeles County Municipal Storm Water NPDES Permit (hereinafter, the LA MS4 Permit) (CAS004001, Order No. 01-182), as receiving water limitations.

In these TMDLs, waste load allocations (WLAs) are expressed as the number of sample days at a shoreline monitoring site that may exceed the single sample targets for total coliform, fecal coliform and *Enterococcus* identified under "Numeric Target" in the TMDLs. Waste load allocations are expressed as allowable exceedance days because the bacterial density and frequency of single sample exceedances are the most relevant to public health protection at beaches. The final shoreline compliance point for the WLAs in the TMDLs is the wave wash where there is a freshwater outlet (i.e., publicly owned storm drain or natural creek) to the beach, or at ankle depth at beaches without a freshwater outlet.

The City of Los Angeles, as the owner of Hyperion Treatment Plant, is identified as a responsible jurisdiction in these TMDLs. In these TMDLs, Hyperion Treatment Plant is assigned a WLA of zero days of exceedance of the single sample bacterial objectives during all three identified periods – summer dry weather, winter dry weather and wet weather. Hyperion Treatment Plant's WLA of zero exceedance days requires that no discharge from its outfalls may cause or contribute to any exceedances of the single sample bacteria objectives at the shoreline compliance points identified in the TMDL and subsequently approved Coordinated Shoreline Monitoring Plan (dated April 7, 2004) submitted by responsible agencies and jurisdictions under the TMDLs. The shoreline

monitoring data collected as part of the Los Angeles County MS4 Permit will be used to demonstrate compliance with the WLAs in these TMDLs.

V. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations: 40 CFR part 122.44(a) requires that permits include applicable technology-based limitations and standards, and 40 CFR part 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where numeric water quality objectives have not been established, 40 CFR 122.44(d) specifies that WQBELs may be established using USEPA criteria guidance under CWA section 304(a); proposed State criteria or a State policy interpreting narrative criteria supplemented with other relevant information may be used; or an indicator parameter may be established.

A. Discharge Prohibitions

Discharge prohibitions in this Order/Permit are based on the requirements in section III.H of the Ocean Plan (2005).

B. Technology-Based Effluent Limitations

1. Scope and Authority

Section 301(b) of the CWA and implementing regulations at 40 CFR part 125.3, require that NPDES permits include limitations which meet applicable technology-based requirements, at a minimum. The discharge authorized by this Order/Permit must meet minimum federal technology-based requirements for POTWs at 40 CFR 133 and other technology requirements based on Best Professional Judgment (BPJ) in accordance with 40 CFR part 125.3. A detailed discussion of technology-based effluent limitations development is included in the Fact Sheet (Attachment F).

2. Applicable Technology-Based Effluent Limitations

Pursuant to sections 301(b)(1)(B) and 304(d) of the CWA, USEPA has established standards of performance for secondary treatment at 40 CFR 133. Secondary treatment is defined in terms of three parameters – 5-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), and pH. The following summarizes the technology-based requirements for secondary treatment, which are applicable to the Facility:

Table 6. Summary of Technology-based Effluent Limitations for Secondary Treatment Facility by USEPA at 40 CFR part 133.102

| Constituent | Average Monthly | Average Weekly | Percent Removal |
|------------------|---------------------|----------------|-----------------|
| BOD ₅ | 30 mg/L | 45 mg/L | 85% |
| TSS | 30 mg/L | 45 mg/L | 85% |
| pH | 6.0 to 9.0 pH units | | |

Also, Table A of the Ocean Plan establishes the following technology-based effluent limitations, which are applicable to the Facility:

Table 7. Summary of Technology-based Effluent Limitations for POTWs established by the Ocean Plan (2005)

| Constituent | Average Monthly | Average Weekly | Instantaneous Maximum | Percent Removal |
|-------------------|---------------------|----------------|-----------------------|------------------|
| Oil & Grease | 25 mg/L | 40 mg/L | 75 mg/L | -- |
| TSS | -- | -- | -- | 75% ² |
| Settleable Solids | 1.0 ml/L | 1.5 ml/L | 3.0 ml/L | -- |
| Turbidity | 75 NTU | 100 NTU | 225 NTU | -- |
| pH | 6.0 to 9.0 pH units | | | |

All technology-based effluent limitations from Order No. R4-2005-0020 for BOD₅, TSS, oil and grease, settleable solids, pH, and turbidity are retained in this Order/Permit with minor changes for oil and grease, settleable solids, and turbidity, as described below. Limitations for BOD₅, TSS, and pH are based on secondary treatment standards established by the USEPA at 40 CFR 133. Limitations for oil and grease, settleable solids, and turbidity are based on requirements in the 2005 Ocean Plan. To be consistent with the Ocean Plan, daily maximum limitations for these three constituents in the existing permit are prescribed as instantaneous maximum limitations in this Order/Permit. All technology-based effluent limitations are not dependent upon the dilution ratio for the discharge outfall. In addition to the concentration-based effluent limitations, mass-based effluent limitations based on the average design flow rate of 420 million gallons per day for the Hyperion Treatment Plant in the 1994 permit are also included.

The following table summarizes the technology-based effluent limitations for the discharge from the Facility:

² Dischargers shall, as a 30-day average, remove 75% of TSS from the influent stream before discharging wastewaters to the ocean, except that the effluent limitation to be met shall not be lower than 60 mg/L.

Table 8. Summary of Technology-based Effluent Limitations - Discharge Points 001 and 002

| Parameter | Units | Effluent Limitations | | | | |
|------------------------------|----------------------|----------------------|----------------|---------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| BOD ₅ 20°C | mg/L | 30 | 45 | -- | -- | -- |
| | lbs/day ³ | 113,000 | 169,000 | -- | -- | -- |
| | % removal | 85 | -- | -- | -- | -- |
| Total Suspended Solids (TSS) | mg/L | 30 | 45 | -- | -- | -- |
| | lbs/day ⁵ | 113,000 | 169,000 | -- | -- | -- |
| | % removal | 85 | -- | -- | -- | -- |
| Oil and Grease | mg/L | 25 | 40 | -- | -- | 75 |
| | lbs/day ⁵ | 93,800 | 150,000 | -- | -- | 281,000 |
| Settleable Solids | mL/L | 1.0 | 1.5 | -- | -- | 3.0 |
| Turbidity | NTU | 75 | 100 | -- | -- | 225 |
| pH | pH unit | -- | -- | -- | 6.0 | 9.0 |

C. Water Quality-Based Effluent Limits (WQBELs)

1. Scope and Authority

Section 301(b) of the CWA and 40 CFR part 122.44(d) require that permits include limitations more stringent than applicable technology-based requirements where necessary to achieve water quality standards and State requirements. 40 CFR part 122.44(d)(1)(i) requires that permits include water quality-based effluent limitations (WQBELs) for all pollutants which are or may be discharged at levels having the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives or criteria within a standard. USEPA has applied CWA section 403(c) and 40 CFR 125, Subpart M, following 40 CFR 122.

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in other State plans and policies, or any applicable water quality standards contained in the Ocean Plan.

³ The mass emission rates are based on the average design flow rate (420 MGD) of the Hyperion Treatment Plant in the 1994 permit: lbs/day = 0.00834 x C_e (effluent concentration, ug/L) x Q (flow rate, MGD). During wet-weather storm events in which the flow exceeds the design capacity, the mass discharge rate limitations shall not apply, and concentration limitations will provide the only applicable effluent limitations.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

The Basin Plan and Ocean Plan establish the beneficial uses for ocean waters of the State. The beneficial uses of the receiving waters affected by the discharge have been described previously in this Fact Sheet. The Ocean Plan contains water quality objectives for bacterial characteristics, physical characteristics, chemical characteristics, biological characteristics, and radioactivity. The Basin Plan contains the bacteria objectives for water bodies designated for water contact recreation as amended by Resolution No. 01-018. Bacteria objectives from the Ocean Plan and Basin Plan were included as receiving water limitations in this Order/Permit.

Table B of the Ocean Plan includes numerical water quality objectives for toxic pollutants.

- a. 6-month median, daily maximum, and instantaneous maximum objectives for 21 chemicals and chemical characteristics, including total residual chlorine, and acute and chronic toxicity, for the protection of marine aquatic life.
- b. 30-day average objectives for 20 non-carcinogenic chemicals for the protection of human health.
- c. 30-day average objectives for 42 carcinogenic chemicals for the protection of human health.

3. Expression of WQBELs

Pursuant to 40 CFR part 122.45(d)(2), for POTW continuous discharges, all permit effluent limitations, standards, and prohibitions, including those necessary to achieve water quality standards, shall, unless impracticable, be stated as average weekly and average monthly discharge limitations. It is impracticable to include only average weekly and average monthly effluent limitations in the Order/Permit because a single daily discharge of certain pollutants, in excess amounts, can cause violations of water quality objectives. The effects of pollutants on aquatic organisms are often rapid. For many pollutants, an average weekly or average monthly effluent limitation alone is not sufficiently protective of beneficial uses. As a result, maximum daily effluent limitations, as referenced in 40 CFR part 122.45(d), are included in the Order/Permit for certain constituents.

The WQBELs for marine aquatic life toxics contained in this Order/Permit are based on Table B water quality objectives contained in the 2005 Ocean Plan that are expressed as six-month median, daily maximum, and instantaneous maximum water quality objectives. However, in the existing Order/Permit (Order No. R4-2005-0020), the calculated effluent limitations based on 6-month

median objectives for marine aquatic life toxics in the 2001 Ocean Plan were prescribed as monthly average limitations. Applying the antibacksliding regulations, this Order/Permit retains the same approach and sets effluent limitations derived from six-month median water quality objectives for marine aquatic life toxics in the 2005 Ocean Plan as monthly average limitations. To be consistent with the Ocean Plan, daily maximum and instantaneous maximum limitations are prescribed in this Order/Permit.

4. Determining the Need for WQBELs

Order No. R4-2005-0020 contains effluent limitations for non-conventional and toxic pollutant parameters in Table B of the Ocean Plan. For this Order/Permit, the need for effluent limitations based on water quality objectives in Table B of the 2005 Ocean Plan was reevaluated in accordance with the Reasonable Potential Analysis (RPA) procedures contained in Appendix VI of the 2005 Ocean Plan. This statistical RPA method (RPcalc version 2.0) accounts for the averaging period of the water quality objective, accounts for and captures the long-term variability of the pollutant in the effluent, accounts for limitations associated with sparse data sets, accounts for uncertainty associated with censored data sets, and assumes a lognormal distribution of the facility-specific effluent data. The program calculates the upper confidence bound (UCB) of an effluent population percentile after complete mixing. In the evaluation employed in this Order/Permit, the UCB is calculated as the one-sided, upper 95 percent confidence bound for the 95th percentile of the effluent distribution after complete mixing. The calculated $UCB_{95/95}$ is then compared to the appropriate objective to determine the potential for an exceedance of that objective and the need for an effluent limitation. For constituents that have an insufficient number of monitoring data or a substantial number of non-detected data with a reporting limit higher than the respective water quality objective, the RPA result is likely to be inconclusive. As suggested by the Ocean Plan, existing effluent limitations for these constituents are retained in the new Order/Permit. For Discharge Point 001, these include beryllium, chlordane, DDT, PAH, PCBs, and TCDD. For Discharge Point 002, these include chlordane, DDT, PCBs, and TCDD. In addition, the MRP (Attachment E) of this Order/Permit also requires the Discharger to continue to monitor for these constituents.

Using this statistical procedure, in combination with effluent data provided by the Discharger from July 2005 to July 2009, and minimum initial dilution ratios of 13:1 for Discharge Point 001 and 84:1 for Discharge Point 002, Regional Water Board staff and USEPA have determined that the following constituents, when discharged through the specified outfall, either have reasonable potential to exceed Ocean Plan objectives, or have inconclusive results after performing the RPA, and therefore, require effluent limitations.

Discharge Point 001

Copper, chlorine residual, ammonia (as nitrogen), chronic toxicity, beryllium, chlordane, DDT, PAHs, PCBs, TCDD equivalents.

Discharge Point 002

Acute toxicity, chronic toxicity, chlordane, DDT, PCBs, and TCDD equivalents.

In general, for constituents that have been determined to have no reasonable potential to cause, or contribute to, excursions of water quality objectives, no numerical limits are prescribed; instead a narrative statement to comply with all Ocean Plan requirements is provided and the Discharger is required to monitor for these constituents to gather data for use in RPAs for future Order/Permit renewals and/or updates.

5. 303(d) Listed Constituents and Discharge Limitations - DDT and PCBs

At various locations in Santa Monica Bay, DDT, and PCBs are found in sediments at levels that can be harmful to marine organisms. In addition, DDT and PCBs are found in certain Bay-captured seafood species at levels posing potential health risks to humans. A brief description of these pollutants and their occurrence in Santa Monica Bay is given below.

In the U.S., DDT, an organochlorine insecticide, was widely used in agricultural and urban settings until they were banned in 1973. PCBs, a large group of industrial and commercial chemicals, were widely used as coolants and lubricants in transformers, capacitors and other electronic equipment until the late 1970s when their manufacture was banned. Because of their stable properties, DDT and PCBs persist in the environment, the result of historical uses which no longer occur. They have low water solubility and are generally found in sediments and fish tissue.

Bight '98 surveys included efforts to assess the spatial extent of anthropogenic contaminant accumulation in benthic sediments and their effects on marine biota in the Southern California Bight. These surveys showed that while elevated levels of DDT and PCBs continue to be measured in sediments near Hyperion Treatment Plant's 5-mile outfall, much of this is reflective of historical deposition and not the levels of contaminants associated with recent discharges. These surveys also concluded that DDT and PCBs in sediments are a dominant source of contaminant exposure levels in bottom living fish. DDT continues to be found in fish tissue at levels of concern throughout the Bight, although these levels are declining over time. Monitoring data show that effluent levels of DDT and PCBs discharged from the 5-mile outfall remain at non-detect concentrations.

Nearshore and offshore waters of Santa Monica Bay are on California’s 2006 CWA 303(d) list of water quality limited segments for DDT (sediment and tissue, centered on Palos Verdes Shelf) and PCBs (sediment and tissue). TMDLs for DDT and PCBs have not been scheduled. As TMDLs for these two constituents have not been completed, the Order/Permit continues forward mass emission and concentration WQBELs contained in the 2005 Order/Permit. These limits are based on Ocean Plan water quality objectives and effluent limitation calculation procedures, and, for Discharge Point 002, the average design flow rate (420 MGD) of the Hyperion Treatment Plant in 1994. Current performance for DDT and PCBs in the Hyperion Treatment Plant effluent are set at non-detect concentrations. The Ocean Plan RPA results for DDT and PCBs are inconclusive.

| DDT | Effluent Concentration (ug/L) | Effluent Limitation (ug/L) carried over from R4-2005-0020 |
|-------------|-------------------------------|---|
| Outfall 002 | <0.002 - <0.006 | 0.014 |
| Outfall 001 | <0.002 - <0.006 | 0.0024 |
| PCBs | Effluent Concentration (ug/L) | Effluent Limitation (ug/L) carried over from R4-2005-0020 |
| Outfall 002 | <0.07 - <0.49 | 0.002 |
| Outfall 001 | <0.002 - <0.09 | 0.002 |

6. WQBEL Calculations

From the Table B water quality objectives in the Ocean Plan, effluent limitations are calculated according to the following equation for all pollutants, except for acute toxicity (if applicable) :

$$C_e = C_o + D_m(C_o - C_s)$$

where

- C_e = the effluent limitation (µg/L)
- C_o = the water quality objective to be met at the completion of initial dilution (µg/L)
- C_s = background seawater concentration (µg/L) (see Table below)
- D_m = minimum probable initial dilution expressed as parts seawater per part wastewater

The D_m is based on observed waste flow characteristics, receiving water density structure, and the assumption that no currents of sufficient strength to influence the initial dilution process flow across the discharge structure. In this Order/Permit, dilution ratios of 84:1 and 13:1 have been applied to Discharge Points 002 and 001, respectively.

Initial dilution is the process that results in the rapid and irreversible turbulent mixing of wastewater with ocean water around the point of discharge. For a submerged buoyant discharge, characteristic of most municipal and industrial wastes that are released from the submarine outfalls, the momentum of the discharge and its initial buoyancy act together to produce turbulent mixing. Initial dilution in this case is completed when the diluting wastewater ceases to rise in the water column and first begins to spread horizontally. As site-specific water quality data is not available, in accordance with Table B implementing procedures, C_s equals zero for all pollutants, except the following:

Table 9. Pollutants with Background Seawater Concentrations

| Constituent | Background Seawater Concentration (C_s) |
|-------------|---|
| Arsenic | 3 µg/L |
| Copper | 2 µg/L |
| Mercury | 0.0005 µg/L |
| Silver | 0.16 µg/L |
| Zinc | 8 µg/L |

The calculation of WQBELs for copper and ammonia are demonstrated below for Discharge Point 001, as examples:

Table 10. Ocean Plan Water Quality Objectives (C_o) for Copper and Ammonia

| Constituents | 6-Month Median | Daily Maximum | Instantaneous Maximum | 30 Day Average |
|--------------|----------------|---------------|-----------------------|----------------|
| Copper | 3 µg/L | 12 µg/L | 30 µg/L | -- |
| Ammonia | 0.60 mg/L | 2.4 mg/L | 6 mg/L | -- |

Using the equation, $C_e = C_o + D_m(C_o - C_s)$, effluent limitations are calculated as follows before rounding to two significant digits. All calculations are based on discharge through Discharge Point 001 and, therefore, a dilution ratio (D_m) of 13:1 is applied.

Copper

$C_e = 3 + 13(3-2) = 16 \text{ µg/L}$ (prescribed as Average Monthly, see section 3 above)

$C_e = 12 + 13(12-2) = 142 \text{ µg/L}$ (rounded to 140 µg/L prescribed as Daily Maximum)

$C_e = 30 + 13(30-2) = 394 \text{ µg/L}$ (However, this Order/Permit maintains the effluent limitation of 160 µg/L from Order No. R4-2005-0020, per the anti-backsliding requirements; 160 µg/L is prescribed as Instantaneous Maximum.)

Ammonia

$C_e = 0.6 + 13(0.6) = 8.4 \text{ mg/L}$ (prescribed as Average Monthly, see section 3 above)

$$C_e = 2.4 + 13(2.4) = 33.6 \text{ mg/L (rounded to 34 mg/L prescribed as Daily Maximum)}$$

$$C_e = 6.0 + 13(6.0) = 84.0 \text{ mg/L (rounded to 84 mg/L prescribed as Instantaneous Maximum)}$$

Based on the implementing procedures described above, effluent limitations have been calculated for all Table B pollutants (excluding acute toxicity and chronic toxicity) from the Ocean Plan and incorporated into this Order/Permit when applicable.

7. Whole Effluent Toxicity (WET)

This Order/Permit includes water quality-based effluent limitations for acute toxicity and chronic toxicity at Discharge Point 002 and for chronic toxicity at Discharge Point 001. While the 2005 Ocean Plan specifies that discharges with dilution ratios below 100:1 must conduct chronic toxicity testing, it does not preclude permitting authorities implementing 40 CFR 122.44(d)(1) from establishing acute toxicity testing requirements, and effluent limitations, to ensure protection of the acute toxicity objective. Because both marine acute toxicity effluent quality data for POTW ocean discharges having dilution ratios greater than 84:1 periodically show acute toxicity and acute toxicity data collected under the 2005 permit show that the Hyperion discharge has reasonable potential to exceed the current Ocean Plan objective for acute toxicity. The Order/Permit contains a daily maximum acute toxicity effluent limitation for Discharge Point 002 and testing protocols consistent with the 2005 Ocean Plan.

Using the objective of 0.3 TU_a for the daily maximum and 10% of the dilution ratio (as the acute toxicity mixing zone), the daily maximum acute toxicity limit for Discharge Point 002 is calculated as follows:

$$C_e = C_a + (0.1) D_m (C_a)$$

Where

C_e = the effluent daily maximum limit for acute toxicity

C_a = the concentration (water quality objective) to be met at the edge of the acute mixing zone

D_m = minimum probable initial dilution expressed as parts seawater per part wastewater (84:1 and 13:1 for Discharge Points 002 and 001, respectively) (This equation applies only when $D_m > 24$.)

$$C_e = 0.3 + (0.1)(84)(0.3) = 2.8 \text{ TU}_a$$

Since the above equation for calculating an acute toxicity limitation applies only when $D_m > 24$, this Order/Permit does not contain an acute toxicity limitation

for Discharge Point 001 although RP is present. USEPA and Regional Water Board staff consider that acute toxicity is adequately addressed by controlling ammonia, for which this Order/Permit contains an effluent limitation at Discharge Point 001. Ammonia is considered the primary probable cause of acute toxicity in secondary-treated wastewater from POTWs.

D. Final Effluent Limitations

1. Satisfaction of Anti-Backsliding Requirements

All effluent limitations in this Order/Permit are at least as stringent as the effluent limitations in the previous Order/Permit. The effluent limitations of the following marine aquatic life toxicants, and non-carcinogenic and carcinogenic human health toxicants have been deleted because they did not show reasonable potential to cause or contribute to an excursion above the respective water quality objectives for: (1) Discharge Point 002 – radioactivity, tributyltin, and PAHs; and (2) Discharge Point 001 – cyanide, phenolic compounds (chlorinated), HCH, radioactivity, 2,4-dinitrophenol, tributyltin, acrylonitrile, bis(2-chloroethyl) ether, bis(2-ethylhexyl) phthalate, n-nitrosodi-n-propylamine, tetrachloroethylene, and 2,4,6-trichlorophenol. This relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.

2. Satisfaction of Antidegradation Policy

On October 28, 1968, the State Water Board adopted Resolution No. 68-16, *Maintaining High Quality Water*, which established an antidegradation policy for State and Regional Water Boards. The State Water Board has, in State Water Board Order No. 86-17 and an October 7, 1987 guidance memorandum, interpreted Resolution No. 68-16 to be fully consistent with the federal antidegradation policy. Similarly, CWA sections 402(o)/303(d)(4) and USEPA regulations at 40 CFR part 131.12 require that all permitting actions be consistent with the federal antidegradation policy. Together, the State and federal policies are designed to ensure that a water body will not be degraded resulting from the permitted discharge. The provisions of this Order/Permit are consistent with the antidegradation policies.

3. Stringency of Requirements for Individual Pollutants

This Order/Permit contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD₅, TSS, and pH. Restrictions on BOD₅, TSS, and pH are discussed in section V.B.2 of this Fact Sheet. This Order/Permit's technology-based pollutant restrictions implement the minimum applicable federal technology-based requirements.

Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. The scientific procedures for calculating individual water quality-based effluent limitations for priority pollutants are based on the 2005 Ocean Plan, which was approved by USEPA on February 14, 2006. All beneficial uses and water quality objectives contained in the Basin Plan were approved under State law and approved by USEPA. Collectively, this Order/Permit's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA and applicable water quality standards.

Table 11. Summary of Final Effluent Limitations Discharge Point 002
(Footnotes are specified on pages F-41 and F-42 of this Fact Sheet.)

| Parameter | Units | Effluent Limitations ^{1,3} | | | | Performance Goal ² | Basis |
|--|-----------|---|----------------|----------------------------|------------------------------------|-------------------------------|---|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Maximum ⁵ | | |
| BOD ₅ 20°C ⁶ | mg/L | 30 | 45 | -- | -- | -- | Existing/ Secondary treatment standard |
| | lbs/day | 113,000 | 169,000 | -- | -- | | |
| | % removal | 85 | -- | -- | -- | | |
| Total Suspended Solids (TSS) ⁶ | mg/L | 30 | 45 | -- | -- | -- | Existing/ Secondary treatment standard |
| | lbs/day | 113,000 | 169,000 | -- | -- | | |
| | % removal | 85 | -- | -- | -- | | |
| pH ^{5,6,7} | pH unit | 6.0 (instantaneous minimum) – 9.0 (instantaneous maximum) | | | | -- | Existing/ Secondary treatment standard/Oc ean Plan |
| Oil and Grease ⁷ | mg/L | 25 | 40 | -- | 75 | -- | Existing/ Carry-over; Ocean Plan Existing/ Ocean Plan |
| | lbs/day | 93,800 | 150,000 | -- | -- | | |
| Settleable Solids ⁷ | ml/L | 1.0 | 1.5 | -- | 3.0 | -- | Existing/ Carry-over; Ocean Plan |
| Turbidity ⁷ | NTU | 75 | 100 | -- | 225 | -- | Existing/ Carry-over; Ocean Plan Existing/ Ocean Plan |
| Marine Aquatic Life Toxicants⁸ | | | | | | | |
| Arsenic ⁹ | µg/L | -- | -- | -- | -- | 3.5 | No RP ¹⁰ |
| Cadmium ⁹ | µg/L | -- | -- | -- | -- | 2.0 | No RP ¹⁰ |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | Performance Goal ² | Basis |
|---|-------|-------------------------------------|----------------|----------------------------|------------------------------------|-------------------------------|---|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Maximum ⁵ | | |
| Chromium (VI) ⁹ | µg/L | -- | -- | -- | -- | 2.5 | No RP ¹⁰ |
| Copper ⁹ | µg/L | -- | -- | -- | -- | 25 | No RP ¹⁰ |
| Lead ⁹ | µg/L | -- | -- | -- | -- | 10 | No RP ¹⁰ |
| Mercury ⁹ | µg/L | -- | -- | -- | -- | 0.02 | No RP ¹⁰ |
| Nickel ⁹ | µg/L | -- | -- | -- | -- | 3 | No RP ¹⁰ |
| Selenium ⁹ | µg/L | -- | -- | -- | -- | 1.6 | No RP ¹⁰ |
| Silver ⁹ | µg/L | -- | -- | -- | -- | 2.2 | No RP ¹⁰ |
| Zinc ⁹ | µg/L | -- | -- | -- | -- | 31 | No RP ¹⁰ |
| Cyanide | µg/L | -- | -- | -- | -- | 5 | No RP ¹⁰ |
| Chlorine Residual | mg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Ammonia as N | mg/L | -- | -- | -- | -- | 44.1 | No RP ¹⁰ |
| Phenolic compounds (non-chlorinated) | µg/L | -- | -- | -- | -- | 2.0 | No RP ¹⁰ |
| Phenolic compounds (chlorinated) | µg/L | -- | -- | -- | -- | 2.0 | No RP ¹⁰ |
| Endosulfan | µg/L | -- | -- | -- | -- | 0.04 | No RP ¹⁰ |
| HCH | µg/L | -- | -- | -- | -- | 0.015 | No RP ¹⁰ |
| Endrin | µg/L | -- | -- | -- | -- | 0.025 | No RP ¹⁰ |
| Acute toxicity | TUa | -- | -- | 2.8 | -- | -- | RP; Existing; Carry-over; Ocean Plan ⁴ |
| Chronic toxicity | TUc | -- | -- | 84 | -- | -- | RP; Existing/ Carry-over; Ocean Plan ⁵ |
| Radioactivity | | | | | | | |
| Gross alpha | pCi/L | -- | -- | -- | -- | 9.72 | No RP ¹¹ |
| Gross beta | pCi/L | -- | -- | -- | -- | 27.5 | No RP ¹¹ |
| Combined Radium 226 & Radium-228 | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Tritium | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Strontium-90 | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Uranium | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Human Health Toxicants – Non Carcinogens⁸ | | | | | | | |
| Acrolein | µg/L | -- | -- | -- | -- | 20 | No RP ¹⁰ |
| Antimony ⁹ | µg/L | -- | -- | -- | -- | 1.5 | No RP ¹⁰ |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | Performance Goal ² | Basis |
|---|---------|-------------------------------------|----------------|----------------------------|------------------------------------|-------------------------------|--|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Maximum ⁵ | | |
| Bis(2-chloroethoxy) methane | µg/L | -- | -- | -- | -- | 0.5 | No RP ¹⁰ |
| Bis(2-chloroisopropyl) ether | µg/L | -- | -- | -- | -- | 0.5 | No RP ¹⁰ |
| Chlorobenzene | µg/L | -- | -- | -- | -- | 0.6 | No RP ¹⁰ |
| Chromium (III) | µg/L | -- | -- | -- | -- | 1 | No RP ¹⁰ |
| Di-n-butyl-phthalate | µg/L | -- | -- | -- | -- | 5 | No RP ¹⁰ |
| Dichlorobenzenes ³ | µg/L | -- | -- | -- | -- | 0.6 | No RP ¹⁰ |
| Diethyl phthalate | µg/L | -- | -- | -- | -- | 0.6 | No RP ¹⁰ |
| Dimethyl phthalate | µg/L | -- | -- | -- | -- | 2.7 | No RP ¹⁰ |
| 2-Methyl-4,6-dinitrophenol | µg/L | -- | -- | -- | -- | 4 | No RP ¹⁰ |
| 2,4-Dinitrophenol | µg/L | -- | -- | -- | -- | 2.1 | No RP ¹⁰ |
| Ethyl benzene | µg/L | -- | -- | -- | -- | 0.8 | No RP ¹⁰ |
| Fluoranthene | µg/L | -- | -- | -- | -- | 0.2 | No RP ¹⁰ |
| Hexachlorocyclopentadiene | µg/L | -- | -- | -- | -- | 29 | No RP ¹⁰ |
| Nitrobenzene | µg/L | -- | -- | -- | -- | 0.5 | No RP ¹⁰ |
| Thallium ⁹ | µg/L | -- | -- | -- | -- | 0.1 | No RP ¹⁰ |
| Toluene | µg/L | -- | -- | -- | -- | 0.6 | No RP ¹⁰ |
| Tributyltin | ng/L | -- | -- | -- | -- | 9.6 | No RP ¹⁰ |
| 1,1,1-Trichloroethane | µg/L | -- | -- | -- | -- | 0.5 | No RP ¹⁰ |
| Human Health Toxicants – Carcinogens⁸ | | | | | | | |
| Acrylonitrile | µg/L | -- | -- | -- | -- | 0.4 | No RP ¹⁰ |
| Aldrin | µg/L | -- | -- | -- | -- | 0.0019 | No RP ¹⁰ |
| Benzene | µg/L | -- | -- | -- | -- | 0.35 | No RP ¹⁰ |
| Benzidine | µg/L | -- | -- | -- | -- | 0.0059 | No RP ¹⁰ |
| Beryllium | µg/L | -- | -- | -- | -- | 1 | No RP ¹⁰ |
| Bis(2-chloroethyl) ether | µg/L | -- | -- | -- | -- | 0.45 | No RP ¹⁰ |
| Bis(2-ethylhexyl) phthalate | µg/L | -- | -- | -- | -- | 5 | No RP ¹⁰ |
| Carbon tetrachloride | µg/L | -- | -- | -- | -- | 0.45 | No RP ¹⁰ |
| Chlordane | µg/L | 0.0019 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day | 0.0067 | -- | -- | -- | -- | |
| Chlorodibromomethane | µg/L | -- | -- | -- | -- | 0.25 | No RP ¹⁰ |
| Chloroform | µg/L | -- | -- | -- | -- | 8.7 | No RP ¹⁰ |
| DDT ³ | µg/L | 0.014 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day | 0.049 | -- | -- | -- | -- | |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | Performance Goal ² | Basis |
|-------------------------------|---------|-------------------------------------|----------------|----------------------------|------------------------------------|-------------------------------|--|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Maximum ⁵ | | |
| 1,4-Dichlorobenzene | µg/L | -- | -- | -- | -- | 2.0 | No RP ¹⁰ |
| 3,3'-Dichlorobenzidine | µg/L | -- | -- | -- | -- | 0.55 | No RP ¹⁰ |
| 1,2-Dichloroethane | µg/L | -- | -- | -- | -- | 0.5 | No RP ¹⁰ |
| 1,1-Dichloroethylene | µg/L | -- | -- | -- | -- | 0.6 | No RP ¹⁰ |
| Bromodichloromethane | µg/L | -- | -- | -- | -- | 0.3 | No RP ¹⁰ |
| Dichloromethane ³ | µg/L | -- | -- | -- | -- | 6.5 | No RP ¹⁰ |
| 1,3-Dichloropropene | µg/L | -- | -- | -- | -- | 0.45 | No RP ¹⁰ |
| Dieldrin | µg/L | -- | -- | -- | -- | 0.0034 | No RP ¹⁰ |
| 2,4-Dinitrotoluene | µg/L | -- | -- | -- | -- | 0.4 | No RP ¹⁰ |
| 1,2-Diphenylhydrazine | µg/L | -- | -- | -- | -- | 0.3 | No RP ¹⁰ |
| Halomethanes ³ | µg/L | -- | -- | -- | -- | 1.05 | No RP ¹⁰ |
| Heptachlor | µg/L | -- | -- | -- | -- | 0.0043 | No RP ¹⁰ |
| Heptachlor epoxide | µg/L | -- | -- | -- | -- | 0.0017 | Existing/ Carry-over; Ocean Plan |
| Hexachlorobenzene | µg/L | -- | -- | -- | -- | 0.018 | No RP ¹⁰ |
| Hexachlorobutadiene | µg/L | -- | -- | -- | -- | 0.35 | No RP ¹⁰ |
| Hexachloroethane | µg/L | -- | -- | -- | -- | 0.35 | No RP ¹⁰ |
| Isophorone | µg/L | -- | -- | -- | -- | 0.35 | No RP ¹⁰ |
| N-Nitrosodimethylamine | µg/L | -- | -- | -- | -- | 0.85 | No RP ¹⁰ |
| N-Nitrosodi-N-propylamine | µg/L | -- | -- | -- | -- | 0.65 | No RP ¹⁰ |
| N-Nitrosodiphenylamine | µg/L | -- | -- | -- | -- | 0.45 | No RP ¹⁰ |
| PAHs ³ | µg/L | -- | -- | -- | -- | 0.70 | No RP ¹⁰ |
| PCBs ³ | µg/L | 0.0020 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day | 0.0070 | -- | -- | -- | -- | |
| TCDD equivalents ³ | pg/L | 0.33 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day | 1.2xE-6 | -- | -- | -- | -- | |
| 1,1,2,2-Tetrachloroethane | µg/L | -- | -- | -- | -- | 0.55 | No RP ¹⁰ |
| Tetrachloroethylene | µg/L | -- | -- | -- | -- | 0.5 | No RP ¹⁰ |
| Toxaphene | µg/L | -- | -- | -- | -- | 0.018 | No RP ¹⁰ |
| Trichloroethylene | µg/L | -- | -- | -- | -- | 0.4 | No RP ¹⁰ |
| 1,1,2-Trichloroethane | µg/L | -- | -- | -- | -- | 0.25 | No RP ¹⁰ |
| 2,4,6-Trichlorophenol | µg/L | -- | -- | -- | -- | 0.45 | No RP ¹⁰ |
| Vinyl chloride | µg/L | -- | -- | -- | -- | 0.35 | No RP ¹⁰ |

Table 12. Summary of Final Effluent Limitations Discharge Point 001
(Footnotes are specified on pages F-41 and F-42 of this Fact Sheet.)

| Parameter | Units | Effluent Limitations ^{1,3} | | | | Performance Goal ² | Basis |
|--|-----------|---|----------------|----------------------------|------------------------------------|-------------------------------|--|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Maximum ⁵ | | |
| BOD ₅ 20°C ⁶ | mg/L | 30 | 45 | -- | -- | -- | Existing; Carry-over; Secondary treatment standard |
| | lbs/day | 113,000 | 169,000 | -- | -- | | |
| | % removal | 85 | -- | -- | -- | | |
| Total Suspended Solids (TSS) ⁶ | mg/L | 30 | 45 | -- | -- | -- | Existing; Carry-over; Secondary treatment standard |
| | lbs/day | 113,000 | 169,000 | -- | -- | | |
| | % removal | 85 | -- | -- | -- | | |
| pH ^{5,6,7} | pH unit | 6.0 (instantaneous minimum) – 9.0 (instantaneous maximum) | | | | -- | Existing; Carry-over; Ocean Plan |
| Oil and Grease ⁷ | mg/L | 25 | 40 | -- | 75 | -- | Existing; Carry-over; Ocean Plan |
| | lbs/day | 93,800 | 150,000 | -- | -- | | |
| Settleable Solids ⁷ | ml/L | 1.0 | 1.5 | -- | 3.0 | -- | Existing; Carry-over; Ocean Plan |
| Turbidity ⁷ | NTU | 75 | 100 | -- | 225 | -- | Existing; Carry-over; Ocean Plan |
| Marine Aquatic Life Toxicants⁸ | | | | | | | |
| Arsenic ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Cadmium ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| | lbs/day | -- | -- | -- | -- | -- | |
| Chromium (VI) ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Copper ⁹ | µg/L | 16 | -- | 140 | 160 | -- | RP; Existing; Carry-over; Ocean Plan |
| | lbs/day | 56 | -- | 490 | 560 | -- | |
| Lead ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Mercury ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Nickel ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Selenium ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Silver ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Zinc ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Cyanide | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Chlorine Residual | µg/L | 28 | -- | 112 | 840 | -- | No RP ¹⁰ |
| | lbs/day | 98 | -- | 320 | 2900 | -- | |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | Performance Goal ² | Basis |
|---|---------|-------------------------------------|----------------|----------------------------|------------------------------------|-------------------------------|--|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Maximum ⁵ | | |
| Ammonia as N | mg/L | 8.4 | -- | 34 | 84 | -- | RP; Existing; Carry-over; Ocean Plan |
| | lbs/day | 29,000 | -- | 120,000 | 290,000 | -- | |
| Phenolic compounds (non-chlorinated) | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Phenolic compounds (chlorinated) | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Endosulfan | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| HCH | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Endrin | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Acute toxicity | TUa | -- | -- | | -- | -- | BPJ |
| Chronic toxicity | TUc | -- | -- | 13 | -- | -- | RP; Existing Carry-over; Ocean Plan ⁴ |
| Radioactivity | | | | | | | |
| Gross alpha | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Gross beta | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Combined Radium 226 & Radium-228 | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Tritium | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Strontium-90 | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Uranium | pCi/L | -- | -- | -- | -- | -- | No RP ¹¹ |
| Human Health Toxicants – Non Carcinogens⁸ | | | | | | | |
| Acrolein | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Antimony ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Bis(2-chloroethoxy) methane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Bis(2-chloroisopropyl) ether | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Chlorobenzene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Chromium (III) ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Di-n-butyl-phthalate | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Dichlorobenzenes ³ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Diethyl phthalate | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Dimethyl phthalate | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 2-Methyl-4,6-dinitrophenol | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 2,4-Dinitrophenol | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Ethyl benzene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Fluoranthene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | Performance Goal ² | Basis |
|---|---------|-------------------------------------|----------------|----------------------------|------------------------------------|-------------------------------|--|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Maximum ⁵ | | |
| Hexachlorocyclopentadiene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Nitrobenzene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Thallium ⁹ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Toluene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Tributyltin | ng/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 1,1,1-Trichloroethane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Human Health Toxicants – Carcinogens⁸ | | | | | | | |
| Acrylonitrile | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Aldrin | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Benzene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Benzidine | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Beryllium ⁸ | µg/L | 0.46 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day | 1.6 | -- | -- | -- | -- | |
| Bis(2-chloroethyl) ether | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Bis(2-ethylhexyl) phthalate | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Carbon tetrachloride | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Chlordane | µg/L | 0.0003 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day | 0.0011 | -- | -- | -- | -- | |
| Chlorodibromomethane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Chloroform | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| DDT | µg/L | 0.0024 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day | 0.0084 | -- | -- | -- | -- | |
| 1,4-Dichlorobenzene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 3,3'-Dichlorobenzidine | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 1,2-Dichloroethane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 1,1-Dichloroethylene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Bromodichloromethane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Dichloromethane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 1,3-Dichloropropene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Dieldrin | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 2,4-Dinitrotoluene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 1,2-Diphenylhydrazine | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Halomethanes ³ | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Heptachlor | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |

| Parameter | Units | Effluent Limitations ^{1,3} | | | | Performance Goal ² | Basis |
|-------------------------------|----------------------|-------------------------------------|----------------|----------------------------|------------------------------------|-------------------------------|--|
| | | Average Monthly | Average Weekly | Maximum Daily ⁴ | Instantaneous Maximum ⁵ | | |
| Heptachlor epoxide | µg/L | | -- | -- | -- | -- | No RP ¹⁰ |
| Hexachlorobenzene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Hexachlorobutadiene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Hexachloroethane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Isophorone | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| N-Nitrosodimethylamine | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| N-Nitrosodi-N-propylamine | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| N-Nitrosodiphenylamine | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| PAHs ³ | µg/L | 0.12 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day ⁶ | 0.43 | -- | -- | -- | -- | |
| PCBs ³ | µg/L | 0.00030 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day ⁶ | 0.0084 | -- | -- | -- | -- | |
| TCDD equivalents ³ | pg/L | 0.055 | -- | -- | -- | -- | Existing/ Carry-over; Ocean Plan |
| | lbs/day ⁶ | 1.93xE-7 | -- | -- | -- | -- | |
| 1,1,2,2-Tetrachloroethane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Tetrachloroethylene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Toxaphene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Trichloroethylene | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 1,1,2-Trichloroethane | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| 2,4,6-Trichlorophenol | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |
| Vinyl chloride | µg/L | -- | -- | -- | -- | -- | No RP ¹⁰ |

Footnotes:

¹ Effluent limitations for conventional, nonconventional, and toxic pollutants were calculated based on effluent limitations in *Table A* and water quality objectives in *Table B* of the Ocean Plan. The minimum dilution ratios used to calculate effluent limitations for nonconventional and toxic pollutants based on water quality objectives in *Table B* of the Ocean Plan are 84:1 (i.e., 84 parts seawater to one part effluent) and 13:1 for Discharge Points 002 and 001, respectively. The calculations of mass emission rates are shown in the accompanying Fact Sheet.

The mass emission rates are based on the average design flow rate (420 MGD) of the Hyperion Treatment Plant in the 1994 permit: lbs/day = 0.00834 x Ce (effluent concentration in ug/L) x Q (flow rate in MGD). During storm events when flow exceeds the dry weather design capacity, the mass emission rate limitations shall not apply.

² The performance goals are based upon the actual performance data of Hyperion Treatment Plant and are specified only as an indication of the treatment efficiency of the plant. They are not considered effluent limitations or standards for the treatment plant. Hyperion Treatment Plant shall make best efforts to maintain, if not improve, the effluent quality at the level of these performance goals. The Executive Officer and USEPA

may modify any of the performance goals if the City requests and has demonstrated that the change is warranted.

- ³ See section VIII of this Order and Attachment A for definition of terms.
 - ⁴ The maximum daily effluent concentration limitation shall apply to flow-weighted 24-hour composite samples. It may apply to grab samples if the collection of composite samples for those constituents is not appropriate because of the instability of the constituents.
 - ⁵ The instantaneous maximum effluent limitations shall apply to grab sample results.
 - ⁶ The effluent limitations are based on secondary treatment standards, 40 CFR 133.102.
 - ⁷ Based on Ocean Plan Table A effluent limitations.
 - ⁸ Effluent limitations for these constituents are based on Ocean Plan Table B objectives using initial dilution ratios of 84 and 13 parts of seawater to 1 part effluent for Discharge Points 002 and 001, respectively.
 - ⁹ Represents total recoverable metal value.
 - ¹⁰ These constituents did not show reasonable potential to exceed Ocean Plan Table B objectives; therefore, no numerical water quality-based effluent limits are prescribed.
-

VI. PERFORMANCE GOALS

Chapter III, section F.2, of the 2005 Ocean Plan allows the Regional Water Board to establish more restrictive water quality objectives and effluent limitations than those set forth in the Ocean Plan as necessary for the protection of the beneficial uses of ocean waters.

Pursuant to this provision and to implement the recommendation of the Water Quality Advisory Task Force (*Working Together for an Affordable Clean Water Environment, A final report presented to the California Water Quality Control Board, Los Angeles Region by Water Quality Advisory Task Force, September 30, 1993*) that was adopted by the Regional Water Board on November 1, 1993, performance goals that are more stringent than those based on Ocean Plan objectives are prescribed in this Order/Permit. This approach is consistent with the antidegradation policy in that it requires the Discharger to maintain its treatment level and effluent quality, recognizing normal variations in treatment efficiency and sampling and analytical techniques. However, this approach does not address substantial changes in treatment plant operations that could significantly affect the quality of the treated effluent.

While performance goals were previously placed in many POTW permits in the Region, they have not been continued for discharges that are to inland surface waters. For inland surface waters, the California Toxics Rule (40 CFR part 131.38) has resulted in effluent limitations as stringent as many performance goals. However, the Ocean Plan allows for significant dilution, and the continued use of performance goals serves to maintain

existing treatment levels and effluent quality and supports State and federal antidegradation policies.

The performance goals are based upon the actual performance of the Hyperion Treatment Plant and are specified only as an indication of the treatment efficiency of the Facility. Performance goals are intended to minimize pollutant loading (primarily for toxics), while maintaining the incentive for future voluntary improvement of water quality whenever feasible, without the imposition of more stringent limits based on improved performance. They are not considered enforceable limitations or standards for the regulation of the discharge from the treatment facility. The Executive Officer may modify any of the performance goals if the Discharger requests and has demonstrated that the change is warranted.

Procedures for the Determination of Performance Goals

1. For constituents that have been routinely detected in the effluent (at least 20 percent detectable data), performance goals are based on the one-sided, upper 95 percent confidence bound ($UCB_{95/95}$) of the 95th percentile of July 2005 through July 2009 performance data using the RPA protocol contained in the 2005 Ocean Plan. Effluent data are assumed lognormally distributed. Performance goals are calculated according to the equation $C_{PG} = UCB_{95/95}$.
 - a. If the maximum detected effluent concentration is greater than the calculated performance goal, then the calculated performance goal is used as the performance goal; or
 - b. If the maximum detected effluent concentration is less than the calculated performance goal, then the maximum detected effluent concentration is used as the performance goal.
2. For constituents where monitoring data have consistently shown nondetectable levels (less than 20 percent detectable data), performance goals are set at five times the Method Detection Limit reported in the 2008 Annual Report. However, if the maximum detected effluent concentration is less than the calculated value based on MDL, then the maximum detected effluent concentration is used as the performance goal.
3. For constituents with no effluent limitations, if the performance goal derived from the steps, above, exceeds the respective calculated Ocean Plan effluent limitation, then the calculated effluent limitation is prescribed as the performance goal.
4. For constituents with effluent limitations, if the performance goal derived from the steps, above, exceeds respective effluent limitation, then a performance goal is not prescribed.

The performance goals for Discharge Point 002 are prescribed in this Order/Permit. The listed performance goals are not enforceable effluent limitations or standards. The Discharger shall maintain, if not improve, its treatment efficiency. Any exceedance of the performance goals shall trigger an investigation into the cause of the exceedance. If the exceedance persists in three successive monitoring periods, the Discharger shall submit a written report to the Regional Water Board and USEPA on the nature of the exceedance, the results of the investigation as to the cause of the exceedance, and the corrective actions taken or proposed corrective measures with timetable for implementation, if necessary.

VII. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water

The Ocean Plan and Basin Plan contain numeric and narrative water quality standards applicable to surface waters within the Los Angeles Region. Water quality objectives include a policy to maintain the high quality waters pursuant to federal regulations (40 CFR part 131.12) and State Water Board Resolution No. 68-16. Receiving water limitations in the Order/Permit are included to ensure protection of beneficial uses of the receiving water.

VIII. MASS EMISSION CAPS

Mass emission caps are applied to four pollutants of concern identified by the SMBRP (copper, lead, silver, and zinc) that are causing or could cause deterioration of designated beneficial uses in the Santa Monica Bay. Caps are set at 1995 allowable emission rates. The Discharger should make best efforts to discharge these pollutants of concern below cap values. The Executive Officer and USEPA may modify any of the mass emission cap values, if the Discharger requests and demonstrates that the change is warranted.

The mass emission caps are based on 1995 average flow rate of 347 MGD and the 1995 average concentration of the pollutant of concern. If performance data showed nondetectable levels, one half of the detection limit was used to calculate an average concentration. Mass emission cap calculations are shown below.

| <u>Parameter</u> | <u>Mass Emission CAP, lbs/year</u> |
|------------------|------------------------------------|
| Copper | 41,100 |
| Lead | 2,700 |
| Silver | 5,500 |
| Zinc | 59,100 |

Mass Emission Cap Calculation:

1995 average flow: 347 MGD

Monthly Monitoring Results in 1995

| Month | Unit | Constituent | | | |
|-------------------------|--------|-------------|-------|--------|--------|
| | | Copper | Lead* | Silver | Zinc |
| Jan | ug/L | 35 | <3 | 4.2 | 45 |
| Feb | ug/L | 46 | <6 | 6 | 62 |
| Mar | ug/L | 33 | <3 | 6 | 40 |
| Apr | ug/L | 30 | <3 | 1.2 | 34 |
| May | ug/L | 36 | <3 | 7 | 51 |
| Jun | ug/L | 45 | 3 | 6.7 | 77 |
| Jul | ug/L | 39 | <3 | 8.9 | 45 |
| Aug | ug/L | 38 | 10 | 5.5 | 53 |
| Sep | ug/L | 46 | 3 | 3.4 | 57 |
| Oct | ug/L | 42 | <3 | 2.6 | 60 |
| Nov | ug/L | 43 | <3 | 7.2 | 54 |
| Dec | ug/L | 34 | <3 | 3.9 | 94 |
| Average | ug/L | 39 | 2.6 | 5.2 | 56 |
| Mass Emission Cap ** | Lbs/yr | 41,181 | 2,745 | 5,491 | 59,132 |

* One half of the detection limit is used in the calculation.

** Mass Emission Cap is based on the 1995 flow rate of 347 MGD.

Example calculation for copper:

$39 \text{ ug/L} \times 1 \text{ g/1,000,000 ug} \times 347,000,000 \text{ gals/day} \times 3.785\text{L/gal} \times \text{lb/454 g} \times 365 \text{ days/year} = 41,181 \text{ lbs/year}$

IX. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

40 CFR part 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. California Water Code sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP), Attachment E of this Order/Permit, establishes monitoring and reporting requirements to implement federal and State requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this facility.

A. Influent Monitoring

Influent monitoring is required to:

- Determine compliance with NPDES permit conditions.
- Assess treatment plant performance.
- Assess effectiveness of the Pretreatment Program.

Influent monitoring in this Order/Permit follows the influent monitoring requirements in the previous Order/Permit with minor changes. The monitoring frequencies for some parameters have been increased due to RP for those parameters.

B. Effluent Monitoring

The Discharger is required to conduct monitoring of the permitted discharges in order to evaluate compliance with permit limitations and conditions. Monitoring requirements are specified in the Monitoring and Reporting Program (Attachment E). This Order/Permit requires compliance with the Monitoring and Reporting Program, and is based on 40 CFR parts 122.48, 122.44(i), and 122.41(j). The Monitoring and Reporting Program is a standard requirement in almost all NPDES permits (including this Order/Permit) issued by the Regional Water Board or USEPA. In addition to containing definition of terms, it specifies general sampling/analytical protocols and the requirements of reporting spills, violation, and routine monitoring data in accordance with NPDES regulations, the California Water Code, and Regional Water Board and USEPA policies. The Monitoring and Reporting Program also contains sampling program specific for the Discharger's wastewater treatment plant. It defines the sampling stations and frequency, pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all pollutants for which effluent limitations are specified.

Monitoring for those pollutants expected to be present in the discharge from the facility, will be required as shown on the proposed Monitoring and Reporting Program (Attachment E) and as required in the Ocean Plan.

C. Receiving Water Monitoring

1. Surface Water

Receiving water monitoring is required to determine compliance with receiving water limitations and to characterize the water quality of the receiving water. Requirements are based on the Ocean Plan and Basin Plan. The conceptual framework for the receiving water program has three components that comprise a range of spatial and temporal scales: (a) core monitoring; (b) regional monitoring; and (c) special studies.

- a. Core monitoring is local in nature and focused on monitoring trends in quality and effects of the point source discharge. This includes effluent monitoring as well as many aspects of receiving water monitoring. In the monitoring program described below these core components are typically referred to as local monitoring.
- b. Regional monitoring is focused on questions that are best answered by a region-wide approach that incorporates coordinated survey design and sampling techniques. The major objective of regional monitoring is to collect information required to assess how safe it is to swim in the ocean, how safe it is to eat seafood from the ocean, and whether the marine ecosystem is being protected. Key components of regional monitoring include elements to address pollutant mass emission estimations, public health concerns, monitoring of trends in natural resources, assessment of regional impacts from all contaminant sources, and protection of beneficial uses. The final design of regional monitoring programs is developed by means of steering committees and technical committees comprised of participating agencies and organizations and is not specified in this Order/Permit. Instead, for each regional component, the degree and nature of participation of the Discharger is specified. For this Order/Permit, these levels of effort are based upon past participation of the Discharger in regional monitoring programs.

The Discharger shall participate in regional monitoring activities coordinated by the SCCWRP or any other appropriate agency approved by the Regional Water Board and USEPA. The procedures and time lines for the Regional Water Board and USEPA approval shall be the same as detailed for special studies, below.

- c. Special studies are focused on refined questions regarding specific effects or development of monitoring techniques and are anticipated to be of short duration and/or small scale, although multiyear studies also may be needed. Questions regarding effluent or receiving water quality, discharge impacts, ocean processes in the area of the discharge, or development of techniques for monitoring the same, arising out of the results of core or regional monitoring, may be pursued through special studies. These studies are by nature ad hoc and cannot be typically anticipated in advance of the five-year permit cycle.

The Discharger, the Regional Water Board and USEPA shall consult annually to determine the need for special studies. Each year, the Discharger shall submit proposals for any proposed special studies to the Regional Water Board and USEPA by December 31, for the following year's monitoring effort (July through June). The following year, detailed scopes of work for proposals, including reporting schedules, shall be

presented by the Discharger at a Spring Regional Water Board meeting, to obtain the Regional Water Board approval and to inform the public. Upon approval by the Regional Water Board and USEPA, the Discharger shall implement its special study or studies. (Note: The CEC and Nutrient special studies have different deadlines for submitting a Workplan.)

- d. The receiving water monitoring program contains the following core and regional components: Inshore and offshore water quality monitoring; benthic infauna and sediment chemistry monitoring; fish and macroinvertebrate (trawl and rig fishing) monitoring, including bioaccumulation/seafood safety; and kelp bed monitoring. Local and regional survey questions, sampling designs, monitoring locations, and other specific monitoring requirements are detailed in the MRP.

D. Other Monitoring Requirements

1. Outfall and Diffuser Inspection

This survey answers the question: “Are the outfall structures in serviceable condition ensuring their continued safe operation?” The data collected will be used for a periodic assessment of the integrity of the outfall pipes and ballasting system.

2. Biosolids and Sludge Management

Attachment H establishes monitoring and reporting requirements for the storage, handling and disposal practices of biosolids/sludge generated from the operation of this POTW.

X. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR part 122.41, and additional conditions applicable to specified categories of NPDES permits in accordance with 40 CFR part 122.42, are provided in Attachment D to the Order/Permit. 40 CFR part 122.41(a) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions are incorporated into this Order/Permit expressly.

B. Special Provisions

1. Reopener Provisions

These provisions are based on 40 CFR part 123.25. The Regional Water Board and USEPA may reopen the Order/Permit to modify conditions and requirements. Causes for modifications can include, but are not limited to, the promulgation of new regulations, modification in sludge use or disposal practices, or adoption of new regulations by the State Water Board or Regional Water Board, including revisions to the Ocean Plan and Basin Plan.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

a. Toxicity Reduction Requirements

If the discharge consistently exceeds an effluent limitation for toxicity as specified in this Order/Permit, the Discharger shall conduct a TRE as detailed in section V of the MRP (Attachment E). The TRE will help the Discharger identify the possible source(s) of toxicity. The Discharger shall take all reasonable steps to reduce toxicity to the required level.

3. Best Management Practices and Pollution Prevention

a. Spill Clean-Up Contingency Plan (SCCP)

Since spills or overflows are a common event in the POTW, this Order/Permit requires the Discharger to review and update, if necessary, its SCCP after each incident. The Discharger shall ensure that the up-to-date SCCP is readily available to the sewage system personnel at all times and that the sewage personnel are familiar with it.

b. Pollutant Minimization Program

This provision is based on the requirements of section III.C.9 of the Ocean Plan.

4. Construction, Operation and Maintenance Specifications

This provision is based on the requirements of 40 CFR 122.41(e) and the previous Order/Permit.

5. Special Provisions for Municipal Facilities (POTWs Only)

a. Sludge (Biosolids) Requirements. Section 405 of the CWA and implementing regulations at 40 CFR 503 require that producers of sewage sludge/biosolids meet certain reporting, handling, and use or disposal

requirements. The State has not been delegated the authority to implement this program; therefore, USEPA is the implementing agency. This Order/Permit contains sewage sludge/biosolids requirements that are applicable to the Discharger.

- b. Pretreatment Program Requirements. Section 402 of the CWA and implementing regulations at 40 CFR part 403 establish pretreatment requirements for POTWs which receive pollutants from non-domestic users. This Order/Permit contains pretreatment program requirements that are applicable to the Discharger.
6. Spill Reporting Requirements for POTWs. This Order/Permit established a reporting protocol for how different types of spills, overflows, and bypasses of raw or partially treated sewage from the POTW shall be reported to regulatory agencies.

In addition, the State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order No. 2006-0003-DWQ (General Order) on May 2, 2006. The amended General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions. Furthermore, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating SSOs. The Discharger's collection system is part of the POTW that is subject to this Order/Permit. The Discharger must comply with both the General Order and this Order/Permit.

XI. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, Los Angeles Region (Regional Water Board) and the U.S. Environmental Protection Agency, Region 9 (USEPA) are considering reissuance of waste discharge requirements (WDR) and a National Pollutant Discharge Elimination System (NPDES) permit for the above-referenced POTW. As an initial step in this process, Regional Board and USEPA staff have developed a tentative WDR and NPDES permit. The Regional Water Board and USEPA encourage public participation in this reissuance process.

A. Written Comments

Staff determinations are tentative. Interested persons are invited to submit written comments concerning the tentative WDR and draft NPDES permit. Comments must be submitted either in person or by mail to:

EXECUTIVE OFFICER
California Regional Water Quality Control Board, Los Angeles Region
320 W. 4th Street, Suite 200
Los Angeles, CA 90013

Robyn Stuber
U.S. Environmental Protection Agency, Region 9
NPDES Permits Office (WTR-5)
75 Hawthorne Street
San Francisco, CA 94105-3901

To facilitate consideration by the Regional Water Board and USEPA, written comments should be received at Regional Water Board and USEPA offices by June 21, 2010. In addition, written and oral public comments may be submitted until the close of the public hearing at the Regional Water Board's regular Board meeting on July 8 and 9, 2010.

B. Public Hearing

The Regional Water Board and USEPA held a joint public hearing on the tentative WDR and NPDES permit during the regular Board meeting on the following date, time, and location:

Date and Time: July 8 at 9:00 a.m. and 9, 2010 at 8:00 a.m.
Location: County Government Center, Board of Supervisors Hearing Room
800 S. Victoria Avenue
Ventura, California

Interested parties and persons were invited to attend. At the public hearing, the Regional Water Board and USEPA heard testimonies pertinent to the waste discharge, WDR, and NPDES permit.

In addition, the Regional Water Board will hold a public hearing on the tentative WDR during its regular Board meeting on the following date and time and at the following location:

Date and Time: November 4, 2010 at 9 a.m.
Location: Metropolitan Water District of Southern California
700 North Alameda Street
Los Angeles, California

Interested parties and persons are invited to attend. However, since the comment period ended on July 9, 2010, oral testimony pertinent to the waste discharge, WDR, and NPDES permit will not be heard at the public hearing.

The Regional Water Board's web address is www.swrcb.ca.gov/rwqcb4 where interested persons can access the current agenda for changes in Board meeting dates, times and venues.

C. Information and Copying

The Report of Waste Discharge (ROWD), related documents, tentative effluent limitations and special conditions, comments received, and other information are on file and may be inspected at 320 West 4th Street, Suite 200, Los Angeles, California and 75 Hawthorne Street, San Francisco, California, at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged by calling the Los Angeles Regional Water Board at (213) 576-6600 or USEPA at (415) 972-3524.

D. Waste Discharge Requirements Appeals

Any aggrieved person may petition the State Water Board to review the decision of the Regional Water Board regarding the final WDR. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
ATTN: Michael Lauffer
P.O. Box 100, 1001 I Street
Sacramento, CA 95812

E. Federal NPDES Permit Appeals

When a final NPDES permit is issued by USEPA, it will become effective 33 days following the date it is mailed to the Discharger, unless a request for review is filed. If a request for review is filed, only those permit conditions which are uncontested will go into effect pending disposition of the request for review. Requests for review must be filed within 33 days following the date the final permit is mailed and must meet the requirements of 40 CFR part 124.19. All requests for review should be addressed to the Environmental Appeals Board (EAB) as follows. Requests sent through the U.S. Postal Service (except by Express Mail) must be addressed to the EAB's mailing address, which is:

U.S. Environmental Protection Agency
Clerk of the Board
Environmental Appeals Board (MC 1103B)
Ariel Rios Building
1200 Pennsylvania Avenue, N.W.
Washington, D.C. 20460-0001

All filings delivered by hand or courier, including Federal Express, UPS, and U.S. Postal Express Mail, should be directed to the following address:

Environmental Appeals Board
U.S. Environmental Protection Agency
Colorado Building
1341 G Street, N.W., Suite 600
Washington, D.C. 20460

Those persons filing a request for review must have filed comments on the draft permit, or participated in the public hearing. Otherwise, any such request for review may be filed only to the extent of changes from the draft to the final permit decision.

F. Additional Information

Requests for additional information or questions regarding this Order/Permit should be directed to Ms. Robyn Stuber at stuber.robyn@epa.gov or (415) 972-3524, or Dr. Cathy Chang at cchang@waterboards.ca.gov or (213) 576-6760.

ATTACHMENT G – GENERIC TOXICITY REDUCTION EVALUATION (TRE) WORKPLAN (POTW)

1. Information and Data Acquisition

a. Operations and performance review

- i. NPDES permit requirements
 - (1) Effluent limitations
 - (2) Special conditions
 - (3) Monitoring data and compliance history
- ii. POTW design criteria
 - (1) Hydraulic loading capacities
 - (2) Pollutant loading capacities
 - (3) Biodegradation kinetics calculations/assumptions
- iii. Influent and effluent conventional pollutant data
 - (1) Biochemical oxygen demand (BOD₅)
 - (2) Chemical oxygen demand (COD)
 - (3) Suspended solids (SS)
 - (4) Ammonia
 - (5) Residual chlorine
 - (6) pH
- iv. Process control data
 - (1) Primary sedimentation - hydraulic loading capacity and BOD₅ and SS removal
 - (2) Activated sludge - Food-to-microorganism (F/M) ratio, mean cell residence time (MCRT), mixed liquor suspended solids (MLSS), sludge yield, and BOD₅ and COD removal
 - (3) Secondary clarification - hydraulic and solids loading capacity, sludge volume index and sludge blanket depth
- v. Operations information
 - (1) Operating logs
 - (2) Standard operating procedures
 - (3) Operations and maintenance practices
- vi. Process sidestream characterization data
 - (1) Sludge processing sidestreams
 - (2) Tertiary filter backwash
 - (3) Cooling water
- vii. Combined sewer overflow (CSO) bypass data
 - (1) Frequency
 - (2) Volume
- viii. Chemical coagulant usage for wastewater treatment and sludge processing
 - (1) Polymer
 - (2) Ferric chloride
 - (3) Alum

- b. POTW influent and effluent characterization data**
 - i. Toxicity
 - ii. Priority pollutants
 - iii. Hazardous pollutants
 - iv. SARA 313 pollutants
 - v. Other chemical-specific monitoring results
- c. Sewage residuals (raw, digested, thickened and dewatered sludge and incinerator ash) characterization data**
 - i. EP toxicity
 - ii. Toxicity Characteristic Leaching Procedure (TCLP)
 - iii. Chemical analysis
- d. Industrial waste survey (IWS)**
 - i. Information on IUs with categorical standards or local limits and other significant non-categorical IUs
 - ii. Number of IUs
 - iii. Discharge flow
 - iv. Standard Industrial Classification (SIC) code
 - v. Wastewater flow
 - (1) Types and concentrations of pollutants in the discharge
 - (2) Products manufactured
 - vi. Description of pretreatment facilities and operating practices
 - vii. Annual pretreatment report
 - viii. Schematic of sewer collection system
 - ix. POTW monitoring data
 - (1) Discharge characterization data
 - (2) Spill prevention and control procedures
 - (3) Hazardous waste generation
 - x. IU self-monitoring data
 - (1) Description of operations
 - (2) Flow measurements
 - (3) Discharge characterization data
 - (4) Notice of sludge loading
 - (5) Compliance schedule (if out of compliance)
 - xi. Technically based local limits compliance reports
 - xii. Waste hauler monitoring data manifests
 - xiii. Evidence of POTW treatment interferences (i.e., biological process inhibition)

ATTACHMENT H

BIOSOLIDS AND SLUDGE MANAGEMENT

(Note: "Biosolids" refers to non-hazardous sewage sludge, as defined at 40 CFR 503.9. Sewage sludge that is hazardous, as defined at 40 CFR 261, must be disposed of in accordance with the Resource Conservation and Recovery Act (RCRA).)

1. General Requirements

- a. All biosolids generated by the Discharger shall be used or disposed of in compliance with applicable portions of Clean Water Act and Safe Drinking Water Act, including: 40 CFR 503—for biosolids that are land applied, placed in a surface disposal site (dedicated land disposal site, monofill, or sludge-only parcel at a municipal landfill), or incinerated; 40 CFR 258—for biosolids disposed of in a municipal solid waste landfill (with other materials); and 40 CFR 257—for all biosolids use and disposal practices not covered under 40 CFR 258 or 503.

40 CFR 503, Subpart B (land application), sets forth requirements for biosolids that are applied for the purpose of enhancing plant growth or for land reclamation. 40 CFR 503, Subpart C (surface disposal), sets forth requirements for biosolids that are placed on land for the purpose of disposal.

The Discharger is responsible for assuring that all biosolids produced at its facility are used or disposed of in accordance with these rules, whether the Discharger uses or disposes of the biosolids itself, or transfers their biosolids to another party for further treatment, use, or disposal. The Discharger is responsible for informing subsequent preparers, appliers, and disposers of requirements they must meet under these rules.

- b. Duty to Mitigate: The Discharger shall take all reasonable steps to prevent or minimize any biosolids use or disposal which has a likelihood of adversely affecting human health or the environment.
- c. No biosolids shall be allowed to enter wetlands or other waters of the United States.
- d. Biosolids treatment, storage, use, or disposal shall not contaminate groundwater.
- e. Biosolids treatment, storage, use, or disposal shall not create a nuisance such as objectionable odors or flies.

- f. The Discharger shall assure that haulers transporting biosolids off-site for treatment, storage, use, or disposal take all necessary measures to keep the biosolids contained. Trucks hauling biosolids that are not Class A, as defined at 40 CFR 503.32(a), shall be cleaned as necessary after loading and after unloading, so as to have no biosolids on the exterior of the truck or wheels. Trucks hauling biosolids that are not Class A shall be tarped. All haulers must have spill clean-up procedures. Trucks hauling biosolids that are not Class A shall not be used for hauling food or feed crops after unloading the biosolids unless the Discharger submits a hauling description, to be approved by USEPA, describing how trucks will be thoroughly cleaned prior to adding food or feed.
- g. If biosolids are stored for over two years from the time they are generated, the Discharger must ensure compliance with all requirements for surface disposal under 40 CFR 503, Subpart C, or must submit a written request to USEPA and the State with the information specified under 40 CFR 503.20(b), demonstrating the need for longer temporary storage. During storage of any length for non-Class A biosolids, whether on the facility site or off-site, adequate procedures must be taken to restrict access by the public and domestic animals.
- h. Any biosolids treatment, disposal, or storage site shall have facilities adequate to divert surface runoff from adjacent areas, to protect the site boundaries from erosion, and to prevent any conditions that would cause drainage from the materials to escape from the site. Adequate protection is defined as protection from at least a 100-year storm and the highest tidal stage which may occur.
- i. There shall be adequate screening at the plant headworks and/or at the biosolids treatment units to ensure that all pieces of metal, plastic, glass, and other inert objects with a diameter greater than 3/8 inches are removed.
- j. Sewage sludge containing more than 50 mg/kg PCBs shall be disposed of in accordance with 40 CFR 761.
- k. The Discharger shall ensure compliance with the requirements in State Water Board Order No. 2004-10-DWQ, "General Waste Discharge Requirements for the Discharge of Biosolids to Land for Use as a Soil Amendment in Agricultural, Silvicultural, Horticultural and Land Reclamation Activities" for those sites receiving the Discharger's biosolids which a Regional Water Board has placed under this general order, and with the requirements in individual Waste Discharge Requirements (WDRs) issued by a Regional Water Board for sites receiving the Discharger's biosolids.

- I. The Discharger shall comply, if applicable, with WDRs issued by Regional Water Boards to which jurisdiction the biosolids are transported and applied, and with the State of Arizona's biosolids rule for biosolids transported to Arizona for treatment and/or use.

2. Inspection and Entry

The Regional Water Board, USEPA, or an authorized representative thereof, upon the presentation of credentials, shall be allowed by the Discharger, directly or through contractual arrangements with their biosolids management contractors, to:

- a. Enter upon all premises where biosolids produced by the Discharger are treated, stored, used, or disposed of, by either the Discharger or another party to whom the Discharger transfers biosolids for further treatment, storage, use, or disposal.
- b. Have access to and copy any records that must be kept by either the Discharger or another party to whom the Discharger transfers biosolids for further treatment, storage, use, or disposal, under the conditions of this Order/Permit or 40 CFR 503.
- c. Inspect any facilities, equipment (including monitoring and control equipment), practices, or operations used in biosolids treatment, storage, use, or disposal by either the Discharger or another party to whom the Discharger transfers biosolids for further treatment, storage, use, or disposal.

3. Monitoring

- a. Biosolids shall be monitored for the following constituents, at the frequency stipulated in Table 1 of 40 CFR 503.16: arsenic, cadmium, chromium, copper, lead, mercury, molybdenum, nickel, selenium, zinc, organic nitrogen, ammonia nitrogen, and total solids. If biosolids are removed for use or disposal on a routine basis, sampling should be scheduled at regular intervals throughout the year. If biosolids are stored for an extended period prior to use or disposal, sampling may occur at regular intervals, or samples of the accumulated stockpile may be collected prior to use or disposal, corresponding to the tons accumulated in the stockpile over that period.

Monitoring shall be conducted using the methods in Test Methods for Evaluating Solid Waste, Physical/Chemical Methods (SW-846), or as otherwise required under 40 CFR 503.8(b). All results must be reported on a 100% dry weight basis and records of all analyses must state on each page of the analytical results whether the reported results are expressed on an "as-is" or a "100% dry weight" basis.

- b. The Discharger shall sample biosolids twice per year for the pollutants listed under CWA section 307(a) using best practicable detection limits.

For accumulated, previously untested biosolids, the Discharger shall develop a representative sampling plan, which addresses the number and location of sampling points, and collect representative samples.

Test results shall be expressed in mg pollutant per kg biosolids on a 100% dry weight basis.

Biosolids to be land applied shall be tested for Organic-N, ammonium-N, and nitrate-N at the frequencies required above.

- c. Class 1 facilities (facilities with pretreatment programs or others designated as Class 1 by the Regional Administrator) and Federal facilities with >5 mgd influent flow shall sample biosolids for pollutants listed under Section 307(a) of the Clean Water Act (as required in the pretreatment section of the permit for POTWs with pretreatment programs.) Class 1 facilities and Federal facilities with >5 mgd influent flow shall test dioxins/dibenzofurans using a detection limit of <1 pg/g during their next sampling period if they have not done so within the past 5 years and once per 5 years thereafter.
- d. The biosolids shall be tested annually, or more frequently if necessary, to determine hazardousness in accordance with California Law.

4. Pathogen and Vector Control

- a. Prior to land application, the Discharger shall demonstrate that the biosolids meet Class A or Class B pathogen reduction levels by one of the methods listed under 40 CFR 503.32.
- b. Prior to disposal in a surface disposal site, the Discharger shall demonstrate that the biosolids meet Class B levels pathogen reduction levels, or ensure that the site is covered at the end of each operating day. If pathogen reduction is demonstrated using a "Process to Further Reduce Pathogens" or one of the "Processes to Significantly Reduce Pathogens", the Discharger shall maintain daily records of the operating parameters used to achieve this reduction. If pathogen reduction is demonstrated by testing for fecal coliform and/or pathogens, samples must be collected at the frequency specified in Table 1 of 40 CFR 503.16. If Class B is demonstrated using fecal coliform, at least seven grab samples must be collected during each monitoring period and a geometric mean calculated from these samples. The following holding times between sample collection and analysis shall not be exceeded: fecal coliform- 6 hours when cooled to <4 degrees C (extended to 24 hours when cooled to <4 degrees C for Class A composted, Class B aerobically digested, and Class B anaerobically digested sample types); Salmonella spp. Bacteria-

24 hours when cooled to <4 degrees C (unless using Method 1682- 6 hours when cooled to <10 degrees C); enteric viruses- 6 hours when cooled to <10 degrees C (extended to 24 hours when cooled to <4 degrees C or 2 weeks when frozen); helminth ova- 6 hours when cooled to <10 degrees C (extended to one month when cooled to <4 degrees C).

- c. For biosolids that are land applied or placed in a surface disposal site, the Discharger shall track and keep records of the operational parameters used to achieve Vector Attraction Reduction requirements in under 40 CFR 503.33 (b).

5. Surface Disposal

If biosolids are placed in a surface disposal site (dedicated land disposal site or monofill), a qualified groundwater scientist shall develop a groundwater monitoring program for the site, or shall certify that the placement of biosolids on the site will not contaminate an aquifer.

6. Landfill Disposal

Biosolids placed in a municipal landfill shall be tested by the Paint Filter Test (SW-846, Method 9095) at the frequency specified in Table 1 of 40 CFR 503.16, or more often if necessary to demonstrate that there are no free liquids.

7. Notifications

The Discharger either directly or through contractual arrangements with their biosolids management contractors shall comply with the following notification requirements:

- a. Notification of Non-compliance

The Discharger shall notify USEPA and the State (for both Discharger and use or disposal site) of any non-compliance within 24 hours, if the non-compliance may seriously endanger health or the environment. For other instances of non-compliance, the Discharger shall notify USEPA and the State of the non-compliance in writing within 5 working days of becoming aware of the non-compliance. The Discharger shall require their biosolids management contractors to notify USEPA and the State of any non-compliance within these same time-frames.

- b. Interstate Notification

If biosolids are shipped to another State or Tribal Land, the Discharger shall send 60 days prior notice of the shipment to the permitting authorities in the receiving State or Tribal Land, and the USEPA Regional Office.

c. Land Application Notification

Prior to using any biosolids from this facility (other than composted biosolids) at a new or previously unreported site, the Discharger shall notify USEPA and the State. This notification shall include a description and topographic map of the proposed site(s), names and addresses of the applicler and site owner, and a listing of any State or local permits which must be obtained. It shall also include a description of the crops or vegetation to be grown, proposed loading rates, and a determination of agronomic rates.

Within a given monitoring period, if any biosolids do not meet the applicable metals concentration limits specified under 40 CFR 503.13, then the Discharger (or its contractor) must pre-notify USEPA, and determine the cumulative metals loading at that site to date, as required by 40 CFR 503.12.

d. Surface Disposal Notification

Prior to disposal at a new or previously unreported site, the Discharger shall notify USEPA and the State. The notice shall include a description and topographic map of the proposed site, depth to groundwater, whether the site is lined or unlined, site operator and site owner, and any State or local permits. It shall also describe procedures for ensuring grazing and public access restrictions for three years following site closure. The notice shall include a groundwater monitoring plan or description of why groundwater monitoring is not required.

8. Reporting

The Discharger shall furnish this Regional Water Board with a copy of any report submitted to USEPA, State Water Board or other Regional Water Board, with respect to municipal sludge or biosolids. The Discharger shall submit an annual biosolids report to the USEPA Region 9 Biosolids Coordinator and the State by February 19 of each year for the period covering the previous calendar year. The report shall include:

- a. The amount of biosolids generated that year, in dry metric tons, and the amount accumulated from previous years.
- b. Results of all pollutant monitoring required under Monitoring, above. Results must be reported on a 100% dry weight basis.
- c. Demonstrations of pathogen and vector attraction reduction methods, as required under 40 CFR 503.17 and 503.27, and certifications.
- d. Names, mailing addresses, and street addresses of persons who received biosolids for storage, further treatment, disposal in a municipal landfill, deep

- well injection, or other use or disposal method not covered above, and tonnage delivered to each.
- e. The following information must be submitted by the Discharger, unless the Discharger requires its biosolids management contractors to report this information directly to the USEPA Region 9 Biosolids Coordinator.
- i. For land application sites:
- Locations of land application sites (with field names and numbers) used that calendar year, size of each field applied to, applier, and site owner.
- Volumes applied to each field (in wet tons and dry metric tons), nitrogen applied, and calculated plant available nitrogen.
- Crops planted, dates of planting and harvesting.
- For biosolids exceeding 40 CFR 503.13 Table 3 metals concentrations, the locations of sites where the biosolids were applied and cumulative metals loading at the sites to date.
- Certifications of management practices at 40 CFR 503.14.
- Certifications of site restrictions at 40 CFR 503(b)(5).
- ii. For surface disposal sites:
- Locations of sites, site operator and site owner, size of parcel on which biosolids were disposed.
- Results of any required groundwater monitoring.
- Certifications of management practices at 40 CFR 503.24.
- iii. For closed sites, the date of site closure and certifications of management practices for three years following site closure.
- f. All reports shall be submitted to:
- Regional Biosolids Coordinator
U.S. Environmental Protection Agency
CWA Compliance Office (WTR-7)
75 Hawthorne Street
San Francisco, CA 94105-3901
- Biosolids Program Coordinator
Arizona Department of Environmental Quality
Mail Code: 5415B-1

1110 West Washington Street
Phoenix, AZ 85007

ATTACHMENT I

PRETREATMENT PROGRAM REQUIREMENTS

1. The Discharger shall be responsible and liable for the performance of all Control Authority pretreatment requirements contained in 40 CFR 403, including any subsequent revisions to that part. Where 40 CFR 403 or subsequent revisions place mandatory actions upon the Discharger, as Control Authority, but do not specify a timetable for completion, the Discharger shall complete the mandatory actions within 180 days of the effective date of this Order/Permit, or the effective date of the revisions to 40 CFR 403, whichever is later. For violations of pretreatment requirements, the Discharger shall be subject to enforcement actions, penalties, fines, and other remedies imposed by the USEPA, the Regional Water Board, or other appropriate parties as provided in the CWA and/or the California Water Code. The Regional Water Board or USEPA may initiate enforcement action against a nondomestic user for noncompliance with applicable standards and requirements, as provided in the CWA and/or the California Water Code.
2. The Discharger shall implement and enforce in its entire service area, including contributing jurisdictions, its approved pretreatment program, and all subsequent revisions, which are hereby made enforceable conditions of this Order/Permit. The Discharger shall enforce the requirements promulgated pursuant to CWA sections 307(b), 307(c), 307(d), and 402(b) with timely, appropriate, and effective enforcement actions. The Discharger shall cause all nondomestic users subject to federal categorical standards to achieve compliance no later than the date specified in those requirements, or, in the case of a new nondomestic user, upon commencement of discharge.
3. The Discharger shall perform the pretreatment functions required by 40 CFR 403, including, but not limited to:
 - a. Implement the necessary legal authorities as required by 40 CFR 403.8(f)(1);
 - b. Enforce the pretreatment requirements under 40 CFR 403.5 and 403.6;
 - c. Implement the programmatic functions as required by 40 CFR 403.8(f)(2); and
 - d. Provide the requisite funding and personnel to implement the pretreatment program as required by 40 CFR 403.8(f)(3).
4. By March 1 of each year, the Discharger shall submit an annual report to the Regional Water Board, State Water Board, and USEPA describing its pretreatment activities over the previous calendar year (January through December 31). In the event the Discharger is not in compliance with any condition or requirement of this Order/Permit, or any pretreatment compliance inspection/audit requirements, the Discharger shall include the reasons for noncompliance and state how and when it

will comply with such conditions and requirements. The annual report shall contain, but not be limited to, the following information:

- a. A summary of analytical results from representative flow-proportioned 24-hour composite sampling of the Discharger's influent and effluent for those pollutants USEPA has identified under CWA section 307(a) which are known or suspected to be discharged by nondomestic users. Representative grab sampling shall be employed for pollutants that may degrade after collection, or where the use of automatic sampling equipment may otherwise result in unrepresentative sampling. Such pollutants include, but are not limited to, cyanide, oil and grease, volatile organic compounds, chlorine, phenol, sulfide, pH, and temperature. This will consist of an annual full priority pollutant scan in July. Wastewater sampling and analysis shall be performed in accordance with the minimum frequency of analysis required by the MRP (Attachment E). The Discharger shall also provide influent and effluent monitoring data for non-priority pollutants, which the Discharger believes may be causing or contributing to interference or pass through. The Discharger is not required to sample and analyze for asbestos. Sludge sampling and analysis is addressed elsewhere in this Order/Permit. Wastewater sampling and analysis shall be performed in accordance with 40 CFR 136.
- b. A discussion of upset, interference, or pass through, if any, at the Discharger's facilities, which the Discharger knows or suspects were caused by nondomestic users of the POTW system. The discussion shall include the reasons why the incidents occurred, any corrective actions taken, and, if known, the name and address of the responsible nondomestic user(s). The discussion shall also include a review of the applicable local pollutant limitations to determine whether any additional limitations or changes to existing limitations, are necessary to prevent pass-through, interference, or noncompliance with sludge disposal requirements.
- c. An updated list of the Discharger's SIUs including their names and addresses, and a list of deletions, additions and SIU name changes keyed to the previously submitted list. The Discharger shall provide a brief explanation for each change. The list shall identify the SIUs subject to federal categorical standards by specifying which set(s) of standards are applicable to each SIU. The list shall also indicate which SIUs are subject to local limitations.
- d. The Discharger shall characterize the compliance status of each SIU by providing a list or table for the following:

Name of SIU;

Category, if subject to categorical standards;

Type of wastewater treatment or control processes in place;

Number of samples taken by SIU during the year;

Number of samples and inspections by Discharger during the year;

For an SIU subject to discharge requirements for total toxic organics, whether all required certifications were provided;

A list of pretreatment standards (categorical or local) violated during the year, or any other violations;

SIUs in significant noncompliance (SNC) as defined at 40 CFR 403.8(f)(2)(viii), at any time during the year;

A summary of enforcement actions or any other actions taken against SIUs during the year. Describe the type of action, final compliance date, and the amount of fines and/or penalties collected, if any. Describe any proposed actions for bringing SIUs into compliance.

- e. A brief description of any programs the Discharger implements to reduce pollutants from nondomestic users not classified as SIUs;
 - f. A brief description of any significant changes in operating the pretreatment program which differ from the previous year, including, but not limited to, changes in the program's administrative structure, local limits, monitoring program, legal authority, enforcement policy, funding, and staffing levels;
 - g. A summary of the annual pretreatment program budget, including the cost of pretreatment program functions and equipment purchases;
 - h. A summary of activities to involve and inform the public of the pretreatment program, including a copy of the newspaper notice, if any, required by 40 CFR 403.8(f)(2)(vii);
 - i. A description of any changes in sludge disposal methods;
 - j. A discussion of any concerns not described elsewhere in the annual report.
5. Any substantial modifications to the approved Pretreatment Program, as defined in 40 CFR 403.18(b), shall be submitted in writing to the Regional Water Board and USEPA and shall not become effective until Regional Water Board and USEPA approval is obtained.

6. Semiannual SIU Status Report

The Discharger shall submit a semiannual SIU noncompliance status report to the Regional Water Board, State Water Board, and USEPA. The report shall cover the period of January 1 through June 30 and shall be submitted no later than September 1. (All required information for semiannual SIU noncompliance status

reporting covering the period July 1 through December 31 shall be included in the annual report that is due March 1.) The report shall contain:

- a. The names and addresses of all SIUs which violated any discharge or reporting requirements during the semi-annual reporting period;
 - b. A description of the violations, including whether the discharge violations were for categorical standards or local limits;
 - c. A description of the enforcement actions or other actions taken to remedy the noncompliance;
 - d. The status of enforcement actions or other actions taken in response to SIU noncompliance identified in previous reports.
7. The Discharger is required to describe in the annual report any programs the POTW implements to reduce pollutants from non-domestic sources.

8. Nonindustrial Source Control and Public Education Programs

The Discharger shall continue to develop and implement its nonindustrial source control program and public education program. The purpose of these programs is to reduce nonindustrial toxic pollutants and pesticides into the POTW. These programs shall be periodically reviewed and addressed in the annual report.

9. Signatory Requirements and Report Submittal

- a. The semi-annual and annual reports must be signed by a principal executive officer, ranking elected official or other duly authorized employee if such employee is responsible for the overall operation of the POTW. Any person signing these reports must make the following certification (40 CFR 403.6(a)(2)(ii)):

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

- b. An original copy of the Annual Report and Semi-Annual Report must be sent to the Pretreatment Program Coordinator of the Regional Water Board and the duplicate copies of the Reports must be sent to USEPA through the following addresses:

Information and Technology Unit
Attn: Pretreatment Program Coordinator
California Regional Water Quality Control Board, Los Angeles Region
320 West 4th Street, Suite 200
Los Angeles, CA 90013

Pretreatment Program
U.S. Environmental Protection Agency, Region 9
CWA Compliance Office (WTR-7)
75 Hawthorne Street
San Francisco, CA 94105-3901