

MUNICIPAL NPDES PERMIT

issued to

Permittee:

City of Danbury
155 Deer Hill Road
Danbury, Connecticut 06810

Location Address:

City of Danbury WPCF
Newtown Road
Danbury, Connecticut 06810

Facility ID: 034-001**Permit ID:** CT0100145**Permit Expires:****Receiving Stream:** Limekiln Brook**Design Flow Rate:** 15.5 MGD

SECTION 1: GENERAL PROVISIONS

- (A) This permit is reissued in accordance with Section 22a-430 of Chapter 446k, Connecticut General Statutes ("CGS"), and Regulations of Connecticut State Agencies ("RCSA") adopted thereunder, as amended, and Section 402(b) of the Clean Water Act, as amended, 33 USC 1251, et. seq., and pursuant to an approval dated September 26, 1973, by the Administrator of the United States Environmental Protection Agency for the State of Connecticut to administer a N.P.D.E.S. permit program.
- (B) The **City of Danbury**, ("permittee"), shall comply with all conditions of this permit including the following sections of the RCSA which have been adopted pursuant to Section 22a-430 of the CGS and are hereby incorporated into this permit. **Your attention is especially drawn to the notification requirements of subsection (i)(2), (i)(3), (j)(1), (j)(6), (j)(8), (j)(9)(C), (j)(10)(C), (j)(11)(C), (D), (E), and (F), (k)(3) and (4) and (l)(2) of Section 22a-430-3.** To the extent this permit imposes conditions more stringent than those found in the regulations, this permit shall apply.

Section 22a-430-3 General Conditions

- (a) Definitions
- (b) General
- (c) Inspection and Entry
- (d) Effect of a Permit
- (e) Duty to Comply
- (f) Proper Operation and Maintenance
- (g) Sludge Disposal
- (h) Duty to Mitigate
- (i) Facility Modifications; Notification
- (j) Monitoring, Records and Reporting Requirements
- (k) Bypass
- (l) Conditions Applicable to POTWs
- (m) Effluent Limitation Violations
- (n) Enforcement
- (o) Resource Conservation
- (p) Spill Prevention and Control
- (q) Instrumentation, Alarms, Flow Recorders
- (r) Equalization

Section 22a-430-4 Procedures and Criteria

- (a) Duty to Apply
- (b) Duty to Reapply
- (c) Application Requirements
- (d) Preliminary Review

- (e) Tentative Determination
- (f) Draft Permits, Fact Sheets
- (g) Public Notice, Notice of Hearing
- (h) Public Comments
- (i) Final Determination
- (j) Public Hearings
- (k) Submission of Plans and Specifications. Approval.
- (l) Establishing Effluent Limitations and Conditions
- (m) Case-by-Case Determinations
- (n) Permit Issuance or Renewal
- (o) Permit or Application Transfer
- (p) Permit Revocation, Denial or Modification
- (q) Variances
- (r) Secondary Treatment Requirements
- (s) Treatment Requirements
- (t) Discharges to POTWs - Prohibitions

- (C) Violations of any of the terms, conditions, or limitations contained in this permit may subject the permittee to enforcement action including, but not limited to, seeking penalties, injunctions and/or forfeitures pursuant to applicable sections of the CGS and RCSA.
- (D) Any false statement in any information submitted pursuant to this Section of the permit may be punishable as a criminal offense under Section 22a-438 or 22a-131a of the CGS or in accordance with Section 22a-6, under Section 53a-157b of the CGS.
- (E) The permittee shall comply with Section 22a-416-1 through Section 22a-416-10 of the RCSA concerning operator certification.
- (F) No provision of this permit and no action or inaction by the Commissioner shall be construed to constitute an assurance by the Commissioner that the actions taken by the permittee pursuant to this permit will result in compliance or prevent or abate pollution.
- (G) Nothing in this permit shall relieve the permittee of other obligations under applicable federal, state and local law.
- (H) An annual fee shall be paid for each year this permit is in effect as set forth in Section 22a-430-7 of the RCSA. As of October 1, 2009 the annual fee is \$3,005.00.

SECTION 2: DEFINITIONS

- (A) The definitions of the terms used in this permit shall be the same as the definitions contained in Section 22a-423 of the CGS and Section 22a-430-3(a) and 22a-430-6 of the RCSA, except for "Composite" and "No Observable Acute Effect Level (NOAEL)" which are redefined below.
- (B) In addition to the above, the following definitions shall apply to this permit:

"-----" in the limits column on the monitoring tables in Attachment 1 means a limit is not specified but a value must be reported on the DMR, MOR, and/or the ATMR.

"**Annual**" in the context of any sampling frequency, shall mean the sample must be collected in the month of July except in the case of Chronic Toxicity when the samples must be collected in the months of July, August or September.

"**Average Monthly Limit**" means the maximum allowable "Average Monthly Concentration" as defined in Section 22a-430-3(a) of the RCSA when expressed as a concentration (e.g. mg/l); otherwise, it means "Average Monthly Discharge Limitation" as defined in Section 22a-430-3(a) of the RCSA.

"**Bi-Weekly**" in the context of any sampling frequency, shall mean once every two weeks.

"**Composite**" or "(C)" means a sample consisting of a minimum of eight aliquot samples collected at equal intervals of no less than 30 minutes and no more than 60 minutes and combined proportionally to flow over the sampling period provided that during the sampling period the peak hourly flow is experienced.

"**Critical Test Concentration**" or "(CTC)" means the specified effluent dilution at which the permittee is to conduct a single-concentration Aquatic Toxicity Test.

"Daily Composite" or **"(DC)"** means a composite sample taken over a full operating day consisting of grab samples collected at equal intervals of no more than sixty (60) minutes and combined proportionally to flow; or, a composite sample continuously collected over a full operating day proportionally to flow.

"Daily Concentration" means the concentration of a substance as measured in a daily composite sample, or, arithmetic average of all grab sample results defining a grab sample average.

"Daily Quantity" means the quantity of waste discharged during an operating day.

"Geometric Mean" is the "n"th root of the product of "n" observations.

"Infiltration" means water other than wastewater that enters a sewer system (including sewer system and foundation drains) from the ground through such means as defective pipes, pipe joints, connections, or manholes. Infiltration does not include, and is distinguished from, inflow.

"Inflow" means water other than wastewater that enters a sewer system (including sewer service connections) from sources such as, but not limited to, roof leaders, cellar drains, yard drains, area drains, drains from springs and swampy areas, cross connections between storm sewers and sanitary sewers, catch basins, cooling towers, storm waters, surface runoff, street wash waters, or drainage. Inflow does not include, and is distinguished from, infiltration.

"Instantaneous Limit" means the highest allowable concentration of a substance as measured by a grab sample, or the highest allowable measurement of a parameter as obtained through instantaneous monitoring.

"In-stream Waste Concentration" or **"(IWC)"** means the concentration of a discharge in the receiving water after mixing has occurred in the allocated zone of influence.

"MGD" means million gallons per day.

"Maximum Daily Limit" means the maximum allowable "Daily Concentration" (defined above) when expressed as a concentration (e.g. mg/l), otherwise, it means the maximum allowable "Daily Quantity" as defined above, unless it is expressed as a flow quantity. If expressed as a flow quantity it means "Maximum Daily Flow" as defined in Section 22a-430-3(a) of the RCSA.

"Monthly Minimum Removal Efficiency" means the minimum reduction in the pollutant parameter specified when the effluent average monthly concentration for that parameter is compared to the influent average monthly concentration.

"NA" as a Monitoring Table abbreviation means "not applicable".

"NR" as a Monitoring Table abbreviation means "not required".

"No Observable Acute Effect Level" or **"(NOAEL)"** means any concentration equal to or less than the critical test concentration in a single concentration (pass/fail) toxicity test, conducted pursuant to Section 22a-430-3(j)(7)(A)(i) of the RCSA, demonstrating 90% or greater survival of test organisms at the CTC.

"Quarterly" in the context of any sampling frequency, shall mean sampling is required in the months of January, April, July, and October.

"Range During Sampling" or **"(RDS)"** as a sample type means the maximum and minimum of all values recorded as a result of analyzing each grab sample of; 1) a Composite Sample, or, 2) a Grab Sample Average. For those permittees with pH meters that provide continuous monitoring and recording, Range During Sampling means the maximum and minimum readings recorded with the continuous monitoring device during the Composite or Grab Sample Average sample collection.

"Range During Month" or **"(RDM)"** as a sample type means the lowest and the highest values of all of the monitoring data for the reporting month.

"Sanitary Sewage" means wastewaters from residential, commercial and industrial sources introduced by direct connection to the sewerage collection system tributary to the treatment works including non-excessive inflow/infiltration sources.

"Semiannual" in the context of any sampling frequency, shall mean the sample must be collected in the months of January and July.

"Twice per Month" in the context of any sampling frequency, mean two samples per calendar month collected no less than 12 days apart.

"ug/l" means micrograms per liter

"Work Day" in the context of a sampling frequency means, Monday through Friday excluding holidays.

SECTION 3: COMMISSIONER'S DECISION

- (A) The Commissioner of Energy and Environmental Protection ("Commissioner") has issued a final decision and found that modification of the existing system or installation of a new system would protect the waters of the state from pollution. The Commissioner's decision is based on application no. 200702097 for permit reissuance received on August 16, 2007 and the administrative record established in the processing of that application.
- (B) The Commissioner hereby authorizes the Permittee to discharge in accordance with the provisions of this permit, the above referenced application, and all approvals issued by the Commissioner or his authorized agent for the discharges and/or activities authorized by, or associated with, this permit.
- (C) The Commissioner reserves the right to make appropriate revisions to the permit, if required after Public Notice, in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the Federal Clean Water Act or the CGS or regulations adopted thereunder, as amended. Such revisions may include, but are not limited to, the potential removal of phosphorus on a year round basis. The permit as modified or renewed under this paragraph may also contain any other requirements of the Federal Clean Water Act or CGS or regulations adopted thereunder which are then applicable.

SECTION 4: GENERAL LIMITATIONS AND OTHER CONDITIONS

- (A) The Permittee shall not accept any new sources of non-domestic wastewater conveyed to its POTW through its sanitary sewerage system or by any means other than its sanitary sewage system unless the generator of such wastewater; (a) is authorized by a permit issued by the Commissioner under Section 22a-430 CGS (individual permit), or, (b) is authorized under Section 22a-430b (general permit), or, (c) has been issued an emergency or temporary authorization by the Commissioner under Section 22a-6k. All such non-domestic wastewaters shall be processed by the POTW via receiving facilities at a location and in a manner prescribed by the permittee which are designed to contain and control any unplanned releases.
- (B) No new discharge of domestic sewage from a single source to the POTW in excess of 50,000 gallons per day shall be allowed by the permittee until the permittee has notified in writing the Municipal Facilities Section of said new discharge. New discharge notifications as described in this section shall be submitted to the staff identified in section 9(H) included herein.
- (C) The permittee shall maintain a system of user charges based on sufficient to operate and maintain the POTW (including the collection system) and replace critical components.
- (D) The permittee shall maintain a sewer use ordinance that is consistent with the Model Sewer Ordinance for Connecticut Municipalities prepared by the Department of Energy and Environmental Protection. The Commissioner of Energy and Environmental Protection alone may authorize certain discharges which may not conform to the Model Sewer Ordinance.
- (E) No discharge shall contain or cause in the receiving stream a visible oil sheen, floating solids, visible discoloration, or foaming.
- (F) No discharge shall cause acute or chronic toxicity in the receiving water body beyond any Zone Of Influence (ZOI) specifically allocated to that discharge in this permit.
- (G) The permittee shall maintain an alternate power source adequate to provide full operation of all pump stations in the sewerage collection system and to provide a minimum of primary treatment and disinfection at the water pollution control facility to insure that no discharge of untreated wastewater will occur during a failure of a primary power source.
- (H) The average monthly effluent concentration shall not exceed 15% of the average monthly influent concentration for BOD₅ and Total Suspended Solids for all daily composite samples taken in any calendar month.
- (I) Any new or increased amount of sanitary sewage discharge to the sewer system is prohibited where it will cause a dry weather overflow or exacerbate an existing dry weather overflow.
- (J) Sludge Conditions

- (1) The permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices, including but not limited to 40 CFR Part 503.
 - (2) If an applicable management practice or numerical limitation for pollutants in sewage sludge more stringent than existing federal and state regulations is promulgated under Section 405(d) of the Clean Water Act (CWA), this permit shall be modified or revoked and reissued to conform to the promulgated regulations.
 - (3) The permittee shall give prior notice to the Commissioner of any change(s) planned in the permittees' sludge use or disposal practice. A change in the permittees' sludge use or disposal practice may be a cause for modification of the permit.
 - (4) Testing for inorganic pollutants shall follow "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods", EPA Publication SW-846 as updated and/or revised.
- (K) This permit becomes effective on the 1st day of the month following the date of signature.
- (L) When the arithmetic mean of the average daily flow from the POTW for the previous 180 days exceeds 90% of the design flow rate, the permittee shall develop and submit within one year, for the review and approval of the Commissioner, a plan to accommodate future increases in flow to the plant. This plan shall include a schedule for completing any recommended improvements and a plan for financing the improvements.
- (M) When the arithmetic mean of the average daily BOD₅ or TSS loading into the POTW for the previous 180 days exceeds 90% of the design load rate, the permittee shall develop and submit for the review of the Commissioner within one year, a plan to accommodate future increases in load to the plant. This plan shall include a schedule for completing any recommended improvements and a plan for financing the improvements.
- (N) On or before July 31st of each calendar year the main flow meter shall be calibrated by an independent contractor in accordance with the manufacturer's specifications. The actual record of the calibration shall be retained onsite and, upon request, the permittee shall submit to the Commissioner a copy of that record.
- (O) The permittee shall operate and maintain all processes as installed in accordance with the approved plans and specifications and as outlined in the associated operation and maintenance manual. This includes but is not limited to all preliminary treatment processes, primary treatment processes, recycle pumping processes, anaerobic treatment processes, anoxic treatment processes, aerobic treatment processes, flocculation processes, effluent filtration processes or any other processes necessary for the optimal removal of pollutants. The permittee shall not bypass or fail to operate any of the aforementioned processes without the written approval of the Commissioner.
- (P) On or before 2.5 years from issuance each anaerobic digester unit shall be sampled, in a manner approved in writing by the Commissioner, to determine the amount of grit and depth of scum blanket. The results of the sampling shall be maintained at the POTW and, upon request, the permittee shall submit to the Commissioner a copy of the sampling data.
- (Q) The permittee is hereby authorized to accept septage at the treatment facility or other locations as approved by the Commissioner.
- (R) The temperature of any discharge shall not increase the temperature of the receiving stream above 85°F, or, in any case, raise the normal temperature of the receiving stream more than 4°F.
- (S) The terms and conditions of this Permit, including but not limited to any effluent limit or similar requirement, remain in effect and enforceable until this permit expires. However, the inclusion of any such term or condition in this permit, including but not limited to any effluent limit or similar requirement, shall not be deemed or construed to be a waiver of the permittee's ability to contest such term or condition should any such term or condition be included in any subsequent permit issued by the Commissioner.

SECTION 5: SPECIFIC EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- (A) The Permittee's discharge(s) shall not exceed and shall otherwise conform to the specific terms and conditions listed in this permit. The Permittee's discharge(s) shall be restricted by, and shall be monitored in accordance with Tables A through G incorporated in this permit as Attachment 1.
- (B) The Permittee shall monitor the performance of the treatment process in accordance with the Monthly Operating Report (MOR) incorporated in this permit as Attachment 2.
- (C) Each year for the period beginning April 1st through and including October 31st (referred to in this paragraph as "the season") for discharge

(DSN) 001-1, the Permittee shall comply with the following limits, which are independent separate requirements; each being enforceable independent of the other:

- (i) the seasonal average for total phosphorus shall not exceed 0.6 mg/l. This seasonal average shall be calculated by determining the average monthly discharge of total phosphorus for each month during the season, adding the monthly averages together and dividing by 7; and
 - (ii) For no two consecutive months during the season shall the average monthly discharge for total phosphorus exceed 0.6 mg/l.
 - (iii) The total mass loading of total phosphorus during the season shall not exceed 57.08 lbs/day calculated on a seasonal average basis.
- (D) Beginning November 1, 2014 through and including March 31, 2015, the Permittee shall operate the ferric chloride treatment system at its facility to optimize removal of phosphorus.

SECTION 6: SAMPLE COLLECTION, HANDLING and ANALYTICAL TECHNIQUES

(A) Chemical Analysis

- (1) Chemical analyses to determine compliance with effluent limits and conditions established in this permit shall be performed using the methods approved pursuant to the Code of Federal Regulations, Part 136 of Title 40 (40 CFR 136) unless an alternative method has been approved in writing pursuant to 40 CFR 136.4 or as provided in Section 22a-430-3-(j)(7) of the RCSA. Chemicals which do not have methods of analysis defined in 40 CFR 136 or the RCSA shall be analyzed in accordance with methods specified in this permit.
- (2) All metals analyses identified in this permit shall refer to analyses for Total Recoverable Metal, as defined in 40 CFR 136 unless otherwise specified.
- (3) Grab samples shall be taken during the period of the day when the peak hourly flow is normally experienced.
- (4) Samples collected for bacteriological examination shall be collected between the hours of 11 a.m. and 3 p.m. or at that time of day when the peak hourly flow is normally experienced. A chlorine residual sample must be taken at the same time and the results recorded.
- (5) The Minimum Levels specified below represent the concentrations at which quantification must be achieved and verified during the chemical analyses for the parameters identified in Attachment 1, Tables A, C, and E. Analyses for these parameters must include check standards within ten percent of the specified Minimum Level or calibration points equal to or less than the specified Minimum Level.

<u>Parameter</u>	<u>Minimum Level</u>
Aluminum	0.050 mg/l
Antimony, Total	0.010 mg/l
Arsenic, Total	0.005 mg/l
Beryllium, Total	0.001 mg/l
Cadmium, Total	0.0005 mg/l
Chlorine, Total Residual	0.050 mg/l
Chromium, Total	0.005 mg/l
Chromium, Total Hexavalent	0.010 mg/l
Copper, Total	0.005 mg/l
Cyanide, Total	0.010 mg/l
Iron, Total	0.040 mg/l
Lead, Total	0.005 mg/l
Mercury, Total	0.0002 mg/l
Nickel, Total	0.005 mg/l
Phosphorus, Total	0.10 mg/l
Selenium, Total	0.005 mg/l
Silver, Total	0.002 mg/l
Thallium, Total	0.005 mg/l
Zinc, Total	0.020 mg/l

- (6) The value of each parameter for which monitoring is required under this permit shall be reported to the maximum level of accuracy and precision possible consistent with the requirements of this Section of the permit.
 - (7) Effluent analyses for which quantification was verified during the analysis at or below the minimum levels specified in this Section and which indicate that a parameter was not detected shall be reported as "less than x" where 'x' is the numerical value equivalent to the analytical method detection limit for that analysis.
 - (8) Results of effluent analyses which indicate that a parameter was not present at a concentration greater than or equal to the Minimum Level specified for that analysis shall be considered equivalent to zero (0.0) for purposes of determining compliance with effluent limitations or conditions specified in this permit.
- (B) Acute Aquatic Toxicity Test**
- (1) Samples for monitoring of Acute Aquatic Toxicity shall be collected and handled as prescribed in "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA-821-R-02-012).
 - (a) Composite samples shall be chilled as they are collected. Grab samples shall be chilled immediately following collection. Samples shall be held at 0 - 6°C until Acute Aquatic Toxicity testing is initiated.
 - (b) Effluent samples shall not be dechlorinated, filtered, or, modified in any way, prior to testing for Aquatic Toxicity unless specifically approved in writing by the Commissioner for monitoring at this facility. Facilities with effluent dechlorination and/or filtration designed as part of the treatment process are not required to obtain approval from the Commissioner.
 - (c) Samples shall be taken after dechlorination for Acute Aquatic Toxicity unless otherwise approved in writing by the Commissioner for monitoring at this facility.
 - (d) Chemical analyses of the parameters identified in Attachment 1, Table C shall be conducted on an aliquot of the same sample tested for Acute Aquatic Toxicity.
 - (i) At a minimum, pH, total alkalinity, total hardness, and total residual chlorine shall be measured in the effluent sample and, during Acute Aquatic Toxicity tests, in the highest concentration of the test and in the dilution (control) water at the beginning of the test and at test termination. If total residual chlorine is not detected at test initiation, it does not need to be measured at test termination. Dissolved oxygen, pH, and temperature shall be measured in the control and all test concentrations at the beginning of the test, daily thereafter, and at test termination.
 - (e) Tests for Acute Aquatic Toxicity shall be initiated within 36 hours of sample collection.
 - (2) Monitoring for Acute Aquatic Toxicity to determine compliance with the permit limit on Acute Aquatic Toxicity (invertebrate) shall be conducted for 48 hours utilizing neonatal (less than 24 hours old) *Daphnia pulex*.
 - (3) Monitoring for Acute Aquatic Toxicity to determine compliance with the permit limit on Acute Aquatic Toxicity (vertebrate) shall be conducted for 48 hours utilizing larval (1 to 14-day old with no more than 24 hours range in age) *Pimephales promelas*.
 - (4) Tests for Acute Aquatic Toxicity shall be conducted as prescribed for static non-renewal acute tests in "Methods for measuring the Acute Aquatic Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA/821-R-02-012), except as specified below.
 - (a) For Acute Aquatic Toxicity limits, and for monitoring only conditions, expressed as a NOAEL value, Pass/Fail (single concentration) tests shall be conducted at a specified Critical Test Concentration (CTC) equal to the Aquatic Toxicity limit, (100% in the case of monitoring only conditions), as prescribed in Section 22a-430-3(j)(7)(A)(i) of the RCSA.
 - (b) Organisms shall not be fed during the tests.
 - (c) Synthetic freshwater prepared with deionized water adjusted to a hardness of 50±5 mg/L as CaCO₃ shall be used as dilution water in the tests.
 - (d) Copper nitrate shall be used as the reference toxicant.
 - (5) For limits expressed as NOAEL = 100%, compliance shall be demonstrated when the results of a valid pass/fail Acute Aquatic

Toxicity Test indicate 90% or greater survival in the effluent sample at the CTC (100%).

(C) Chronic Aquatic Toxicity Test for Freshwater Discharges

- (1)** Chronic Aquatic Toxicity testing of the discharge shall be conducted annually during July, August, or September of each year.
- (2)** Chronic Aquatic Toxicity testing shall be performed on the discharge in accordance with the test methodology established in “Short-Term Methods for Estimating The Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms” (EPA-821-R-02-013) as referenced in 40 CFR 136 for *Ceriodaphnia* survival and reproduction and Fathead minnow larval survival and growth.
 - (a)** Chronic Aquatic Toxicity tests shall utilize a minimum of five effluent dilutions prepared using a dilution factor of 0.5 (100% effluent, 50% effluent, 25% effluent, 12.5% effluent, 6.25% effluent).
 - (b)** Limekiln Brook water collected immediately upstream of the area influenced by the discharge shall be used as control (0% effluent) and dilution water in the toxicity tests.
 - (c)** A laboratory water control consisting of synthetic freshwater prepared in accordance with EPA-821-R-02-013 at a hardness of 50±5 mg/l shall be used as an additional control (0% effluent) in the toxicity tests.
 - (d)** Daily composite samples of the discharge (final effluent following disinfection) and grab samples of Limekiln Brook, for use as site water control and dilution water, shall be collected on day 0 for test solution renewal on day 1 and day 2 of the test; day 2, for test solution renewal on day 3 and day 4 of the test; and day 4, for test solution renewal for the remainder of the test. Samples shall not be pH or hardness adjusted, or chemically altered in any way.
- (3)** All samples of the discharge and Limekiln Brook water used in the Chronic Aquatic Toxicity test shall, at a minimum, be analyzed and results reported in accordance with the provisions listed in Section 6(A) of this permit for the parameters listed in Attachment 1, Table C included herein.

SECTION 7: RECORDING AND REPORTING REQUIREMENTS

- (A)** The results of chemical analyses and any aquatic toxicity test required above in Section 5 and the referenced Attachment 1 shall be entered on the Discharge Monitoring Report (DMR) and reported to the Bureau of Water Protection and Land Reuse. The report shall also include a detailed explanation of any violations of the limitations specified. The DMR must be received at the following address by the 15th day of the month following the month in which samples are collected:

ATTN: Municipal Wastewater Monitoring Coordinator
Connecticut Department of Energy and Environmental Protection
Bureau of Water Protection and Land Reuse, Planning and Standards Division
79 Elm Street
Hartford, Connecticut 06106-5127

- (1)** For composite samples, from other than automatic samplers, the instantaneous flow and the time of each aliquot sample collection shall be recorded and maintained at the POTW.
- (B)** Complete and accurate test data, including percent survival of test organisms in each replicate test chamber, LC₅₀ values and 95% confidence intervals for definitive test protocols, and all supporting chemical/physical measurements performed in association with any aquatic toxicity test, shall be entered on the Aquatic Toxicity Monitoring Report form (ATMR) and sent to the Bureau of Water Protection and Land Reuse at the address specified above in Section 7 (A) of this permit by the 15th day of the month following the month in which samples are collected.
- (C)** The results of the process monitoring required above in Section 5 shall be entered on the Monthly Operating Report (MOR) form, included herein as Attachment 2, and reported to the Bureau of Water Protection and Land Reuse. The MOR report shall also be accompanied by a detailed explanation of any violations of the limitations specified. The MOR must be received at the address specified above in Section 7 (A) of this permit by the 15th day of the month following the month in which the data and samples are collected.
- (D)** A complete and thorough report of the results of the chronic toxicity monitoring outlined in Section 6(C) shall be prepared as outlined in Section 10 of EPA-821-R-02-013 and submitted to the Department for review on or before December 31 of each calendar year to the address specified above in Section 7 (A) of this permit.

(E) NetDMR Reporting Requirements

- (1) Unless otherwise approved in writing by the Commissioner, no later than one-hundred and twenty (120) days after the issuance of this permit, the Permittee shall begin reporting to the Department electronically using NetDMR, a web-based tool that allows Permittees to electronically submit discharge monitoring reports (DMRs) and other required reports through a secure internet connection. Specific requirements regarding subscription to NetDMR and submittal of data and reports in hard copy form and for submittal using NetDMR are described below:

(a) NetDMR Subscriber Agreement

On or before fifteen (15) days after the issuance of this permit, the Permittee and/or the person authorized to sign the Permittee's discharge monitoring reports ("Signatory Authority") as described in RCSA Section 22a-430-3(b)(2) shall contact the Department and initiate the subscription process for electronic submission of Discharge Monitoring Report (DMR) information. On or before ninety (90) days after issuance of this permit the Permittee shall submit a signed and notarized copy of the *Connecticut DEP NetDMR Subscriber Agreement* to the Department.

(b) Submittal of Reports Using NetDMR

Unless otherwise approved by the Commissioner, on or before one-hundred and twenty (120) days after issuance of this permit, the Permittee and/or the Signatory Authority shall electronically submit DMRs and reports required under this permit to the Department using NetDMR in satisfaction of the DMR submission requirement of this permit. DMRs shall be submitted electronically to the Department no later than the 15th day of the month following the completed reporting period.

(c) Submittal of NetDMR Opt-Out Requests

If the Permittee is able to demonstrate a reasonable basis, such as technical or administrative infeasibility, that precludes the use of NetDMR for electronically submitting DMRs and reports, the Commissioner may approve the submission of DMRs and other required reports in hard copy form ("opt-out request"). Opt-out requests must be submitted in writing to the Department for written approval on or before fifteen (15) days prior to the date a Permittee would be required under this permit to begin filing DMRs and other reports using NetDMR. This demonstration shall be valid for twelve (12) months from the date of the Department's approval and shall thereupon expire. At such time, DMRs and reports shall be submitted electronically to the Department using NetDMR unless the Permittee submits a renewed opt-out request and such request is approved by the Department.

All opt-out requests and requests for the NetDMR subscriber form should be sent to the following address:

Attn: NetDMR Coordinator
Connecticut Department of Energy and Environmental Protection
Water Permitting and Enforcement Division – 2nd Floor
79 Elm Street
Hartford, CT 06106-5127

SECTION 8: RECORDING AND REPORTING OF VIOLATIONS, ADDITIONAL TESTING REQUIREMENTS, BYPASSES, MECHANICAL FAILURES, AND MONITORING EQUIPMENT FAILURES

- (A) If any Acute Aquatic Toxicity sample analysis indicates that an Aquatic toxicity effluent limitation has been exceeded, or that the test was invalid, an additional sample of the effluent shall be collected and tested for Acute Aquatic Toxicity and associated chemical parameters, as described above in Section 5 and Section 6, and the results reported to the Bureau of Water Protection and Land Reuse (Attn: Aquatic Toxicity) via the ATMR form (see Section 7 (B)) within 30 days of the previous test. These test results shall also be reported on the next month's DMR report pursuant to Section 7 (A). The results of all toxicity tests and associated chemical parameters, valid and invalid, shall be reported.
- (B) If any two consecutive Acute Aquatic Toxicity test results or any three Acute Aquatic Toxicity test results in a twelve month period indicates that the Acute Aquatic Toxicity limit has been exceeded, the permittee shall immediately take all reasonable steps to eliminate toxicity wherever possible and shall submit a report, to the Bureau of Water Protection and Land Reuse (Attn: Aquatic Toxicity), for the review and written approval of the Commissioner in accordance with Section 22a-430-3(j)(10)(c) of the RCSA describing proposed steps to eliminate the toxic impact of the discharge on the receiving water body. Such a report shall include a proposed time schedule to accomplish toxicity reduction and the permittee shall comply with any schedule approved by the Commissioner.
- (C) Section 22a-430-3(k) of the RCSA shall apply in all instances of bypass including a bypass of the treatment plant or a component of the sewage collection system planned during required maintenance. The Department of Energy and Environmental Protection, Bureau of Water

Protection and Land Reuse, Planning and Standards Division, Municipal Facilities Section (860) 424-3704, the Department of Public Health, Water Supply Section (860) 509-7333 and Recreation Section (860) 509-7297, and the local Director of Health shall be notified within 2 hours of the permittee learning of the event by telephone during normal business hours. If the discharge or bypass occurs outside normal working hours (8:30 a.m. to 4:30 p.m. Monday through Friday), notification shall be made within 2 hours of the permittee learning of the event to the Emergency Response Unit at (860) 424-3338 and the Department of Public Health at (860) 509-8000. A written report shall be submitted to the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Planning and Standards Division, Municipal Facilities Section within five days of the permittee learning of each occurrence, or potential occurrence, of a discharge or bypass of untreated or partially treated sewage.

The written report shall contain:

- (a) The nature and cause of the bypass permit violation, treatment component failure, and/or equipment failure,
 - (b) the time the incident occurred and the anticipated time which it is expected to continue or, if the condition has been corrected, the duration,
 - (c) the estimated volume of the bypass or discharge of partially treated or raw sewage,
 - (d) the steps being taken to reduce or minimize the effect on the receiving waters, and
 - (e) the steps that will be taken to prevent reoccurrence of the condition in the future.
- (D) Section 22a-430-3(j) 11 (D) of the RCSA shall apply in the event of any noncompliance with a maximum daily limit and/or any noncompliance that is greater than two times any permit limit. The permittee shall notify in the same manner as in paragraph C of this Section, the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse Planning and Standards Division, Municipal Facilities Section except, if the noncompliance occurs outside normal working hours (8:30 a.m. to 4:30 p.m. Monday through Friday) the permittee may wait to make the verbal report until 10:30 am of the next business day after learning of the noncompliance.
- (E) Section 22a-430-3(j) 8 of the RCSA shall apply in all instances of monitoring equipment failures that prevent meeting the requirements in this permit. In the event of any such failure of the monitoring equipment including, but not limited to, loss of refrigeration for an auto-sampler or lab refrigerator or loss of flow proportion sampling ability, the permittee shall notify in the same manner as in paragraph C of this Section, the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Planning and Standards Division, Municipal Facilities Section except, if the failure occurs outside normal working hours (8:30 a.m. to 4:30 p.m. Monday through Friday) the permittee may wait to make the verbal report until 10:30 am of the next business day after learning of the failure.
- (F) In addition to the reporting requirements contained in Section 22a-430-3(i), (j), and (k) of the Regulations of Connecticut State Agencies, the permittee shall notify in the same manner as in paragraph C of this Section, the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Planning and Standards Division, Municipal Facilities Section concerning the failure of any major component of the treatment facilities which the permittee may have reason to believe would result in an effluent violation.

SECTION 9: COMPLIANCE SCHEDULES

- (A) The permittee shall comply with the following requirements of this permit regarding **phosphorus** for DSN 001-1, in accordance with the following schedule:
- (1) Beginning April 1, 2015, the permittee shall comply with the total phosphorus limit **identified in footnotes 5 and 6 of Table A of this permit as Total Phosphorus (A)**.
 - (2) On or before **December 15, 2017** the permittee shall retain one or more qualified consultants acceptable to the Commissioner to prepare the documents and implement or oversee the actions required by this permit and shall, by that date, notify the Commissioner in writing of the identity of such consultant(s). The municipality shall retain one or more qualified consultants acceptable to the Commissioner until this permit is fully complied with, and, within ten days after retaining any consultant other than the one originally identified under this paragraph, the municipality shall notify the Commissioner in writing of the identity of such other consultant. The consultant(s) retained shall be a qualified professional engineer licensed to practice in Connecticut. The permittee shall submit to the Commissioner a description of a consultant's education, experience and training which is relevant to the work required by this permit within ten days after a request for such a description. Nothing in this paragraph shall preclude the Commissioner from finding a previously acceptable consultant unacceptable.
 - (3) On or before **October 31, 2018**, the permittee shall submit to the Commissioner for his review and written approval a comprehensive and thorough engineering report which: a) evaluates the alternatives to achieve compliance with the limits identified in Table A of this

permit as Total Phosphorus(B) and Total Phosphorus (C); b) states in detail the most expeditious schedule for performing each alternative; c) lists all permits and approvals required for each alternative, including but not limited to, any permits required under sections 22a-32, 22a-42a, 22a-342, 22a-361, 22a-368 or 22a-430 of the Connecticut General Statutes; d) proposes a preferred alternative with supporting justification therefor; and e) proposes a detailed program and schedule to carry out the preferred alternative, including but not limited to, a schedule for applying for and obtaining all permits and approvals required for such alternative. The schedule shall provide for completion of all actions necessary to achieve compliance with the limits identified in Table A of this permit as Total Phosphorus (B) and Total Phosphorus (C), as soon as possible, but in no event later than **April 1, 2022**.

- (4) Unless another deadline is specified in writing by the Commissioner, on or before **three hundred sixty-five (365) days** after the Commissioner's written approval of the report described in the preceding paragraph, the permittee shall (1) submit for the Commissioner's review and written approval, contract plans and specifications to implement the alternative approved in writing by the Commissioner to achieve compliance with the limits identified in Table A of this permit as Total Phosphorus (B) and Total Phosphorus (C); and (2) submit applications for all permits and approvals required under Sections 22a-32, 22a-42a, 22a-342, 22a-361, 22a-368 or 22a-430 of the Connecticut General Statutes to implement the alternative approved in writing by the Commissioner to achieve compliance with the limits identified in Table A of this permit as Total Phosphorus(B) and Total Phosphorus (C). The permittee shall use best efforts to obtain all required permits and approvals.
 - (5) In accordance with the schedule approved in writing by the Commissioner, but in no event later than **April 1, 2020**, the permittee shall begin construction of the contract plans and specifications approved in writing by the Commissioner to achieve compliance with the limits identified in Table A of this permit as Total Phosphorus (B) and Total Phosphorus (C). Within fifteen days after beginning such actions, the permittee shall certify to the Commissioner in writing that construction, as required by this paragraph, has begun.
 - (6) In accordance with the schedule approved in writing by the Commissioner, but in no event later than **April 1, 2022**, the permittee shall complete the actions approved in writing by the Commissioner necessary to achieve compliance with the limits identified in Table A of this permit as Total Phosphorus (B) and Total Phosphorus (C). Within fifteen days after completing such actions, the permittee shall certify to the Commissioner in writing that such actions, as required by this paragraph, have been completed.
 - (7) The permittee may request that the Commissioner approve, in writing, revisions to any document previously approved by the Commissioner hereunder in order to make such document consistent with law or for any other appropriate reason.
- (B) The permittee shall comply with the following requirements of this permit regarding **Escherichia coli** for DSN 001-1, in accordance with the following:
- (1) On or before **300 days** after the date of issuance of this permit, the permittee shall submit for the Commissioner's review and written approval a comprehensive and thorough report which describes the actions to be taken by the permittee necessary to achieve compliance with the requirements for **Escherichia coli** in Table A of this permit. Such report shall include a schedule for implementation of such actions not to exceed **730 days** after the date of issuance of this permit.
 - (2) In accordance with the schedule approved in writing by the Commissioner, but in no event later than **730 days** after the date of issuance of this permit, the permittee shall perform the actions approved in writing by the Commissioner necessary to comply with the requirements for **Escherichia coli** in Table A of this permit. Within fifteen days after completing such actions, the permittee shall certify to the Commissioner in writing that the actions have been completed as approved by the Commissioner.
 - (3) If prior to the date in the schedule approved by the Commissioner for the permittee to comply with the requirements in Table A of this permit for **Escherichia coli**, or **730 days** after the date of issuance of this permit, whichever is sooner, the permittee monitors for **Escherichia coli**, this permit does not require that the permittee submit such monitoring results to the Commissioner and any such monitoring results shall not constitute "implementation of E. Coli monitoring" under Footnote 4 in Table A of this permit".
- (C) With respect to the requirements of paragraph 9(A) of this section the permittee shall submit quarterly status reports to the Commissioner beginning sixty days after the date of approval of the report referenced in paragraph 9(A) (3) of this Section. With respect to the requirements of paragraph 9(B) of this Section, the permittee shall submit quarterly status reports to the Commissioner beginning sixty days after the date of approval of the report referenced in paragraph 9(B)(1) of this Section. Status reports shall include, but not be limited to, a detailed description of progress made by the permittee in performing actions required by Section 9(A) or 9(B), as applicable, in accordance with the approved schedule including, but not limited to, development of engineering plans and specifications, construction activity, contract bidding, operational changes, preparation and submittal of permit applications, and any other actions required under paragraph 9(A) or 9(B), respectively, of this Section.

- (D) In addition to the requirements in Section 5(D) of this permit, the permittee shall comply with the following requirements regarding the potential operation of system for removal phosphorus during the entire year:
- (1) On or before October 15, 2014, the Permittee shall submit for the Commissioner's review and written approval a scope of study describing how the Permittee will evaluate the efficacy of operating its ferric chloride treatment system on a year round basis for removal of phosphorus. The report shall describe the method for removal of phosphorus, if chemical addition is used, a method for tracking the amount of chemical added and maintaining a record of the amount of chemical added, and how sampling will be performed to determine the efficacy of year round treatment. The scope of study shall include a schedule for the taking of all actions necessary for the study. The permittee shall implement the report as approved by the Commissioner.
 - (2) On or before May 31, 2015, and at any other time specified in the approved scope of study, the permittee shall submit a report to the Commissioner evaluating the efficacy of operating the ferric chloride treatment system currently at the permittee's facility for removal of phosphorus on a year round basis. The report shall at a minimum comply with the requirements of the preceding paragraph.
- (E) The permittee shall use best efforts to submit to the Commissioner all documents required by this Section of the permit in a complete and approvable form. If the Commissioner notified the permittee that any document or other action is deficient, and does not approve it with conditions or modifications, it is deemed disapproved, and the permittee shall correct the deficiencies and resubmit it within the time specified by the Commissioner or, if no time is specified by the Commissioner, within thirty days of the Commissioner's notice of deficiencies. In approving any document or other action under this Compliance Schedule, the Commissioner may approve the document or other action as submitted or performed or with such conditions or modifications as the Commissioner deems necessary to carry out the purposes of this Section of the permit. Nothing in this paragraph shall excuse noncompliance or delay.
- (F) Dates. The date of submission to the Commissioner of any document required by this section of the permit shall be the date such document is received by the Commissioner. The date of any notice by the Commissioner under this section of the permit, including but not limited to notice of approval or disapproval of any document or other action, shall be the date such notice is personally delivered or the date three days after it is mailed by the Commissioner, whichever is earlier. Except as otherwise specified in this permit, the word "day" as used in this Section of the permit means calendar day. Any document or action which is required by this Section only of the permit, to be submitted, or performed, by a date which falls on, Saturday, Sunday, or a Connecticut or federal holiday, shall be submitted or performed on or before the next day which is not a Saturday, Sunday, or Connecticut or federal holiday.
- (G) Notification of noncompliance. In the event that the permittee becomes aware that it did not or may not comply, or did not or may not comply on time, with any requirement of this Section of the permit or of any document required hereunder, the permittee shall immediately notify the Commissioner and shall take all reasonable steps to ensure that any noncompliance or delay is avoided or, if unavoidable, is minimized to the greatest extent possible. In so notifying the Commissioner, the permittee shall state in writing the reasons for the noncompliance or delay and propose, for the review and written approval of the Commissioner, dates by which compliance will be achieved, and the permittee shall comply with any dates which may be approved in writing by the Commissioner. Notification by the permittee shall not excuse noncompliance or delay, and the Commissioner's approval of any compliance dates proposed shall not excuse noncompliance or delay unless specifically so stated by the Commissioner in writing.
- (H) Notice to Commissioner of changes. Within fifteen days of the date the permittee becomes aware of a change in any information submitted to the Commissioner under this Section of the permit, or that any such information was inaccurate or misleading or that any relevant information was omitted, the permittee shall submit the correct or omitted information to the Commissioner.
- (I) Submission of documents. Any document, other than a DMR, ATMR or MOR required to be submitted to the Commissioner under this Section of the permit shall, unless otherwise specified in writing by the Commissioner, be directed to:

Stacy Pappano
Department of Energy and Environmental Protection
Bureau of Water Protection and Land Reuse, Planning and Standards Division
79 Elm Street
Hartford, Connecticut 06106-5127

This permit is hereby issued on

Betsey Wingfield
Bureau Chief
Bureau of Water Protection and Land Reuse

ATTACHMENT 1

Tables A through H

DRAFT

TABLE A

Discharge Serial Number (DSN): 001-1					Monitoring Location: 1					
Wastewater Description: Sanitary Sewage										
Monitoring Location Description: Final Effluent										
Allocated Zone of Influence (ZOI): 3.15 cfs					In-stream Waste Concentration (IWC): 88.4 %					
PARAMETER	Units	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			REPORT FORM	Minimum Level Analysis See Section 6
		Average Monthly Limit	Maximum Daily Limit	Sample Freq.	Sample type	Instantaneous Limit or Required Range ²	Sample Freq.	Sample Type		
Alkalinity	mg/l	NA	NA	NR	NA	-----	Monthly	Grab	MOR	
Biochemical Oxygen Demand (5 day), See remark E October 1 st – June 30 th July 1 st – September 30 th	mg/l	30 20	50 30	3/Week	Daily Composite	NA	NR	NA	DMR/MOR	
Chlorine, Total Residual, See remark A May 1 st through September 30 th	mg/l	0.01	0.02	4/Work Day	Grab	≤ 0.04	4/ Work Day	Grab	DMR/MOR	
Copper, Total	mg/l	0.019	0.029	Weekly	Daily Composite	NA	NA	NA	DMR/MOR	*
Lead, Total	kg/d	0.070	0.117	Weekly	Daily Composite	NA	NA	NA	DMR/MOR	*
Fecal coliform (May 1 st through September 30 th) ³	Colonies per100 ml	NA	NA	NR	NA	200 and 400 see remarks (B) and (C) below	3/Week	Grab	DMR/MOR	
Escherichia coli (May 1 st through September 30 th) ⁴ see remark (D) below	Colonies per100 ml	NA	NA	NR	NA	≤410	3/Week	Grab	DMR/MOR	
Flow	MGD	-----	-----	Continuous ¹	Average Daily Flow	NA	NR	NA	DMR/MOR	
Nitrogen, Ammonia (total as N) January - April May June July - September October November - December	mg/l	4.0 1.9 1.7 1.5 1.9 4.0	-----	3/Week	Daily Composite	NA	NR	NA	DMR/MOR	
Nitrogen, Nitrate (total as N)	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	

Nitrogen, Nitrite (total as N)	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Total Kjeldahl	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Total	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Total	lbs/day	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Oxygen, Dissolved	mg/l	NA	NA	NR	NA	≥ 6.0	Work Day	Grab	DMR/MOR	
pH	S.U.	NA	NA	NR	NA	6 – 9	Work Day	Grab	DMR/MOR	
Phosphate, Ortho	mg/l	NA	-----	Weekly	Daily Composite	NA	NR	NA	MOR	
Phosphorus, Total November 1 st , 2014 through March 30 th , 2015	mg/l	-----	-----	2/Week	Daily Composite	NA	NA	NA	MOR	
Phosphorus (A), Total ^{5/6} April 1 st through October 31 st See Remark F November 1 st through March 30 th	mg/l	----- NA	NA -----	2/Week Monthly	Daily Composite	NA	NR	NA	DMR/MOR	
Phosphorus (B), Total ⁷ April 1 st through October 31 st November 1 st through March 30 th	mg/l	0.14 NA	0.31 -----	2/Week Monthly	Daily Composite	NA	NR	NA	DMR/MOR MOR	
Phosphorus, Total April 1 st through October 31 st November 1 st through March 30 th	lbs/day	----- NA	----- -----	2/Week Monthly	Daily Composite	NA	NA	NA	DMR/MOR MOR	
Phosphorus (C), Total (Average Seasonal Load Cap) ⁸ October	lbs/day	-----	NA	2/Week	Calculated	NA	NA	NA	DMR/MOR	
Solids, Settleable	ml/l	NA	NA	NR	NA	-----	Work Day	Grab	MOR	
Solids, Total Suspended, See remark e	mg/l	30	50	3/Week	Daily Composite	NA	NA	NA	DMR/MOR	
Temperature	°F	NA	NA	NR	NA	-----	Work Day	Grab	MOR	
Turbidity	NTU	NA	NA	NR	NA	-----	Work Day	Grab	MOR	
Zinc, Total	mg/l	0.053	0.080	Weekly	Daily Composite	NA	NA	NA	DMR/MOR	*

TABLE A – CONDITIONS

Footnotes:

- ¹ The permittee shall record and report on the monthly operating report the minimum, maximum and total flow for each day of discharge and the average daily flow for each sampling month. The permittee shall report, on the discharge monitoring report, the average daily flow and maximum daily flow for each sampling month.
- ² The instantaneous limits in this column are maximum limits except for Dissolved Oxygen which is a minimum limit and pH which is a range of 6 to 9.
- ³ During the period beginning at the date of issuance of this permit and lasting until the implementation of Escherichia coli monitoring, the discharge shall not exceed and shall otherwise conform to specific terms and conditions listed for fecal coliform.
- ⁴ During the period beginning after the implementation of Escherichia coli monitoring, which may be before but no later than **730** days after permit issuance, lasting until expiration, the discharge shall also not exceed and shall otherwise conform to the specific terms and conditions listed for Escherichia coli.

⁵ From April 1st through and including October 31st of each year, in no two consecutive months shall the average monthly limit exceed **0.6 mg/l**.

TABLE A – CONDITIONS (continued)

⁶ From April 1st through and including October 31st of each year (“the season”), the seasonal average shall not exceed **0.6 mg/l**. The seasonal average shall be calculated by determining the average monthly discharge of total phosphorus for each month of the season (April through and including October) adding the average monthly discharges together and dividing by 7.

⁷ This limit shall be effective beginning **April 1, 2022**.

⁸ This limit shall be effective beginning **April 30, 2022**. The Average Seasonal Load Cap shall be calculated as follows: The permittee's discharge shall not exceed the total phosphorus Average Seasonal **Load Cap of 7.55 lb/day of total phosphorus per day for any two consecutive calendar years or any two of three consecutive calendar years.**

Remarks:

- (A) The use of chlorine for disinfection and sulphur dioxide for dechlorination shall be discontinued from October 1st through April 30th except that chlorination and dechlorination equipment may be started and tested no earlier than April 15th, and any residual chlorine gas or liquid and sulphur dioxide may be used up until, but no later than, October 15th. During these times in April and October the total residual chlorine of the effluent shall not be greater than **0.04 mg/l**, as an instantaneous limit, and **0.02 mg/l**, as a maximum daily limit. The analytical results shall be reported on the MOR for the months of April and October.
- (B) The geometric mean of the Fecal coliform bacteria values for the effluent samples collected in a period of thirty (30) consecutive days during the period from May 1st through September 30th shall not exceed 200 per 100 milliliters.
- (C) The geometric mean of the Fecal coliform bacteria values for the effluent samples collected in a period of seven (7) consecutive days during the period from May 1st through September 30th shall not exceed 400 per 100 milliliters.
- (D) The geometric mean of the Escherichia coli bacteria values for the effluent samples collected in a period of thirty (30) consecutive days during the period from May 1st through September 30th shall not exceed 126 per 100 milliliters.
- (E) The Average Weekly discharge Limitation for BOD₅ and Total Suspended Solids shall be 1.5 times the Average Monthly Limit listed above.
- (F) The limits for Total Phosphorus (A) in footnotes 5 and 6 are separate and independent requirements; each is enforceable independent of the other.

TABLE B

Discharge Serial Number (DSN): 001-1			Monitoring Location: K		
Wastewater Description: Sanitary Sewage					
Monitoring Location Description: Final Effluent					
Allocated Zone of Influence (ZOI): 3.15 cfs			In-stream Waste Concentration (IWC): 88.4%		
PARAMETER	Units	FLOW/TIME BASED MONITORING			REPORT FORM
		Average Monthly Minimum	Sample Freq.	Sample type	
Biochemical Oxygen Demand (5 day) Percent Removal ¹	% of Influent	85	3/Week	Calculated ²	DMR/MOR
Solids, Total Suspended Percent Removal ¹	% of Influent	85	3/Week	Calculated ²	DMR/MOR
TABLE B – CONDITIONS					
Footnotes:					
¹ The discharge shall be less than or equal to 15% of the average monthly influent BOD ₅ and total suspended solids (Table E, Monitoring Location G).					
² Calculated based on the average monthly results described in Table A. Removal efficiency = $\frac{\text{Inf. BOD or TSS} - \text{Effluent BOD or TSS}}{\text{Inf. BOD or TSS}} \times 100$					

TABLE C

Discharge Serial Number (DSN): 001-1			Monitoring Location: T			
Wastewater Description: Sanitary Sewage						
Monitoring Location Description: Final Effluent after dechlorination						
Allocated Zone of Influence (ZOI): 3.15 cfs			In-stream Waste Concentration (IWC): 88.40 %			
PARAMETER	Units	Maximum Daily Limit	Sampling Frequency	Sample Type	Reporting form	Minimum Level Analysis See Section 6
Aluminum, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Antimony, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
NOAEL Static 48Hr Acute D. Pulex ¹ NOAEL=100%	% survival	≥90%	Quarterly	Daily Composite	ATMR/DMR	
NOAEL Static 48Hr Acute Pimephales ¹ NOAEL=100%	% survival	≥90%	Quarterly	Daily Composite	ATMR/DMR	
Arsenic, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Beryllium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
BOD ₅	mg/l	-----	Quarterly	Daily Composite	ATMR	
Cadmium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Chromium, Hexavalent	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Chromium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Chlorine, Total Residual	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Copper, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Cyanide, Amenable	mg/l	-----	Quarterly	Daily Composite	ATMR	
Cyanide, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Iron, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Lead, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Mercury, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Nickel, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Nitrogen, Ammonia (total as N)	mg/l	-----	Quarterly	Daily Composite	ATMR	
Nitrogen, Nitrate, (total as N)	mg/l	-----	Quarterly	Daily Composite	ATMR	
Nitrogen, Nitrite, (total as N)	mg/l	-----	Quarterly	Daily Composite	ATMR	
Phosphorus, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	
Phenols, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	
Selenium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Silver, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Suspended Solids, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	
Thallium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
Zinc, Total	mg/l	-----	Quarterly	Daily Composite	ATMR	*
TABLE C - CONDITIONS						
Remarks: ¹ The results of the Toxicity Tests are recorded in % survival. The permittee shall report % survival on the DMR based on criteria in Section 6(B) of this permit.						
ATMR – Aquatic Toxicity Monitoring Report						

TABLE D

Discharge Serial Number: 001-1		Monitoring Location: N		
Wastewater Description: Activated Sludge (secondary treatment)				
Monitoring Location Description: Each Aeration Unit				
PARAMETER	REPORTING FORMAT	INSTANTANEOUS MONITORING		REPORTING FORM
		Sample Frequency	Sample Type	
Oxygen, Dissolved	High & low for each WorkDay	4/WorkDay	Grab	MOR
Sludge Volume Index	WorkDay	WorkDay	Grab	MOR
Mixed Liquor Suspended Solids	WorkDay	WorkDay	Grab	MOR

TABLE E

Discharge Serial Number: 001-1			Monitoring Location: G				
Wastewater Description: Sanitary Sewage							
Monitoring Location Description: Influent							
PARAMETER	Units	DMR REPORTING FORMAT	FLOW/TIME BASED MONITORING		INSTANTANEOUS MONITORING		REPORTING FORM
			Sample Frequency	Sample Type	Sample Frequency	Sample Type	
Biochemical Oxygen Demand (5 day)	mg/l	Monthly average	3/Week	Daily Composite	NA	NA	DMR/MOR
Copper, Total	mg/l	Monthly average and maximum day	Weekly	Daily Composite	NA	NA	MOR
Lead, Total	mg/l		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Ammonia (total as N)	mg/l		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Nitrate (total as N)	mg/l		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Nitrite (total as N)	mg/l		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Total Kjeldahl	mg/l		Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Total	mg/l		Monthly	Daily Composite	NA	NA	MOR
Phosphate, Ortho	mg/l		Monthly	Daily Composite	NA	NA	MOR
Phosphorus, Total	mg/l		Monthly	Daily Composite	NA	NA	MOR
pH	S.U.		NA	NA	Work Day	Grab	MOR
Solids, Total Suspended	mg/l	Monthly average	3/Week	Daily Composite	NA	NA	DMR/MOR
Temperature	°F		NA	NA	Work Day	Grab	MOR
Zinc, Total	mg/l	Monthly average and maximum day	Weekly	Daily Composite	NA	NA	MOR

TABLE F

Discharge Serial Number: 001-1			Monitoring Location: P				
Wastewater Description: Primary Effluent							
Monitoring Location Description: Primary Sedimentation Basin Effluent							
PARAMETER	Units	REPORTING FORMAT	TIME/FLOW BASED MONITORING		INSTANTANEOUS MONITORING		REPORTING FORM
			Sample Frequency	Sample Type	Sample Frequency	Sample type	
Alkalinity, Total	mg/l	Monthly	NA	NA	Monthly	Grab	MOR
Biochemical Oxygen Demand (5 day)	mg/l	Monthly average	Weekly	Composite	NA	NA	MOR
Nitrogen, Ammonia (total as N)	mg/l		Monthly	Composite	NA	NA	MOR
Nitrogen, Nitrate (total as N)	mg/l		Monthly	Composite	NA	NA	MOR
Nitrogen, Nitrite (total as N)	mg/l		Monthly	Composite	NA	NA	MOR
Nitrogen, Total Kjeldahl	mg/l		Monthly	Composite	NA	NA	MOR
Nitrogen, Total	mg/l		Monthly	Composite	NA	NA	MOR
pH	S.U.		NA	NA	Work Day	Grab	MOR
Solids, Total Suspended	mg/l	Monthly average	Weekly	Composite	NA	NA	MOR

TABLE G

Discharge Serial Number: 001-1		Monitoring Location: SL	
Wastewater Description: Dewatered Sludge			
Monitoring Location Description: At dewatered sludge draw off			
PARAMETER	INSTANTANEOUS MONITORING		REPORTING FORM
	Units	Grab Sample Freq.	
Arsenic, Total	mg/kg	Bi-monthly	DMR
Beryllium, Total	mg/kg	Bi-monthly	DMR
Cadmium, Total	mg/kg	Bi-monthly	DMR
Chromium, Total	mg/kg	Bi-monthly	DMR
Copper, Total	mg/kg	Bi-monthly	DMR
Lead, Total	mg/kg	Bi-monthly	DMR
Mercury, Total	mg/kg	Bi-monthly	DMR
Nickel, Total	mg/kg	Bi-monthly	DMR
Nitrogen, Ammonia *	mg/kg	Bi-monthly	DMR*
Nitrogen, Nitrate (total as N) *	mg/kg	Bi-monthly	DMR*
Nitrogen, Organic *	mg/kg	Bi-monthly	DMR*
Nitrogen, Nitrite (total as N) *	mg/kg	Bi-monthly	DMR*
Nitrogen, Total *	mg/kg	Bi-monthly	DMR*
pH *	S.U.	Bi-monthly	DMR*
Polychlorinated Biphenyls	mg/kg	Bi-monthly	DMR
Solids, Fixed	%	Bi-monthly	DMR
Solids, Total	%	Bi-monthly	DMR
Solids, Volatile	%	Bi-monthly	DMR
Zinc, Total	mg/kg	Bi-monthly	DMR
<p>(*) required for composting or land application only Testing for inorganic pollutants shall follow “Test Methods for Evaluating Solid Waste, Physical/Chemical Methods”, EPA Publication SW-846 as updated and/or revised.</p>			

TABLE H

Discharge Serial Number: 001-1	Monitoring Location: L		
Wastewater Description: Digested sludge			
Monitoring Location Description: Each Anaerobic Digestion Unit			
PARAMETER	INSTANTANEOUS MONITORING		REPORTING FORM
	Sample Frequency	Sample Type	
Temperature	Weekly	Grab	MOR
Alkalinity	Weekly	Grab	MOR
Volatile Acids	Weekly	Grab	MOR
pH	Weekly	Grab	MOR

ATTACHMENT 2
MONTHLY OPERATING REPORT FORM

DRAFT

DATA TRACKING AND TECHNICAL FACT SHEET

Permittee: City of Danbury

PERMIT, ADDRESS, AND FACILITY DATA

PERMIT #: CT0100145 APPLICATION #: 200702097 FACILITY ID. 034-001

Mailing Address: City of Danbury Street: 155 Deer Hill Road City: Danbury ST: CT Zip: 06810 Contact Name: David Day Phone No.: 203-797-4539	Location Address: Street: Newtown Road City: Danbury ST: CT Zip: 06810 Contact Name: Walter Royals (Veolia Water) Phone No.: 203-748-9116
---	---

DMR/MOR contact information: Walter Royals, Veolia Water (203) 748-9116
walter.roys@veoliawaterna.com

PERMIT INFORMATION

DURATION 5 YEAR 10 YEAR ___ 30 YEAR ___

TYPE New ___ Reissuance Modification ___

CATEGORIZATION POINT (X) NON-POINT () GIS #

NPDES (X) PRETREAT () GROUND WATER(UIC) () GROUND WATER (OTHER) ()

NPDES MAJOR(MA)

NPDES SIGNIFICANT MINOR or PRETREAT SIU (SI) ___

NPDES or PRETREATMENT MINOR (MI) ___

COMPLIANCE SCHEDULE YES NO ___

POLLUTION PREVENTION ___ TREATMENT REQUIREMENT ___

WATER QUALITY REQUIREMENT ___ OTHER ___

OWNERSHIP CODE

Private ___ Federal ___ State ___ Municipal (town only) Other public ___

DEP STAFF ENGINEER Stacy Pappano

PERMIT FEES

Discharge Code	DSN Number	Annual Fee
111000g	001	\$3,005.00

FOR NPDES DISCHARGES

Drainage Basin Code: 6606 Water Quality Classification Goal: B Segment: 6606-00-3

NATURE OF BUSINESS GENERATING DISCHARGE

Municipal Sanitary Sewage Treatment

PROCESS AND TREATMENT DESCRIPTION (by DSN)

Secondary treatment with denitrification and seasonal disinfection

RESOURCES USED TO DRAFT PERMIT

- Federal Effluent Limitation Guideline 40CFR 133* Secondary Treatment Category
- Performance Standards*
- Federal Development Document* name of category
- Department File Information*
- Connecticut Water Quality Standards*
- Anti-degradation Policy*
- Coastal Management Consistency Review Form*
- Other - Explain*

BASIS FOR LIMITATIONS, STANDARDS OR CONDITIONS

- Secondary Treatment (Section 22a-430-4(r) of the Regulations of Connecticut State Agencies)*
- Case-by-Case Determination (See Other Comments)*
- In order to meet in-stream water quality (See General Comments)*
- Anti-degradation policy*

GENERAL COMMENTS

The City of Danbury (“Danbury”) operates a municipal water pollution control facility (“the facility”) located at Newtown Road, Danbury. The facility is designed to treat and discharge up to 15.5 million gallons a day of effluent into Limekiln Brook. The facility currently uses advanced biological treatment, including denitrification and seasonal chlorine disinfection with dechlorination to treat effluent before being discharged. Pursuant to Conn. Gen. Stat. § 22a-430, the Department of Energy and Environmental Protection (“the Department”) has issued Danbury a permit for the discharge from this facility. Danbury has submitted an application to renew its permit. The Department has made a tentative determination to approve Danbury’s application and has prepared a draft permit consistent with that determination.

The most significant changes from the current permit are the addition of: chronic aquatic toxicity testing, limits on e. coli and limits on total phosphorus along with a compliance schedule for implementation of improvements to meet those new limits.

SPECIFIC REQUIREMENTS OR REVISIONS

The Department reviewed the application for consistency with Connecticut’s Water Quality Standards and determined that with the limits in the draft permit, including those discussed below, that the draft permit is consistent with maintenance and protection of water quality in accordance with the Tier I Anti-degradation Evaluation and Implementation Review provisions of such Standards.

The need for inclusion of water quality based discharge limitations in this permit was evaluated consistent with Connecticut Water Quality Standards and criteria, pursuant to 40 CFR 122.44(d). Danbury discharge monitoring

data was evaluated for consistency with the available aquatic life criteria (acute and chronic) and human health (fish consumption only) criteria. In addition to this review, the statistical procedures outlined in the EPA Technical Support Document for Water Quality-based Toxics Control (EPA/505/2-90-001) were employed to calculate the need for such limits. Comparison of monitoring data (see attached) and its inherent variability with the calculated water quality based limits indicates a statistical probability of exceeding such limits. Therefore, water quality based limits for **lead** are included in the draft permit.

Permit limits for copper, zinc, chlorine, and ammonia were derived from the Total Maximum Daily Load (TMDL) established by the Department for segment of Limekiln Brook not meeting water quality standards, pursuant to the requirements of Section 303(d) of the Federal Clean Water Act. The TMDL includes a waste load allocation (WLA) to the Danbury Water Pollution Control Facility ("WPCF") for each of the aforementioned parameters. These permit limits were calculated from the waste load allocations consistent with EPA's Technical Support Document for Water Quality-based Toxics Control (EPA/505/2-90-001). Limits are expressed in the permit as concentrations for all parameters based on the long-term average treatment plant performance required to consistently meet the wasteload allocation for each parameter. Mass limits were converted to concentration units by dividing the calculated mass limit by the critical treatment plant flow used to develop the TMDL (13.15cfs for WLA that apply year round and 14.06cfs for WLA that apply during the winter only). Past monitoring data submitted by the Danbury WPCF was used to estimate expected variability in effluent quality (coefficient of variation (CV) = 0.3 for copper and zinc; CV = 1.2 for ammonia). Limits for ammonia included in the previous permit were more restrictive than TMDL/WLA – based limits for the period June through September. These limits were retained in this permit as required by the anti-backsliding provisions in section 22a-430-4(1)(4)(A) of the Regulations of Connecticut State Agencies.

The draft permit also includes performance-based limits for chlorine reflecting the expected operation of the dechlorination system from May 1st through and including September 30th each year. The Department considers compliance with the performance-based limits for chlorine sufficient to meet the WLA for chlorine established in the TMDL.

Another condition is included in this permit:

Minimum Levels (ML) are established for several parameters noted with an asterisk in Table C of the draft permit that require the use of sensitive analytical methods and clean sampling techniques for monitoring effluent quality.

A compliance schedule is included for the reduction of phosphorus in the effluent as follows:

Currently, the facility discharges into a portion of Limekiln Brook that has been identified on Connecticut's List of Waters Not Meeting Water Quality Standards. Nutrient enrichment is a contributing cause of the impairment to this portion of Limekiln Brook. To address this impairment, the Department developed an interim nutrient management strategy for freshwater non-tidal streams. The strategy focuses on phosphorus, since phosphorus is the primary limiting nutrient in freshwater systems. The draft permit includes a compliance schedule that will reduce phosphorus in the effluent from the facility in two steps. The initial step, beginning in 2013, is for Danbury to meet a limit applicable during April through and including October. The limit, calculated over the season, is 0.6mg/l per month and in addition, during this season, Danbury's average monthly discharge cannot exceed 0.6 mg/l for two consecutive months. The Department anticipates that Danbury will continue chemical treatment to meet this initial limit. The second step provides Danbury nine years to plan, design and construct additional facility improvements to meet a more stringent water quality standard based limit discussed below.

This compliance schedule should provide environmental benefits. Currently, the facility has a varying seasonal limit on phosphorus in its effluent. As such, the initial technology-based limit noted above, will result in a meaningful reduction in the amount of phosphorus being discharged into Limekiln Brook by the facility. Providing this level of phosphorus removal now and allowing an extended schedule to meet a more stringent water quality standards based limits provides an environmental benefit significantly above that had the Department not imposed any interim limit and required the more stringent limit to be met within one permit cycle.

This environmental benefit will also be achieved in a timely manner. Danbury is part of a coalition of towns that have reached agreement on a schedule that will result in environmental improvements. The benefits of this

agreement mean that real reductions in the amount of phosphorus discharged into Limekiln Brook will not be delayed by administrative hearings and possibly other legal action.

The Department also notes that the proposed compliance schedule is site specific; it is based upon and limited to the particular circumstances present in this situation. It is not, and is not intended to be, a blueprint for any other facility. Rather, the Department will assess the need for and propose the use of a compliance schedule based on the particular circumstances of each situation. In this situation, for reasons discussed in this fact sheet, the proposed compliance schedule is warranted.

The lower water quality standard based limits for phosphorus was calculated in the following manner:

A nutrient watershed analysis was conducted for the Limekiln Brook watershed that indicated significant phosphorus loading contributions from the Danbury WPCF into the river. The seasonal (April 1st through October 31st) nutrient loading from this facility discharging to the watershed was reduced to achieve an enrichment factor of 8.4 or lower throughout the brook. An EF is representative of the amount of anthropogenic phosphorus loading to river and streams. It is calculated by dividing the current total seasonal phosphorus load by a modeled total phosphorus load under complete forested conditions at a particular point along the river. The goal of an 8.4 enrichment factor represents a threshold at which a significant change is seen in the algal communities indicating highly enriched conditions and impacts to aquatic life uses.

The current enrichment factor at the Danbury WPCF discharge is 89.8. The final proposed seasonal load allocation for Danbury WPCF is 7.55 lbs/day. This load equates to a proposed treatment performance limit of 0.10 mg/l multiplied by the current seasonal average flow of 9.05 MGD.

This limit is consistent with the narrative policy statements in the CT WQS (Paragraph 19, page 6 and SURFACE WATER CLASSIFICATIONS AND CRITERIA, CLASS B DESIGNATED USES AND CRITERIA, page 12) and where the facility discharges its effluent is expected to result in the attainment and maintenance of all designated uses for that portion of Limekiln Brook. If the Department develops numeric criteria in the future, or it is found that the current limit is not sufficient to achieve designated uses, the facility may need to meet a more stringent limit.

Translating the average performance level of 7.55 lbs/day into enforceable permit limits requires consideration of effluent variability and frequency of monitoring in order to comply with federal permitting regulations. The procedure used is as follows:

1. Consider the permit performance level (0.10 mg/l) to be equivalent to the Long Term Average (LTA)
2. Calculate the Maximum Daily Limit by multiplying the LTA by the 99th percentile LTA Multiplier appearing in Table 5-2 of the Technical Support Document (page 103 of EPA/505/2-90-001) corresponding to a CV (co-efficient of variation) of 0.6% to account for effluent variability:

Maximum Daily Limit: $0.10 \text{ mg/l} * 3.11 = 0.311 \text{ mg/l}$

3. Calculate the Average Monthly Limit by multiplying the LTA by the 95th percentile LTA Multiplier appearing in Table 5-2 of the Technical Support Document corresponding to a CV of 0.6% to account for effluent variability and either n=4 samples/month or n=10 samples/month as appropriate for the facility to account for the precision of estimating the true monthly average based on an average for the days the effluent was sampled:

Average Monthly Limit: $0.10 \text{ mg/l} * 1.38 = 0.138 \text{ mg/l}$

Summary of Limits for Danbury:

Average Daily Load = 7.55 lbs/day

Total Seasonal Load = (7.55 lbs/day * 214 Days/Season) = 1,615.7

Maximum Daily Limit = 0.31 mg/l

Average Monthly Limit = 0.14 mg/l

(With respect to the foregoing summary of limits, it should be noted that compliance with the Maximum Daily Limit

or the Average Monthly Limit during the time the seasonal load limit is calculated will not ensure compliance with the Total Seasonal Load limit. For example, if the Permittee discharged phosphorus at the maximum permitted by either the Maximum Daily Limit or the Average Monthly Limit throughout the time that the seasonal load is calculated, the Permittee would exceed the Total Seasonal Load limit. For this reason, the Permittee must monitor compliance with the Total Seasonal Load limit independent of its compliance with the Maximum Daily Limit and the Average Monthly Limit.

WATER QUALITY LIMIT CALCULATIONS

See attached

DRAFT



**Notice of Tentative Determination to Approve
NPDES Permit Renewal
Applicant: City of Danbury
Application No. 200702097
City/Town: City of Danbury**

The Commissioner of the Department of Energy and Environmental Protection (“DEEP”) hereby gives notice that a tentative determination has been reached to approve the following application.

Applicant’s Name and Address: City of Danbury
Contact Name and Phone No.: David Day
(203) 797-4539
Type of Permit and No.: NPDES – CT0100145
Type of Facility: Domestic wastewater treatment
Facility Location: Newtown Road, Danbury, Connecticut
Facility design capacity: 15.5 million gallons per day

COMMISSIONER’S FINDINGS/REGULATORY CONDITIONS

The applicant has previously received a permit from the Department of Energy and Environmental Protection (“Department”) authorizing the discharge of up to an annual average daily design flow of 15.5 million gallons a day of secondary advanced treated municipal wastewaters to the Limekiln Brook. The applicant has submitted an application to renew its existing permit. This renewal application is the subject of this notice.

THE DRAFT PERMIT

The Department has prepared a draft permit consistent with the tentative determination to approve The City of Danbury’s renewal application. This draft is available on the public participation section of the Department’s website. In accordance with Sections 22a-430-4(l) and 22a-430-4(r) of the Regulations of Connecticut State Agencies (RCSA), the draft permit contains effluent limitations that meet Connecticut’s Water Quality Standards for the following: Ammonia, Aquatic Toxicity, Biochemical Oxygen Demand (5 day), chlorine, copper, escherichia coli, flow, pH, lead, total nitrogen, total phosphorus, total suspended solids, and zinc.

This permit contains an enforceable compliance schedule which requires the applicant to 1) comply with total phosphorus limits and to evaluate alternatives to achieve compliance with total phosphorus limits; 2) achieve compliance with implementation of Escherichia coli monitoring; and 3) evaluate efficacy of removal of total phosphorus utilizing chemical addition.

INFORMATION REQUESTS/PUBLIC COMMENT

This application has been assigned No. 200702097, please use this number when corresponding with DEEP regarding this application. Interested persons may obtain copies of the application from the applicant at the above address. The application and supporting documentation are available for inspection at the Department of Energy and Environmental Protection, Water Protection and Land Reuse, 79 Elm Street, Hartford, CT from Monday - Friday from 8:30 am – 4:00 pm and at other times by appointment. Questions may be directed to Stacy Pappano of the Municipal Facilities Section at (860) 424-3704 or stacy.pappano@ct.gov.


Before making a final decision on this application, the Commissioner shall consider written comments on the application from interested persons. Written comments on the application should be directed to Stacy Pappano, Planning and Standards Division, Water Protection and Land Reuse Bureau, Department of Energy and Environmental Protection, 79 Elm Street, Hartford, CT 06106-5127, or may be submitted via electronic mail to: stacy.pappano@ct.gov no later than thirty (30) days from the publication date of this notice.

PETITIONS FOR HEARING

The Commissioner may conduct a public hearing if the Commissioner determines that the public interest will best be served thereby, or shall hold a hearing upon receipt of a petition signed by at least twenty-five persons. Petitions should include the application number noted above and also identify a contact person to receive notifications. Petitions may also identify a person who is authorized to engage in discussions regarding the application and, if resolution is reached, withdraw the petition. Original signed petitions may be scanned and sent electronically to deep.adjudications@ct.gov or may be *mailed or delivered* to: DEEP Office of Adjudications, 79 Elm Street, 3rd floor, Hartford, CT 06106-5127. All petitions must be received within the comment period noted above. If submitted electronically, original signed petitions must also be mailed or delivered to the address above within ten days of electronic submittal. If a hearing is held, timely notice of such hearing will be published in a newspaper of general circulation.

Dated:

September 17, 2014


Denise Ruzicka, Director
Planning and Standards Division
Bureau of Water Protection and Land Reuse

The Connecticut Department of Energy and Environmental Protection is an Affirmative Action and Equal Opportunity Employer that is committed to complying with the Americans with Disabilities Act. To request an accommodation contact us at (860) 418-5910 or deep.accommodations@ct.gov.