



UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION IV
611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-8064

December 3, 1999

J. H. Swailes, Vice President of
Nuclear Energy
Nebraska Public Power District
P.O. Box 98
Brownville, Nebraska 68321

SUBJECT: NRC INSPECTION REPORT NO. 50-298/99-15

Dear Mr. Swailes:

This refers to the inspection conducted on November 15-18, 1999, at the Cooper Nuclear Station facility. The results of this inspection were discussed with Mr. R. Beilke and other members of your staff at the completion of the inspection. The enclosed report presents the results of this inspection.

This inspection was an examination of activities conducted under your license as they relate to radiation safety and compliance with the Commission's rules and regulations and with the conditions of your license. Within these areas, the inspection consisted of a selected examination of procedures and representative records, observations of activities, and interviews with personnel. Specifically, this inspection focused on the implementation of your liquid and gaseous radioactive waste effluents program. During this inspection, no safety significant issues were identified.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be placed in the NRC Public Document Room (PDR).

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

John L. Pellet for

Gail M. Good
Plant Support Branch
Division of Reactor Safety

Docket No.: 50-298
License No.: DPR-46

Enclosure:
NRC Inspection Report No.
50-298/99-15

c w/enclosure:

G. R. Horn, Senior Vice President
of Energy Supply
Nebraska Public Power District
1414 15th Street
Columbus, Nebraska 68601

John R. McPhail, General Counsel
Nebraska Public Power District
P.O. Box 499
Columbus, Nebraska 68602-0499

B. L. Houston, Nuclear Licensing
and Safety Manager
Nebraska Public Power District
P.O. Box 98
Brownville, Nebraska 68321

Dr. William D. Leech
Manager - Nuclear
MidAmerican Energy
907 Walnut Street
P.O. Box 657
Des Moines, Iowa 50303-0657

Ron Stoddard
Lincoln Electric System
1040 O Street
P.O. Box 80869
Lincoln, Nebraska 68501-0869

Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P.O. Box 98922
Lincoln, Nebraska 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, Nebraska 68305

Cheryl K. Rogers, Program Manager
Nebraska Health and Human Services System
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P.O. Box 95007
Lincoln, Nebraska 68509-5007

Ronald A. Kucera, Director
of Intergovernmental Cooperation
Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Jerry Uhlmann, Director
State Emergency Management Agency
P.O. Box 116
Jefferson City, Missouri 65101

Vick L. Cooper, Chief
Kansas Department of Health
and Environment
Bureau of Air and Radiation
Radiation Control Program, RCP
Forbes Field Building 283
Topeka, Kansas 66620

E-mail report to D. Lange (DJL)
E-Mail report to NRR Event Tracking System (IPAS)
E-Mail report to Document Control Desk (DOCDESK)

E-Mail all documents to Jim Isom for Pilot Plant Program (JAI)
E-Mail all documents to Sampath Malur for Pilot Plant Program (SKM)

bcc to DCD (IE06) - Radiological Protection Reports

bcc distrib. by RIV:
Regional Administrator Resident Inspector
DRP Director RIV File
DRS Director RITS Coordinator
Branch Chief (DRP/C)
Branch Chief (DRP/TSS)
Project Engineer (DRP/C)

DOCUMENT NAME: R:_CNS\CN915RP.JBN.WPD

To receive copy of document, indicate in box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

RIV:PSB	RIV:PSB\SRS	E	C:DRS\PSB	E	C:DRP\C	C:DRS\OB
MPShannon (s)	JBNicholas (s)		GMGood TWDexter (s)		CSMarschal (s)l	JLPellet (s)
12/01/99	12/01/99		12/01/99		12/03/99	12/03/99

OFFICIAL RECORD COPY

ENCLOSURE

U.S. NUCLEAR REGULATORY COMMISSION
REGION IV

Docket No.: 50-298
License No.: DPR 46
Report No.: 50-298/99-15
Licensee: Nebraska Public Power District
Facility: Cooper Nuclear Station
Location: P.O. Box 98
Brownville, Nebraska
Dates: November 15-18, 1999
Inspector: J. Blair Nicholas, Ph.D., Senior Radiation Specialist
Plant Support Branch
Approved By: Gail M. Good, Chief, Plant Support Branch
Division of Reactor Safety

SUMMARY OF FINDINGS

Cooper Nuclear Station
NRC Inspection Report No. 50-298/99-15

This inspection focused on the implementation of the licensee's liquid and gaseous radioactive waste effluents program.

Cornerstone: Public Radiation Safety

- No findings.

Report Details

2 RADIATION SAFETY

2PS1 Gaseous and Liquid Effluent Treatment Program

a. Inspection Scope

The inspector interviewed members of the licensee's chemistry staff responsible for implementing the liquid and gaseous radioactive waste effluent program and the system engineers responsible for maintaining the engineered-safety-related ventilation systems. Additionally, the configuration and material condition of the liquid and gaseous radioactive waste collection and processing equipment and the filter housings for the standby gas treatment system and control room emergency filtration system were inspected. The inspector observed the collection and analysis of airborne particulate and charcoal samples from the elevated release point, radwaste building ventilation, and turbine building ventilation systems. The inspector reviewed the following items:

- Implementing procedures for the liquid and gaseous radioactive waste effluent program as described in the Offsite Dose Assessment Manual
- Eight randomly selected batch radioactive liquid waste effluent release permits for discharges from the floor drain sample and waste sample tanks for the period April 1998 through October 1999
- Randomly selected gaseous waste effluent sample analyses of continuous release samples from the elevated release point, reactor building, augmented radwaste building, and turbine building ventilation systems for the period April 1998 through October 1999
- Compensatory sampling and analyses performed during effluent releases made while effluent radiation monitors were inoperable
- Off-site dose calculation methodologies and the dose results calculated from liquid and gaseous radioactive waste effluents released during the period January 1998 through September 1999
- Calibration and quality control procedures and records for the chemistry counting room gamma analysis instrumentation
- The chemistry laboratory's interlaboratory analysis comparison program performance during 1998 and 1999
- Procedures and records of liquid and gaseous effluent radiation monitor checks and calibrations performed during the period January 1998 through September 1999

- Calculation and installation of effluent radiation monitor alarm set points
- Revisions to the Offsite Dose Assessment Manual involving changes to the liquid and gaseous radioactive waste effluent program
- Records and results of the in-place filter testing of high efficiency particulate filters and charcoal adsorbers for the standby gas treatment system and control room emergency filtration system
- Records and results of the laboratory tests performed on the charcoal adsorber material sampled from the standby gas treatment system and control room emergency filtration system
- 1997 and 1998 Annual Radioactive Effluent Release Reports

b. Observations and Findings

There were no findings identified.

4 **OTHER ACTIVITIES**

4OA1 Identification and Resolution of Problems

a. Inspection Scope (71122.01)

The inspector reviewed the following items:

- Quality assurance audit and surveillance schedules for 1997, 1998, and 1999
- Quality assurance audit and surveillance reports of the liquid and gaseous radioactive waste effluent program activities performed during the period January 1, 1997 through November 15, 1999
- Audit scoping plans ASP-406, "Chemistry" and ASP-412, "Public Radiation Safety"
- Nuclear Procurement Issues Committee audits of the two contractor laboratories used to perform surveillance tests and sample analyses required by the radioactive waste effluent program and the engineered-safety-related ventilation filter systems testing program
- Problem identification reports involving the liquid and gaseous radioactive waste effluent program activities
- Special reports related to the liquid and gaseous radioactive waste effluent program required by the Offsite Dose Assessment Manual

b. Observations and Findings

There were no findings identified.

4OA5 Management Meetings

Exit Meeting Summary

The inspector presented the inspection results to members of licensee management at an exit meeting on November 18, 1999. The licensee acknowledged the findings presented. No proprietary information was identified.

PARTIAL LIST OF PERSONS CONTACTED

Licensee

R. Beilke, Acting Manager, Licensing
D. Kimball, Assistant Manager, Radiation Protection
J. Geyer, Senior Health Physicist, Radiation Protection
G. Grotrian, Auditor, Quality Assurance
K. Fike, Plant Chemist, Chemistry
B. Houston, Manager, Quality Assurance Operations
L. Lockard, Chemistry Supervisor, Chemistry
J. Peters, Licensing
J. Teten, Chemistry Crew Leader, Chemistry
B. Toline, Audit Supervisor, Quality Assurance
J. Warren, Chemistry Specialist, Chemistry
C. Weers, Radiological Support Supervisor, Radiation Protection
R. Weller, Chemistry/Radiation Protection Technician, Chemistry

NRC

J. Clark, Senior Resident Inspector

ITEMS OPENED, CLOSED, AND DISCUSSED

Opened

None

Closed

None

Discussed

None

LIST OF DOCUMENTS REVIEWED

QUALITY ASSURANCE AUDITS

Quality Assurance Audit Report 97-11, "Chemistry," performed July 31 through August 14, 1997

Quality Assurance Audit Report 99-04, "Chemistry," performed March 2-16, 1999

QUALITY ASSURANCE SURVEILLANCE

Quality Assurance Surveillance Report S412-9901, "Effluent Treatment Systems," performed

October 18-28, 1999

VENDOR AUDITS

NUPIC Audit Number NJ #16367, Thermo Nutech Richmond, California, December 7-9, 1998

NUPIC Audit Number NJ #16358, NCS Corporation, Columbus Ohio, December 8-10, 1998

CHEMISTRY PROCEDURES

- 8.2.1 "Chemistry Analysis and Instrument Calibration Schedule," Revision 23
- 8.2.2 "Instrument Performance Monitoring," Revision 1
- 8.2.4 "Blind and Spiked Sampling," Revision 16
- 8.3 "Control Parameters and Limits," Revision 25
- 8.5.2.1 "Cannberra System Operation," Revision 8
- 8.8.8 "Particulate, Iodine, and Noble Gas Sample Collection for Effluent Monitors, Control Building Intake Monitor, and Drywell Air Monitor," Revision 22
- 8.8.11 "Liquid Radioactive Waste Discharge Authorization," Revision 20
- 8.11.1 "Effects Program," Revision 7

SURVEILLANCE PROCEDURES

- 6.HV.101 "Control Room Ventilation," Revision 4
- 6.HV.103 "Control Room Emergency Fan Filter Train Differential Pressure Test," Revision 3
- 6.HV.104 "Control Room Emergency Fan Charcoal and HEPA Filter Leak Test, Fan Capacity Test, and Charcoal Sampling," Revision 4
- 6.HV.301 "Turbine Building Ventilation Flow Monitor Channel Calibration," Revision 3
- 6.HV.302 "Reactor Building Ventilation Flow Monitor Channel Calibration," Revision 3
- 6.HV.304 "Radwaste Building Ventilation Flow Monitor Channel Calibration," Revision 3
- 6.HV.701 "Turbine Building Ventilation Flow Monitor Channel Functional Test," Revision 0

- 6.HV.702 "Reactor Building Ventilation Flow Monitor Channel Functional Test," Revision 0
- 6.HV.704 "Radwaste Building Ventilation Flow Monitor Channel Functional Test," Revision 0
- 6.OG.303 "Off-Gas Flow Monitor Calibration," Revision 1
- 6.PRM.301 "Off-Gas Radiation Monitor Source Check Test," Revision 3
- 6.PRM.302 "Off-Gas Radiation Monitor Linearity Test and Efficiency Determination," Revision 2
- 6.PRM.303 "SW Radiation Monitor Source Check," Revision 2
- 6.PRM.304 "SW Radiation Monitor Source Check and Functional Test," Revision 3
- 6.PRM.305 "SW Radiation Monitor Calibration Check and Instrument Channel Test," Revision 4
- 6.PRM.306 "Liquid Radwaste Effluent Flow Monitor Channel Calibration," Revision 2
- 6.PRM.307 "Liquid Radwaste Effluent System Channel Calibration and Channel Functional Test," Revision 3
- 6.PRM.308 "Liquid Radwaste Effluent System Channel Calibration," Revision 3
- 6.PRM.309 "ERP Kaman Monitor Channel Functional Test," Revision 3
- 6.PRM.310 "ERP Kaman Monitor Channel Calibration," Revision 9
- 6.PRM.312 "Reactor Building Kaman Monitor Channel Functional Test," Revision 3
- 6.PRM.313 "Reactor Building Kaman Monitor Channel Calibration," Revision 3
- 6.PRM.314 "Turbine Building Kaman Monitor Channel Functional Test," Revision 3
- 6.PRM.315 "Turbine Building Kaman Monitor Channel Calibration." Revision 6
- 6.PRM.319 "RW/ARW Kaman Monitor Channel Functional Test," Revision 3
- 6.PRM.320 "Radwaste Building Kaman Monitor Channel Calibration," Revision 6
- 6.PRM.706 "Liquid Radwaste Effluent Flow Monitor Channel Functional Test," Revision 2
- 6.1PRM.304 "Reactor Building Ventilation Radiation Monitor Channel Calibration and Functional Test/Source Check," Revision 5
- 6.1PRM.305 "Off-Gas Radiation Monitor Channel Calibration and Functional Test," Revision 2
- 6.1PRM.306 "Off-Gas Radiation Monitor Channel Functional Test," Revision 4

- 6.1PRM.311 "Reactor Building Ventilation Radiation Monitor Source Check," Revision 2
- 6.2PRM.304 "Reactor Building Ventilation Radiation Monitor Channel Calibration and Functional Test/Source Check," Revision 5
- 6.2PRM.305 "Off-Gas Radiation Monitor Channel Calibration and Functional Test," Revision 2
- 6.2PRM.306 "Off-Gas Radiation Monitor Channel Functional Test," Revision 5
- 6.2PRM.311 "Reactor Building Ventilation Radiation Monitor Source Check," Revision 2
- 6.1OG.301 "Augmented Off-Gas Hydrogen Monitor Channel Calibration and Functional Test," Revision 5
- 6.1SGT.101 "A SGT Filter Differential Pressure, Heater Output, and Fan Motor Running Current Test," Revision 2
- 6.1SGT.301 "SGT Operability Test/Off Gas Flow Monitor Channel Functional Test," Revision 5
- 6.1SGT.501 "In-Place Leak Tests of the SGT A Charcoal Adsorber, HEPA Filters, and Components," Revision 4
- 6.1SGT.601 "SGT-A Charcoal Filter Carbon Analysis - Methyl Iodide," Revision 3
- 6.1SJAE.301 "Steam Jet Air Ejector Flow Monitor Channel Calibration and Channel Functional Test," Revision 4
- 6.2OG.301 "Augmented Off-Gas Hydrogen Monitor Channel Calibration and Functional Test," Revision 5
- 6.2SGT.101 "B SGT Filter Differential Pressure, Heater Output, and Fan Motor Running Current Test," Revision 2
- 6.2SGT.301 "SGT Operability Test/Off Gas Flow Monitor Channel Functional Test," Revision 5
- 6.2SGT.501 "In-Place Leak Tests of the SGT B Charcoal Adsorber, HEPA Filters, and Components," Revision 4
- 6.2SGT.601 "SGT-B Charcoal Filter Carbon Analysis - Methyl Iodide," Revision 3
- 6.2SJAE.301 "Steam Jet Air Ejector Flow Monitor Channel Calibration and Channel Functional Test," Revision 4

ANNUAL REPORTS

Annual Radioactive Effluent Release Reports - 1997 and 1998

MISCELLANEOUS DOCUMENTS

Offsite Dose Assessment Manual, dated August 26, 1999

Selected Problem Identification Reports

Special Reports



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-8064**

December 28, 1999

J. H. Swailes, Vice President of
Nuclear Energy
Nebraska Public Power District
P.O. Box 98
Brownville, Nebraska 68321

SUBJECT: NRC INSPECTION REPORT 50-298/99-15

The radiological effluent performance indicator verification that was performed during the inspection that was conducted November 15-18, 1999, was not reported in the original inspection report. Therefore, please insert the enclosures to this letter as a replacement to the cover letter and page 5 of NRC Inspection Report 50-298\99-15.

Sincerely,

/RA/

Gail M. Good, Chief
Plant Support Branch
Division of Reactor Safety

Docket No.: 50-298
License No.: DPR-46

cc:
G. R. Horn, Senior Vice President
of Energy Supply
Nebraska Public Power District
1414 15th Street
Columbus, Nebraska 68601

John R. McPhail, General Counsel
Nebraska Public Power District
P.O. Box 499
Columbus, Nebraska 68602-0499

Nebraska Public Power District

-2-

B. L. Houston, Nuclear Licensing
and Safety Manager
Nebraska Public Power District
P.O. Box 98
Brownville, Nebraska 68321

Dr. William D. Leech
Manager - Nuclear
MidAmerican Energy
907 Walnut Street
P.O. Box 657
Des Moines, Iowa 50303-0657

Ron Stoddard
Lincoln Electric System
1040 O Street
P.O. Box 80869
Lincoln, Nebraska 68501-0869

Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P.O. Box 98922
Lincoln, Nebraska 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, Nebraska 68305

Cheryl K. Rogers, Program Manager
Nebraska Health and Human Services System
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P.O. Box 95007
Lincoln, Nebraska 68509-5007

Ronald A. Kucera, Director
of Intergovernmental Cooperation
Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Nebraska Public Power District

-3-

Jerry Uhlmann, Director
State Emergency Management Agency
P.O. Box 116
Jefferson City, Missouri 65101

Vick L. Cooper, Chief
Radiation Control Program, RCP
Kansas Department of Health
and Environment
Bureau of Air and Radiation
Forbes Field Building 283
Topeka, Kansas 66620

E-mail report to D. Lange (DJL)
E-Mail report to NRR Event Tracking System (IPAS)
E-Mail report to Document Control Desk (DOCDESK)

E-Mail notification of report issuance to the CNS SRI and Site Secretary (JAC, SLN).

E-Mail notification of issuance of all documents to Nancy Holbrook (NBH).

bcc to DCD (IE06)

bcc distrib. by RIV:

Regional Administrator
DRP Director
DRS Director
Branch Chief (DRP/C)
Branch Chief (DRP/TSS)
Project Engineer (DRP/C)

CNS Resident Inspector
RIV File
RITS Coordinator

DOCUMENT NAME: R:_CNS\CN915ERR.JBN.WPD

To receive copy of document, indicate in box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

RIV:PSB	E	C:DRS\PSB	E						
*JBNicholas:nh /s/		GMGood /s/							
12/26/99		12/27/99							

*Previously concurred.

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION IV
611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-8064

December 3, 1999

J. H. Swailes, Vice President of
Nuclear Energy
Nebraska Public Power District
P.O. Box 98
Brownville, Nebraska 68321

SUBJECT: NRC INSPECTION REPORT NO. 50-298/99-15

Dear Mr. Swailes:

This refers to the inspection conducted on November 15-18, 1999, at the Cooper Nuclear Station facility. The results of this inspection were discussed with Mr. R. Beilke and other members of your staff at the completion of the inspection. The enclosed report presents the results of this inspection.

This inspection was an examination of activities conducted under your license as they relate to radiation safety and compliance with the Commission's rules and regulations and with the conditions of your license. Within these areas, the inspection consisted of a selected examination of procedures and representative records, observations of activities, and interviews with personnel. Specifically, this inspection focused on the implementation of your liquid and gaseous radioactive waste effluents program and the radiological effluent performance indicator. During this inspection, no safety significant issues were identified.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be placed in the NRC Public Document Room (PDR).

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

John L. Pellet for

Gail M. Good
Plant Support Branch
Division of Reactor Safety

Docket No.: 50-298
License No.: DPR-46

Enclosure:
NRC Inspection Report No.
50-298/99-15

b. Observations and Findings

There were no findings identified.

4OA2 Performance Indicator Verification

a. Inspection Scope (71151)

The inspector reviewed corrective action program records for liquid and gaseous effluent releases, licensee event reports, and the annual effluent release report for the past 4 quarters to confirm that any radiological dose occurrences were properly recorded as performance indicators and reported to the NRC.

b. Observations and findings

There were no findings identified.

4OA5 Management Meetings

Exit Meeting Summary

The inspector presented the inspection results to members of licensee management at an exit meeting on November 18, 1999. The licensee acknowledged the findings presented. No proprietary information was identified.