



**UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 400
ARLINGTON, TEXAS 76011-4005**

December 6, 2004

M. R. Blevins, Senior Vice President
and Principal Nuclear Officer
TXU Energy
ATTN: Regulatory Affairs
Comanche Peak Steam Electric Station
P.O. Box 1002
Glen Rose, TX 76043

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION - NRC RADIATION SAFETY
TEAM INSPECTION REPORT 05000445/2004009 AND 05000446/2004009**

Dear Mr. Blevins:

On October 22, 2004, the U.S. Nuclear Regulatory Commission (NRC) completed an inspection at your Comanche Peak Steam Electric Station, Units 1 and 2, facility. The enclosed report documents the inspection findings, which were discussed at the conclusion of the inspection with Mr. M. Lucas, Vice President, Nuclear Engineering, and other members of your staff.

The inspection examined activities conducted under your license as they relate to safety and compliance with the Commission's rules and regulations and with the conditions of your license. The team reviewed selected procedures and records, observed activities, and interviewed personnel. Specifically, the team evaluated the inspection areas within the Radiation Protection Strategic Performance Area that are scheduled for review every two years. These areas are:

- Radiation Monitoring Instrumentation
- Radioactive Gaseous and Liquid Effluent Treatment and Monitoring Systems
- Radioactive Material Processing and Transportation
- Radiological Environmental Monitoring Program and Radioactive Material Control Program

This inspection report documents one self-revealing, non-cited violation of very low safety significance (Green). However, because the finding was of very low safety significance and it was entered into your corrective action program, the NRC is treating this finding as a non-cited violation consistent with Section VI.A of the NRC Enforcement Policy. Additionally, two licensee-identified violations which were determined to be of very low safety significance are listed in this report. If you contest any non-cited violation in this report, you should provide a response within 30 days of the date of this inspection report, with the basis for your denial, to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington DC 20555-0001; with copies to the Regional Administrator, U.S. Nuclear Regulatory Commission Region IV, 611 Ryan Plaza Drive, Suite 400, Arlington, Texas 76011-4005; the Director, Office of Enforcement, U.S. Nuclear Regulatory Commission, Washington DC 20555-001; and the NRC Resident Inspector at the Comanche Peak Steam Electric Station facility.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter, its enclosure, and your response (if any) will be made available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

//RA//

Michael P. Shannon, Chief
Plant Support Branch
Division of Reactor Safety

Dockets: 50-445
50-446
Licenses: NPF-87
NPF-89

Enclosure:
NRC Inspection Report 05000445/2004009 and 05000446/2004009
w/attachment: Supplemental Information

cc:
Fred W. Madden
Regulatory Affairs Manager
TXU Generation Company LP
P.O. Box 1002
Glen Rose, TX 76043

George L. Edgar, Esq.
Morgan Lewis
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Terry Parks, Chief Inspector
Texas Department of Licensing
and Regulation
Boiler Program
P.O. Box 12157
Austin, TX 78711

The Honorable Walter Maynard
Somervell County Judge
P.O. Box 851
Glen Rose, TX 76043

TXU Energy

-3-

Richard A. Ratliff, Chief
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Environmental and Natural
Resources Policy Director
Office of the Governor
P.O. Box 12428
Austin, TX 78711-3189

Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
1701 North Congress Avenue
Austin, TX 78711-3326

Susan M. Jablonski
Office of Permitting, Remediation and Registration
Texas Commission on Environmental Quality
MC-122
P.O. Box 13087
Austin, TX 78711-3087

Electronic distribution by RIV:
 Regional Administrator (**BSM1**)
 DRP Director (**ATH**)
 DRS Director (**DDC**)
 DRS Deputy Director (**GLS**)
 Senior Resident Inspector (**DBA**)
 Branch Chief, DRP/A (**WDJ**)
 Senior Project Engineer, DRP/A (**TRF**)
 Team Leader, DRP/TSS (**RVA**)
 RITS Coordinator (**KEG**)

Only inspection reports to the following:

DRS STA (**DAP**)
 J. Dixon-Herrity, OEDO RIV Coordinator (**JLD**)
 CP Site Secretary (**ESS**)

ADAMS: Yes No Initials: _ltr_____
 Publicly Available Non-Publicly Available Sensitive Non-Sensitive

R:_CP\2004\CP2004-09RP-LTR.wpd

RIV:PSB\SHP	PSB\HP	PSB\HP	DRP\PE	
LTRicketson:jlh	BDBaca	BKTharakan	DLStearns	
/RA/	/RA/	/RA/	/RA/	
11/29/04	12/01/04	12/01/04	12/01/04	
C:PSB	DRP\	C:PSB		
MPShannon	WDJohnson	MPShannon		
/RA/	/RA/	/RA/		
11/30/04	12/02/04	12/06/04		

OFFICIAL RECORD COPY

T=Telephone

E=E-mail

F=Fax

**U.S. NUCLEAR REGULATORY COMMISSION
REGION IV**

Dockets: 50-445, 50-446
Licenses: NPF-87, NPF-89
Report: 05000445/2004009 and 05000446/2004009
Licensee: TXU Generation Company LP
Facility: Comanche Peak Steam Electric Station, Units 1 and 2
Location: FM-56, Glen Rose, Texas
Dates: October 18 - 22, 2004
Inspectors: Larry Ricketson, P.E., Senior Health Physicist, Plant Support Branch
Bernadette Baca, Health Physicist, Plant Support Branch
Binesh Tharakan, Health Physicist, Plant Support Branch
Donald Stearns, Project Engineer, Branch E, Division of Reactor
Projects
Approved By: Michael P. Shannon, Chief, Plant Support Branch
Division of Reactor Safety

Enclosure

SUMMARY OF FINDINGS

IR 05000445/2004009; 10/18/2004 - 10/22/2004; Comanche Peak Steam Electric Station, Units 1 and 2 ; Radioactive Gaseous and Liquid Effluent Treatment and Monitoring Systems

The report covered a one week period of inspection on site by a team of four region-based inspectors. A finding of very low safety significance (Green) was identified. The significance of most findings is indicated by their color (Green, White, Yellow, Red) using IMC 0609, "Significance Determination Process". Findings for which the Significance Determination Process does not apply may be "Green" or be assigned a severity level after NRC management review. The NRC's program for overseeing the safe operation of commercial nuclear power reactors is described in NUREG-1649, "Reactor Oversight Process," Revision 3, dated July 2000.

A. NRC-Identified and Self-Revealing Findings

Cornerstone: Public Radiation Safety

- Green. The team reviewed a self-revealing non-cited violation of Technical Specification 5.5.1, which occurred when the licensee failed on two occasions to sample in accordance with Offsite Dose Calculation Manual requirements. Specifically, non-cited during the third quarter of 2002 and the fourth quarter of 2003, the licensee failed to maintain portions of composite samples from the plant effluent tanks. The samples are required to be collected monthly and analyzed quarterly. The finding was placed into the licensee's corrective action program.

The finding is greater than minor because it is associated with one of the cornerstone attributes (effluent measurement) and affects the cornerstone objective because the failure to implement offsite dose calculation requirements decreases the licensee's assurance that the public will not receive unnecessary dose. The team determined that the finding had very low safety significance because: (1) the finding was not a radioactive material control finding, (2) it was an effluent release program finding, (3) the finding impaired the licensee's ability to assess dose, (4) the licensee did not fail to assess dose because it was able to assess dose to the public using the remaining composite samples, and (5) it did not result in doses that exceeded 10 CFR Part 50, Appendix I or 10 CFR 20.1301(d). This finding had crosscutting aspects associated with human performance. When licensee personnel failed to store the samples properly, they directly contributed to the finding (Section 2PS1).

B. Licensee Identified Violations

Violations of very low safety significance, which were identified by the licensee have been reviewed by the inspectors. Corrective actions taken or planned by the licensee have been entered into the licensee's corrective action program. These violations and corrective actions are listed in Section 4OA7 of this report.

Enclosure

REPORT DETAILS

2. RADIATION SAFETY

Cornerstones: Occupational Radiation Safety [OS] and Public Radiation Safety [PS]

2OS3 Radiation Monitoring Instrumentation and Protective Equipment (71121.03)

a. Inspection Scope

This area was inspected to determine the accuracy and operability of radiation monitoring instruments that are used for the protection of occupational workers and the adequacy of the program to provide self-contained breathing apparatus (SCBA) to workers. The team used the requirements in 10 CFR Part 20 and the licensee's procedures required by technical specifications as criteria for determining compliance. The team interviewed licensee personnel and reviewed:

- Calibration of area radiation monitors associated with transient high and very high radiation areas and post-accident monitors used for remote emergency assessment
- Calibration of portable radiation detection instrumentation, electronic alarming dosimetry, and continuous air monitors used for job coverage
- Calibration of whole body counting equipment and radiation detection instruments utilized for personnel and material release from the radiologically controlled area
- Self-assessments and audits
- Corrective action program reports since the last inspection
- Licensee action in cases of repetitive deficiencies or significant individual deficiencies
- Calibration expiration and source response check currency on radiation detection instruments staged for use
- The licensee's capability for refilling and transporting SCBA air bottles to and from the control room and operations support center during emergency conditions, status of SCBA staged and ready for use in the plant and associated surveillance records, and personnel qualification and training
- Qualification documentation for onsite personnel designated to perform maintenance on the vendor-designated vital components, and the vital component maintenance records for SCBA units

Either because the conditions did not exist or an event had not occurred, no opportunities were available to review the following items:

- Licensee Event Reports

The inspector completed 9 of the required 9 samples.

b. Findings

No findings of significance were identified.

2PS1 Radioactive Gaseous and Liquid Effluent Treatment and Monitoring Systems (71122.01)

a. Inspection Scope

This area was inspected to ensure that the gaseous and liquid effluent processing systems are maintained so that radiological releases are properly mitigated, monitored, and evaluated with respect to public exposure. The team used the requirements in 10 CFR Part 20, 10 CFR Part 50, Appendices A and I, the Offsite Dose Calculation Manual (ODCM), and the licensee's procedures required by technical specifications as criteria for determining compliance. The team interviewed licensee personnel and reviewed:

- The most current radiological effluent release reports
- Gaseous and liquid release system component configurations
- Radioactive liquid and gaseous effluent release permits and dose projections to members of the public
- Changes made by the licensee to the ODCM, the liquid or gaseous radioactive waste system design, procedures, or operation since the last inspection
- Monthly, quarterly, and annual dose calculations
- Surveillance test results involving air cleaning systems and stack or vent flow rates
- Instrument calibrations of discharge effluent radiation monitors and flow measurement devices, effluent monitoring system modifications, effluent radiation monitor alarm setpoint values, and counting room instrumentation calibration and quality control
- Interlaboratory comparison program results
- Audits, self-assessments, and corrective action reports performed since the last inspection

Either because the conditions did not exist or an event had not occurred, no opportunities were available to review the following items:

- Changes to radiation monitor setpoint calculation methodology, anomalous sampling results, effluent radiological occurrence performance indicator incidents, and licensee event reports
- Abnormal releases

The inspector completed 10 of the required 10 samples.

b. Findings

Introduction. The team reviewed a self-revealing, non-cited violation of Technical Specification 5.5.1, which occurred when the licensee failed on two occasions to sample in accordance with ODCM requirements. The violation had very low safety significance.

Description. The licensee collects monthly liquid samples from the plant effluent tanks. These monthly samples form a composite sample which is shipped offsite for vendor analysis, quarterly. The vendor conducts analyses for Fe-55, Sr-89, and Sr-90. According to the 2002 and 2003 Annual Effluent Reports, the licensee lost or misplaced a monthly sample during the third quarter of 2002 and during the fourth quarter of 2003. This finding is considered self-revealing because the licensee was alerted to the problem by the absence of the samples.

Analysis. The failure to maintain required samples for analysis is a performance deficiency. The finding is greater than minor because it is associated with one of the cornerstone attributes (effluent measurement) and affects the cornerstone objective because the failure to implement offsite dose calculation requirements decreases the licensee's assurance that the public will not receive unnecessary dose. Because the finding involved an occurrence in the licensee's radiological effluent monitoring program that is contrary to ODCM requirements, the team processed the finding using the Public Radiation Safety Significance Determination Process. Using the process, the team determined that the finding had very low safety significance because: (1) the finding was not a radioactive material control finding, (2) it was an effluent release program finding, (3) the finding impaired the licensee's ability to assess dose, (4) the licensee did not fail to assess dose because it was able to assess dose to the public using the remaining composite samples, and (5) it did not result in doses that exceeded 10 CFR Part 50, Appendix I or 10 CFR 20.1301(d). This finding had crosscutting aspects associated with human performance. When licensee personnel failed to store the samples properly, they directly contributed to the finding.

Enforcement. Technical Specification 5.5.1 requires that the ODCM be established, implemented, and maintained. ODCM Surveillance Requirement 4.11.1.1.1 states that radioactive liquid wastes shall be sampled and analyzed according to the sampling and analysis program of Table 4.11-1. Table 4.11-1 requires liquids released from plant effluent tanks be sampled during each batch release and a composite analysis conducted quarterly. The licensee violated this requirement when it failed to maintain samples for analysis on two occasions. The finding was documented in the licensee's corrective action program by SmartForms 2002-003448 and 2004-000060. Because this violation was of very low safety significance and was entered into the licensee's corrective action program, it is being treated as a non-cited violation (NCV), consistent with Section VI.A of the NRC Enforcement Policy: NCV 05000445; 05000446/2004009-01, Failure to maintain and analyze composite samples on two occasions.

2PS2 Radioactive Material Processing and Transportation (71122.02)

a. Inspection Scope

This area was inspected to verify that the licensee's radioactive material processing and transportation program complies with the requirements of 10 CFR Parts 20, 61, and 71 and Department of Transportation regulations contained in 49 CFR Parts 171-180. The team interviewed licensee personnel and reviewed:

- The radioactive waste system description, recent radiological effluent release reports, and the scope of the licensee's audit program
- Liquid and solid radioactive waste processing systems configurations, the status and control of any radioactive waste process equipment that is not operational or is abandoned in place, changes made to the radioactive waste processing systems since the last inspection, and current processes for transferring radioactive waste resin and sludge discharges
- Radio-chemical sample analysis results for radioactive waste streams and use of scaling factors and calculations to account for difficult-to-measure radionuclides
- Shipment packaging, surveying, labeling, marking, placarding, vehicle checking, driver instructing, and disposal manifesting
- Shipping records for non-excepted package shipments
- Audits, state agency reports, self-assessments and corrective action reports performed since the last inspection

Either because the conditions did not exist or an event had not occurred, no opportunities were available to review the following items:

- Licensee event reports and special reports

The inspector completed 6 of the required 6 samples.

b. Findings

No findings of significance were identified.

2PS3 Radiological Environmental Monitoring Program (REMP) and Radioactive Material Control Program (71122.03)

This area was inspected to ensure that the REMP verifies the impact of radioactive effluent releases to the environment and sufficiently validates the integrity of the radioactive gaseous and liquid effluent release program; and that the licensee's surveys and controls are adequate to prevent the inadvertent release of licensed materials into the public domain. The team used the requirements in 10 CFR Part 20, 10 CFR Part 50, Appendix I,

the ODCM, and the licensee's procedures required by technical specifications as criteria for determining compliance. The team interviewed licensee personnel and reviewed:

- Annual environmental monitoring reports
- Eight air sampling stations and eleven thermoluminescence dosimeter (TLD) monitoring stations
- Collection and preparation of particulate, iodine, and surface water environmental samples
- Operability, calibration, and maintenance of meteorological instruments
- Each event documented in the Annual Environmental Monitoring Report which involved a missed sample, inoperable sampler, lost TLD, or anomalous measurement
- Calibration and maintenance records for the licensee air samplers, vendor quality control program, vendor interlaboratory comparison program results, and vendor audits
- Locations where the licensee monitors potentially contaminated material leaving the radiological controlled area and the methods used for control, survey, and release from these areas
- Type of radiation monitoring instrumentation used to monitor items released, survey and release criteria of potentially contaminated material, radiation detection sensitivities, procedural guidance, and material release records
- Audits, self-assessments and corrective action reports performed since the last inspection

Either because the conditions did not exist or an event had not occurred, no opportunities were available to review the following items:

- Significant changes made by the licensee to the ODCM as the result of changes to the land census or sampler station modifications since the last inspection
- Licensee event reports and special reports

The inspector completed 10 of the required 10 samples.

b. Findings

No findings of significance were identified.

4. OTHER ACTIVITIES

4OA2 Problem Identification and Resolution

a. Inspection Scope

The team evaluated the effectiveness of the licensee's problem identification and resolution process with respect to the following inspection areas:

- Radiation Monitoring Instrumentation (Section 2OS3)
- Radioactive Gaseous and Liquid Effluent Treatment and Monitoring Systems (Section 2PS1)
- Radioactive Material Processing and Transportation (Section 2PS2)
- Radiological Environmental Monitoring Program and Radioactive Material Control Program (Section 2PS3)

a. Findings and Observations

No findings of significance were identified.

4OA4 Cross-Cutting Aspects of Findings

Section 2PS1 describes an issue with a human performance cross-cutting aspect which involved the failure to sample in accordance with ODCM requirements.

4OA6 Management Meetings

Exit Meeting Summary

On October 22, 2004, the team presented the inspection results to Mr. M. Lucas, Vice President, Nuclear Engineering, and other members of the staff who acknowledged the findings. The team confirmed that proprietary information was not provided or examined during the inspection.

4OA7 Licensee Identified Violations

The following findings of very low significance were identified by the licensee and are violations of NRC requirements which meet the criteria of Section VI of the NRC Enforcement Policy, NUREG-1600 for being dispositioned as Non-Cited Violations.

1. 10 CFR 71.12(c)(2) requires a licensee to comply with the terms and conditions of the Certificate of Compliance. Certificate of Compliance 9168 requires successful passage of a leak test of the secondary lid on a CNS 8-120B cask. However, the licensee identified one example in which it shipped a cask that had not successfully met the secondary lid leak test acceptance criteria.

The licensee performed the leak test using a modified test rig (as allowed by vendor procedures.) The modification involved the use of a longer than normal length of hose. During a review of shipment records, the licensee determined through an engineering

analysis that Shipment Number 2002-0043, shipped on June 3, 2002, would not have met the leak testing acceptance criteria. The finding was placed in the licensee's corrective action program as SmartForm 2003-003675. The finding was of very low safety significance because (1) it was associated with radioactive material control and transportation, (2) there was no radiation limit exceeded, (3) there was no breach of the package during transit, (4) it was a Certificate of Compliance finding, (5) there was no design documentation deficiency, and (6) it was a maintenance/use performance deficiency.

2. Technical Specification 5.4.1.a. requires that procedures be established, implemented, and maintained covering the applicable procedures in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978. Appendix A, Section 7 specify procedures for the Control of Radioactivity. Procedure RPI-213, Section 4.2.1 stated that the criteria for unconditional release from the radiological controlled area (RCA) is "no detectable activity." On October 18, 2003, a nylon sling marked "RCA ONLY" was found at the Service Water Intake Structure Building. The sling was counted in a small article monitor and found to have a radioactivity level of 5,900 disintegration per minute. This finding was documented in the licensee's corrective action program as Smart Form 2004-3304. This finding was of very low safety significance because (1) it involved an occurrence in the licensee's radioactive material control program, (2) public exposure was not greater than five millirem, and (3) there were no more than five occurrences during the previous eight quarters.

SUPPLEMENTAL INFORMATION

KEY POINTS OF CONTACT

Licensee

R. Barrios, Digital Radiation Monitoring System Technician, Instruments and Controls
S. Bradley, Health Physics Supervisor, Radiation and Industrial Safety
A. Caves, Radiation Protection Technician, Radiation and Industrial Safety
J. Curtis, Radiation Protection Manager, Radiation and Industrial Safety
T. Edwards, Supervisor, Radioactive Waste Operations
D. Farnsworth, Senior Chemist, Chemistry
R. Garcia, Radiation Protection Supervisor, Radiation and Industrial Safety
R. Knapp, Health Physicist, Radiation and Industrial Safety
W. Knowles, Radiation Protection Supervisor, Radiation and Industrial Safety
M. Macho, Health Physicist, Radiation and Industrial Safety
M. Lucas, Vice President, Nuclear Engineering
D. O'Connor, Radiation Protection Supervisor, Radiation and Industrial Safety
T. Parker, Engineered Safety Features System Engineer, Nuclear Engineering
M. Syed, Digital Radiation Monitoring System Engineer, Nuclear Engineering
B. Vaughan, Radiation Protection Technician, Health Physics
M. Watts, Radiation Protection Technician, Radiation and Industrial Safety
D. Wilder, Manager, Radiation and Industrial Safety Manager

NRC

D. Allen, Senior Resident Inspector
A. Sanchez, Resident Inspector

LIST OF ITEMS OPENED, CLOSED, AND DISCUSSED

Opened

NONE

Opened and Closed During this Inspection

05000445; 05000446/2004009-01 NCV Failure to maintain and analyze composite samples on two occasions (Section 2PS1)

LIST OF DOCUMENTS REVIEWED

Section 20S3: Radiation Monitoring Instrumentation and Protective Equipment

Work Orders and Calibration Packages

Work Order # 3-03-308167-01 Channel Calibration Data Package: North Vent Stack Discharge Gas Radiation Detector 5567B Process Skid

Work Order # 5-03-501846-AA, Digital Channel Operational Test; Liquid Waste Processing Discharge Radiation Monitor

Work Order # 5-02-502068-AA, Digital Channel Operational Test; South Vent Stack Wide Range Gas Monitor 5570A

Work Order # 5-02-501813-AA, Channel Calibration Data Package North Vent Stack Wide Range Gas Monitor 5570B

Work Order # 5-01-502200-AA, Digital Channel Operational Test Data Package; Unit 2 Station Service Water Train B

Work Order # 5-03-504311-AA, Digital Channel Operational Test Data Package; LVW/Evap Pond Vent & Drain Header Radiation Detector 5251A

Work Order # 5-03-502026-AA, Digital Channel Operational Test Data Package; Unit 2 Station Service Water Train A

Work Order # 5-03-502680-AA, Digital Channel Operational Test Data Package; Unit 1 Station Service Water Train A

Work Order # 3-03-321913-01, Channel Calibration Data Package South Vent Stack Discharge Gas Radiation Detector 5567A

Work Order # 5-02-502604-AA, Channel Calibration Data Package; Turbine Building Sump 2-04 Radiation Detector

Work Order # 5-02-502518-AA, Digital Channel Operational Test Data Package; Unit 1 Station Service Water Train B.

RPI-508-1, Whole Body Count System Calibration Data Package, FSCAN, Calibration Certificate # 68578-108

RPI-508-1, Whole Body Count System Calibration Data Package, ASCAN, Calibration Certificate # 66355-108

INC-7090X, Rev 5, Digital Channel Operational Test, Analog Channel Operational Test, and Channel Calibration Plant Vent Stack Wide Range Gas Monitor.

Procedures

RPI-212, Radioactive Source Control, Revision 8

RPI-711, DRMS Source Check Surveillance, Revision 7

RPI-801, Operation of Portable Survey Instruments, Revision 4

RPI-881, Calibration of Portable Dose Rate Instruments, Revision 7

RPI-867, Determination of the Calibration Well Source Exposure Rates, Revision 7

RPI-868, Determining Reproducibility of Calibration Well Source Exposure Rates, Revision 6

RPI-809, Operation of the Calibration Well Source, Revision 9

RPI-800, Control of Radiation Protection Equipment, Revision 6

RPI-508, Calibration of the Stand-Up Whole Body Counter, Revision 7

RPI-503, Operation of the Stand-Up Whole Body Counter, Revision 9

STA-658, Radiation Protection Equipment Calibration Program, Revision 6

RPI-729, Primary/Transfer Calibration of DRMS Particulate Detectors, Revision 2

ICI-4961, Channel Calibration Digital High Range Area Monitor, Revision 2

ICI-4995, Rev 4, Channel Calibration Plant Vent Stack Gas Channels: X-RE-5567A & X-RE-5567B

INC-7084, Rev 8, Digital Channel Operational Test and Channel Calibration Turbine Building Floor Drains Liquid Process Radiation Monitor Channel: 1-RE-5100/2-RE-5100

INC-7081, Rev 6, Digital Channel Operational Test and Channel Calibration Liquid Waste Effluent Process Radiation Monitor Channel: X-RE-5253

INC-4914, Rev 3, Channel Calibration Main Steam Line Monitor Channels 1-RE-2325/2327, 2-RE-2325/2327, 1-RE-2326/2328, 2-RE-2326/2328

INC-2078, Rev 0, Transfer Calibration of DRMS Gaseous Process Monitor Detectors (RD-52)

INC-2080, Rev 1, Calibration of DRMS High Range Radiation Monitor Detectors (RD-23)

INC-7101, Rev 1, DRMS Check Source Surveillance

Corrective Action Documents (SmartForms)

2003-000414, 2003-000899, 2003-001325, 2003-001558, 2003-002975, 2003-003653, 2004-000671, 2004-001955, 2003-000045, 2003-001409, 2003-001610, 2003-001802, 2004-000445, 2004-002770

Section 2PS1: Radioactive Gaseous and Liquid Effluent Treatment and Monitoring Systems

Audits and Self-Assessments

EVAL-203-022, Annual Radiation Protection Audit (09/02/2003 to 09/11/2003)

In-place Filter Testing Results

Control Room Emergency Pressurization Unit X-21-Train A(11/14/02; 6/01/04)
Control Room Emergency Pressurization Unit X-21 (2/14/02;11/14/02)
Control Room Emergency Pressurization Unit X-22 (1/22/03)
Control Room Emergency Pressurization Unit X22-Train B (4/10/02; 12/17/03)
Control Room Emergency Filtration Unit X-23 (6/01/04)
Control Room Emergency Filtration Unit X-23 Train (8/13/02; 1/28/04)
Control Room Emergency Filtration Unit X-24 (11/24/03)
Control Room Emergency Filtration Unit X-24-Train B (9/17/02; 3/03/04)
PPT-SX-7523B, Control Room Ventilation Filter Test CPX-VAFUPK-24, Revision 0

Procedures

SAF-101 Recharging Breathing Air Cylinders, Revision 0
SAF-104 Inspection of Respiratory Protection Equipmnet, Revision 3
SAF-106 Testing of Breathing Air Systems, Revision 1
CHM-104 Quality Assurance and Quality Control, Revision 16
CHM-170 Liquid and Gaseous Effluent Program, Revision 1
COP-816 Plant Ventilation, Revision 2

Corrective Action Documents (SmartForms)

2002-004283, 2002-004317, 2003-001180, 2004-000060, 2004-002916

Miscellaneous

2002 Annual Effluent Report

2003 Annual Effluent Report

Section 2PS2: Radioactive Material Processing and Transportation

Smart Forms (SMF):

2003-000355, 2003-000399, 2003-001178, 2003-001216, 2003-001894, 2003-002687,
2004-000737, 2004-001003, 2004-001684, 2004-002282, 2004-003496

Procedures:

RPI-202, Receipt of Radioactive Material, Revision 8

RPI-215, Waste Stream Sampling, Revision 4

RPI-230, Radioactive Material Shipments, Revision 2

RPI-232, Characterizing Radioactive Material For Shipment, Revision 4

RPI-234, Packaging Radioactive Material/Waste for Shipment, Revision 8

RPI-235, Marking and Labeling Radioactive Material/Waste Packages for Shipment, Revision 5

RPI-237, Placarding Radioactive Material/Waste Shipments, Revision 4

RPI-238, Radioactive Material/Waste Shipment Surveys, Revision 6

RPI-239, Radioactive Material Shipment Documentation, Revision 7

RPI-240, Radioactive Waste Shipments, Revision 5

RPI-242, Radioactive Waste Characterization and Classification, Revision 5

RPI-247, Radioactive Waste Shipment Documentation, Revision 8

STA-709, Radioactive Waste Management Program, Revision 8

STA-713, Process Control Program (PCP), Revision 1

Audits and Assessments:

EVAL-2003-022, Annual Radiation Protection Audit

EVAL-2004-003, Radioactive Waste, Effluent, and Environmental Audit

Shipment Packages (Manifest #)

2002-043, 2003-017, 2003-032, 2004-049, 2004-067

Section 2PS3: Radiological Environmental Monitoring Program (REMP) And Radioactive Material Control Program

Audits, Self-Assessments, and Interlaboratory Comparison Results

EL 161-02 Framatome ANP DE&S Environmental Laboratory Analytical Services Semi-Annual Quality Assurance Status Report - January/June 2002
EL 027-03 Framatome ANP DE&S Environmental Laboratory Analytical Services Semi-Annual Quality Assurance Status Report - July/December 2002
EL 114-03 Framatome ANP DE&S Environmental Laboratory Analytical Services Semi-Annual Quality Assurance Status Report - January/June 2003
EL 038-04 Framatome ANP DE&S Environmental Laboratory Analytical Services Semi-Annual Quality Assurance Status Report - July/December 2003
EVAL-2003-012 Radioactive Effluent and Environmental Monitoring Evaluation
EVAL-2004-003 Radioactive Waste, Effluent, and Environmental Audit

Smart Forms

2003-0129, 2003-0773, 2003-0874, 2003-0899, 2003-0904, 2003-1147, 2003-1190, 2003-1411, 2003-2495, 2003-2952, 2003-3304, 2003-3511, 2003-3669, 2003-3903, 2004-0096, 2004-0351, 2004-0623, 2004-1217, 2004-1545, 2004-1663, 2004-2401, 2004-2942, 2004-3327, 2004-3515

Procedures

RPI-115 Alarm Response, Revision 1
RPI-213 Radioactive Source Control, Revision 8
RPI-213 Survey and Release of Material and Personnel, Revision 9
RPI-309 Routine Operations of the Meteorological Computer System, Revision 7
RPI-710 Radiological Environmental Monitoring Program, Revision 7
RPI-712 Radiological Environmental Sampling/Analysis Program, Revision 3
RPI-713 Collection, Preparation, and Shipment of Radiological Environmental Samples, Revision 3
STA-613 Control of Measurement and Test Equipment Inside a Radiologically Controlled Area, Revision 2
STA-652 Radioactive Material Control, Revision 11
STA-714 Meteorological Monitoring Program, Revision 3

Calibration Documents

RPI-888-1 HP-2188B, July 26, 2004
RPI-888-1 HP-2189B, July 26, 2004
RPI-888-1 HP-2190B, July 26, 2004
WO 3-04-315564-01, WO 3-04-316260-01, WO 3-04-325182-01, WO 3-04-325429-01,
WO 5-04-500117-AA, WO 5-04-501440-AA, WO 5-04-501551-AA, WO 5-04-501633-AA,
WO 5-04-502127-AA, WO 5-04-502210-AA, WO 5-04-502261-AA, and WO 5-04-502577-AA

Miscellaneous

2002 Comanche Peak Steam Electric Station Annual Radiological Environmental Operating Report

2003 Comanche Peak Steam Electric Station Annual Radiological Environmental Operating Report

2004 Comanche Peak Steam Electric Station Land Use Census

NUPIC Audit Number 18822 PPL ASQL Number 1658, Susquehanna Steam Electric Station
NUPIC Audit of Framatome ANP DE&S PPL Audit Number 2003-061 (QAA-04-008)

Offsite Dose Calculation Manual, Revision 20

Texas Department of Health Application for Disposal of Waste with Trace Levels of Radioactivity (Sanitary Sewage Sludge), November 30, 2000

Texas Department of Health Application for Disposal of Waste with Trace Levels of Radioactivity (Evaporator Pond Solids and Secondary Side Process Resin), June 24, 2002