

FY2014 CHEU Plant Outage

Listed below are the number of days the CHEU was considered off-line based on the helium production of 1,000 Mcf per day or less.

well	Date	pressure	temp	flow	he flow	Planned/UnPlanned	marker	description
HEU Prdct	Mar-24-2014	7.2	27.3	0.0	0.0	UnPlanned	1	
HEU Prdct	Mar-25-2014	5.8	40.9	0.0	0.0	UnPlanned	1	
HEU Prdct	Mar-26-2014	67.7	48.7	0.0	0.0	UnPlanned	1	
HEU Prdct	Mar-27-2014	174.9	41.2	0.0	0.0	UnPlanned	1	
HEU Prdct	Mar-28-2014	151.9	33.3	0.0	0.0	UnPlanned	1	
HEU Prdct	Mar-29-2014	447.3	45.9	37.1	28.6	UnPlanned	1	
HEU Prdct	May-16-2014	449.5	56.1	908.2	626.8	UnPlanned	1	
HEU Prdct	Jun-22-2014	453.7	61.9	443.4	271.8	UnPlanned	1	
HEU Prdct	Jun-23-2014	326.2	62.2	1103.5	794.3	UnPlanned	1	
HEU Prdct	Jul-28-2014	Null	Null	0.0	0.0	Planned	1	Scheduled Plant Shutdown
HEU Prdct	Jul-29-2014	9.7	65.7	0.0	0.0	Planned	1	
HEU Prdct	Jul-30-2014	Null	Null	0.0	0.0	Planned	1	
HEU Prdct	Jul-31-2014	15.3	61.7	0.0	0.0	Planned	1	
HEU Prdct	Aug-01-2014	16.1	59.9	0.0	0.0	Planned	1	
HEU Prdct	Aug-02-2014	Null	Null	0.0	0.0	Planned	1	
HEU Prdct	Aug-03-2014	10.6	64.0	0.0	0.0	Planned	1	
HEU Prdct	Aug-04-2014	16.1	59.9	184.8	140.1	Planned	1	
HEU Prdct	Aug-05-2014	16.1	59.9	184.8	140.1	Planned	1	
HEU Prdct	Aug-06-2014	16.1	59.9	184.8	140.1	Planned	1	
HEU Prdct	Aug-07-2014	16.1	59.9	184.8	140.1	Planned	1	
HEU Prdct	Aug-08-2014	16.1	59.9	184.8	140.1	Planned	1	
HEU Prdct	Aug-09-2014	16.1	59.9	0.0	0.0	Planned	1	
HEU Prdct	Aug-10-2014	16.1	59.9	0.0	0.0	Planned	1	
HEU Prdct	Aug-11-2014	16.1	59.9	0.0	0.0	Planned	1	
HEU Prdct	Aug-12-2014	16.1	59.9	0.0	0.0	Planned	1	
HEU Prdct	Aug-13-2014	18.6	68.0	0.0	0.0	Planned	1	
HEU Prdct	Aug-14-2014	19.2	69.3	0.0	0.0	Planned	1	
HEU Prdct	Aug-17-2014	444.5	68.1	1357.4	958.5	Planned	1	

Note: There were several unplanned equipment outages during the fiscal year, but the outages were short in duration and exceeded the cut-off point.

	total	28 days
total annual operating days		340 days
percentage of operating time		91.76%

Oct-19-2016

I:\123FLG\CLIFF\clf heu ops 2014.xls]Plt Dwn Rpt

The report saves under i:\cheu 2003\plant outages