



Fuel Spill Response Procedures

Constantine management will oversee all emergency response measures necessary, including notifying the appropriate regulatory and spill clean up personnel and containing the spill. In the event of a spill, employees and contractors will initiate the following procedures.

1. Protect personnel by moving them away from spill and turning off engines and extinguish all sources of ignition.
2. **IF SAFE TO DO SO**, immediately stop the release of fuel. Close all valves, plug or kink any ruptured line, and shut off pumps.
3. Notify Constantine management (Garfield, Darwin, Shayne, Darsie, Liz, or Steve). Inform that person of the location, scope of spill, and type of fuel or oil spilled.
4. Take immediate measures using properly protected personnel to contain the spill using sorbent booms, rolls of sorbent, soil, snow or other appropriate mechanisms and equipment. Apply sorbent directly to recover liquid product; place used sorbents in an approved container (open top drum) for proper disposal. Drums, bags of sorbents, and other containers will be labeled with date, person, type of contaminant, and type of contaminated material.
5. Document the incident, including but not limited to: (1) date, time, location, (2) volume spilled, (3) what the spill was to (soil, snow, stream, containment etc), (4) the effected volume (if applicable), (5) the response actions taken, (6) the person(s) and equipment at site involved in the spill and response, (7) estimated volume of contaminated material, and number and nature of the containers use, (9) the method(s) for storing contaminated material and the plan (or steps taken) to remove and dispose of the material

In addition to the spill response procedures outlined above, **Constantine management** will contact ADEC

(1) as soon as the person has knowledge of a

- (A) discharge or release of a hazardous substance other than fuel;
- (B) discharge or release of fuel to water; or
- (C) discharge or release, including a cumulative discharge or release, of fuel in excess of 55 gallons solely to land outside an impermeable secondary containment area or structure; and

(2) within 48 hours after the person has knowledge of a discharge or release, including a cumulative discharge, of fuel solely to land

- (A) in excess of 10 gallons, but 55 gallons or less; or
- (B) in excess of 55 gallons, if the discharge or release is the result of the escape or release of oil from its original storage tank, pipeline, or other immediate container into an impermeable secondary containment area or structure.

Contact Information

ADEC: (800) 478-9300 or (907) 428-7200 (after hours)
(907) 465-5066 (Juneau)
(907) 465-5340 (Juneau Division of Spill Response)

EPA: (907) 271- 5083 (Emergency Responses – Juneau, AK)
(907) 271-5083 (Alaska EPA Operations office)

National Response Center: (800) 424-8802 or (202) 267-2675 (24hr)

Local Contact Info for Delta Western Inc.

Main Office: (907) 766-3190
Fred Gray: (907) 314-0280
Mike Denker: (907) 314-0723